

Entergy Operations, Inc. 1340 Echelon Parkway Jackson, Mississippi 39213-8298 Tel 601-368-5758

F. G. Burford Acting Director Nuclear Safety & Licensing

CNRO-2004-00025

April 21, 2004

U. S. Nuclear Regulatory Commission Attn: Document Control Desk Washington, DC 20555

SUBJECT:

ANO-1 Relaxation Request #1 to NRC Order EA-03-009 for Reactor

Pressure Vessel Head Penetration Nozzles

Arkansas Nuclear One, Unit 1

Docket No. 50-313 License No. DPR-51

REFERENCE:

Entergy Operations, Inc. letter CNRO-2004-00008 to the NRC,

Relaxation Request to NRC Order EA-03-009, dated February 8, 2004

In the referenced letter, Entergy Operations, Inc. (Entergy) requested relaxation from inspection requirements of NRC Order EA-03-009 for Arkansas Nuclear One, Unit 1 (ANO-1) via ANO-1 Relaxation Request #1. Specifically, the ANO-1 reactor pressure vessel (RPV) head penetration nozzles cannot be effectively examined as required by the Order.

On April 21, 2004; the NRC staff requested that Entergy respond to a question pertaining to ANO-1-Relaxation Request!#1. 'The question and Entergy's response are provided below.

## NRC Question: \*~

Please confirm that the methodology used in your crack growth calculations is identical to the methodology used for the control element drive mechanism (CEDM) penetration nozzles at Arkansas Nuclear One, Unit 2 (ANO-2), which was approved by the NRC. If it is not the same, identify and discuss all of the differences including the justification and the level of conservatism.

## Entergy Response:

The methodology used in the crack growth calculations that support ANO-1 Relaxation .... Request #1 is identical to the methodology used in the crack growth calculations for the CEDM nozzles that supports the similar relaxation request for ANO-2.

Falloust find En al Reducisté de datable de la sente sécologique de la falloust find de la sente sécologique de la falloust find de la falloust fi

HUTERS OF BURNESS OF BURNESS OF SCOUS TO THE URD OF SCOUS TO THE U

The Manager OF 1921 The Material Manager The Manager CNRO-2004-00025 Page 2 of 2

This letter contains no commitments.

Should you have any questions, please contact Guy Davant at (601) 368-5756.

Sincerely,

FGB/GHD/ghd

cc:

Mr. W. A. Eaton (ECH) Mr. J. S. Forbes (ANO)

- Dr. Bruce S. Mallett Regional Administrator U. S. Nuclear Regulatory Commission Region IV 611 Ryan Plaza Drive, Suite 400 Arlington, TX 76011-8064

NRC Senior Resident Inspector Arkansas Nuclear One P. O. Box 310 London, AR 72847

U. S. Nuclear Regulatory Commission Attn: Mr. T. W. Alexion MS O-7 D1 Washington, DC 20555-0001