

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE -- PNO-I-06-014A

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the Region I staff on this date.

Facility

Constellation Generation Group, LLC
Calvert Cliffs Unit 2
Lusby, MD
Docket: 50-318

Licensee Emergency Classification

- Notification of Unusual Event
 Alert
 Site Area Emergency
 General Emergency
 X Not Applicable

SUBJECT: UPDATE - SHUTDOWN GREATER THAN 72 HOURS DUE TO
REACTOR/TURBINE TRIP FROM THE UNEXPECTED CLOSURE OF MAIN
TURBINE GOVERNOR AND INTERCEPT VALVES

On November 16, 2006, at 12:18 a.m., Calvert Cliffs Unit 2 experienced an automatic reactor trip from full power due to the unexpected closure of main turbine valves during a maintenance activity. Closure of the turbine valves resulted in a reactor trip on high reactor coolant system (RCS) pressure. All control rods fully inserted in response to the reactor trip. One power operated relief valve (PORV), which opened to control RCS pressure, remained open for longer than expected (approximately 90 seconds). The resulting RCS depressurization caused a safety injection actuation signal (SIAS) and safety-related equipment responded as expected. Operators implemented emergency operating procedures, stabilized the plant in hot shutdown, and initiated a plant cooldown.

Cold shutdown conditions were established as of 1:25 a.m., on November 17. During the shutdown, plant workers replaced the pressurizer PORV that malfunctioned and the quench tank rupture disk. One pressurizer safety valve was also replaced due to suspected seat leakage. Plant staff and the NRC inspectors completed physical inspections of the PORV and relief valve tail pipes, associated supports, and the quench tank. No significant equipment problems were identified. The licensee's preliminary investigation found that the initiating event (turbine valve closure with no direct reactor trip) was caused by an electrical maintenance tagout that was not adequately reviewed for operational impacts. The plant response to the trip was as expected, with the exception of the pressurizer PORV that did not immediately close when its pilot solenoid was de-energized. A detailed evaluation and inspection of the PORV will be performed by the licensee as part of followup actions for this event. The results of their evaluation will be provided to the NRC as part of the required Licensee Event Report for the trip. After completing post-maintenance tests and establishing corrective actions to prevent recurrence of this event, licensee personnel began preparations for a reactor startup.

Routine NRC inspection followup is planned for this event. The State of Maryland will be informed. The information in this updated preliminary notification has been reviewed with the Calvert Cliffs Director of Licensing, and is current as of 2:30 p.m. EST on Monday, November 20, 2006.

ADAMS Accession Number: ML063240221

CONTACT: Brian McDermott
(610) 337-5233

Arthur Burritt
(610) 337-5069

DISTRIBUTION: (PN Recipient List)

<u>OWFN</u>	<u>TWFN</u>	<u>LST</u>
Chairman Klein	IRO	PDR
Comm. Lyons	NMSS	
Comm. Jazcko	ACRS	
Comm. McGaffigan Jr.	OIG	
Comm. Merrifield	RES	
OIP	NSIR	
OCA		
OGC		
OPA		
EDO		
OE		
NRR		
SECY		
Regional Offices		

By Fax:

DOT:Trans

INPO

NSAC

RI Resident Office

Licensee: Constellation Generation Group, LLC (Calvert Cliffs)

ADAMS Accession Number: ML063240221

SUNSI Review Complete: BJM (Reviewer's Initials)

DOCUMENT NAME: C:\FileNet\ML063240221.wpd

After declaring this document "An Official Agency Record" it will be released to the Public.

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure
 "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	RI/DRP		RI/DRP		RI/ORA		RI/DRP		RI/DRP	
NAME	ABurritt/ARB		NMcNamara/MM for		DScreenci/DPS		BMcDermott/BJM		DLew/DCL	
DATE	11/20/06		11/20/06		11/20/06		11/20/06		11/20/06	

OFFICIAL RECORD COPY