

March 29, 2007

CAL No. NRR-07-023

Mr. Paul A. Harden
Site Vice President, Palisades Nuclear Plant
Palisades Nuclear Plant
Nuclear Management Company, LLC
27780 Blue Star Memorial Highway
Covert, MI 49043-9530

SUBJECT: CONFIRMATORY ACTION LETTER - PALISADES NUCLEAR PLANT
(TAC NO. MD4168)

Dear Mr. Harden:

This letter confirms commitments by Nuclear Management Company, LLC, regarding Alloy 82/182 butt welds in the pressurizer at Palisades Nuclear Plant.

The discovery, in October 2006, of five circumferential indications in three dissimilar metal (DM) welds on the pressurizer at the Wolf Creek Generating Station (Wolf Creek) raised safety concerns based on the size and location of the indications. At Wolf Creek, three indications were in the pressurizer surge nozzle-to-safe end weld, and two separate indications were in the safety and relief nozzle-to-safe end welds. These findings also indicated that significant concerns might exist with the inspection schedules for addressing the pressurizer weld concerns issued by the industry-sponsored Materials Reliability Program (MRP), in "Primary System Piping Butt Weld Inspection and Evaluation Guideline (MRP-139)."

The Nuclear Regulatory Commission (NRC) is concerned about the pressurizer surge nozzle-to-safe end weld indications, as this is the first time that multiple circumferential primary water stress-corrosion cracking (PWSCC) indications have been identified in a weld. This condition calls into question the degree of safety margin present in past structural integrity evaluations for flawed DM welds susceptible to PWSCC, since multiple stress-corrosion cracking flaws may grow independently and ultimately grow together, significantly reducing the time from flaw initiation to leakage or rupture. The size of the relief nozzle-to-safe end flaw is also of concern, as this flaw has a much larger aspect ratio than those assumed in the estimates used to establish the basis for completing the baseline inspections required by the industry-sponsored MRP. Larger aspect ratios could result in achieving a critical flaw size and rupture before the onset of detectable leakage.

The long-term resolution of this issue is expected to involve changes to the American Society of Mechanical Engineers Boiler and Pressure Vessel Code (ASME Code), and will involve changes to the NRC regulations in Title 10 of the *Code of Federal Regulations* (10 CFR), Part 50, Section 50.55a, "Codes and standards." The development of the NRC regulations, whether the rule adopts the ASME Code standards or defines separate requirements, will likely benefit from additional operating experience, continuing assessments, and analysis being conducted by the NRC and the MRP.

Until NRC regulations are revised, it is necessary to establish a minimum set of enhanced reactor coolant system (RCS) DM butt weld inspection expectations for nickel-based Alloy 82/182 pressurizer surge, spray, safety, and relief nozzle butt welds, including safe end welds, to supplement existing inspection and other requirements of the ASME Code and NRC regulations. In addition, enhanced monitoring of RCS leakage is needed to promptly identify any through-wall flaws in the pressurizer surge, spray, safety, or relief nozzle DM butt welds or safe end DM butt welds to prevent additional degradation from occurring. The above actions provide reasonable assurance that there is no undue risk to the health and safety of the public while the NRC regulations are revised.

The NRC communicated the need for near-term enhancements to the industry through public meetings held on November 30, 2006, December 20, 2006, and February 2, 2007. Licensees submitted letters voluntarily committing to the enhanced inspection and leakage monitoring requirements. After teleconferences with specific licensees held between February 12 through February 23, 2007, the licensees submitted supplemental commitment letters addressing the NRC staff's concerns regarding inspection, compensatory actions, and reporting.

In your letter dated February 27, 2007 (Agencywide Documents Access & Management System (ADAMS) Accession Number ML070590333) you described actions you will take at Palisades Nuclear Plant for the pressurizer dissimilar metal butt welds containing Alloy 82/182 material. These commitments address: 1) completion schedules for inspection of the welds; 2) RCS leak monitoring frequency, action levels, and actions; 3) reporting requirements and 4) reinspection frequencies.

The NRC staff has reviewed these actions and commitments and agrees the actions and commitments are appropriate to address the potential of PWSCC of the applicable pressurizer dissimilar metal butt welds containing Alloy 82/182 material.

Pursuant to Section 182 of the Atomic Energy Act, 42 U.S.C. 2232, you are required to:

- 1) Notify me immediately if your understanding differs from that set forth above;
- 2) Notify me if for any reason you cannot complete the actions and commitments within the specified schedule and advise me in writing of your modified schedule in advance of the change; and
- 3) Notify me in writing when you have completed the actions and commitments addressed in this Confirmatory Action Letter.

Issuance of this Confirmatory Action Letter does not preclude issuance of an order formalizing the above commitments or requiring other actions on the part of the licensee; nor does it preclude the NRC from taking enforcement action for violations of NRC requirements that may have prompted the issuance of this letter. In addition, failure to take the actions addressed in this Confirmatory Action Letter may result in enforcement action.

In accordance with 10 CFR 2.390 of the NRC's "Rules of Practice," a copy of this letter and your response will be made available electronically for public inspection in the NRC Public Document Room or from the NRC's ADAMS, accessible from the NRC Web site at

<http://www.nrc.gov/reading-rm/adams.html>. To the extent possible, your response should not include any personal privacy, proprietary, or safeguards information so that it can be made available to the Public without redaction. If personal privacy or proprietary information is necessary to provide an acceptable response, then please provide a bracketed copy of your response that identifies the information that should be protected and a redacted copy of your response that deletes such information. If you request withholding of such material, you must specifically identify the portions of your response that you seek to have withheld and provide in detail the bases for your claim of withholding (e.g., explain why the disclosure of information will create an unwarranted invasion of personal privacy or provide the information required by 10 CFR 2.390(b) to support a request for withholding confidential commercial or financial information). If safeguards information is necessary to provide an acceptable response, please provide the level of protection described in 10 CFR 73.21.

Sincerely,

/RA/

J. E. Dyer, Director
Office of Nuclear Reactor Regulation

Docket No. 50-255
License No. DPR-20

cc: See next page

P. Harden

-3-

<http://www.nrc.gov/reading-rm/adams.html>. To the extent possible, your response should not include any personal privacy, proprietary, or safeguards information so that it can be made available to the Public without redaction. If personal privacy or proprietary information is necessary to provide an acceptable response, then please provide a bracketed copy of your response that identifies the information that should be protected and a redacted copy of your response that deletes such information. If you request withholding of such material, you must specifically identify the portions of your response that you seek to have withheld and provide in detail the bases for your claim of withholding (e.g., explain why the disclosure of information will create an unwarranted invasion of personal privacy or provide the information required by 10 CFR 2.390(b) to support a request for withholding confidential commercial or financial information). If safeguards information is necessary to provide an acceptable response, please provide the level of protection described in 10 CFR 73.21.

Sincerely,

/RA/

J. E. Dyer, Director
Office of Nuclear Reactor Regulation

Docket No. 50-255
License No. DPR-20

cc: See next page

Distribution:

PUBLIC LPL3-1 R/F
RidsNrrDorlLpl3-1
RidsRgn3MailCenter
RidsNrrDci
RidsEdoMailCenter
RLickus, State Liaison Officer, Region 3
TLupold, NRR
RidsNrrDciCpnb

RidsNrrPMMChawla
RidsOgcRp
RidsNrrOd
RidsNrrDirs
TBloomer, EDO Region 3

ESullivan, NRR
RidsNrrAdes

RidsNrrLATHarris
RidsAcrcAcnwMailCenter
RidsNrrDorl
RidsOEMailCenter
JStrasma, OPA, Region 3

RPascarelli, NRR

ADAMS Accession No. ML070800449

OFFICE	CPNB	DCI	LPL3-1/PM	LPL3-1/LA	LPL3-1/BC	TECH ED	DIRS/TA
NAME	KHoffman	ESullivan	MChawla	THarris	LRaghavan	HChang	RPascarelli
DATE	3/22/07	3/22/07	3/22/07	3/22/07	3/22/07	2/28/07	3/23/07

OFFICE	CPNB/BC	DRP/D RGN3	DORL/D	DCI/D	AD:DES	NRR/D
NAME	TChan	MSatorius	CHaney	MEvans	JGrobe	JDyer
DATE	3/22/07	3/28/07	3/26/07	3/28/07	3/28/07	3/29/07

OFFICIAL RECORD COPY

Palisades Plant

cc:

Robert A. Fenech, Senior Vice President
Nuclear, Fossil, and Hydro Operations
Consumers Energy Company
1945 Parnall Rd.
Jackson, MI 49201

Arunas T. Udry, Esquire
Consumers Energy Company
1 Energy Plaza
Jackson, MI 49201

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
Suite 210
2443 Warrenville Road
Lisle, IL 60532-4351

Supervisor
Covert Township
P. O. Box 35
Covert, MI 49043

Office of the Governor
P. O. Box 30013
Lansing, MI 48909

U.S. Nuclear Regulatory Commission
Resident Inspector's Office
Palisades Plant
27782 Blue Star Memorial Highway
Covert, MI 49043

Michigan Department of Environmental Quality
Waste and Hazardous Materials Division
Hazardous Waste and Radiological
Protection Section
Nuclear Facilities Unit
Constitution Hall, Lower-Level North
525 West Allegan Street
P.O. Box 30241
Lansing, MI 48909-7741

Michigan Department of Attorney General
Special Litigation Division
525 West Ottawa St.
Sixth Floor, G. Mennen Williams Building
Lansing, MI 48913

Michael B. Sellman
President and Chief Executive Officer
Nuclear Management Company, LLC
700 First Street
Hudson, MI 54016

Jonathan Rogoff, Esquire
Vice President, Counsel & Secretary
Nuclear Management Company, LLC
700 First Street
Hudson, WI 54016

Douglas E. Cooper
Senior Vice President and
Chief Nuclear Officer
Nuclear Management Company, LLC
700 First Street
Hudson, WI 54016

Stephen T. Wawro, Director
of Nuclear Assets
Consumers Energy Company
Palisades Nuclear Plant
27780 Blue Star Memorial Highway
Covert, MI 49043

Laurie A. Lahti, Manager
Regulatory Affairs
Nuclear Management Company, LLC
Palisades Nuclear Plant
27780 Blue Star Memorial Highway
Covert, MI 49043

July 2006