

**ENCLOSURE (1)**

---

**NINE MILE POINT NUCLEAR STATION, UNIT 1  
RADIOACTIVE EFFLUENT RELEASE REPORT**

**January 1, 2006 – December 31, 2006**

**Facility Operating License DPR-63  
Docket No. 50-220**

---

**NINE MILE POINT NUCLEAR STATION - UNIT 1**  
**ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT**  
*January – December 2006*

---



**NINE MILE POINT NUCLEAR STATION - UNIT 1**  
**ANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT**

**JANUARY – DECEMBER 2006**

***SUPPLEMENTAL INFORMATION***

**Facility: Nine Mile Point Unit #1**

**Licensee: Nine Mile Point Nuclear Station, LLC**

**1. TECHNICAL SPECIFICATION LIMITS**

**A) FISSION AND ACTIVATION GASES**

1. The dose rate limit of noble gases released in gaseous effluents from the site to areas at and beyond the site boundary shall be less than or equal to 500 mrem/year to the total body and less than or equal to 3000 mrem/year to the skin.
2. The air dose due to noble gases released in gaseous effluents from Nine Mile Point Unit 1 to areas at and beyond the site boundary shall be limited during any calendar quarter to less than or equal to 5 milliroentgen for gamma radiation and less than or equal to 10 mrad for beta radiation, and during any calendar year to less than or equal to 10 milliroentgen for gamma radiation and less than or equal to 20 mrad for beta radiation.

**B&C) TRITIUM, IODINES AND PARTICULATES, HALF LIVES > 8 DAYS**

1. The dose rate limit of Iodine-131, Iodine-133, Tritium and all radionuclides in particulate form with half-lives greater than eight days, released in gaseous effluents from the site to areas at and beyond the site boundary shall be less than or equal to 1500 mrem/year to any organ.
2. The dose to a member of the public from Iodine-131, Iodine-133, Tritium and all radionuclides in particulate form with half-lives greater than eight days in gaseous effluents released from Nine Mile Point Unit 1 to areas at and beyond the site boundary shall be limited during any calendar quarter to less than or equal to 7.5 mrem to any organ and, during any calendar year to less than or equal to 15 mrem to any organ.

**D) LIQUID EFFLUENTS**

1. The concentration of radioactive material released in liquid effluents to unrestricted areas shall be limited to the concentrations specified in 10 CFR Part 20, Appendix B, Table II, Column 2 for radionuclides other than dissolved or entrained noble gases. For dissolved or entrained noble gases, the concentration shall be limited to 2E-04 microcuries/ml total activity.
2. The dose or dose commitment to a member of the public from radioactive materials in liquid effluents released from Nine Mile Point Unit 1 to unrestricted areas shall be limited during any calendar quarter to less than or equal to 1.5 mrem to the total body and to less than or equal to 5 mrem to any organ, and during any calendar year to less than or equal to 3 mrem to the total body and to less than or equal to 10 mrem to any organ.

## 2. MEASUREMENTS AND APPROXIMATIONS OF TOTAL RADIOACTIVITY

Described below are the methods used to measure or approximate the total radioactivity and radionuclide composition in effluents.

### A) FISSION AND ACTIVATION GASES

Noble gas effluent activity is determined by on-line gamma spectroscopic monitoring (intrinsic germanium crystal) or gross activity monitoring (calibrated against gamma isotopic analysis of a 4.0L Marinelli grab sample) of an isokinetic stack sample stream.

### B) IODINES

Iodine effluent activity is determined by gamma spectroscopic analysis (at least weekly) of charcoal cartridges sampled from an isokinetic stack sample stream.

### C) PARTICULATES

Activity released from the main stack is determined by gamma spectroscopic analysis (at least weekly) of particulate filters sampled from an isokinetic sample stream and composite analysis of the filters for non-gamma emitters.

### D) TRITIUM

Tritium effluent activity is measured by liquid scintillation or gas proportional counting of monthly samples taken with an air sparging/water trap apparatus. Tritium effluent activity is measured during purge and weekly when fuel is offloaded until stable tritium release rates are demonstrated.

### E) EMERGENCY CONDENSER VENT EFFLUENTS

The effluent curie quantities are estimated based on the isotopic distribution in the Condensate Storage Tank water and the Emergency Condenser shell water. Actual isotopic concentrations are found via gamma spectroscopy. Initial release rates of Sr-89, Sr-90 and Fe-55 are estimated by applying scaling factors to release rates of gamma emitters and actual release rates are determined from post offsite analysis results. The activity of fission and activation gases released due to tube leaks is based on reactor steam leak rates using offgas isotopic analyses.

### F) LIQUID EFFLUENTS

Isotopic contents of liquid effluents are determined by isotopic analysis of a representative sample of each batch and composite analysis of non-gamma emitters. Tritium activity is estimated on the most recent analysis of the Condensate Storage Tank water. Initial release rates of Sr-89, Sr-90, and Fe-55 are estimated by applying scaling factors to release rates of gamma emitters and actual release rates are determined from post offsite analysis results.

### G) SOLID EFFLUENTS

Isotopic contents of waste shipments are determined by gamma spectroscopy analysis of a representative sample of each batch. Scaling factors established from primary composite sample analyses conducted off-site are applied, where appropriate, to find estimated concentration of non-gamma emitters. For low activity trash shipments, curie content is estimated by dose rate measurement and application of appropriate scaling factors

# Attachment 1

## Summary Data

Unit 1	<u>  X  </u>	Unit 2		Reporting Period <u>January -December 2006</u>
--------	--------------	--------	--	--

**Liquid Effluents:**

ODCM Required MEC = 10 x 10CFR20, Appendix B, Table 2, Column 2

There were no discharges of liquid radwaste requiring use of MEC to determine allowable release rate.

There were no Emergency Condenser Vent Liquid Discharges in 2006

Average MEC - $\mu\text{Ci/ml}$ (Qtr. 1) =	NO RELEASES	Average MEC - $\mu\text{Ci/ml}$ (Qtr. 3) =	NO RELEASES
Average MEC - $\mu\text{Ci/ml}$ (Qtr. 2) =	NO RELEASES	Average MEC - $\mu\text{Ci/ml}$ (Qtr. 4) =	NO RELEASES

**Average Energy (Fission and Activation gases - MeV):**

Qtr. 1:	$\bar{E}_\gamma$	=	<u>N/A</u>	$\bar{E}_\beta$	=	<u>N/A</u>
Qtr. 2:	$\bar{E}_\gamma$	=	<u>5.63E-02</u>	$\bar{E}_\beta$	=	<u>1.45E-01</u>
Qtr. 3:	$\bar{E}_\gamma$	=	<u>4.54E-02</u>	$\bar{E}_\beta$	=	<u>1.35E-01</u>
Qtr. 4:	$\bar{E}_\gamma$	=	<u>2.47E-01</u>	$\bar{E}_\beta$	=	<u>3.17E-01</u>

Liquid:	Radwaste	EC Vent
Numbr of Batch Releases	0	0
Total Time Period for Batch Releases (hrs)	N/A	N/A
Maximum Time Period for a Batch Release (hrs)	N/A	N/A
Average Time Period for a Batch Release (hrs)	N/A	N/A
Minimum Time Period for a Batch Release (hrs)	N/A	N/A

Total volume of water used to dilute the liquid effluent during release period (L)	<u>1st</u>	<u>2nd</u>	<u>3rd</u>	<u>4th</u>
	N/A	N/A	N/A	N/A

Total volume of water available to dilute the liquid effluent during report period (L)	<u>1st</u>	<u>2nd</u>	<u>3rd</u>	<u>4th</u>
	1.30E+11	1.32E+11	1.38E+11	1.34E+11

**Gaseous(Emergency Condenser Vent):**

Numbr of Batch Releases	0
Total Time Period for Batch Releases (hrs)	N/A
Maximum Time Period for a Batch Release (hrs)	N/A
Average Time Period for a Batch Release (hrs)	N/A
Minimum Time Period for a Batch Release (hrs)	N/A

**Gaseous (Primary Containment Purge):**

Numbr of Batch Releases	2
Total Time Period for Batch Releases (hrs)	1.78E+01
Maximum Time Period for a Batch Release (hrs)	1.05E+01
Average Time Period for a Batch Release (hrs)	8.90E+00
Minimum Time Period for a Batch Release (hrs)	7.30E+00

# Attachment 1

## Summary Data

Unit 1	X	Unit 2		Reporting Period <u>January - December 2006</u>
<b>Abnormal Releases:</b>				
<b>A. Liquids:</b>				
		Number of Releases	0	
		Total Activity Released	N/A	Ci
<b>B. Gaseous:</b>				
		Number of Releases	0	
		Total Activity Released	N/A	Ci

# Attachment 2

Unit 1	<u>  X  </u>	Unit 2		Reporting Period <u>January - December 2006</u>			
<b>GASEOUS EFFLUENTS - SUMMATION OF ALL RELEASES, ELEVATED AND GROUND LEVEL</b>							
		<u>1st Quarter</u>	<u>2nd Quarter</u>	<u>3rd Quarter</u>	<u>4th Quarter</u>	<u>EST. TOTAL ERROR, %</u>	
<b>A. Fission &amp; Activation Gases (1)</b>							
1.	Total Release	Ci	**	1.48E+01	5.95E-02	3.00E-02	5.00E+01
2.	Average Release Rate	µCi/sec	**	1.88E+00	7.48E-03	3.78E-03	
<b>B. Iodines (1)</b>							
1.	Total Iodine - 131	Ci	2.49E-04	2.68E-04	3.20E-04	3.48E-04	3.00E+01
2.	Average Release Rate for Period	µCi/sec	3.21E-05	3.41E-05	4.01E-05	4.33E-05	
<b>C. Particulates (1)</b>							
1.	Particulates with half-lives>8 days	Ci	5.83E-04	1.14E-03	7.49E-04	1.67E-03	3.00E+01
2.	Average Release Rate for Period	µCi/sec	7.50E-05	1.46E-04	9.41E-05	2.08E-04	
3.	Gross alpha radioactivity	Ci	3.58E-05	5.33E-05	1.56E-05	**	2.50E+01
<b>D. Tritium (1)</b>							
1.	Total release	Ci	9.54E+00	8.01E+00	8.67E+00	8.16E+00	5.00E+01
2.	Average Release Rate for Period	µCi/sec	1.23E+00	1.02E+00	1.09E+00	1.02E+00	
<b>E. Percent of Tech. Spec. Limits</b>							
<u>Fission and Activation Gases</u>							
	Percent of Quarterly Gamma Air Dose Limit (5 mR)	%	0.00E+00	1.38E-02	4.39E-05	1.38E-04	
	Percent of Quarterly Beta Air Dose Limit (10 mrad)	%	0.00E+00	1.27E-02	4.95E-05	5.63E-05	
	Percent of Annual Gamma Air Dose Limit to Date (10 mR)	%	0.00E+00	6.89E-03	6.91E-03	6.98E-03	
	Percent of Annual Beta Air Dose Limit to Date (20 mrad)	%	0.00E+00	6.35E-03	6.37E-03	6.45E-03	
	Percent of Whole Body Dose Rate Limit (500 mrem/yr)	%	0.00E+00	3.34E-04	1.03E-06	3.62E-06	
	Percent of Skin Dose Rate Limit (3000 mrem/yr)	%	0.00E+00	1.30E-04	4.13E-07	1.27E-06	
<u>Tritium, Iodines, and Particulates (with half-lives greater than 8 days)</u>							
	Percent of Quarterly Dose Limit (7.5 mrem)	%	1.10E-01	1.22E-01	1.37E-01	1.62E-01	
	Percent of Annual Dose Limit to Date (15 mrem)	%	5.54E-02	1.17E-01	1.87E-01	2.69E-01	
	Percent of Organ Dose Limit (1500 mrem/yr)	%	2.23E-03	2.45E-03	2.72E-03	3.19E-03	
(1) Concentrations less than the lower limit of detection of the counting system used are indicated with a double asterisk.							

Unit 1     X     Unit 2                      Reporting Period January -December 2006

## GASEOUS EFFLUENTS - ELEVATED RELEASE

Continuous Mode (2)

Nuclides Released 1st Quarter 2nd Quarter 3rd Quarter 4th Quarter

**Fission Gases (1)**

Argon-41	Ci	**	**	**	**
Krypton-85	Ci	**	**	**	**
Krypton-85m	Ci	**	**	**	**
Krypton-87	Ci	**	**	**	**
Krypton-88	Ci	**	**	**	**
Xenon-127	Ci	**	**	**	**
Xenon-131m	Ci	**	**	**	**
Xenon-133	Ci	**	1.40E+01	5.82E-02	**
Xenon-133m	Ci	**	**	**	**
Xenon-135	Ci	**	8.04E-01	**	3.00E-02
Xenon-135m	Ci	**	**	**	**
Xenon-137	Ci	**	**	**	**
Xenon-138	Ci	**	**	**	**

**Iodines (1)**

Iodine-131	Ci	2.49E-04	2.68E-04	3.20E-04	3.48E-04
Iodine-133	Ci	3.84E-04	1.80E-03	1.19E-03	9.52E-04
Iodine-135	Ci	**	**	**	**

**Particulates (1)**

Strontium-89	Ci	**	1.63E-05	**	**
Strontium-90	Ci	**	5.20E-06	**	**
Cesium-134	Ci	**	**	**	**
Cesium-137	Ci	6.49E-06	**	6.35E-06	3.76E-06
Cobalt-60	Ci	3.92E-04	4.38E-04	4.03E-04	7.74E-04
Cobalt-58	Ci	2.08E-05	1.77E-05	4.39E-05	6.26E-05
Manganese-54	Ci	4.55E-06	7.38E-06	5.91E-06	6.45E-05
Barium-140	Ci	**	**	**	**
Lanthanum-140	Ci	**	**	**	**
Niobium-95	Ci	**	**	**	**
Cerium-141	Ci	**	**	**	**
Cerium-144	Ci	**	**	**	**
Iron-59	Ci	**	**	**	**
Cesium-136	Ci	**	**	**	**
Chromium-51	Ci	**	**	**	**
Zinc-65	Ci	**	3.83E-05	3.53E-05	9.57E-05
Iron-55	Ci	1.59E-04	6.22E-04	2.55E-04	6.72E-04
Molybdenum-99	Ci	**	**	**	**
Neodymium-147	Ci	**	**	**	**

**Tritium (1)**

Ci	8.23E+00	6.62E+00	7.04E+00	7.22E+00
----	----------	----------	----------	----------

(1) Concentrations less than the lower limit of detection of the counting system used are indicated with a double asterisk " \*\* ". A lower limit of detection of 1.00E-04 µCi/ml for required noble gases, 1.00E-11 µCi/ml for required particulates, 1.00E-12 µCi/ml for required Iodines, and 1.00E-06 µCi/ml for Tritium as required by the ODCM, has been verified.  
 (2) Contributions from purges are included. There were no other batch releases during the reporting period.

# Attachment 4

Unit 1	<u>  X  </u>	Unit 2		Reporting Period <u>January - December 2006</u>	
<b>GASEOUS EFFLUENTS - GROUND LEVEL RELEASES</b>					
Ground level releases are determined in accordance with the Off-Site Dose Calculation Manual and Chemistry procedures.					
<b>Continuous Mode (2)</b>					
<b>Nuclides Released</b>		<b><u>1st Quarter</u></b>	<b><u>2nd Quarter</u></b>	<b><u>3rd Quarter</u></b>	<b><u>4th Quarter</u></b>
<b><u>Fission Gases (1)</u></b>					
Argon-41	Ci	**	**	**	**
Krypton-85	Ci	**	**	**	**
Krypton-85m	Ci	**	**	**	**
Krypton-87	Ci	**	**	**	**
Krypton-88	Ci	**	**	**	**
Xenon-127	Ci	**	**	**	**
Xenon-131m	Ci	**	**	**	**
Xenon-133	Ci	**	**	1.26E-03	**
Xenon-133m	Ci	**	**	**	**
Xenon-135	Ci	**	**	**	2.48E-05
Xenon-135m	Ci	**	**	**	**
Xenon-137	Ci	**	**	**	**
Xenon-138	Ci	**	**	**	**
<b><u>Iodines (1)</u></b>					
Iodine-131	Ci	**	**	**	**
Iodine-133	Ci	**	**	**	**
Iodine-135	Ci	**	**	**	**
<b><u>Particulates (1)</u></b>					
Strontium-89	Ci	**	**	**	**
Strontium-90	Ci	**	**	**	**
Cesium-134	Ci	**	**	**	**
Cesium-137	Ci	**	**	**	**
Cobalt-60	Ci	**	**	**	**
Cobalt-58	Ci	**	**	**	**
Manganese-54	Ci	**	**	**	**
Barium-140	Ci	**	**	**	**
Lanthanum-140	Ci	**	**	**	**
Niobium-95	Ci	**	**	**	**
Cerium-141	Ci	**	**	**	**
Cerium-144	Ci	**	**	**	**
Iron-59	Ci	**	**	**	**
Cesium-136	Ci	**	**	**	**
Chromium-51	Ci	**	**	**	**
Zinc-65	Ci	**	**	**	**
Iron-55	Ci	**	**	**	**
Molybdenum-99	Ci	**	**	**	**
Neodymium-147	Ci	**	**	**	**
<b><u>Tritium (1)</u></b>					
	Ci	1.31E+00	1.39E+00	1.63E+00	9.37E-01

(1) Concentrations less than the lower limit of detection of the counting system used are indicated with a double asterisk \*\*.

(2) There were no ground batch mode releases during the reporting period.

# Attachment 5

Unit 1	X	Unit 2		Reporting Period	January - December 2006	
<b>LIQUID EFFLUENTS - SUMMATION OF ALL RELEASES</b>						
		<u>1st Quarter</u>	<u>2nd Quarter</u>	<u>3rd Quarter</u>	<u>4th Quarter</u>	<u>Est. Total Error, %</u>
<b>A. Fission &amp; Activation Products</b>						
1. Total Release (not including Tritium, gases, alpha)	Ci	No Releases	No Releases	No Releases	No Releases	5.00E+01
2. Average diluted concentration during reporting period	µCi/ml	No Releases	No Releases	No Releases	No Releases	
<b>B. Tritium</b>						
1. Total release	Ci	No Releases	No Releases	No Releases	No Releases	5.00E+01
2. Average diluted concentration during the reporting period	µCi/ml	No Releases	No Releases	No Releases	No Releases	
<b>C. Dissolved and Entrained Gases</b>						
1. Total release	Ci	No Releases	No Releases	No Releases	No Releases	5.00E+01
2. Average diluted concentration during the reporting period	µCi/ml	No Releases	No Releases	No Releases	No Releases	
<b>D. Gross Alpha Radioactivity</b>						
1. Total release	Ci	No Releases	No Releases	No Releases	No Releases	5.00E+01
<b>E. Volumes</b>						
1. Prior to Dilution	Liters	No Releases	No Releases	No Releases	No Releases	5.00E+01
2. Volume of dilution water used during release period	Liters	No Releases	No Releases	No Releases	No Releases	5.00E+01
3. Volume of dilution water available during reporting period	Liters	1.30E+11	1.32E+11	1.38E+11	1.34E+11	5.00E+01
<b>F. Percent of Tech. Spec. Limits</b>						
<u>Fission and Activation Gases</u>						
Percent of Quarterly Whole Body Dose Limit (1.5 mrem)	%	No Releases	No Releases	No Releases	No Releases	
Percent of Annual Whole Body Dose Limit to Date (3 mrem)	%	No Releases	No Releases	No Releases	No Releases	
Percent of Quarterly Organ Dose Limit (5 mrem)	%	No Releases	No Releases	No Releases	No Releases	
Percent of Annual Organ Dose Limit to Date (10 mrem)	%	No Releases	No Releases	No Releases	No Releases	
Percent of 10CFR20 Concentration Limit	%	No Releases	No Releases	No Releases	No Releases	
Percent of Dissolved or Entrained Noble Gas Limit (2.00E-04 µCi/ml)	%	No Releases	No Releases	No Releases	No Releases	

# Attachment 5

Unit 1	<u>  X  </u>	Unit 2		Reporting Period <u>January - December 2006</u>
--------	--------------	--------	--	---

## LIQUID EFFLUENTS RELEASED

Nuclides Released		Batch Mode (1),(2)			
		1st Quarter	2nd Quarter	3rd Quarter	4th Quarter
<b>Nuclides Released</b>					
Strontium-89	Ci	No Releases	No Releases	No Releases	No Releases
Strontium-90	Ci	No Releases	No Releases	No Releases	No Releases
Cesium-134	Ci	No Releases	No Releases	No Releases	No Releases
Cesium-137	Ci	No Releases	No Releases	No Releases	No Releases
Iodine-131	Ci	No Releases	No Releases	No Releases	No Releases
Cobalt-58	Ci	No Releases	No Releases	No Releases	No Releases
Cobalt-60	Ci	No Releases	No Releases	No Releases	No Releases
Iron-59	Ci	No Releases	No Releases	No Releases	No Releases
Zinc-65	Ci	No Releases	No Releases	No Releases	No Releases
Manganese-54	Ci	No Releases	No Releases	No Releases	No Releases
Chromium-51	Ci	No Releases	No Releases	No Releases	No Releases
Zirconium-95	Ci	No Releases	No Releases	No Releases	No Releases
Niobium-95	Ci	No Releases	No Releases	No Releases	No Releases
Molybdenum-99	Ci	No Releases	No Releases	No Releases	No Releases
Barium-140	Ci	No Releases	No Releases	No Releases	No Releases
Lanthanum-140	Ci	No Releases	No Releases	No Releases	No Releases
Cerium-141	Ci	No Releases	No Releases	No Releases	No Releases
Iodine-133	Ci	No Releases	No Releases	No Releases	No Releases
Iron-55	Ci	No Releases	No Releases	No Releases	No Releases
Cerium-144	Ci	No Releases	No Releases	No Releases	No Releases
Cesium-136	Ci	No Releases	No Releases	No Releases	No Releases
Copper-64	Ci	No Releases	No Releases	No Releases	No Releases
Manganese-56	Ci	No Releases	No Releases	No Releases	No Releases
Nickel-65	Ci	No Releases	No Releases	No Releases	No Releases
Sodium-24	Ci	No Releases	No Releases	No Releases	No Releases
Dissolved or Entrained Gases	Ci	No Releases	No Releases	No Releases	No Releases
Tritium	Ci	No Releases	No Releases	No Releases	No Releases

(1) No continuous mode release occurred during the report period as indicated by effluent sampling.

(2) Concentrations less than the lower limit of detection of the counting system used have been verified for sampled effluents. A lower limit of detection of 5.00E-07 µCi/ml for required gamma emitting nuclides, 1.00E-05 µCi/ml for required dissolved and entrained noble gases and tritium, 5.00E-08 µCi/ml for Sr 80/90, 1.00E-06 µCi/ml for I-131 and Fe-55, and 1.00E-07 µCi/ml for gross alpha radioactivity, as identified in the ODCM, has been verified.

# Attachment 6

Unit 1	X	Unit 2	Reporting Period <u>January - December 2006</u>			
SOLID WASTE AND IRRADIATED FUEL SHIPMENTS						
A.1 TYPE	<u>Volume</u> (m <sup>3</sup> )			<u>Activity (1)</u> (Ci)		
	<u>Class</u>			<u>Class</u>		
	A	B	C	A	B	C
a.1 Spent Resin (Dewatered)	2.08E+01	0.00E+00	0.00E+00	5.73E+01	0.00E+00	0.00E+00
a.2 Filter Sludge	0.00E+00	1.51E+01	0.00E+00	0.00E+00	1.05E+03	0.00E+00
Totals	2.08E+01	1.51E+01	0.00E+00	5.73E+01	1.05E+03	0.00E+00
b.1 Dry Compressible Waste	4.51E+02	0.00E+00	0.00E+00	5.72E-01	0.00E+00	0.00E+00
b.2 Dry Non-Compressible Waste (Contaminated Equipment)	3.63E-01	0.00E+00	0.00E+00	8.07E-02	0.00E+00	0.00E+00
Totals	4.87E+02	0.00E+00	0.00E+00	6.53E-01	0.00E+00	0.00E+00
c. Irradiated Components, Control Rods, etc.	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
d. Other (to vendor for processing)						
d.1 Sump Debris	4.60E+00	0.00E+00	0.00E+00	1.32E+01	0.00E+00	0.00E+00
d.2 Roof Grit	5.10E+01	0.00E+00	0.00E+00	1.21E-02	0.00E+00	0.00E+00
(1) The estimated total error is 5.0E+01%						

# Attachment 6

Unit 1	X	Unit 2		Reporting Period <u>January - December 2006</u>
<b>SOLID WASTE AND IRRADIATED FUEL SHIPMENTS</b>				
<b>A1. TYPE</b>	<b><u>Container</u></b>	<b><u>Package</u></b>	<b><u>Solidification Agent</u></b>	
a.1 Spent Resin (Dewatered)	Poly Liner	General Design Type A	None	
a.2 Filter Sludge	Poly Liner	Type A / Type B	None	
b.1 Dry Compressible Waste	Metal Box	General Design	None	
b.2 Dry Non-Compressible Waste (contaminated equipment)	Metal Box	General Design	None	
c. Irradiated Components, Control Rods	N/A	N/A	N/A	
d. Other (To vendor for processing)				
d.1 Sump Debris	Poly Liner	General Design	None	
d.2 Roof Grit	Metal Box	General Design	None	

# Attachment 6

Unit 1	<u>    </u> <b>X</b> <u>    </u>	Unit 2	<u>    </u> <u>    </u>	Reporting Period <u>January - December 2006</u>
<b>SOLID WASTE AND IRRADIATED FUEL SHIPMENTS</b>				
A2. ESTIMATE OF MAJOR NUCLIDE COMPOSITION (BY TYPE OF WASTE)				
a. Spent Resins, Filter Sludges, Concentrated Waste				
	<u>Nuclide</u>			<u>Percent</u>
	Fe-55			70.8
	Co-60			21.4
	Cs-137			3.5
	Mn-54			2.8
	Other			1.5
b. Dry Compressible Waste, Dry Non-Compressible Waste (Contaminated Equipment)				
	<u>Nuclide</u>			<u>Percent</u>
	Fe-55			71.1
	Co-60			21.2
	Cs-137			3.4
	Mn-54			2.1
	Other			2.2
c. Irradiated Components, Control Rods				
	<u>Nuclide</u>			<u>Percent</u>
	N/A			N/A
d. Other: (To vendor for processing)				
1. Sump Debris				
	<u>Nuclide</u>			<u>Percent</u>
	Fe-55			74.1
	Co-60			22.2
	Mn-54			2.1
	Other			1.6
2. Roof Grit				
	<u>Nuclide</u>			<u>Percent</u>
	Co-60			76.8
	Cs-137			23.2

# Attachment 6

Unit 1	<u>      X      </u>	Unit 2	<u>                    </u>	Reporting Period	<u>January - December 2006</u>
<b>SOLID WASTE AND IRRADIATED FUEL SHIPMENTS</b>					
A3. SOLID WASTE DISPOSITION					
<u>Number of Shipments</u>		<u>Mode of Transportation</u>		<u>Destination</u>	
10		Hittman Transport		Duratek Services, Inc	
16		Hittman Transport		Studsvik Processing Facility, LLC	
1		Race Logistics		Studsvik Race, LLC	
B. IRRADIATED FUEL SHIPMENTS (Disposition)					
<u>Number of Shipments</u>		<u>Mode of Transportation</u>		<u>Destination</u>	
0		N/A		N/A	
D. SEWAGE WASTES SHIPPED TO A TREATMENT FACILITY FOR PROCESSING AND BURIAL					
There were no shipments of sewage sludge from NMPNS to the treatment facility during the reporting period.					

# ATTACHMENT 7

Unit 1 <input checked="" type="checkbox"/>	Unit 2 <input type="checkbox"/>	Reporting Period <b>January – December 2006</b>	
<b>SUMMARY OF CHANGES TO THE OFF-SITE DOSE CALCULATION MANUAL (ODCM)</b>			
<p>The Unit 1 Off-Site Dose Calculation Manual (ODCM) was revised during the reporting period to change the Liquid Radwaste Effluent Line Flow Rate Measurement Device Channel Calibration Frequency, change the administrative method to ensure containment vent and purge valves remain close, and to allow on-site analysis of tritium, strontium, and iron. These changes do not affect the levels of radioactive effluent control required by 10 CFR 20.1302, 40 CFR 190, 10 CFR 50.36a, and 10 CFR 50 Appendix I, and do not adversely impact the accuracy or reliability of effluent, dose, or setpoint calculations. A copy of the ODCM, Revision 27 is attached and a summary of the changes presented to and approved by the Station Operations Review Committee on May 23, 2006 is provided below. The summary also includes the justification for the change.</p>			
<b>Revision 27</b>			
Page #	New/Amended Section #	Description of Change	Reason for Change
13.1-5	Table D 4.6.14-1	Liquid Radwaste Effluent Line Flow Rate Measurement Device channel calibration is required prior to removal of the blank flange in the discharge line and until the blank flange is replaced.	This change aligns with the calibration frequency requirements for the Liquid Radwaste Effluent Line Gross Radioactivity Monitor. NMP1 discharges liquid Radwaste infrequently, as such the liquid Radwaste effluent line blank flange is in for extend periods of time greater than one year. Requiring the channel calibration to be performed prior to removal and annually until the blank flange is reinstalled ensures operability of the device prior to blank flange removal and result in occupational dose avoidance as a result of unnecessary calibrations.
13.1-10	Table D 3.6.14-2	Changed D 3.6.14-2 (a) (1)(b) "Vent and Purge valves are closed and CLEARANCE applied", to "Vent and Purge valves are closed and administratively controlled."	This change is a change to the administrative method to ensure vent and purge valves remain closed. The administrative method used to ensure valves remain closed will be procedurally controlled.
II 6 II 24	1.1.4.4 2.2.2.3	This change allows tritium, strontium, and iron analyses to also be performed on-site.	Nine Mile Point has the capability to perform tritium analyses on-site. The capabilities to perform strontium and iron analyses on-site are under development. Therefore, this administrative change deletes the reference that only off-site analyses are allowed.
<b>SUMMARY OF CHANGES TO THE OFF-SITE DOSE CALCULATION MANUAL (ODCM)</b>			
<p>The Unit 1 Off-Site Dose Calculation Manual (ODCM) was revised during the reporting period to extend certain surveillance interval requirements, and to add the definition of "FUNCTIONALITY" and replace "OPERABILITY" with "FUNCTIONALITY". These changes do not affect the levels of radioactive effluent control required by 10 CFR 20.1302, 40 CFR 190, 10 CFR 50.36a, and 10 CFR 50 Appendix I, and do not adversely impact the accuracy or reliability of effluent, dose, or setpoint calculations. A copy of the ODCM, Revision 28 is attached and a summary of the changes presented to and approved by the Station Operations Review Committee on September 26, 2006 is provided below. The summary also includes the justification for the change.</p>			
<b>Revision 28</b>			
Page #	New/Amended Section #	Description of Change	Reason for Change
13.1-5 13.1-12	D 3/4.6.14, Table D 4.6.14-1 D 3/4.6.14, Table D 4.6.14-2	This change extends certain Offsite Dose Calculation Manual surveillance interval requirements from the current monthly, quarterly, and annually to 92 day, 184 day, and 24 month intervals plus the allowable 25% grace period and to clarify that "Operating Cycle" surveillance frequency means "24 months"	The changes were evaluated with the guidance provided in Generic Letter 91-04, "Changes in Technical Specifications Requirements to Accommodate a 24-Month Fuel Cycle", which has been viewed as an acceptable method of verifying that all critical factors have been reviewed for a surveillance interval change. These increases in surveillance frequency intervals do not adversely affect the systems' availability. Therefore these changes are acceptable.

# ATTACHMENT 7

I 1.0-1	1.0	This change adds the definition of "FUNCTIONALITY" and replaces "OPERABILITY" with "FUNCTIONALITY."	This change corresponds to the guidance in Regulatory Issues Summary 2005-20. The purpose of this change is to clarify that the SSCs in the ODCM are not described in Technical Specifications but warrant programmatic controls to ensure that SSC availability and reliability is maintained.
I 3.1-1	D 3/4.6.14		
I 3.1-2			
I 3.1-3			
I 3.1-4			
I 3.1-7			
I 3.1-8			
I 3.1-9			
I 3.1-10			
I 3.1-11			
I 3.1-23	D 3/4.6.15		
I 3.1-27	D 3/4.6.16		
I 3.1-28			
I B 3.1-1	B 3/4.6.14		
I B 3.1-8	B 3/4.6.16		
I 6.0-4	D 6.9.3		
II 2	1.1.1		
II 5	1.1.4.2		
II 11	1.3.2.3		
II 17	2.1.5.6		
II 25	2.2.3.2		

# Attachment 8

Unit 1   X   Unit 2           

Reporting Period January - December 2006

## SUMMARY OF CHANGES TO THE PROCESS CONTROL PROGRAM (PCP)

There were no changes to the NMP1 Process Control Program (PCP) during the report period.

# Attachment 9

Unit 1   X   Unit 2           

Reporting Period January - December 2006

## SUMMARY OF INOPERABLE MONITORS

There were no inoperable monitors for a period of greater than 30 days for the period.

Unit 1   X   Unit 2           Reporting Period January – December 2006**DOSES TO MEMBERS OF THE PUBLIC DUE TO THEIR ACTIVITIES INSIDE THE SITE BOUNDARY****Introduction**

An assessment of the radiation dose potentially received by a Member of the Public due to their activities inside the site boundary from Nine Mile Point Unit 1 (NMP1) liquid and gaseous effluents has been conducted for the period January through December 2006.

This assessment considers the maximum exposed individual and the various exposure pathways resulting from liquid and gaseous effluents to identify the maximum dose received by a Member of the Public during their activities within the site boundary.

Prior to September 11, 2001, the public had access to the Energy Information Center for purposes of observing the educational displays or for picnicking and associated activities. Fishing also occurred near the shoreline adjacent to the NMP. Fishing near the shoreline adjacent to the NMP Site was the onsite activity that resulted in the potential maximum dose received by a Member of the Public. Following September 11, 2001 public access to the Energy Information Center has been restricted and fishing by Members of the Public at locations on site is also prohibited. Although fishing was not conducted during 2006 the annual dose to a hypothetical fisherman was still evaluated to provide continuity of data for the location.

**Dose Pathways**

Dose pathways considered for this evaluation included direct radiation, inhalation and external ground (shoreline sediment or soil doses). Other pathways, such as ingestion pathways, are not considered because they are either not applicable, insignificant, or are considered as part of the evaluation of the total dose to a member of the public located off-site. In addition, only releases from the NMP1 stack and emergency condenser vent were evaluated for the inhalation pathway. Dose due to aquatic pathways such as liquid effluents is not applicable since swimming is prohibited at the Nine Mile Point Site.

Dose to a hypothetical fisherman is received through the following pathways while standing on the shoreline fishing:

- External ground pathway; this dose is received from plant related radionuclides detected in the shoreline sediment.
- Inhalation pathway; this dose is received through inhalation of gaseous effluents released from NMP1 Stack and Emergency Condenser Vent.
- Direct radiation pathway; dose resulting from the operation of NMP1, Nine Mile Point Unit 2 (NMP2) and the James A. Fitzpatrick (JAF) Facilities.

**Methodologies for Determining Dose for Applicable Pathways****External Ground (Shoreline Sediment) pathway**

Dose from the external ground (shoreline sediment) is based on the methodology in the NMP1 Offsite Dose Calculation Manual (NMP1 ODCM) as adapted from Regulatory Guide 1.109. For this evaluation it is assumed that the hypothetical maximum exposed individual fished from the shoreline at all times.

The total dose received by the whole body and skin of the maximum exposed individual during 2006 was calculated using the following input parameters:

- Usage Factor = 312 hours (fishing 8 hours per week, 39 weeks per year)
- Density in grams per square meter = 40,000
- Shore width factor = 0.3
- Whole body and skin dose factor for each radionuclide = Regulatory Guide 1.109, Table E-6.
- Fractional portion of the year = 1 (used average radionuclide concentration over total time period)
- Average Cs-137 concentration = 1.99E-01 pCi/g

The total whole body and skin doses received by a hypothetical maximum exposed fisherman from the external ground pathway is presented in Table 1, Exposure Pathway Dose.

Unit 1   X        Unit 2           

Reporting Period   January – December 2006  

## DOSES TO MEMBERS OF THE PUBLIC DUE TO THEIR ACTIVITIES INSIDE THE SITE BOUNDARY

### Inhalation Pathway

The inhalation dose pathway is evaluated by utilizing the inhalation equation in the NMP1 ODCM, as adapted from Regulatory Guide 1.109. The total whole body dose and organ dose received by the hypothetical maximum exposed fisherman during 2006 calculated using the following input parameters for gaseous effluents released from both the NMP1 Stack and Emergency Condenser Vent for the time period exposure is received:

#### **NMP 1 Stack:**

Variable	Fisherman *
X/Q (s/m <sup>3</sup> )	8.9E-06
Inhalation dose factor	Table E-7 Regulatory Guide 1.109
Annual air intake m <sup>3</sup> /year) (adult)	8000
Fractional portion of the year (hours)	0.0356
H-3 (pCi/sec)	8.76 E+05
Mn-54 (pCi/sec)	3.26 E+00
Co-58 (pCi/sec)	5.20 E+00
Co-60 (pCi/sec)	6.77 E+01
Zn-65 (pCi/sec)	7.09 E+00
Sr-89 (pCi/sec)	6.84 E-01
Sr-90 (pCi/sec)	2.18 E-01
Cs-137 (pCi/sec)	4.24 E-01
I-131 (pCi/sec)	3.92 E+01
I-133 (pCi/sec)	1.65 E+02

#### **NMP1 Emergency Condenser Vent:**

Variable	Fisherman *
X/Q (s/m <sup>3</sup> )	6.63E-06
Inhalation dose factor	Table E-7 Regulatory Guide 1.109
Annual air intake m <sup>3</sup> /year) (adult)	8000
Fractional portion of the year	0.0356
H-3 (pCi/sec)	1.66 E+05

- The maximum exposed fisherman is assumed to be present on site during the period of April through December at a rate of 8 hours per week for 39 weeks per year equivalent to 312 hours for the year (fractional portion of the year = 0.0356). Therefore, the Average Stack and Vent flow rates and radionuclide concentrations used to determine the dose are represented by second, third and fourth quarter gaseous effluent flow and concentration values.

The total whole body dose and maximum organ dose received by the hypothetical maximum exposed fisherman is presented in Table 1, Exposure Pathway Dose.

Unit 1   X   Unit 2           

Reporting Period   January – December 2006  

## DOSES TO MEMBERS OF THE PUBLIC DUE TO THEIR ACTIVITIES INSIDE THE SITE BOUNDARY

### Direct Radiation Pathway

The direct radiation pathway is evaluated in accordance with the methodology found in the NMP1 ODCM. This pathway considers four components: direct radiation from the generating facilities, direct radiation from any possible overhead plume, direct radiation from ground deposition and direct radiation from plume submersion. The direct radiation pathway is evaluated by the use of high sensitivity environmental Thermoluminescent Dosimeters (TLDs). Since fishing activities occur between April 1 – December 31, TLD data for the second, third, and fourth quarters of 2006 from TLDs placed in the general area where fishing once occurred were used to determine an average dose to the hypothetical maximum exposed fisherman from direct radiation. The following is a summary of the average dose rate and assumed time spent on site used to determine the total dose received:

Variable	Fisherman
Average Dose Rate (mRem/hr)	7.13E-03
Exposure time (hours)	312

Total Doses received by the hypothetical maximum exposed fisherman from direct radiation is presented in Table 1, Exposure Pathway Dose

### Dose Received By A Hypothetical Maximum Exposed Member Of The Public Inside the Site Boundary During 2006

The following is a summary of the dose received by a hypothetical maximum exposed fisherman from Liquid and Gaseous effluents released from NMP1 during 2006:

**TABLE 1 Exposure Pathway Annual Dose**

Exposure Pathway	Dose Type	Fisherman (mRem)
External Ground	Whole Body	3.13 E-03
	Skin of Whole Body	3.66E-03
Inhalation	Whole Body	4.02 E-04
	Maximum Organ	Thyroid: 6.61 E-04
Direct Radiation	Whole Body	0.48

Based on these values the total annual dose received by a hypothetical maximum exposed member of the public inside the site boundary is as follows:

**TABLE 2 Annual Dose Summary**

Total Annual Dose for 2006	Fisherman
Total Whole Body (mRem)	0.488
Skin of Whole Body (mRem)	3.66E-03
Maximum Organ (mRem)	Thyroid: 6.61 E-04

# ATTACHMENT 11

Unit 1   X   Unit 2           

Reporting Period   January – December 2006  

## DOSES TO MEMBERS OF THE PUBLIC DUE TO THEIR ACTIVITIES OUTSIDE THE SITE BOUNDARY

### Introduction

An assessment of radiation doses potentially received by the likely most exposed member of the public located beyond the site boundary was conducted for the period January through December 2006 for comparison against the 40CFR190 annual dose limits.

The intent of 40 CFR 190 requires that the effluents of Nine Mile Point Unit 1 (NMP1), as well as other nearby uranium fuel cycle facilities, be considered. In this case, the effluents of NMP1, Nine Mile Point Unit 2 (NMP2) and the James A. FitzPatrick (JAF) facilities must be considered.

40CFR190 requires the annual radiation dose received by members of the public in the general environment, as a result of plant operations, be limited to:

- < 25 mRem wholebody
- < 25 mRem any organ (except thyroid)
- < 75 mRem thyroid

This evaluation compares doses resulting from Liquid and Gaseous effluents and direct radiation originating from the site as a result of the operation of the NMP1, NMP2 and JAF nuclear facilities.

### Dose Pathways

Dose pathways considered for this evaluation included doses resulting from liquid effluents, gaseous effluents and direct radiation from all nuclear operating facilities located on the Nine Mile Point Site.

Dose to the most likely member of the public, outside the site boundary, is received through the following pathways:

- Fish consumption pathway; this dose is received from plant radionuclides that have concentrated in fish that is consumed by a member of the public.
- Shoreline Sediment; this dose is received as a result of an individual's exposure to plant radionuclides deposited in the shoreline sediment, which is used as a recreational area.
- Deposition, Inhalation and Ingestion pathways resulting from gaseous effluents; this dose is received through exposure to gaseous effluents released from NMP1, NMP2 and JAF operating facilities.
- Direct Radiation pathway; radiation dose resulting from the operation of NMP1, NMP2 and JAF facilities.

### Methodologies for Determining Dose for Applicable Pathways

#### Fish Consumption

Dose received as a result of fish consumption is based on the methodology specified in the NMP1 Off-site Dose Calculation Manual (NMP1 ODCM) as adapted from Regulatory Guide 1.109. The dose for 2006 is calculated from actual analysis results of environmental fish samples taken near the site discharge points. For this evaluation it is assumed that the most likely exposed member of the public consumes fish taken near the site discharge points.

No radionuclides were detected in fish samples collected and analyzed during 2006; therefore no dose was received by the whole body and organs of the likely most exposed Member of the Public during 2006.

#### Shoreline Sediment

Dose received from shoreline sediment is based on the methodology in the NMP1 ODCM as adapted from Regulatory Guide 1.109. For this evaluation it is assumed that the most likely exposed member of the public spends 67 hours/year along the shoreline for recreational purposes.

# ATTACHMENT 11

Unit 1   X   Unit 2       

Reporting Period   January – December 2006  

## DOSES TO MEMBERS OF THE PUBLIC DUE TO THEIR ACTIVITIES OUTSIDE THE SITE BOUNDARY

### Shoreline Sediment Continued:

The total dose received by the whole body and skin of the maximum exposed individual during 2006 is calculated using the following input parameters:

- Usage Factor = 67 hours per year
- Density in grams per square meter = 40,000
- Shore width factor = 0.3
- Whole body and skin dose factor for each radionuclide = Regulatory Guide 1.109, Table E-6
- Fractional portion of the year = 1
- Average Cs-137 Concentration = 0.056 pCi/g

### Dose Pathways Resulting From Gaseous Effluents

Dose received by the likely most exposed member of the public due to gaseous effluents is calculated in accordance with the methodology provided in the NMP1 ODCM, NMP2 Offsite Dose Calculation Manual, and the JAF Offsite Dose Calculation Manual. These calculations consider deposition, inhalation and ingestion pathways. The total sum of doses resulting from gaseous effluents from NMP1, NMP2 and JAF during 2006 provide a total dose to the whole body and maximum organ dose for this pathway.

### Direct Radiation Pathway

Dose as a result of direct gamma radiation from the site, encompasses doses from direct "shine" from the generating facilities, direct radiation from any overhead gaseous plumes, plume submersion and from ground deposition. This total dose is measured by environmental TLDs. The critical location is based on the closest year-round residence from the generating facilities as well as the closest residence in the critical downwind sector in order to evaluate both direct radiation from the generating facilities and gaseous plumes as determined by the local meteorology. During 2006, the closest residence and the critical downwind residence are at the same location.

### Dose Potentially Received by the Likely Most Exposed Member of the Public Outside the Site Boundary During 2006

Exposure Pathway	Dose Type	Dose (mRem)
Fish Consumption	Total Whole Body	No Dose
	Total Maximum Organ	No Dose
Shoreline Sediment	Total Whole Body	1.89E-04
	Total Skin of Whole Body	2.21E-04
Gaseous Effluents	Total Whole Body	1.17E-02
	Total Maximum Organ	Thyroid: 9.28E-02
Direct Radiation	Total Whole Body	2.0

Based on these values the maximum total annual dose potentially received by the most likely exposed member of the public during 2006 is as follows:

- Total Whole Body: 2.01 mRem
- Total Skin of Whole Body: 9.38E-03 mRem
- Maximum Organ: Thyroid: 9.28E-02 mRem

### 40CFR190 Evaluation

The maximum total doses presented in this attachment are the result of operations at the NMP1, NMP2 and the JAF facilities. The maximum organ dose (Thyroid: 0.093 mRem) and the maximum whole body dose (2.01 mRem) are below the 40 CFR 190 criteria of 25 mRem per calendar year to the maximum exposed organ or the whole body, and below 75 mRem per calendar year to the thyroid.

## **ATTACHMENT 12**

### **Off-Site Dose Calculation Manual (ODCM)**