

DCS No.: 05000277080807
Date: August 8, 2007

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE - PNO-I-07-007

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the Region I staff on this date.

Facility
Exelon Generation Company
Peach Bottom Atomic Power Station
Units 2 and 3
Delta, PA
Docket: 50-277, 278

Licensee Emergency Classification

- Notification of Unusual Event
- Alert
- Site Area Emergency
- General Emergency
- Not Applicable

Subject: ALERT DECLARED DUE TO CARBON DIOXIDE LEAK FROM A PORTABLE FIRE EXTINGUISHER IN THE DIESEL GENERATOR BUILDING

On August 8, 2007, at 3:36 p.m., Exelon declared an Alert at Peach Bottom Unit 2 and 3, due to a leak on a carbon dioxide fire extinguisher in the E-3 Diesel Generator Room. Since the concentrations of carbon dioxide and oxygen were not known, the room was evacuated and an Alert was declared due to the potential for a hazardous atmosphere to exist. The E-3 diesel generator was unaffected by the event and remained available if needed. There were no personnel injuries reported. Peach Bottom Units 2 and 3 remained at 100% and 99% power, respectively, throughout the event.

At 4:53 p.m. Exelon exited the Alert due to verification that the EDG room's atmosphere was safe for access.

The NRC resident inspectors were onsite and responded to the main control room to monitor and evaluate plant safety performance. NRC Region I, in King of Prussia, PA, contacted the appropriate Pennsylvania and Maryland emergency management agencies, and the Region I Public Affairs Office responded to media inquiries.

The information presented herein has been discussed with Exelon and is current as of August 8, at 6:00 p.m.

This preliminary notification is issued for information only and no further preliminary notification update by the staff is anticipated.

ADAMS Accession Number: ML072200656

Contacts: G. Dentel (610) 337-5233 gtd@nrc.gov R. Fuhrmeister (610) 337-5059 rlf1@nrc.gov

DISTRIBUTIONS:

BY E-MAIL:

OWFN TWFN

Chairman Klein

Comm. McGaffigan Jr. NMSS

Comm. Jaczko OIG

Comm. Lyons RES

OIP

OCA

OGC

EDO

OE

NRR

SECY

Regional Offices

BY FAX:

DOT:Trans

INPO

NSAC

RI Resident Office

Licensee: Exelon Generation Company

Peach Bottom Nuclear Generating Station

ADAMS: ML072200656

SUNSI Review Complete: RLF (Reviewer's Initials)

DOCUMENT NAME: C:\FileNet\ML072200656.wpd

After declaring this document "An Official Agency Record" it will be released to the Public.

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure
"E" = Copy with attachment/enclosure "N" = No copy

| OFFICE | RI/DRP | RI/POA | RI/ORA | RI/DRP |
|--------|------------------|-------------------|---------------------|----------|
| NAME | RFuhrmeister/RLF | DScrenici/NAS for | MmcLaughlin/NTM for | DLew/DCL |
| DATE | 08/08/07 | 08/08/07 | 08/08/07 | 08/08/07 |

OFFICIAL RECORD COPY