



LIQUID AND PLASTIC LIMITS TEST REPORT



SOURCE	SAMPLE #	DEPTH/ELEV.	DATE SAMPLED	USCS	MATERIAL DESCRIPTION	NM %	LL	PI
B-3001	UD-5	133.5/84.90	1/23/07		SHELL HASH, silty with sand (GM)		47	24

Client GPC c/o SNOC

Project Vogtle Units 3 & 4 COL Project



Project No. 6141-06-0286

Lab no.

**MACTEC ENGINEERING
AND
CONSULTING, INC.**

• Tested by: EH Reviewed by: HJ

LIQUID AND PLASTIC LIMITS TEST REPORT



SOURCE	SAMPLE #	DEPTH/ELEV.	DATE SAMPLED	USCS	MATERIAL DESCRIPTION	NM %	LL	PI
B-3002	UD-2	113.5/105.39	11/30/06		SAND, silty (SM)		85	50

Client GPC c/o SNOC

Project Vogtle Units 3 & 4 COL Project



Project No. 6141-06-0286

Lab no.

**MACTEC ENGINEERING
AND
CONSULTING, INC.**

• Tested by: EH Reviewed by: HJ

LIQUID AND PLASTIC LIMITS TEST REPORT





SOURCE	SAMPLE #	DEPTH/ELEV.	DATE SAMPLED	USCS	MATERIAL DESCRIPTION	NM %	LL	PI
B-3003	SS-24	113.5/104.79	1/30/07	GM	SHELL HASH, silty with sand (GM)	22.0	60	28
		ft.						

Client GPC c/o SNOC
 Project Vogtle Units 3 & 4 COL Project
 Project No. 6141-06-0286 Lab no. 7673

**MACTEC ENGINEERING
AND
CONSULTING, INC.**

• Tested by: EH Reviewed by: HJ

LIQUID AND PLASTIC LIMITS TEST REPORT



SOURCE	SAMPLE #	DEPTH/ELEV.	DATE SAMPLED	USCS	MATERIAL DESCRIPTION	NM %	LL	PI
B-3004	UD-1	93.0/125.51	3/1/07		SILT (MH)		97	44
		ft.						

Client GPC c/o SNOC

Project Vogtle Units 3 & 4 COL Project



Project No. 6141-06-0286

Lab no. 7507

**MACTEC ENGINEERING
AND
CONSULTING, INC.**

• Tested by: EH Reviewed by: HJ

LIQUID AND PLASTIC LIMITS TEST REPORT



SOURCE	SAMPLE #	DEPTH/ELEV.	DATE SAMPLED	USCS	MATERIAL DESCRIPTION	NM %	LL	PI
B-3005	UD-4	138.0/81.20 ft.	2/13/07		CLAY (CH)		52	28



Client GPC c/o SNOC
 Project Vogtle Units 3 & 4 COL Project

Project No. 6141-06-0286 Lab no. 7512

**MACTEC ENGINEERING
AND
CONSULTING, INC.**

• Tested by: EH Reviewed by: HJ

LIQUID AND PLASTIC LIMITS TEST REPORT



SOURCE	SAMPLE #	DEPTH/ELEV.	DATE SAMPLED	USCS	MATERIAL DESCRIPTION	NM %	LL	PI
B-3006	SS-33	143.5/74.09	12/7/200	GC	SHELL HASH, clayey with sand (GC)	14.3	49	29

Client GPC c/o SNOG

Project Vogtle Units 3 & 4 COL Project



Project No. 6141-06-0286

Lab no.

**MACTEC ENGINEERING
AND
CONSULTING, INC.**

• Tested by: EH Reviewed by: HJ
Test Date: 6/8/07 Review Date: 6/15/07

LIQUID AND PLASTIC LIMITS TEST REPORT



SOURCE	SAMPLE #	DEPTH/ELEV.	DATE SAMPLED	USCS	MATERIAL DESCRIPTION	NM %	LL	PI
B-3008	SS-13	43.5/174.36 Ft.	11/9/200	SC	SAND, clayey (SC)		42	19

Client GPC c/o SNOC

Project Vogtle Units 3 & 4 COL Project

Project No. 6141-06-0286



Lab no. 7258

**MACTEC ENGINEERING
AND
CONSULTING, INC.**

• Tested by: EH

Reviewed by: HJ

LIQUID AND PLASTIC LIMITS TEST REPORT





SOURCE	SAMPLE #	DEPTH/ELEV.	DATE SAMPLED	USCS	MATERIAL DESCRIPTION	NM %	LL	PI
B-3008	SS-27	113.5/104.36	11/10/06		SILT (MH)	52.12	58	22
		Ft.						

Client GPC c/o SNOC	
Project Vogtle Units 3 & 4 COL Project	
Project No. 6141-06-0286	Lab no. 6812

**MACTEC ENGINEERING
AND
CONSULTING, INC.**

• Tested by: JM Reviewed by: HJ

LIQUID AND PLASTIC LIMITS TEST REPORT





SOURCE	SAMPLE #	DEPTH/ELEV.	DATE SAMPLED	USCS	MATERIAL DESCRIPTION	NM %	LL	PI
B-3008	SS-29	123.5-125 Ft.	11/14/06		CLAY (CH)	41.4	61	31

Client GPC c/o SNOC	
Project Vogtle Units 3 & 4 COL Project	
Project No. 6141-06-0286	Lab no. 6813

**MACTEC ENGINEERING
AND
CONSULTING, INC.**

• Tested by: JM Reviewed by: HJ

LIQUID AND PLASTIC LIMITS TEST REPORT





SOURCE	SAMPLE #	DEPTH/ELEV.	DATE SAMPLED	USCS	MATERIAL DESCRIPTION	NM %	LL	PI
B-3015	UD-1C	121.5/100.28 ft.	3/6/07		CLAY (CH)		52	25

Client GPC c/o SNOC
 Project Vogtle Units 3 & 4 COL Project
 Project No. 6141-06-0286 Lab no. 7520

**MACTEC ENGINEERING
AND
CONSULTING, INC.**

• Tested by: EH Reviewed by: HJ

LIQUID AND PLASTIC LIMITS TEST REPORT



SOURCE	SAMPLE #	DEPTH/ELEV.	DATE SAMPLED	USCS	MATERIAL DESCRIPTION	NM %	LL	PI
B-3018	SS-25	108.5/111.30 ft.	3/7/07	MH	SILT, sandy (MH)	32.0	66	33

Client GPC c/o SNOC

Project Vogtle Units 3 & 4 COL Project



Project No. 6141-06-0286

Lab no. 7721

**MACTEC ENGINEERING
AND
CONSULTING, INC.**

• Tested by: EH Reviewed by: HJ

LIQUID AND PLASTIC LIMITS TEST REPORT



SOURCE	SAMPLE #	DEPTH/ELEV.	DATE SAMPLED	USCS	MATERIAL DESCRIPTION	NM %	LL	PI
B-3018	SS-31	143.5/76.30 ft.	3/8/07	CL	CLAY, with sand (CL)	28.3	34	11

Client GPC c/o SNOC

Project Vogtle Units 3 & 4 COL Project

Project No. 6141-06-0286

Lab no. 7723

**MACTEC ENGINEERING
AND
CONSULTING, INC.**

• Tested by: EH Reviewed by: HJ