



TENNESSEE VALLEY AUTHORITY WATTS BAR NUCLEAR PLANT UNIT 2



Refurbishment Program

August 6, 2009

Agenda



- Introductions
- WBN Unit 2 Material Condition
- WBN Unit 2 Refurbishment Program
- WBN Unit 2 Refurbishment Program Implementation
- WBN Unit 2 Testing Programs
- Conclusion

WBN Unit 2 Material Condition



Evaluation of Material Condition

- Performed Plant Walkdowns
 - Identify Missing/Removed Components
 - Baseline to Determine Current Configuration of Installed Equipment
 - Electrical
 - Mechanical
 - Civil
- Reviewed Quality Assurance Records to Support ASME Section III Program
- Results Addressed by Engineering Modifications and Refurbishment Program

WBN Unit 2 Material Condition



As-found condition of internal piping shown below.



Containment Spray Piping – 676' Pipe Chase

WBN Unit 2 Material Condition



Centrifugal Charging Pump
2B-B



Pump recently removed for refurbishment. Internal suction piping shown above and discharge at left.

WBN Unit 2 Material Condition



Centrifugal Charging
Pump 2A-A



Pump is currently
being removed for
refurbishment.
Internal pump
casing shown at left
and suction piping
at right.



WBN Unit 2 Material Condition




Ventilation Damper

Damper sent off-site to vendor facility for inspection, evaluation and recommended refurbishment and testing requirements.

WBN Unit 2 Refurbishment Program



Overview



WBN Unit 2 Refurbishment Program



Refurbishment Program

Equipment Scope

- Safety Related / Non-Quality Related
- Active / Passive

Refurbishment Program Process Steps

- Identification
- Classification
- Inspection/Evaluation
- Refurbishment/Replacement
- Component/System Testing

Required Outcome

- Plant meets original licensing, design and equipment vendor specifications

WBN Unit 2 Material Condition




Refurbishment/Replacement Commodity Estimates

COMMODITY	TOTAL PROJECT (estimate)
Pumps	80
Motors	90
Breakers	600
Manual Valves	4000
Air Operated Valves	500
Motor Operated Valves	200
Safety/Relief Valves	300


Refurbishment Program Implementation



Overview



Refurbishment Program Implementation



Refurbishment Program Implementation



- Implementing Work Instructions/Procedures
 - Provide Guidance on Refurbishment to be Performed
 - Provide Guidance for Refurbishment/Evaluation Requirements to be Met
 - Vendor Manuals
 - Design Specifications
 - Piping Standards
 - Operating Experience

Refurbishment Program Implementation



6.3.6 Pump and Motor Installation (Continued)

(QC hold point)

- [5] **TORQUE** nuts (38A4) to 85 ft-lbs, REF. MI-74.001.

M&TE ID No: _____

Field Engineer _____ date _____

Verified By _____ date _____
QC Inspector

- [6] **UNCOVER** seal water piping. **ENSURE** system openings are clean.

(QC hold point)

- [7] **VERIFY** seal water piping/flanges meets **CLASS-B** (Seal Water flanges), and (Component Cooling Water flanges) meet **CLASS-C** cleanliness and document per 25402-000-GPP-0000-N3505 Appendix-C located in TAB-5 of work order.

Sample Work Order

Refurbishment Program Implementation



PIPING SYSTEM CLEANLINESS

NO. 25402-000-GPP-0000-N3505
REV. 1
PAGE 22 OF 36

APPENDIX C
Page 3 of 8
Data Sheet 2

VISUAL/INTERNAL INSPECTION

☐ CLEANNESS CLASS B:

Swipe Test

1. VERIFY chloride and fluoride contamination of internal surfaces is ≤ 0.08 mg/dm².
Swipe Test Number(s) _____

Performed By: _____ Date: _____

NOTE Swipe tests shall be performed in accordance with CM Chapter 6.01.

2. ATTACH a copy of the completed CM Chapter 6.01 swipe results to this data sheet.

Performed By: _____ Date: _____

Visual Inspection

1. VERIFY the internal surface appears to be metal clean.

Performed By: _____ Date: _____

2. VERIFY scattered rust does not exceed two square inches in any square foot.

NOTE A layer of black iron oxide resulting from system operation or welding and temper films are acceptable on carbon steel and stainless steel surfaces.

Performed By: _____ Date: _____

3. VERIFY no evidence of pitting. If pitting from corrosion is observed, THEN CONTACT Nuclear Engineering for an evaluation.
NE contacted? ☐ YES ☐ NO


Performed By: _____ Date: _____

Wipe Cloth

NOTE Oily or otherwise dirty components may require thorough cleaning in accordance with Section 6.0 prior to verifying final cleanliness. Wipe cloth examinations are not required on systems which have been in service unless the surfaces in question required cleaning during the present activities.

**Sample Visual
Internal Inspection
Data Sheet**

Refurbishment Program Implementation



Refurbishment Program Implementation



12" Swing Check Valve

The refurbishment activity has identified surface indications (right) which could affect the pressure boundary in the bonnet gasket area which will likely require a Code repair.



Refurbishment Program Implementation



Data Sheet 1
(Page 1 of 1)

Check Valve Data Sheet

As-Found Inspection: ☐

As-Left Inspection: ☐

CHECK VALVE GENERAL INFORMATION:

(Enter N/A if information was obtained previously or is not available.)

UNID	_____	Type (Swing, Lift, piston, etc.)	_____
WO No	_____	Size	_____
Manufacturer	_____		
Model/Serial No	_____		

Location: (ENTER in the Remarks Section below the valve proximity to upstream flow disturbance, physical orientation, physical location in plant, and any other pertinent information.)


OPERABILITY CHECK:			
Valve operates freely		☐ YES	☐ NO ☐ N/A
Valve internals are clear of sudge buildup, corrosion, or debris which could restrict full opening/closing		☐ YES	☐ NO ☐ N/A
WEAR CHECK:		LOOSE PARTS CHECK:	
Disc/Piston OK	☐ YES ☐ NO ☐ N/A	Tack Welds OK	☐ YES ☐ NO ☐ N/A
Anti-rotation device OK	☐ YES ☐ NO ☐ N/A	Set Screws OK	☐ YES ☐ NO ☐ N/A
Hinge Pin OK	☐ YES ☐ NO ☐ N/A	Cotter Pin OK	☐ YES ☐ NO ☐ N/A
Bushings OK	☐ YES ☐ NO ☐ N/A	Retaining Clip OK	☐ YES ☐ NO ☐ N/A
Disc Arm OK	☐ YES ☐ NO ☐ N/A	Retaining Screws/Bolts OK	☐ YES ☐ NO ☐ N/A
Disc Post OK	☐ YES ☐ NO ☐ N/A	Other _____	☐ YES ☐ NO ☐ N/A
Disc Nut OK	☐ YES ☐ NO ☐ N/A	REMARKS/RECOMMENDED ACTIONS: _____ _____ _____	
Backstop/Body OK	☐ YES ☐ NO ☐ N/A		
Seat Ring OK	☐ YES ☐ NO ☐ N/A		
Spring OK	☐ YES ☐ NO ☐ N/A		
Other _____	☐ YES ☐ NO ☐ N/A		
INSPECTION PERFORMED BY: _____ Field Engineer/Supervisor or Vendor Rep. Date			

A copy of this datasheet forwarded to TVA
check valve coordinator.

Field Engineer/Supervisor Date

Example Check
Valve Data Sheet

Refurbishment Program Implementation



This valve is a 1 1/2", Hammel-Dahl, Globe valve with an A-40 Pneumatic Diaphragm type actuator. The items subject to refurbishment are the actuator diaphragm and valve packing

Refurbishment Program Implementation




FIG. NO.	NO.	PART NUMBER	DESCRIPTION
1	1	3144812011	UPPER DIAPHRAGM CASING
2	1	2218644012	LOWER DIAPHRAGM CASING
3	1	21135012012	DIAPHRAGM
4	1	1112412011	ADPHAGM FLATE
5	1	2017643012	ACTUATOR STEM
6	1	1A12680012	CAP SCREW, 1-8 x 3
7	1	1A11854012	CAP SCREW, 7/16-20 x 2
8	1	1A140324122	HEX NUT, 1/16-20
9	1	1A140324012	CAP SCREW, 1/2-13 x 1-1/4
10	1	1U13144012	ACTUATOR SPRING
11	1	25A0702012	SPRING CASE
12	1	1L44002012	SPRING SEAT
13	1	1H12120012	THINLY BEARING
14	1	1L2402012	SPRING ADJUSTING SCREW
15	1	1H12120012	COVER BAND ASSEMBLY
16	1	1H12120012	CAP SCREW, 1/2-13 x 4
17	1	1H12120012	YOKER
18	1	1H12120012	DRIVE INDICATOR SCALE
19	1	1A12412012	MACHINE SCREW, 1L-24 x 1/4
20	1	1H12120012	DRIVE INDICATOR
21	1	1H12120012	MACHINE SCREW, 5/40 x 1/4
22	1	211812012	STEM CONNECTOR
23	1	1A12412012	CAP SCREW, 1/2-13 x 2-1/4
24	1	1H12120012	SCREW PIN
25	1	1A12412012	CAP SCREW, 1/2-13 x 2-3/4
26	1	1H12120012	HEX NUT, 1/4-13 x 1/2
27	1	1H12120012	SCREW PIN, 3/4 x 12-13/16 x .75
28	1	1H12120012	SEAL SLIDING
29	1	1H12120012	O-RING, 2-7/8 x 3-1/4 x 3/16
30	1	1H12120012	O-RING, 1-3/8 x 2 x 5/16
31	1	3112422012	SPRING CASE ADAPTOR
32	1	1A12412012	CAP SCREW, 1/2-13 x 2
33	1	1H12120012	HEX NUT, 1/2-13
34	1	1H12120012	LOWER DIAPHRAGM FLATE
35	1	1H12120012	TRAVEL STOP
36	1	1H12120012	VENT
37	1	1H12120012	NAMEPLATE
38	1	1A12412012	DRIVE SCREW, 10-24 x 3/16
39	1	2013180012	SPRING CASE EXTENSION
40	1	1H12120012	VALVE BODY
41	1	3114170012	CASE
42	1	1H12120012	CASE GASKET, 5-5/8 x 10-5/8 x .115
43	1	1H12120012	CAP SCREW, 5/16-18 x 3/4
44	1	1H12120012	STUD, 1-3/4-8 x 10-1/2
45	1	1H12120012	HEX NUT, 1-5/8-8
46	1	1H12120012	CASE PIN
47	1	1H12120012	RETAINING SPRING
48	1	1H12120012	VALVE PLATE
49	1	1H12120012	SEAT & LIFTER
50	1	1H12120012	STEM
51	1	1H12120012	SPRAL WOUND GASKET, 10-1/16 x 12-6/16 x .175
52	1	1H12120012	SEAT & LIFTER
53	1	1H12120012	SPRAL WOUND GASKET, 12-12/16 x 11-12/16 x .175
54	1	1H12120012	PACKING FLANGE
55	1	1H12120012	STUD, 5/8-10 x 4-1/4
56	1	1H12120012	HEX NUT, 1/2-10
57	1	1H12120012	PACKING RING, 1-1/4 x 2 x .36
58	1	1H12120012	UPPER WATER
59	1	1H12120012	PACKING BOX RING
60	1	1H12120012	PACKING FOLLOWER
61	1	1H12120012	SAFETY POSITIONER
62	1	1H12120012	MOUNTING BRACKET
63	1	1H12120012	NATURAL GAS LINE SWITCH SAFETY RING
64	1	1H12120012	MOUNTING PLATE
65	1	1H12120012	PRESSURE REGULATOR
66	1	1H12120012	MOUNTING BRACKET
67	1	1H12120012	VOLUME REDUCER
68	1	1H12120012	ANG C BOUNDED VALVE
69	1	1H12120012	MOUNTING PLATE
70	1	1H12120012	NAMEPLATE
71	1	1H12120012	NAMEPLATE, END USER
72	1	1H12120012	TRANSDUCER, W/VALVE
73	1	1H12120012	WIRE, 1/4-1/2
74	1	1H12120012	WIRE, 1/4-1/2
75	1	1H12120012	SPACER
76	1	1H12120012	PIPE PLUG, 3/8-1/2 NPT
77	1	1H12120012	CAP SCREW
78	1	1H12120012	YOKER BRUSHING RETAINER
79	1	1H12120012	YOKER BRUSHING HOLDER
80	1	1H12120012	BRUSHING

* REQUIRED SPARE PARTS: 1, 44, 55, 61, 72, 73, 75, 76, 77, 78, 79, 80, 81, 82, 83, 84
 REQUIRED RETAINING PARTS: 71, 76, 78, 79, 84

Refurbishment Program Implementation



CRF Unit 2	Air Operated Valve Refurbishment and Setup (RQR)	25402-000.GPP-0000- M10013.N Rev. 0001 Page 44 of 59
---------------	---	---

Appendix C
(Page 3 of 3)

AOV Task Data Sheet

WO# _____ UNID _____
1.0 AOV TASK SUMMARY


[1] Work Performed During This Activity (check all that apply):

- | | |
|--|--|
| ☐ Actuator Diaphragm Replaced | ☐ Valve Packing Load Verified |
| ☐ Actuator O-rings/Seals/Packing Replaced | ☐ Adjusted/Set Travel |
| ☐ Valve Disassembled and Refurbished | ☐ Regulator Replaced/Setting Verified |
| ☐ Valve Repacked | ☐ Solenoid Valve Replaced |

Approval of As-Left Data

Field Engineer Date

**Example Air
Operated Valve
Refurbishment
Sheet**



Refurbishment Program Implementation



TVA Valve Packing Data Sheet																															
Facility: WATTS BAR UNIT 2 Unit: 2 System: 006 Tag: 2-LCV-006-00158 Location: TURB	Type: Valve Manufacturer: MASONILAN Model: 35-35200 Valve Size: 6	Status: Future Prepared By: Unverified Work Order: 08-951643-000 Rev: 0																													
VALVE DATA Actuator Type: ACV Stem Orientation:	CONFIGURATION SPW5GGGSWBW 																														
SPECIFICATIONS Gland Stud Torque Pref: 46 FT-LBS Gland Stud Torque Min: 23 FT-LBS Calculated Friction Pref: 2651 Calculated Friction Min: Packing Stress Pref: 4000 Packing Stress Min: 2000	PACKING DATA VERIFIED Packing Type: 5000/6300 (BRAIDED GRAPHITE/GRAFOIL) ☐ Number of Rings: 5 Packing Set Height: 1.875 STEM and BOX DATA Stem Dia (+.005/- .010): 1.5 in ☐ Box Dia (+0.010): 2.250 in ☐ Box Depth (± 0.031): 2.5 in ☐ Gland Box Angled: Gland Insert: in ☐ Gland Follower Lgth: STUD DATA Gland Stud Diameter: 0.625 in ☐ Number of Studs: 2 ☐ Gland Stud Type: STUD ☐ Wrench Size: in ☐ Total Stud Length: BUSHING DATA Upper Bush HT: in ☐ Lower Bushing HT: in ☐ PORT DATA Port Type: ☐ Port Active: ☐ Port Depth: in ☐ Port Dia: in ☐ LIVE LOADING Live Loaded: Yes ☐ Springs/Stud: # ☐ Spring Cfg: SERIES ☐ Flat Washers Per Stud: 2 ☐ INSTALLATION DATA REPACK ☐ RETORQUE ☐ Gland Follow Take Remains: 0 No of Strokes: As Left Gland Stud Torque:																														
COMMENTS 																															
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>CLASS/TYPE</th> <th>SUPPLIER PART NUM</th> <th>STOCK CODE</th> <th>QTY</th> </tr> </thead> <tbody> <tr> <td>BOLTING/Stud</td> <td>1000042473</td> <td>WBG8004</td> <td>1</td> </tr> <tr> <td>PACKING/Bushing</td> <td>B5701500021</td> <td>CJ735Q</td> <td>1</td> </tr> <tr> <td>PACKING/Set</td> <td>5470720</td> <td>CFP299B</td> <td>1</td> </tr> <tr> <td>PACKING/WASHER</td> <td>6200720</td> <td>CPH281C</td> <td>4</td> </tr> <tr> <td>WASHER/Flat</td> <td>1000101100</td> <td>CPH346A</td> <td>4</td> </tr> <tr> <td>WASHER/Spring</td> <td>62H177</td> <td>BPV576C</td> <td>1</td> </tr> </tbody> </table>				CLASS/TYPE	SUPPLIER PART NUM	STOCK CODE	QTY	BOLTING/Stud	1000042473	WBG8004	1	PACKING/Bushing	B5701500021	CJ735Q	1	PACKING/Set	5470720	CFP299B	1	PACKING/WASHER	6200720	CPH281C	4	WASHER/Flat	1000101100	CPH346A	4	WASHER/Spring	62H177	BPV576C	1
CLASS/TYPE	SUPPLIER PART NUM	STOCK CODE	QTY																												
BOLTING/Stud	1000042473	WBG8004	1																												
PACKING/Bushing	B5701500021	CJ735Q	1																												
PACKING/Set	5470720	CFP299B	1																												
PACKING/WASHER	6200720	CPH281C	4																												
WASHER/Flat	1000101100	CPH346A	4																												
WASHER/Spring	62H177	BPV576C	1																												

Example
Valve Packing
Data Sheet


Date Printed: 5/26/2009

Return Completed Data Sheet to the Valve Packing Specialist

Refurbishment Program Implementation



Overview



WBN Unit 2 Testing Programs



System Flushing

Testing

- Construction tests
- Cold Hydrostatic test
- Hot Functional
- RG 1.68 tests

Conclusion



In Summary TVA :

- Established the Existing Condition of WBN Unit 2
- Developed and Implemented Programs to
 - Install New Equipment Where Necessary
 - Refurbish Existing Equipment
 - Improve Material Condition and Equipment Performance Where Appropriate
- Will Perform Testing to Ensure Systems and Components will Meet Original Design, Licensing and Vendor Specifications