

ATTACHMENT 13
Exelon Generation Company, LLC Instrument Setpoint Calculations

LIST OF CALCULATIONS INCLUDED

L-001345, Rev. 2, "Average Power Range Monitor (APRM), Rod Block Monitor (RBM), and
Recirculation Flow Monitor (RFM) Bistable Loop Accuracy for Rod Block and Scram
Functions"

L-001345, Minor Rev. 2 A

L-001345, Minor Rev. 2 B

L-001345, Minor Rev. 2 C

L-001345, Minor Rev. 2 D

Note: Minor Revision 2 D provides the changes related to the proposed power uprate.
However, the preceding revisions are provided, since the minor revisions are not
incorporated into the body of Revision 2.

CALCULATION TITLE PAGE

PAGE NO: 1

ComEd

LaSalle

☒ Unit 1 ☒ Unit 2 ☐ Unit 0

Calculation No. L-001345

DESCRIPTION CODE: 104

DISCIPLINE CODE: I

SYSTEM CODE: C51

ELEVATION (C016) 768' 0"

TITLE: Average Power Range Monitor (APRM), Rod Block Monitor (RBM), and Recirculation Flow Monitor (RFM) Bistable Loop Accuracy for Rod Block and Scram Functions

☒ Safety Related ☐ Regulatory Related ☐ Augmented Quality ☐ Non-Safety Related

REFERENCE NUMBERS (C011 Panel)

Type	Number	Type	Number
AEDV	<u>I&C Engineering</u>		
CHRN			
PAL			
PROG			
PROJ	<u>10620-008</u>		
SSYS			
RNID			

COMPONENT EPN : (C014 Panel)

EPN	Compt Type
<u>See Section 1.0</u>	

DOCUMENT NUMBERS: (C012 Panel)

Doc Type	Sub Type	Document Number	Assoc. Calc.
<u>PROG</u>	<u>STN</u>	<u>See Reference 3.5</u>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
<u>DCD</u>	<u>DCP</u>	<u>9700500</u>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
<u>DCD</u>	<u>DCP</u>	<u>9700502</u>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
<u>CALC</u>	<u>ENG</u>	<u>NED-I-EIC-0255</u>	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
			<input type="checkbox"/> Yes <input type="checkbox"/> No

REMARKS: GE DRF C51-00206

REV. NO.	REVISING ORGANIZATION	APPROVED PRINT/SIGN	DATE
<u>0</u>	<u>General Electric</u>	<u>Larry Chi (GE)</u>	<u>12-22-97</u>
<u>1</u>	<u>Sargent & Lundy</u>	<u>W. A. Barasa</u>	<u>3-19-99</u>
<u>2</u>	<u>Sargent & Lundy</u>	<u>W.A. Barasa</u> <i>W.A. Barasa</i>	<u>7-9-99</u>

CALCULATION NO.

L-001345

Project No.10546-026

PAGE NO.: 2

REVISION SUMMARIESREV: 0 ☐ Partial (Only Revised Pages Included) ☒ Complete (All Calculation Pages Included)

REVISION SUMMARY:

Initial Issue.

Electronic Calculation Data Files:

(Program Name, Version, File name ext/size/date/hour: min)

WordPerfect 6.1, L-001345.6R0/1,281,278/12-22-97/11:55 pm

Word 6.0, L1345FIG.DOC/29,696/12-19-97/2:23 pm

PREPARED BY: W. Kent Green (GE)

Print

Sign

12-22-97

Date

REVIEWED BY: Daniel L. Gould (GE)

Print

Sign

12-22-97

Date

Type of Review

☒ Detailed☐ Alternate☐ Test

Supplemental Review Required

☐ Yes (NEP-12-05 documentation attached)☐ No

Supervisor: _____

DO ANY ASSUMPTIONS IN THIS CALCULATION REQUIRE LATER VERIFICATION

☐ YES☒ NO

Tracked by: _____

REV: 1 ☒ Partial (Only Revised Pages Included) ☐ Complete (All Calculation Pages Included)

REVISION SUMMARY: Revised to widen calibration tolerances for modules $\sigma 3A$, $\sigma 3B$, $\sigma 6A$, $\sigma 6B$ in support of DCPs 9700500 & 9700502. Added limitations to the allowed upscale and comparator trip setpoint calibration tolerances for the recirculation flow monitor. Also corrected minor typos. Revised the following pages: 43, 44, 76, 77, 78, 144, 145, 151, 152, 166, 167, 172, 173, 178, 179, 188, 190, 191.

Also revised pages 1 and 2.

Electronic Calculation Data Files:

(Program Name, Version, File name ext/size/date/hour: min)

PREPARED BY: D.J. Cujko

Print

Sign

3-19-99

Date

REVIEWED BY: P.J. Ripp

Print

Sign

Date

Type of Review

☒ Detailed☐ Alternate☐ Test

Supplemental Review Required

☐ Yes (NEP-12-05 documentation attached)☒ NoSupervisor: Mark Brown

DO ANY ASSUMPTIONS IN THIS CALCULATION REQUIRE LATER VERIFICATION

☐ YES☒ NO

Tracked by: _____

COMMONWEALTH EDISON COMPANY CALCULATION REVISION PAGE

CALCULATION NO. L-001345

PAGE NO.: 2.1 of 191

REVISION SUMMARIES

REV: 2 ☒ Partial (Only Revised Pages Included) ☐ Complete (All Calculation Pages Included)

REVISION SUMMARY: Revised pages 1, 2.1, 3, 6, 7, 10, ^{DJC}11, 14, 17, 18, 44, 110, 111, 113, 114, 149, 150, 153, 154, 155, 156, 160, 161, 168, 169, 171, 184, 187, 188, and 191. Calculated new setpoints and allowable values for APRM flow biased simulated power scram and rod blocks (flow biased and clamp) based on revised analytical limits resulting from power uprate.

ELECTRONIC CALCULATION DATA FILES REVISED:

(Program Name, Version, File name ext/size/date/hour: min)

PREPARED BY: J.R. Basak *Thomas J. Behring for J.R. Basak* DATE: 7/9/99
Print/Sign

REVIEWED BY: D. J. Cujko *D.J. Cujko* *NAB* DATE: 7/9/99
Print/Sign

Type of Review ☒ Detailed ☐ Alternate ☐ Test
Supplemental Review Required ☐ YES (NEP-12-05 documentation attached) ☒ NO
Supervisor: *M. Barosa*

DO ANY ASSUMPTIONS IN THIS CALCULATION REQUIRE LATER VERIFICATION ☐ YES ☒ NO
Tracked by: _____

REV:

REVISION SUMMARY:

ELECTRONIC CALCULATION DATA FILES REVISED:

(Program Name, Version, File name ext/size/date/hour: min)

PREPARED BY: _____ DATE: _____
Print/Sign

REVIEWED BY: _____ DATE: _____
Print/Sign

Type of Review ☐ Detailed ☐ Alternate ☐ Test
Supplemental Review Required ☐ YES (NEP-12-05 documentation attached) ☐ NO
Supervisor: _____

DO ANY ASSUMPTIONS IN THIS CALCULATION REQUIRE LATER VERIFICATION ☐ YES ☐ NO
Tracked by: _____

7483

COMMONWEALTH EDISON COMPANY CALCULATION TABLE OF CONTENTS

CALCULATION NO. L-001345	REV. NO. 2	PAGE NO. 3 OF 191
DESCRIPTION	PAGE NO.	SUB-PAGE NO.
TITLE PAGE	1	
REVISION SUMMARY	2	2.1
TABLE OF CONTENTS	3	
<u>CALCULATION</u>		
SECTION 1.0 PURPOSE and OBJECTIVE	5	
SECTION 2.0 METHODOLOGY and ACCEPTANCE CRITERIA	7	
SECTION 3.0 REFERENCES	11	
SECTION 4.0 DESIGN INPUTS	15	
SECTION 5.0 ASSUMPTIONS	19	
SECTION 6.0 INSTRUMENT CHANNEL CONFIGURATION	21	
SECTION 7.0 PROCESS PARAMETERS	27	
SECTION 8.0 LOOP ELEMENT DATA	28	
SECTION 9.0 CALIBRATION INSTRUMENT DATA	33	
SECTION 10.0 CALIBRATION PROCEDURE DATA	42	
SECTION 11.0 MODULE ERRORS	48	
SECTION 12.0 INSTRUMENT CHANNEL TOTAL ERROR	149	
SECTION 13.0 ERROR ANALYSIS SUMMARY	153	
SECTION 14.0 CONCLUSIONS	168	
SECTION 15.0 CALCULATION SPREADSHEET	174	
ATTACHMENTS		
A. GE Drawing 22A2843, Rev. 7, "Neutron Monitoring System" Design Specification.	A1 - A32	
B. GE Drawing 22A2843AF, Rev. 7, "Neutron Monitoring System" Design Specification Data Sheet.	B1 - B17	
C. GE Drawing 235A1386, Rev. 1, "Design and Performance Specification APRM (Page)."	C1 - C6	

CALCULATION NO. L-001345	REV. NO. 0	PAGE NO. 4 OF 191
DESCRIPTION	PAGE NO.	SUB-PAGE NO.
D. GE Drawing 248A9544, Rev. 1, "Rod Block Monitor (Page) '69" Specification.	D1 - D10	
E. NEDC-31336P-A, "General Electric Instrumentation Setpoint Methodology," September 1996, (GE Proprietary Information), Sections 2.2.5 and 4.5.	E1 - E22	
F. ComEd Letter DG 97-001088, "Reclassification of the drift error term in the ComEd Setpoint Accuracy Methodology," dated 25 August, 1997.	F1 - F3	
G. Rosemount Nuclear Data Sheet, "Model 1152 Alphaline Pressure Transmitter for Nuclear Service," MAN 4235A00, 1995.	G1 - G5	
H. GE Drawing 225A6445, Rev. 0, "Flow Unit (Page)" Design and Performance Specification.	H1 - H5	
I. Letter to File, KG971022.DOC, Documents Telecons with LaSalle NMS Engineer Gene Pfister.	I1 - I2	
J. E-Mail from Julie Leong to Clark F. Canham and W. Kent Green dated 10/14/97, Subject: LaSalle Recirc Flow Drift and Flow Element Accuracy.	J1 - J2	
K. NEDO-31558-A dated March 1993, "Position on NRC Regulatory Guide 1.97, Revision 3, Requirements for Post-Accident Neutron Monitoring System."	K1 - K15	
L. GE letter, A097-011, Allowance for Process Computer Core Power Measurement Analytical Uncertainty in LaSalle, from Jose L. Casillas, dated December 12, 1997.	L1 - L3	
M. GE letter, A097-015 Rev. 1, Flow Biased Simulated Thermal Power Scram and APRM Rod Block in LaSalle, from Jose L. Casillas, dated December 22, 1997 with its Enclosure (4).	M1 - M4	
N. GE Drawing 328X105TD, Rev. 3, "Power Range Monitoring Cabinet," Parts List.	N1 - N3	
O. GE Drawing PL791E507TD, Rev. 10, "Power Range Monitoring Cabinet," Parts List.	O1 - O5	
P. GE Drawing PL791E392BB, Rev. 14, "Flow Unit," Parts List.	P1 - P8	
Q. E-Mail from Andrew N. Poulos to Jose L. Casillas, Daniel L. Gould, and Larry Chi dated December 10, 1997, Subject: LaSalle Flow Bias.	Q1 - Q3	

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 5 of 191

1.0 PURPOSE AND OBJECTIVE

The purpose of this calculation is to determine with a high degree of certainty whether or not there exists positive margin between the Analytical Limits and the calibration and Tech Spec setpoints, and between the Tech Spec LCO values and the calibration and Tech Spec setpoints, for the various trips of the Power Range Neutron Monitoring System (PRNMS). For the purposes of this calculation the PRNMS consists of the Average Power Range Monitors (APRM), the Rod Block Monitors (RBM), and the Recirculation Flow Monitor (RFM). The evaluated trips from these three subsystems can cause a scram via the Reactor Protection System (RPS) or a rod withdrawal block via the Reactor Manual Control System (RMCS). Following is a list of the evaluated trips:

Trips that cause a scram

- APRM Neutron Flux - High (Fixed)
- APRM Neutron Flux - High (Fixed) (Setdown)
- APRM Simulated Thermal Power - Upscale (Flow Biased)
- Two Recirculation Loop Operation
- APRM Flow Biased Trip Clamp
- Two Recirculation Loop Operation
- APRM Simulated Thermal Power - Upscale (Flow Biased)
- Single Recirculation Loop Operation
- APRM Flow Biased Trip Clamp
- Single Recirculation Loop Operation

Trips that cause a rod block

- APRM Neutron Flux - High (Fixed)
- APRM Neutron Flux - Downscale
- APRM Flow Biased Upscale Trip

- RBM Upscale
- RBM Downscale

- RFM Upscale
- RFM Comparator

The equipment covered by this calculation is listed below:

- FT-1B33-N014A FT-1B33-N024A
- FT-1B33-N014B FT-1B33-N024B
- FT-1B33-N014C FT-1B33-N024C
- FT-1B33-N014D FT-1B33-N024D

- FT-2B33-N014A FT-2B33-N024A
- FT-2B33-N014B FT-2B33-N024B

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345		PAGE 6 of 191	
<div> <div>FT-2B33-N014C FT-2B33-N024C</div> <div>FT-2B33-N014D FT-2B33-N024D</div> <div> <div>FY-1B33-K608A FY-1B33-K606A</div> <div>FY-1B33-K608B FY-1B33-K606B</div> <div>FY-1B33-K608C FY-1B33-K606C</div> <div>FY-1B33-K608D FY-1B33-K606D</div> </div> <div> <div>FY-2B33-K608A FY-2B33-K606A</div> <div>FY-2B33-K608B FY-2B33-K606B</div> <div>FY-2B33-K608C FY-2B33-K606C</div> <div>FY-2B33-K608D FY-2B33-K606D</div> </div> <div> <div>FY-1B33-K607A FY-2B33-K607A</div> <div>FY-1B33-K607B FY-2B33-K607B</div> <div>FY-1B33-K607C FY-2B33-K607C</div> <div>FY-1B33-K607D FY-2B33-K607D</div> </div> <div> <div>RY-1C51-K605GM RY-1C51-K605GN</div> <div>RY-1C51-K605GP RY-1C51-K605GR</div> <div>RY-1C51-K605GS RY-1C51-K605GT</div> </div> <div> <div>RY-2C51-K605GM RY-2C51-K605GN</div> <div>RY-2C51-K605GP RY-2C51-K605GR</div> <div>RY-2C51-K605GS RY-2C51-K605GT</div> </div> <div> <div>RY-1C51-K605GU RY-1C51-K605GV</div> <div>RY-2C51-K605GU RY-2C51-K605GV</div> </div> </div> <p>Since the components of the PRNMS are not relied upon for any accident mitigation or post accident control function (Reference 3.21) this calculation takes into account only the normal environmental conditions.</p> <p>The Standard Technical Specifications (Reference 3.24, Table 3.3.1.1-1) are only applicable to this calculation for the Neutron Flux High - Setdown and Fixed Neutron Flux - High Scram trips. The values given for the flow biased trips are differernt than the current LaSalle values (i.e., LaSalle, a BWR/5, has different slope and offset values). The rod block functions of the RBM and Recirculation Flow Monitor are not covered in the Standard Technical Specifications of Reference 3.24.</p> <p>In addition, this calculation will determine the required nominal trip setpoints and allowable values for the APRM flow biased simulated thermal power scram and rod block functions (flow biased and clamped) for the revised analytical limits resulting from the uprating of thermal power discussed in Reference 3.33.</p>			
REVISION NO.	0	2	

COMMONWEALTH EDISON COMPANY

946

CALCULATION NO. L-001345

PAGE 7 of 191

2.0 METHODOLOGY AND ACCEPTANCE CRITERIA

The methodology used for this calculation is that presented in References 3.2 and 3.3. A setpoint will be considered acceptable if the calculation shows that a positive margin exists. If a positive margin does not exist a new setpoint will be calculated according to the criteria of Reference 3.3. Revision 2 of this calculation is in accordance with Reference 3.34.

For all trips, the calculation will begin with the existing Tech Spec Nominal Trip Setpoint (NTSP). The 'Total Error' (TE) for each setpoint will be determined twice, once to support an Analytical Limit (AL) evaluation and once to support an Allowable Value (AV) evaluation. Then, by adding or subtracting the appropriate error terms, the AL and AV margins to the Tech Spec setpoint will be demonstrated to be positive. Positive margin for the procedural setpoints is also documented.

2.1 The evaluation of errors used to determine the 'Total Error' (TE) is consistent with the above methodology with the following exceptions:

- a. The calibration tolerance is assumed to describe the limits of the as-left component outputs. For a random error, this corresponds to 100% of the population and can be statistically represented by a 3 sigma value. Per References 3.2 and 3.3, the 'Setting Tolerance' (ST) is defined as a random error which is due to the procedural allowances given to the technician performing the calibration. For this calculation:

$$ST = (\text{Calibration tolerance})/3 \quad (1\sigma)$$

- b. Drift Time Period Extension

Section 3.3.1 of Reference 3.2, Exhibit A, gives the following equation for calculating the effective drift based on a given surveillance interval (SI) and a known drift uncertainty term (IDE):

$$eD = (1 + LF/SI) * SI * IDE$$

where LF is the late factor. In this equation IDE is some variable per unit time. This effectively says that eD is adjusted for time differences linearly by the ratio of $(1 + LF/SI) * SI$ to the time interval portion of IDE.

REVISION NO.

0

2

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 8 of 191

Reference 3.8 allows drift to be treated as a random variable. Therefore, as is done in Reference 3.13, when it is necessary to adjust the drift data for a time period that is longer than the time period associated with the given drift data, the adjustment will be performed by using the square root of the ratio of the two time periods.

$$RD = \{[(1 + LF/SI) * SI] / IDE_T\}^{0.5} * IDE_V$$

where IDE_T is the per unit time portion (denominator) of IDE , and IDE_V is the drift value portion (numerator) of IDE . Note that drift values will not be reduced when the surveillance interval is less than the given instrument drift time period.

c. Error propagation through Square Root Modules

The Recirculation Flow Monitors each contain two square root modules that convert the 4 to 20 ma signals from the flow transmitters to a 0 to 10 Vdc output. From these values the transfer equation is determined to be

$$V = 25\sqrt{I-4} \quad \text{Equation 1}$$

where V is the output in Vdc and I is the input current from the transmitter in milliamps. Since this is a non-linear function the error transfer from input to output depends on the operating point. The transfer of the error at any point can be determined by taking the derivative of this transfer function (Reference 3.3). The result is

$$dV = \frac{1.25}{\sqrt{I-4}} dI \quad \text{Equation 2}$$

where dV is the output error caused by an input error of dI at a value of I current. Since there may be times where the operating point may be known as a function of the output voltage rather than input current an equation for this condition can be developed by solving the first equation for I and substituting in the second equation. The result is

$$dV = \frac{3.125dI}{V} \quad \text{Equation 3}$$

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 9 of 191

These last two equations will be used as necessary in determining the effect of the flow transmitters' errors on the flow loop accuracy.

The procedures actually measure the input current by running it through a one ohm resistor and measuring the voltage across the resistor. Therefore, the measured value is actually millivolts. However, since the resistor is one ohm the numerical value of the millivolt signal is exactly the same as the current in milliamps. Therefore, the voltage readings in millivolts can be used directly for the terms I and dI in equations 1 through 3.

d. Static Pressure Span Effect

References 3.5.s and 3.5.t state that a 1% of span correction has been included in the calibration to compensate for the static pressure span effect. However, Reference 3.14 states that there is a plus/minus correction uncertainty associated with this compensation. Therefore, this uncertainty will be included as a random error term in this calculation. Although the vendor gives this error term as a percent of reading, it will be considered as percent calibrated span which simplifies the calculation and is conservative.

2.2 Flow Biased Trip Slope Adjustment

The procedures of Reference 3.5 allow a certain tolerance when setting the flow biased trips in both the APRMs and RBMs. This has the effect of permitting a slope other than the specified value in the Flow to Power conversion circuit. Because of this the specified slope will be modified using the methodology of Reference 3.3 to a value that will allow for the setting tolerances.

Both the APRM and RBM procedures check the flow biased trip setpoints at two different values. The maximum error in the slope would then be determined by taking the most positive error at one point and the most negative error at the other point (procedural tolerances are in Vdc). This can then be converted to a percent power change by dividing by the volts per percent power, and then converted to a fraction by dividing by the flow difference between the two measurement points. The resulting error fraction can then be added to the specified slope to give a new value for use in the calculation. This slope will be the worst case slope (maximum) allowable by the procedures. The equation for this new slope is:

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

gub

CALCULATION NO. L-001345

PAGE 10 of 191

$$\text{Slope}_{\text{NEW}} = \text{Slope}_{\text{SP}} + [(T^+ + T^-)/0.08]/\Delta\text{Flow}$$

This will be used for both APRM and RBM flow biased error calculations. For the APRMs, the tolerance (T^+ , T^-) is ± 0.04 Vdc and the calibration flow (Δflow) is 80% flow, (Section 10.4). For the RBMs, the tolerance (T^+ , T^-) is ± 0.04 Vdc and the calibration flow (Δflow) is 100% flow (Section 10.5).

- 2.3 The numbers displayed in this calculation have not been rounded to six decimal places. As such, the internal spreadsheet is carrying additional digits. This may cause the sixth decimal place to vary from normal rounding convention. Rounding was removed to make the electronic file more stable. The variations of the last digits do not affect the final calculation results and therefore are considered acceptable.

REVISION NO.

0

2

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345		PAGE 11 of 191
<p>3.0 REFERENCES</p> <p>3.1 ANSI/ISA-S67.04-1988, "Setpoints for Nuclear Safety Related Instrumentation."</p> <p>3.2 TID-E/I&C-20, Rev. 0, "Basis for Analysis of Instrument Channel Setpoint Error & Loop Accuracy."</p> <p>3.3 TID-E/I&C-10, Rev. 0, "Analysis of Instrument Channel Setpoint Error and Instrument Loop Accuracy."</p> <p>3.4 NED-I-EIC-0255, Rev. 0, dated 04-14-94, "Measurement and Test Equipment (M&TE) Accuracy Calculation For Use With Commonwealth Edison Company Boiling Water Reactors." Chron 208597</p> <p>3.5 LaSalle Station Procedures</p> <ul style="list-style-type: none"> a. LIS-NR-103AA, Rev. 2, "Unit 1 Average Power Range Monitor Channels A, C, and E Rod Block and Scram Semiannual Calibration for Normal Plane Conditions." b. LIS-NR-103AB, Rev. 2, "Unit 1 Average Power Range Monitor Channels A, C, and E Rod Block and Scram Semiannual Calibration During Single Loop Operation." c. LIS-NR-103BA, Rev. 3, "Unit 1 Average Power Range Monitor Channels B, D, and F Rod Block and Scram Semiannual Calibration for Normal Plane Conditions." d. LIS-NR-103BB, Rev. 3, "Unit 1 Average Power Range Monitor Channels B, D, and F Rod Block and Scram Semiannual Calibration During Single Loop Operation." e. LIS-NR-105, Rev. 12, "Unit 1 Rod Block Monitor Calibration." f. LIS-NR-107, Rev. 6, "Unit 1 APRM/RBM Flow Converter to Total Core Flow Adjustment." g. LIS-NR-109, Rev. 7, "Unit 1 APRM Gain Adjustment." h. LIS-NR-111, Rev. 7, "Unit 1 LPRM Flux Amplifier Gain Adjustment." i. LIS-NR-113, Rev. 6, "Unit 1 Rod Block Monitor Calibration for Single Reactor Recirculation Loop Operation." j. LIS-NR-203AA, Rev. 0, "Unit 2 Average Power Range Monitor Channels A, C, and E Rod Block and Scram Semiannual 		
REVISION NO.	0	

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345		PAGE 12 of 191
<p style="text-align: center;">Calibration for Normal Plant Conditions."</p> <p>k. LIS-NR-203AB, Rev. 0, "Unit 2 Average Power Range Monitor Channels A, C, and E Rod Block and Scram Semiannual Calibration During Single Loop Operation."</p> <p>l. LIS-NR-203BA, Rev. 0, "Unit 2 Average Power Range Monitor Channels B, D, and F Rod Block and Scram Semiannual Calibration for Normal Plant Conditions."</p> <p>m. LIS-NR-203BB, Rev. 0, "Unit 2 Average Power Range Monitor Channels B, D, and F Rod Block and Scram Semiannual Calibration During Single Loop Operation."</p> <p>n. LIS-NR-205, Rev. 12, "Unit 2 Rod Block Monitor Calibration."</p> <p>o. LIS-NR-207, Rev. 6, "Unit 2 APRM/RBM Flow Converter to Total Core Flow Adjustment."</p> <p>p. LIS-NR-209, Rev. 7, "Unit 2 APRM Gain Adjustment."</p> <p>q. LIS-NR-211, Rev. 7, "Unit 2 LPRM Flux Amplifier Gain Adjustment."</p> <p>r. LIS-NR-213, Rev. 6, "Unit 2 Rod Block Monitor Calibration for Single Reactor Recirculation Loop Operation."</p> <p>s. LIS-RR-101, Rev. 11, "Unit 1 Recirculation Flow Converter Calibration."</p> <p>t. LIS-RR-201, Rev. 10, "Unit 2 Recirculation Flow Converter Calibration."</p> <p>3.6 LaSalle Station UFSAR, Rev. 11, dated April 8, 1996</p> <p>3.7 LaSalle Station Technical Specification Unit 1, Amendment No. 117, dated January, 29, 1997 and Technical Specification Unit 2, Amendment No. 102, dated January 29,</p> <p>3.8 ComEd Letter DG 97-001088, "Reclassification of the drift error term in the ComEd Setpoint Accuracy Methodology," dated 25 August, 1997.</p> <p>3.9 GE Drawing 22A2843, Rev. 7, "Neutron Monitoring System" Design Specification.</p> <p>3.10 GE Drawing 22A2843AF, Rev 7, "Neutron Monitoring System" Design Specification Data Sheet.</p>		
REVISION NO.	0	

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345		PAGE 13 of 191
<p>3.11 GE Drawing 235A1386, Rev. 1, "Design and Performance Specification APRM (Page)."</p> <p>3.12 GE Drawing 248A9544, Rev. 1, "Rod Block Monitor (Page) '69" Specification.</p> <p>3.13 NEDC-31336P-A, "General Electric Instrumentation Setpoint Methodology," September 1996, (GE Proprietary Information), Sections 2.2.5 and 4.5.</p> <p>3.14 Rosemount Nuclear Data Sheet, "Model 1152 Alphaline Pressure Transmitter for Nuclear Service," MAN 4235A00, 1995.</p> <p>3.15 Core Operating Limits Report, Appendix A, LaSalle Unit 1 Cycle 8 dated March 1996, and Appendix B, LaSalle Unit 2 Cycle 7 (no date).</p> <p>3.16 Letter to File, KG971022.DOC, Documents Telecons with LaSalle NMS Engineer Gene Pfister.</p> <p>3.17 E-Mail from Julie Leong to Clark F. Canham and W. Kent Green dated 10/14/97, Subject: LaSalle Recirc Flow Drift & Flow Element Accuracy.</p> <p>3.18 GE Drawing 225A6445, Rev. 0, "Flow Unit (Page)" Design and Performance Specification.</p> <p>3.19 ABB Combustion Engineering Document 00000-ICE-3231, Rev. 2, "Flow Unit Requirements Specification."</p> <p>3.20 NDIT No. LS-0643, Upgrade 0, Transmittal of information concerning ambient temperature and seismic errors.</p> <p>3.21 NEDO-31558-A dated March 1993, "Position on NRC Regulatory Guide 1.97, Revision 3, Requirements for Post-Accident Neutron Monitoring System."</p> <p>3.22 NDIT No. LS-0588, Upgrade 0, Transmits documents describing ComEd methodology for performing setpoint calculations, MT&E accuracies, and ComEd calibration procedures.</p> <p>3.23 NDIT No. LS-0598, Upgrade 1, Transmits ComEd procedures LIS-RR-101, Rev. 11 and LIS-RR-201, Rev. 10; NEP-12-02, Rev. 5; LaSalle County Station UFSAR, Rev. 11, Chapter 3.11, Environmental Design of Mechanical and Electrical Equipment; Letter DG 97-001088, dated August 25, 1997, regarding, "Reclassification of the drift error term in the ComEd Setpoint Accuracy."</p>		
REVISION NO.	0	

COMMONWEALTH EDISON COMPANY

QUB

CALCULATION NO. L-001345		PAGE 14 of 191	
<p>3.24 NUREG 1434, Rev. 0, "Standard Technical Specifications, General Electric Plants, BWR/6" dated September 1992.</p> <p>3.25 NDIT No. LS-0604, Upgrade 0, Transmittal of ABB "Flow Unit Requirements Specification 00000-ICE-3231, Rev. 2."</p> <p>3.26 GE letter, A097-011, Allowance for Process Computer Core Power Measurement Analytical Uncertainty in LaSalle, from Jose L. Casillas, dated December 12, 1997.</p> <p>3.27 NDIT No. LS-0684, Upgrade 1, "Analytical Limits for use as Inputs in APRM Setpoint Calculations."</p> <p>3.28 GE letter, A097-015 Rev. 1, Flow Biased Simulated Thermal Power Scram and APRM Rod Block in LaSalle, from Jose L. Casillas, dated December 22, 1997 with its Enclosure (4).</p> <p>3.29 GE Drawing 328X105TD, Rev. 3, "Power Range Monitoring Cabinet," Parts List.</p> <p>3.30 GE Drawing PL791E507TD, Rev. 10, "Power Range Monitoring Cabinet," Parts List.</p> <p>3.31 GE Drawing PL791E392BB, Rev. 14, "Flow Unit," Parts List.</p> <p>3.32 E-Mail from Andrew N. Poulos to Jose L. Casillas, Daniel L. Gould, and Larry Chi dated December 10, 1997, Subject: LaSalle Flow Bias.</p> <p>3.33 SEAG 99-000517, "Power Uprate Safety Analysis Report for LaSalle County Station Units 1 and 2", GE Nuclear Energy, NEDC-32701P, Revision 1, DRF A13-00384-16, July 1999.</p> <p>3.34 NES-EIC-20.04, Revision 1, "Analysis of Instrument Channel Setpoint Error and Instrument Loop Accuracy."</p>			
REVISION NO.	0	2	

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345		PAGE 15 of 191	
<p>4.0 DESIGN INPUTS</p> <p>4.1 Accuracy for Flow Transmitters</p> <p>The procedures of Reference 3.5.s and 3.5.t indicate that there are five different calibrated spans for the 16 flow transmitters covered by this calculation. Since some of the uncertainty terms depend on the calibrated span and/or the transmitters upper range, the lowest value of the calibrated span will be used for all flow loops since this will produce conservative results.</p> <p>4.2 Environmental Conditions at Flow Transmitters</p> <p>The ComEd EWCS (Electronic Work Control System) indicates that the EQ Zone for the Flow Transmitters is LH4A. Table 3.11-6 of Reference 3.6 indicates that the short term peak temperature in this area resulting from an HELB event is 145°F with a total integrated gamma dose of 1×10^7 rads. However, the Flow Transmitters are only being evaluated for normal operating conditions so these bounding conditions are not applicable.</p> <p>Table 3.11-15 of Reference 3.6 gives the service conditions environment for this zone. This indicates that under normal conditions temperatures could reach a maximum of 118°F, although this is predicted to occur for only about 9 days out of the remaining plant life (about 13,000 days). Therefore, 118°F will be used as the maximum temperature at the flow transmitter.</p> <p>4.3 Temperature, radiation, humidity, and power supply errors are considered to be included in the manufactures accuracy terms when they are not identified separately.</p> <p>4.4 Instrument reference accuracy was obtained from the published manufacturer's accuracy specifications.</p> <p>4.5 Calibration tolerances were obtained from the associated LIS calibration procedures listed in Reference 3.5.</p> <p>4.6 Per Reference 3.20 "A minimum ambient temperature of 60°F should be used to calculate temperature effect and Measurement & Test Equipment (M&TE) error."</p> <p>4.7 Per Reference 3.20 "For normal errors, seismic events less than or equal to an Operating Basis Earthquake (OBE) are considered to cause no permanent shift in the input/output relationship of the devices. For seismic events greater than an OBE, affected instrumentation will be recalibrated as necessary prior to any subsequent accident (i.e., prior to restart), negating any permanent shift which may have resulted from a post seismic</p>			
REVISION NO.	0		

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 16 of 191

shift. Therefore, the seismic error for normal operating conditions is considered to be negligible." Since the Power Range Neutron Monitoring System is not for mitigation of an accident this statement is applicable for all seismic error terms.

- 4.8 The RBM contains a variable gain function whose purpose is to adjust the reading of the local average monitored by the RBM to equal the overall core average as monitored by a reference APRM. The range of gain variation in the RBM is 1 to 9 (Reference 3.12) in order to accommodate the range of local averages from center core to core edge. For this calculation the gain of the RBM will be considered equal to the nominal APRM gain since the RBM output is adjusted to equal an APRM output. This will produce conservative results when rod movement involves control rods centrally located in the core and non-conservative results when rods near the outside of the core are involved. However, this is considered acceptable for this application since the outside control rods have a lower rod worth making their movement less effective than movement of the inside rods.
- 4.9 The Comparator Trip in the RFM compares the outputs from two RFMs by subtracting one of the signals from the other and then comparing the absolute value of the result with a fixed reference. Because of this subtraction process any portions of each RFM's error terms which are generated by the same input will be canceled. Since all four RFMs receive their input from the same two flow elements (one for the A loop and one for the B loop), the error induced by each flow element into each RFM will be exactly the same. Therefore, this error term does not need to be carried through the RFM when determining the error associated with the Comparator Trip function.
- 4.10 Since the square root converter is not a linear module error terms appearing at the input must be converted to equivalent output values by one of the equations of Section 2.1.c. Also, these equations indicate that the conversion factor is a function of the operating point. Therefore, an operating point must be chosen at which the conversion will take place. For this calculation the operating point is considered to be 6 Vdc (OP_{SR}) at the output of the square root converters which is equal to approximately 75% Flow. Choosing this value is a compromise in that the error term is then conservative at flows greater than 75% but non-conservative at flows less than 75%. This is considered acceptable since in general plant operating margins become larger at low power, low flow conditions (Reference 3.28).

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 17 of 191

4.11 Reference 3.13 indicates that the bias portion of LPRM detector non-linearity (SNL_B), which is part of Primary Element Accuracy (PEA) term, depends on the operating point. Figure 4.5-4 show that at low power levels the bias would actually help the trip to occur sooner than necessary. For the downscale trips the value of the bias is approaching zero. Therefore, in this calculation a value of zero will be used for error determinations involving the APRM and RBM Downscale, APRM Setdown Rod Block, and APRM Setdown Scram trips.

4.12 Flow Element Accuracy

Reference 3.17 provides an accuracy value for the elbow type flow elements used at LaSalle. For the purposes of this calculation this value will be considered to be the error in the measurable parameter (ΔP) over the applicable flow range.

4.13 Errors pertaining to core power measurement as determined by the plant process computer have already been considered by various analyses as is indicated in Reference 3.26. Therefore, the core power measurement uncertainty does not need to be included in the setpoint calculations.

4.14 Analytical Limits and Allowable Values Inputs

From References 3.27 and 3.33, Analytical Limit inputs are provided for all non-flow biased setpoints and the APRM Flow Biased Trip functions (flow biased and clamp). Reference 3.15 provides the Allowable Values for the RBM Upscale Trips. The Analytical Limits for the RBM flow-biased setpoints are calculated in Section 13. The information provided by References 3.15, 3.27, and 3.33 is summarized below:

Bistable	AL	AV	Reference
APRM Flow Biased Trips			
Flow Biased Trip Clamp, Two Recirc Loop Operation (TLO)	115.5%, 119.5%	-	3.27
Flow Biased Trip Clamp, Single Recirc Loop Operation (SLO)	113.8%		3.33
Flow Biased STP Scram -TLO	0.62W+70.9%		3.33
Flow Biased STP Scram -SLO	0.55W+58.33%		3.33
Flow Biased STP Rod Block -TLO	0.62W+59.47%		3.33
Flow Biased STP Rod Block -SLO	0.55W+46.9%		3.33

REVISION NO.

0

2

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 18 of 191

Bistable	AL	AV	Reference
APRM Fixed Trips			
Neutron Flux - High (Fixed) (Scram)	122.4%, 124.2%	-	3.27, 3.33
Neutron Flux - High (Fixed) (Setdown) (Scram)	25%	-	3.27
Neutron Flux - High (Fixed) (Setdown) (Rod Block)	19%	-	3.27
Neutron Flux Downscale (Rod Block)	0%	-	3.27
Rod Block Monitor Trips			
RBM Upscale (Rod Block), Two Recirc Loop Operation	-	0.66W + 48%	3.15 and Section 10.5
RBM Upscale (Rod Block), Single Recirc Loop Operation	-	0.66W + 42.7%	3.15 and Section 10.5
RBM Downscale (Rod Block)	0%	-	3.27
Recirc Flow Monitor Trips			
RFM Upscale (Rod Block)	116%	-	3.27
RFM Comparator (Rod Block)	19%	-	3.27

REVISION NO.

0

2

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345				PAGE 19 of 191
<p>5.0 ASSUMPTIONS</p> <p>5.1 Published instrument and M&TE vendor specifications are considered to be 2 sigma (σ) values unless specific information is available to indicate otherwise.</p> <p>5.2 It is assumed that the M&TE listed in Section 9.0 is calibrated to the required manufacturer's specifications and within the manufacturer's required environmental conditions. Temperature related errors are based on the difference between the manufacturer's specified calibration temperature and the worst case temperature at which the device is used.</p> <p>It is also assumed that the calibration standard accuracy error of the M&TE is negligible with respect to the other error terms unless noted otherwise within this calculation.</p> <p>5.3 Deleted</p> <p>5.4 When no setting tolerances are given in the procedures for measurements using digital instruments, it will be assumed that the setting tolerance is equal to the reference accuracy of the test instrument.</p> <p>5.5 Deleted</p> <p>5.6 Deleted</p> <p>5.7 Since the ABB designed flow unit has not yet been installed, it will be assumed that this flow unit will be mounted in the same general area as is the present flow unit. Therefore, the environmental parameters for the current flow unit will be assumed to be applicable to the new ABB flow unit.</p> <p>5.8 Reference 3.18 gives only a "Stability" value for the specifications of the trip circuits in the GE manufactured Recirculation Flow Monitor. Therefore, it will be assumed that this uncertainty encompasses both accuracy and drift and the value given will be divided equally (algebraically) between accuracy and drift. This makes their values equivalent to those for the APRM Fixed Trips which are of similar design. It will also be assumed that the drift time period given for the analog drift term applies here.</p> <p>5.9 Since there have been no procedures generated for calibrating the ABB designed flow unit it will be assumed that, when developed, they will be similar to those used to calibrate the GE designed flow unit. Therefore, the MTE and ST terms derived for the GE</p>				
REVISION NO.	0			

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 20 of 191

flow unit will be assumed applicable to the calibration of the ABB flow unit.

- 5.10 Reference 3.19 does not give a value for drift for the ABB RFM trip circuits. Therefore, it will be assumed that drift is included in the accuracy term.
- 5.11 Based on the information contained in References 3.4 and 3.16 it will be assumed that LaSalle is using a Wallace and Tiernan Model 65-120 instrument when the procedures of References 3.5.s and 3.5.t call for a Pneumatic Calibrator.

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 21 of 191

6.0 INSTRUMENT CHANNEL CONFIGURATION

The Power Range Neutron Monitoring System (PRNMS) can be divided into three primary blocks; the Recirculation Flow Monitors (RFM) of which there are four, the Average Power Range Monitors (APRM) of which there are six, and the Rod Block Monitors (RBM) of which there are two. Each of these three blocks will be discussed separately. Block diagrams of the complete PRNMS and one for each of the three subsystems follows the discussion.

Recirculation Flow Monitor

Each RFM receives the current output from two differential pressure transmitters that are monitoring the flow in the two reactor recirculation drive loops. These signals are applied to the input of square root converters that change the current input to a voltage output that is proportional to the flow in each loop. The outputs of the square root converters are then summed, the resulting output representing the total flow in the two recirculation loops. The total flow signal is then applied to an Upscale Trip, one input of a Comparator Trip, and to the associated APRMs and RBMs. The other input to the Comparator Trip comes from another RFM, the comparison being a means of determining possible problems in the flow monitoring equipment.

Average Power Range Monitor

An APRM is made up of several individual monitoring channels of Local Power Range Monitors (LPRM) plus the electronic circuitry required to average the outputs of these LPRM channels, and the trip circuits required to indicate high or low average power.

Each LPRM card receives a current signal from an incore neutron detector and converts this signal to a voltage output which in turn is applied to an input of the APRM averaging circuitry. The averaging circuitry takes the inputs from as many as 22 LPRMs and, as the name implies, provides an output that is the average of the inputs. This output is then calibrated to represent average core thermal power.

The output of the averaging circuitry is applied to the several upscale or downscale trip circuits. Some of the trip circuits use a field adjustable voltage as a reference. These are referred to throughout this calculation as the fixed trip circuits. Other trip circuits use as a reference a signal which varies as a function of the recirculation flow. These trips are referred to as flow biased trips. This variable reference is generated within the APRM by a circuit (Flow Controlled Trip Reference Unit) that receives the output from one of the RFMs and

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 22 of 191

converts this to a signal proportional to the input but with a slope less than one. The uncertainties for the Flow Controlled Trip Reference Unit is included in the APRM uncertainties.

The outputs from the trip circuits go either to the Reactor Protection System where they can cause a scram, or to the Reactor Manual Control System where a rod withdrawal block may be initiated.

Rod Block Monitor

The Rod Block Monitor is similar to the APRM in that it receives the signals from multiple LPRMs, averages them, and provides outputs to trip circuits. However, instead of averaging LPRMs from throughout the core, the RBM looks only at those LPRMs immediately surrounding a control rod that has been selected for movement. Once the average has been performed the RBM adjusts the output such that it is equal to or greater than the output of a reference APRM.

The output of the averaging circuit then goes to some flow biased upscale trip circuits and a fixed downscale trip. The flow biased reference in the RBM is generated exactly as it is in the APRM.

The outputs of the trip circuits in the RBM all go to the Reactor Manual Control System where they will initiate a rod block.

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 23 of 191




Figure 1
Power Range
Neutron Monitoring System

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 24 of 191




Figure 2
Recirculation Flow Monitor

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 25 of 191




Figure 3
Average Power Range Monitor

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 26 of 191




Figure 4
Rod Block Monitor

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 27 of 191

7.0 PROCESS PARAMETERS

The process being measured by the LPRM detectors is reactor core neutron activity, normally referred to as neutron flux. The detectors are positioned three-dimensionally throughout the reactor core and are in contact with reactor water.

The following are the applicable process parameters (References 3.9 and 3.10):

Neutron Flux:

Operating: 1.2×10^{12} to 2.8×10^{14} nv (nv = unit of neutron density)
Peak: 3.4×10^{14} nv at 120% Rated Power

Gamma Flux:

Operating: 4.2×10^8 to 1.2×10^9 R/hr at 100% Rated Power

Pressure:

1025 psig nominal at 100% Rated Power
1375 psig maximum emergency

Temperature

546°F nominal
583°F emergency conditions

The Power Range Neutron Monitoring System interfaces with some differential pressure transmitters from the Reactor Recirculation System that are being used to measure recirculation drive flow. The sensing portion of these transmitters is exposed to approximately the same process pressure as are the neutron detectors. The temperature of the fluid has, however, dropped to reactor building ambient temperature by the time it reached the location of the transmitters. Based on References 3.5.s and 3.5.t, 100% Flow in these flow loops is equal to 55,000 GPM.

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 28 of 191

8.0 LOOP ELEMENT DATA

8.1 Module 1

Rosemount Differential Pressure
Transmitter Model 1152DP5E220280PB
(From EWCS)

Equipment Numbers
(From Procedures)

FT-1B33-N014A	FT-1B33-N024A
FT-1B33-N014B	FT-1B33-N024B
FT-1B33-N014C	FT-1B33-N024C
FT-1B33-N014D	FT-1B33-N024D

FT-2B33-N014A	FT-2B33-N024A
FT-2B33-N014B	FT-2B33-N024B
FT-2B33-N014C	FT-2B33-N024C
FT-2B33-N014D	FT-2B33-N024D

8.1.1 Transmitter Specifications (Range 5) (Reference 3.14)

Upper Range:	750 in H ₂ O
Accuracy:	±0.25%SP
Temperature Effect:	±(0.5%UR + 0.5%SP) per 100°F
Drift:	±0.2%UR/30 months
Power Supply Effect:	±0.005%SP/volt
Static Pressure Zero Effect:	±0.25%UR/2000 psi
Static Pressure Span Effect:	±0.25% Reading/1000 psi
(Correction Uncertainty)	
Seismic Effect:	±0.25%UR to 3g
Radiation Effect:	±8%UR for TID = 5×10 ⁶ rads at a dose rate of 0.4×10 ⁶ rad/hr

8.1.2 Environmental Parameters at Transmitter Location (Zone LH4A from EWCS)

The maximum temperature for EQ Zone LH4A is 118°F (See Section 4.3). The minimum temperature is 60°F (Assumption 5.3)

From Table 3.11-15 of Reference 3.6, the expected relative humidity is 35%, the pressure is -0.4" W.G., and the integrated gamma dose is 2×10⁶ rads.

8.2 Module 2

GE Square Root Converter Model
136B3051AAG003 (Reference 3.31)

Equipment Numbers
(From Section 3.5)

FY-1B33-K608A	FY-1B33-K606A
FY-1B33-K608B	FY-1B33-K606B
FY-1B33-K608C	FY-1B33-K606C
FY-1B33-K608D	FY-1B33-K606D

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345		PAGE 29 of 191																												
<div style="text-align: right; margin-bottom: 10px;"> FY-2B33-K608A FY-2B33-K606A FY-2B33-K608B FY-2B33-K606B FY-2B33-K608C FY-2B33-K606C FY-2B33-K608D FY-2B33-K606D </div> <div> <p>8.2.1 Square Root Converter Specifications</p> <p>Per Reference 3.18 the reference accuracy for the square root converter is included in an overall RFM accuracy which will be applied at the output of the Flow Summer (Module 3).</p> <p>8.2.2 Environmental Parameters at Square Root Converter Location (Zone LC1A from EWCS) (Reference 3.6, Table 3.11-24)</p> <table style="width: 100%; margin-top: 10px;"> <tr> <td style="width: 60%;">Temperature (°F)</td> <td style="text-align: right;">72 - 74</td> </tr> <tr> <td>Relative Humidity (%)</td> <td style="text-align: right;">35 - 45</td> </tr> <tr> <td>Radiation</td> <td style="text-align: right;">1x10³ rads gamma (integrated)</td> </tr> </table> <p>8.3 Module 3 GE Flow Summer Model 136B3088AAG001 (Reference 3.31)</p> <table style="width: 100%; margin-top: 10px;"> <tr> <td style="width: 40%;">Equipment Numbers (From Section 3.5)</td> <td style="width: 20%;">FY-1B33-K607A</td> <td style="width: 40%;">FY-2B33-K607A</td> </tr> <tr> <td></td> <td>FY-1B33-K607B</td> <td>FY-2B33-K607B</td> </tr> <tr> <td></td> <td>FY-1B33-K607C</td> <td>FY-2B33-K607C</td> </tr> <tr> <td></td> <td>FY-1B33-K607D</td> <td>FY-2B33-K607D</td> </tr> </table> <p>8.3.1 Flow Summer Specifications</p> <p>Per Reference 3.18 the following specifications apply to the flow unit in total including the square root converters (Module 2).</p> <table style="width: 100%; margin-top: 10px;"> <tr> <td style="width: 60%;">Accuracy:</td> <td style="text-align: right;">±2% FS</td> </tr> <tr> <td>Drift:</td> <td style="text-align: right;">±1.25% FS per 700 hrs.</td> </tr> <tr> <td>Trip Stability:</td> <td style="text-align: right;">2% FS</td> </tr> </table> <p>Per Assumption 5.8 stability is divided equally between accuracy and drift. Therefore,</p> <table style="width: 100%; margin-top: 10px;"> <tr> <td style="width: 60%;">Trip Accuracy:</td> <td style="text-align: right;">1% FS</td> </tr> <tr> <td>Trip Drift:</td> <td style="text-align: right;">1% FS per 700 hrs.</td> </tr> </table> </div>			Temperature (°F)	72 - 74	Relative Humidity (%)	35 - 45	Radiation	1x10 ³ rads gamma (integrated)	Equipment Numbers (From Section 3.5)	FY-1B33-K607A	FY-2B33-K607A		FY-1B33-K607B	FY-2B33-K607B		FY-1B33-K607C	FY-2B33-K607C		FY-1B33-K607D	FY-2B33-K607D	Accuracy:	±2% FS	Drift:	±1.25% FS per 700 hrs.	Trip Stability:	2% FS	Trip Accuracy:	1% FS	Trip Drift:	1% FS per 700 hrs.
Temperature (°F)	72 - 74																													
Relative Humidity (%)	35 - 45																													
Radiation	1x10 ³ rads gamma (integrated)																													
Equipment Numbers (From Section 3.5)	FY-1B33-K607A	FY-2B33-K607A																												
	FY-1B33-K607B	FY-2B33-K607B																												
	FY-1B33-K607C	FY-2B33-K607C																												
	FY-1B33-K607D	FY-2B33-K607D																												
Accuracy:	±2% FS																													
Drift:	±1.25% FS per 700 hrs.																													
Trip Stability:	2% FS																													
Trip Accuracy:	1% FS																													
Trip Drift:	1% FS per 700 hrs.																													
REVISION NO.	0																													

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345		PAGE 30 of 191																																
<p>8.3.2 Environmental Parameters at Flow Summer Location (Zone LC1A from EWCS) (Reference 3.6, Table 3.11-24)</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 60%;">Temperature (°F)</td> <td>72 - 74</td> </tr> <tr> <td>Relative Humidity (%)</td> <td>35 - 45</td> </tr> <tr> <td>Radiation</td> <td>1×10³ rads gamma (integrated)</td> </tr> </table> <p>8.4 Module 4 Average Power Range Monitor (APRM) Model 145C3096BBG001 & G002 (Reference 3.30)</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 40%;">Equipment Numbers (From Section 3.5)</td> <td>RY-1C51-K605GM RY-1C51-K605GN RY-1C51-K605GP RY-1C51-K605GR RY-1C51-K605GS RY-1C51-K605GT</td> </tr> <tr> <td></td> <td>RY-2C51-K605GM RY-2C51-K605GN RY-2C51-K605GP RY-2C51-K605GR RY-2C51-K605GS RY-2C51-K605GT</td> </tr> </table> <p>8.4.1 APRM Specifications</p> <p style="padding-left: 20px;"><u>LPRM Specifications</u> (Reference 3.9)</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 60%;">Accuracy:</td> <td>±0.8% FS</td> </tr> <tr> <td>Drift:</td> <td>±0.8% FS/700 Hrs.</td> </tr> </table> <p style="padding-left: 20px;"><u>Averaging Circuitry Specifications</u> (Reference 3.11)</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 60%;">Accuracy:</td> <td>±0.8% FS</td> </tr> <tr> <td>Drift:</td> <td>±0.5% FS/700 Hrs.</td> </tr> <tr> <td>Gain:</td> <td>2.5 ± 40%</td> </tr> </table> <p style="padding-left: 20px;"><u>Trip Circuits</u> (Non-Flow Biased) (Reference 3.11)</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 60%;">Accuracy:</td> <td>±1% FS</td> </tr> <tr> <td>Drift:</td> <td>±1% FS/700 Hrs.</td> </tr> </table> <p style="padding-left: 20px;"><u>Trip Circuits</u> (Flow Biased) (Reference 3.11)</p> <table style="width: 100%; border: none;"> <tr> <td style="width: 60%;">Accuracy:</td> <td>±1% FS</td> </tr> <tr> <td>(50 to 100% Flow)</td> <td>±2% FS</td> </tr> <tr> <td>(0 to 50% Flow)</td> <td>±1% FS/700 Hrs.</td> </tr> <tr> <td>Drift:</td> <td>(Reference 3.9)</td> </tr> </table>			Temperature (°F)	72 - 74	Relative Humidity (%)	35 - 45	Radiation	1×10 ³ rads gamma (integrated)	Equipment Numbers (From Section 3.5)	RY-1C51-K605GM RY-1C51-K605GN RY-1C51-K605GP RY-1C51-K605GR RY-1C51-K605GS RY-1C51-K605GT		RY-2C51-K605GM RY-2C51-K605GN RY-2C51-K605GP RY-2C51-K605GR RY-2C51-K605GS RY-2C51-K605GT	Accuracy:	±0.8% FS	Drift:	±0.8% FS/700 Hrs.	Accuracy:	±0.8% FS	Drift:	±0.5% FS/700 Hrs.	Gain:	2.5 ± 40%	Accuracy:	±1% FS	Drift:	±1% FS/700 Hrs.	Accuracy:	±1% FS	(50 to 100% Flow)	±2% FS	(0 to 50% Flow)	±1% FS/700 Hrs.	Drift:	(Reference 3.9)
Temperature (°F)	72 - 74																																	
Relative Humidity (%)	35 - 45																																	
Radiation	1×10 ³ rads gamma (integrated)																																	
Equipment Numbers (From Section 3.5)	RY-1C51-K605GM RY-1C51-K605GN RY-1C51-K605GP RY-1C51-K605GR RY-1C51-K605GS RY-1C51-K605GT																																	
	RY-2C51-K605GM RY-2C51-K605GN RY-2C51-K605GP RY-2C51-K605GR RY-2C51-K605GS RY-2C51-K605GT																																	
Accuracy:	±0.8% FS																																	
Drift:	±0.8% FS/700 Hrs.																																	
Accuracy:	±0.8% FS																																	
Drift:	±0.5% FS/700 Hrs.																																	
Gain:	2.5 ± 40%																																	
Accuracy:	±1% FS																																	
Drift:	±1% FS/700 Hrs.																																	
Accuracy:	±1% FS																																	
(50 to 100% Flow)	±2% FS																																	
(0 to 50% Flow)	±1% FS/700 Hrs.																																	
Drift:	(Reference 3.9)																																	
REVISION NO.	0																																	

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345		PAGE 31 of 191	
8.4.2	Environmental Parameters at APRM Location (Zone LC1A from EWCS) (Reference 3.6, Table 3.11-24)		
	Temperature (°F)	72 - 74	
	Relative Humidity (%)	35 - 45	
	Radiation	1×10 ³ rads gamma (integrated)	
8.5	Module 5	Rod Block Monitor (RBM) Model 145C3105BBG001 & G002 (Reference 3.30)	
	Equipment Numbers (Reference 3.16)	RY-1C51-K605GU RY-1C51-K605GV RY-2C51-K605GU RY-2C51-K605GV	
8.5.1	RBM Specifications (Reference 3.12)		
	<u>Averaging and Gain Adjust Circuitry</u>		
	Accuracy:	±0.8% FS	
	Drift:	±0.3% FS per 4 hrs.	
	Gain Range:	1 to 9	
	Accuracy of Null:	±1% of Point	
	<u>Trip Circuits</u> (Non-Flow Biased)		
	Same as APRM	(Uses same Quad Trip Cards)	
	<u>Trip Circuits</u> (Flow Biased)		
	Same as APRM	(Uses same Quad Trip and Flow Biased Trip Unit Cards)	
8.5.2	Environmental Parameters at RBM Location (Zone LC1A from EWCS) (Reference 3.6, Table 3.11-24)		
	Temperature (°F)	72 - 74	
	Relative Humidity (%)	35 - 45	
	Radiation	1×10 ³ rads gamma (integrated)	
REVISION NO.		0	

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345		PAGE 32 of 191
<div style="display: flex; justify-content: space-between;"> <div>8.6 Module 6</div> <div>ABB Recirculation Flow Monitor Model (Reference 3.25)</div> </div> <div style="display: flex; justify-content: space-between; margin-top: 10px;"> <div>Equipment Numbers</div> <div>Not Known</div> </div> <div style="margin-top: 10px;"> 8.6.1 Flow Unit Specifications (Reference 3.19) <div style="margin-left: 40px;"> Accuracy: ±1% CS (Total Flow Voltage Output) </div> <div style="margin-left: 40px;"> Temperature Effect: ±0.5% CS (Total Flow Voltage Output) </div> <div style="margin-left: 40px;"> Drift: ±0.5% CS per 30 months (Total Flow Voltage Output) </div> <div style="margin-left: 40px;"> Comparator Trip Accuracy: ±1% CS (±2% minus 1% total flow error) </div> <div style="margin-left: 40px;"> Upscale Trip Accuracy: ±1% CS (±2% minus 1% total flow error) </div> <div style="margin-left: 40px;"> Transmitter Power Supply Drift: ±2% per 30 months </div> </div> <div style="margin-top: 10px;"> 8.6.2 Environmental Parameters at Flow Unit Location (Zone LC1A from EWCS) (Reference 3.6, Table 3.11-24) [It is assumed that this flow unit will be mounted in the same general area as is the present flow unit] <div style="margin-left: 40px; margin-top: 10px;"> Temperature (°F) 72 - 74 Relative Humidity (%) 35 - 45 Radiation 1×10³ rads gamma (integrated) </div> </div>		
REVISION NO.	0	

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 33 of 191

9.0 CALIBRATION INSTRUMENT DATA

Most of the calibration procedures listed in Section 3.5 specify the specific instrument to be used. However, References 3.5.f, h, o, and q require only that the DMM used should have an accuracy of at least ± 0.01 Vdc. If this is considered a two sigma value the one sigma requirement, which makes it compatible with the DMM data from Reference 3.4, would be $0.01/2$ or ± 0.005 Vdc. This value will be considered the MTE uncertainty term in the portions of the calculation involving the above four specified procedures.

The specified or acceptable DMMs are listed below with the evaluations of Reference 3.4 shown in Section 9.1

<u>Calibration Instrument</u>	<u>MTE Error [1σ]</u>	<u>Evaluation Parameters</u>
-------------------------------	---	------------------------------

MTE for all DMM Calibrations

Fluke 45 Med(30 Vdc Rng)	± 0.002462 Vdc	@10Vdc, 64.4-82.4°F
Fluke 8050A(20 Vdc Rng)	± 0.002693 Vdc	@10Vdc, 64.4-82.4°F
Fluke 8060A(20 Vdc Rng)	± 0.003640 Vdc	@10Vdc, 64.4-82.4°F
Fluke 8300A(10 Vdc Rng)	± 0.001005 Vdc	@10Vdc, 68-86°F
Fluke 8500A(10 Vdc Rng)	± 0.000180 Vdc	@10Vdc, 64.4-82.4°F
Fluke 8505A(10 Vdc Rng)	± 0.000140 Vdc	@10Vdc, 64.4-82.4°F
Fluke 8600A(200 mVdc Rng)	± 0.017205 mV	@20 mVdc, 59-95°F
Fluke 8600A(200 mVdc Rng)	± 0.022809 mV	@20 mVdc, 104°F
Fluke 8600A(200 mVdc Rng)	± 0.034961 mV	@20 mVdc, 122°F
Fluke 8600A(20 Vdc Rng)	± 0.001803 Vdc	@10Vdc, 59-95°F
Fluke 8800A(20 Vdc Rng)	± 0.000658 Vdc	@10Vdc, 64.4-82.4°F
Fluke 8810A(20 Vdc Rng)	± 0.000658 Vdc	@10Vdc, 64.4-82.4°F
Fluke 8840A Slo(20 Vdc Rng)	± 0.000461 Vdc	@10Vdc, 64.4-82.4°F
Fluke 8840A Med(20 Vdc Rng)	± 0.000559 Vdc	@10Vdc, 64.4-82.4°F
Fluke 8840A Fst(20 Vdc Rng)	± 0.002059 Vdc	@10Vdc, 64.4-82.4°F

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 34 of 191

9.1 DMM Measurement Error Evaluations

From Reference 3.5 DMMs are used to measure the voltage of various signals during calibration of the analog and trip functions. Therefore, each DMM which is either specified or acceptable for use in these applications will be evaluated on the appropriate Vdc scale and at the maximum voltage to be read.

FLUKE 45 MEDIUM READING RATE

RANGE: 30 Vdc

Manufacturer's Specifications

Reference Accuracy[†] (RA) = $\pm(0.025\%(\text{RDG}) + 2(\text{digits}))$ [2 σ]

Resolution (RES) = 0.001 V

Temperature Effect^{*} (TE) = $\pm(0.1(\text{Accuracy Spec.})/^\circ\text{C})(\Delta T)$ [2 σ]

[†] 1 Year Accuracy Specification

^{*} From 0 °C to 18 °C and 28 °C to 50 °C

Temperature Differential (ΔT)

64.4 → 82.4 °F (18 → 28 °C) Temperature Effect Not Applicable

104 °F = 40.0 °C ⇒ $\Delta T = (40.0 - 28.0)^\circ\text{C} = 12.0^\circ\text{C}$

122 °F = 50.0 °C ⇒ $\Delta T = (50.0 - 28.0)^\circ\text{C} = 22.0^\circ\text{C}$

Total Measurement Error (MTE)

$$\text{MTE} = \pm[(\text{RA}/2 + \text{TE}/2)^2 + \text{RES}^2]^{1/2} \quad [1\sigma]$$

Maximum Zone Temp.	MTE at RDG = 10 V	MTE at RDG = 30 V
64.4 → 82.4 °F	± 0.002462 V	± 0.004854 V
104 °F	± 0.005050 V	± 0.010498 V
122 °F	± 0.007269 V	± 0.015233 V

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 35 of 191

FLUKE 8050A

RANGE: 20 Vdc

Manufacturer's Specifications

Reference Accuracy[†] (RA) = $\pm(0.03\%(\text{RDG}) + 2(\text{digits}))$ [2 σ]

Resolution (RES) = 0.001 V

Temperature Effect^{*} (TE) = $\pm(0.1(\text{Accuracy Spec.})/^{\circ}\text{C})(\Delta T)$ [2 σ]

[†] 1 Year Accuracy Specification

^{*} From 0 $^{\circ}\text{C}$ to 18 $^{\circ}\text{C}$ and 28 $^{\circ}\text{C}$ to 50 $^{\circ}\text{C}$

Temperature Differential (ΔT)

64.4 \rightarrow 82.4 $^{\circ}\text{F}$ (18 \rightarrow 28 $^{\circ}\text{C}$) Temperature Effect Not Applicable

104 $^{\circ}\text{F}$ = 40.0 $^{\circ}\text{C}$ \Rightarrow $\Delta T = (40.0 - 28.0)^{\circ}\text{C} = 12.0^{\circ}\text{C}$

122 $^{\circ}\text{F}$ = 50.0 $^{\circ}\text{C}$ \Rightarrow $\Delta T = (50.0 - 28.0)^{\circ}\text{C} = 22.0^{\circ}\text{C}$

Total Measurement Error (MTE)

$$\text{MTE} = \pm[(\text{RA}/2 + \text{TE}/2)^2 + \text{RES}^2]^{1/2} \quad [1\sigma]$$

Maximum Zone Temp.	MTE at RDG = 10 V	MTE at RDG = 20 V
64.4 \rightarrow 82.4 $^{\circ}\text{F}$	± 0.002693 V	± 0.004123 V
104 $^{\circ}\text{F}$	± 0.005590 V	± 0.008857 V
122 $^{\circ}\text{F}$	± 0.008062 V	± 0.012839 V

FLUKE 8060A

RANGE: 20 Vdc

Manufacturer's Specifications

Reference Accuracy[†] (RA) = $\pm(0.05\%(\text{RDG}) + 2(\text{digits}))$ [2 σ]

Resolution (RES) = 0.001 V

Temperature Effect^{*} (TE) = $\pm(0.1(\text{Accuracy Spec.})/^{\circ}\text{C})(\Delta T)$ [2 σ]

[†] 1 Year Accuracy Specification

^{*} From 0 $^{\circ}\text{C}$ to 18 $^{\circ}\text{C}$ and 28 $^{\circ}\text{C}$ to 50 $^{\circ}\text{C}$

Temperature Differential (ΔT)

64.4 \rightarrow 82.4 $^{\circ}\text{F}$ (18 \rightarrow 28 $^{\circ}\text{C}$) Temperature Effect Not Applicable

104 $^{\circ}\text{F}$ = 40.0 $^{\circ}\text{C}$ \Rightarrow $\Delta T = (40.0 - 28.0)^{\circ}\text{C} = 12.0^{\circ}\text{C}$

122 $^{\circ}\text{F}$ = 50.0 $^{\circ}\text{C}$ \Rightarrow $\Delta T = (50.0 - 28.0)^{\circ}\text{C} = 22.0^{\circ}\text{C}$

Total Measurement Error (MTE)

$$\text{MTE} = \pm[(\text{RA}/2 + \text{TE}/2)^2 + \text{RES}^2]^{1/2} \quad [1\sigma]$$

Maximum Zone Temp.	MTE at RDG = 10 V	MTE at RDG = 20 V
64.4 \rightarrow 82.4 $^{\circ}\text{F}$	± 0.003640 V	± 0.006083 V
104 $^{\circ}\text{F}$	± 0.007765 V	± 0.013238 V
122 $^{\circ}\text{F}$	± 0.011245 V	± 0.019226 V

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 36 of 191

FLUKE 8300A

RANGE: 10 Vdc

Manufacturer's Specifications

Ref. Accuracy[†] (RA) = $\pm(0.015\%(\text{RDG}) + 0.005\%(\text{RNG}))$ [2 σ]

Resolution (RES) = 0.0001 V

Temp. Effect* (TE) = $\pm((0.0007\%(\text{RDG}) + 0.0003\%(\text{RNG}))/^{\circ}\text{C})(\Delta T)$ [2 σ]

[†] 1 Year Accuracy Specification

* From 0 °C to 20 °C and 30 °C to 50 °C

Temperature Differential (ΔT)

68 → 86 °F (20 → 30 °C) Temperature Effect Not Applicable

104 °F = 40.0 °C ⇒ $\Delta T = (40.0 - 30.0)^{\circ}\text{C} = 10.0^{\circ}\text{C}$

122 °F = 50.0 °C ⇒ $\Delta T = (50.0 - 30.0)^{\circ}\text{C} = 20.0^{\circ}\text{C}$

Total Measurement Error (MTE)

$$\text{MTE} = \pm[(\text{RA}/2 + \text{TE}/2)^2 + \text{RES}^2]^{1/2} \quad [1\sigma]$$

Maximum Zone Temp.	MTE at RDG = 2 V	MTE at RDG = 10 V
68 → 86 °F	± 0.000412 V	± 0.001005 V
104 °F	± 0.000628 V	± 0.001503 V
122 °F	± 0.000846 V	± 0.002003 V

FLUKE 8500A

5½ DIGIT RESOLUTION

RANGE: 10 Vdc

Manufacturer's Specifications

Ref. Accuracy[†] (RA) = $\pm(0.002\%(\text{RDG}) + 1(\text{digit}))$ [2 σ]

Resolution (RES) = 0.0001 V

Temp. Effect* (TE) = $\pm((0.0002\%(\text{RDG}) + 0.5(\text{digit}))/^{\circ}\text{C})(\Delta T)$ [2 σ]

[†] 1 Year Accuracy Specification

* From 0 °C to 18 °C and 28 °C to 50 °C

Temperature Differential (ΔT)

64.4 → 82.4 °F (18 → 28 °C) Temperature Effect Not Applicable

104 °F = 40.0 °C ⇒ $\Delta T = (40.0 - 28.0)^{\circ}\text{C} = 12.0^{\circ}\text{C}$

122 °F = 50.0 °C ⇒ $\Delta T = (50.0 - 28.0)^{\circ}\text{C} = 22.0^{\circ}\text{C}$

Total Measurement Error (MTE)

$$\text{MTE} = \pm[(\text{RA}/2 + \text{TE}/2)^2 + \text{RES}^2]^{1/2} \quad [1\sigma]$$

Maximum Zone Temp.	MTE at RDG = 2 V	MTE at RDG = 10 V
64.4 → 82.4 °F	± 0.000122 V	± 0.000180 V
104 °F	± 0.000406 V	± 0.000579 V
122 °F	± 0.000671 V	± 0.000925 V

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 37 of 191

FLUKE 8600A

RANGE: 200 mVdc

Manufacturer's Specifications

Ref. Accuracy[†] (RA) = $\pm(0.04\%(\text{RDG}) + 0.01\%(\text{RNG}))$ [2 σ]

Resolution (RES) = 0.01 mV

Temp. Effect^{*} (TE) = $\pm((0.003\%(\text{RDG}) + 0.001\%(\text{RNG}))/^{\circ}\text{C})(\Delta\text{T})$ [2 σ]

[†] 6 Month Accuracy Specification

^{*} From 0 $^{\circ}\text{C}$ to 15 $^{\circ}\text{C}$ and 35 $^{\circ}\text{C}$ to 50 $^{\circ}\text{C}$

Temperature Differential (ΔT)

59 \rightarrow 95 $^{\circ}\text{F}$ (15 \rightarrow 35 $^{\circ}\text{C}$) Temperature Effect Not Applicable

104 $^{\circ}\text{F}$ = 40.0 $^{\circ}\text{C}$ \Rightarrow $\Delta\text{T} = (40.0 - 35.0)^{\circ}\text{C} = 5.0^{\circ}\text{C}$

122 $^{\circ}\text{F}$ = 50.0 $^{\circ}\text{C}$ \Rightarrow $\Delta\text{T} = (50.0 - 35.0)^{\circ}\text{C} = 15.0^{\circ}\text{C}$

Total Measurement Error (MTE)

$$\text{MTE} = \pm[(\text{RA}/2 + \text{TE}/2)^2 + \text{RES}^2]^{1/2} \quad [1\sigma]$$

Maximum Zone Temp.	MTE at RDG = 20 mV	MTE at RDG = 50 mV
59 \rightarrow 95 $^{\circ}\text{F}$	± 0.017205 mV	± 0.022361 mV
104 $^{\circ}\text{F}$	± 0.022809 mV	± 0.030439 mV
122 $^{\circ}\text{F}$	± 0.034961 mV	± 0.047319 mV

FLUKE 8600A

RANGE: 20 Vdc

Manufacturer's Specifications

Ref. Accuracy[†] (RA) = $\pm(0.02\%(\text{RDG}) + 0.005\%(\text{RNG}))$ [2 σ]

Resolution (RES) = 0.001 V

Temp. Effect^{*} (TE) = $\pm((0.001\%(\text{RDG}) + 0.0005\%(\text{RNG}))/^{\circ}\text{C})(\Delta\text{T})$ [2 σ]

[†] 6 Month Accuracy Specification

^{*} From 0 $^{\circ}\text{C}$ to 15 $^{\circ}\text{C}$ and 35 $^{\circ}\text{C}$ to 50 $^{\circ}\text{C}$

Temperature Differential (ΔT)

59 \rightarrow 95 $^{\circ}\text{F}$ (15 \rightarrow 35 $^{\circ}\text{C}$) Temperature Effect Not Applicable

104 $^{\circ}\text{F}$ = 40.0 $^{\circ}\text{C}$ \Rightarrow $\Delta\text{T} = (40.0 - 35.0)^{\circ}\text{C} = 5.0^{\circ}\text{C}$

122 $^{\circ}\text{F}$ = 50.0 $^{\circ}\text{C}$ \Rightarrow $\Delta\text{T} = (50.0 - 35.0)^{\circ}\text{C} = 15.0^{\circ}\text{C}$

Total Measurement Error (MTE)

$$\text{MTE} = \pm[(\text{RA}/2 + \text{TE}/2)^2 + \text{RES}^2]^{1/2} \quad [1\sigma]$$

Maximum Zone Temp.	MTE at RDG = 10 V	MTE at RDG = 20 V
59 \rightarrow 95 $^{\circ}\text{F}$	± 0.001803 V	± 0.002693 V
104 $^{\circ}\text{F}$	± 0.002236 V	± 0.003400 V
122 $^{\circ}\text{F}$	± 0.003162 V	± 0.004854 V

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 38 of 191

FLUKE 8800A

RANGE: 20 Vdc

Manufacturer's Specifications

Ref. Accuracy[†] (RA) = $\pm(0.01\%(\text{RDG}) + 0.0015\%(\text{RNG}))$ [2 σ]

Resolution (RES) = 0.0001 V

Temp. Effect* (TE) = $\pm((0.0007\%(\text{RDG}) + 0.0002\%(\text{RNG}))/^{\circ}\text{C})(\Delta T)$ [2 σ]

[†] 90 Day Accuracy Specification

* From 0 °C to 18 °C and 28 °C to 50 °C

Temperature Differential (ΔT)

64.4 → 82.4 °F (18 → 28 °C) Temperature Effect Not Applicable

104 °F = 40.0 °C ⇒ $\Delta T = (40.0 - 28.0)^{\circ}\text{C} = 12.0^{\circ}\text{C}$

122 °F = 50.0 °C ⇒ $\Delta T = (50.0 - 28.0)^{\circ}\text{C} = 22.0^{\circ}\text{C}$

Total Measurement Error (MTE)

$$\text{MTE} = \pm[(\text{RA}/2 + \text{TE}/2)^2 + \text{RES}^2]^{1/2} \quad [1\sigma]$$

Maximum Zone Temp.	MTE at RDG = 10 V	MTE at RDG = 20 V
64.4 → 82.4 °F	± 0.000658 V	± 0.001154 V
104 °F	± 0.001314 V	± 0.002232 V
122 °F	± 0.001863 V	± 0.003132 V

FLUKE 8810A

RANGE: 20 Vdc

Manufacturer's Specifications

Reference Accuracy[†] (RA) = $\pm(0.01\%(\text{RDG}) + 3(\text{digits}))$ [2 σ]

Resolution (RES) = 0.0001 V

Temperature Effect* (TE) = $\pm((0.0007\%(\text{RDG}) + 1(\text{digit}))/^{\circ}\text{C})(\Delta T)$ [2 σ]

[†] 90 Day Accuracy Specification

* From 0 °C to 18 °C and 28 °C to 50 °C

Temperature Differential (ΔT)

64.4 → 82.4 °F (18 → 28 °C) Temperature Effect Not Applicable

104 °F = 40.0 °C ⇒ $\Delta T = (40.0 - 28.0)^{\circ}\text{C} = 12.0^{\circ}\text{C}$

122 °F = 50.0 °C ⇒ $\Delta T = (50.0 - 28.0)^{\circ}\text{C} = 22.0^{\circ}\text{C}$

Total Measurement Error (MTE)

$$\text{MTE} = \pm[(\text{RA}/2 + \text{TE}/2)^2 + \text{RES}^2]^{1/2} \quad [1\sigma]$$

Maximum Zone Temp.	MTE at RDG = 10 V	MTE at RDG = 20 V
64.4 → 82.4 °F	± 0.000658 V	± 0.001154 V
104 °F	± 0.001673 V	± 0.002592 V
122 °F	± 0.002522 V	± 0.003791 V

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 39 of 191

FLUKE 8840A **SLOW READING RATE** **RANGE: 20 Vdc**

Manufacturer's Specifications

Ref. Accuracy[†] (RA) = $\pm(0.006\%(\text{RDG}) + 3(\text{digits}))$ [2 σ]

Resolution (RES) = 0.0001 V

Temp. Effect* (TE) = $\pm((0.0006\%(\text{RDG}) + 0.3(\text{digits}))/^{\circ}\text{C})(\Delta\text{T})$ [2 σ]

[†] 1 Year Accuracy Specification

* From 0 °C to 18 °C and 28 °C to 50 °C

Temperature Differential (ΔT)

64.4 → 82.4 °F (18 → 28 °C) Temperature Effect Not Applicable

104 °F = 40.0 °C ⇒ $\Delta\text{T} = (40.0 - 28.0)^{\circ}\text{C} = 12.0^{\circ}\text{C}$

122 °F = 50.0 °C ⇒ $\Delta\text{T} = (50.0 - 28.0)^{\circ}\text{C} = 22.0^{\circ}\text{C}$

Total Measurement Error (MTE)

$$\text{MTE} = \pm[(\text{RA}/2 + \text{TE}/2)^2 + \text{RES}^2]^{1/2} \quad [1\sigma]$$

Maximum Zone Temp.	MTE at RDG = 10 V	MTE at RDG = 20 V
64.4 → 82.4 °F	± 0.000461 V	± 0.000757 V
104 °F	± 0.000995 V	± 0.001653 V
122 °F	± 0.001443 V	± 0.002402 V

FLUKE 8840A **MEDIUM READING RATE** **RANGE: 20 Vdc**

Manufacturer's Specifications

Ref. Accuracy[†] (RA) = $\pm(0.006\%(\text{RDG}) + 5(\text{digits}))$ [2 σ]

Resolution (RES) = 0.0001 V

Temp. Effect* (TE) = $\pm((0.0006\%(\text{RDG}) + 0.3(\text{digits}))/^{\circ}\text{C})(\Delta\text{T})$ [2 σ]

[†] 1 Year Accuracy Specification

* From 0 °C to 18 °C and 28 °C to 50 °C

Temperature Differential (ΔT)

64.4 → 82.4 °F (18 → 28 °C) Temperature Effect Not Applicable

104 °F = 40.0 °C ⇒ $\Delta\text{T} = (40.0 - 28.0)^{\circ}\text{C} = 12.0^{\circ}\text{C}$

122 °F = 50.0 °C ⇒ $\Delta\text{T} = (50.0 - 28.0)^{\circ}\text{C} = 22.0^{\circ}\text{C}$

Total Measurement Error (MTE)

$$\text{MTE} = \pm[(\text{RA}/2 + \text{TE}/2)^2 + \text{RES}^2]^{1/2} \quad [1\sigma]$$

Maximum Zone Temp.	MTE at RDG = 10 V	MTE at RDG = 20 V
64.4 → 82.4 °F	± 0.000559 V	± 0.000856 V
104 °F	± 0.001095 V	± 0.001753 V
122 °F	± 0.001543 V	± 0.002502 V

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 40 of 191

FLUKE 8840A **FAST READING RATE** **RANGE:** **20 Vdc**

Manufacturer's Specifications

Ref. Accuracy[†] (RA) = $\pm(0.006\%(\text{RDG}) + 3(\text{digits}))$ [2 σ]

Resolution (RES) = 0.001 V

Temp. Effect* (TE) = $\pm((0.0006\%(\text{RDG}) + 0.3(\text{digits}))/^{\circ}\text{C})(\Delta T)$ [2 σ]

† 1 Year Accuracy Specification

* From 0 °C to 18 °C and 28 °C to 50 °C

Temperature Differential (ΔT)

64.4 → 82.4 °F (18 → 28 °C) Temperature Effect Not Applicable

104 °F = 40.0 °C ⇒ $\Delta T = (40.0 - 28.0)^{\circ}\text{C} = 12.0^{\circ}\text{C}$

122 °F = 50.0 °C ⇒ $\Delta T = (50.0 - 28.0)^{\circ}\text{C} = 22.0^{\circ}\text{C}$

Total Measurement Error (MTE)

$$\text{MTE} = \pm[(\text{RA}/2 + \text{TE}/2)^2 + \text{RES}^2]^{1/2} \quad [1\sigma]$$

Maximum Zone Temp.	MTE at RDG = 10 V	MTE at RDG = 20 V
64.4 → 82.4 °F	± 0.002059 V	± 0.002326 V
104 °F	± 0.004084 V	± 0.004727 V
122 °F	± 0.005846 V	± 0.006794 V

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 41 of 191

9.2 Pressure Measurement Error Evaluation

References 3.5.s and 3.5.t specify the use of a "Pneumatic Calibrator, 0-850" W.C. (Accuracy: ± 2.0 " W.C., minimum)." Discussions with site personnel (Reference 3.16) revealed that the instrument used at LaSalle is from Wallace & Tiernan and has a minor scale division of 1" W.C. Of the two possible instruments listed in Reference 3.4 only Model 65-120 meets the accuracy requirement of the procedure at the environmental conditions where it will be used, and then only if the procedural accuracy is considered to be a one sigma value. Also, Reference 3.4 does not indicate that this instrument is used at LaSalle, only at Quad Cities.

WALLACE & TIERNAN MODEL 65-120

-100 "WC to 850 "WC

Manufacturer's Specifications

Reference Accuracy (RA) = $\pm(2)(0.1\%(\text{RNG}))$ [2 σ]

Minor Division (MD) = 1.0 "WC

Temperature Effect* (TE) = $\pm(0.1\%(\text{RNG})/10\text{ }^{\circ}\text{C})(\Delta T)$ [2 σ]

* Referred to 25 $^{\circ}\text{C}$

Calibrated Accuracy - RA Rounded Up To Nearest Minor Division

RA = $\pm(2)(0.1\%(\text{RNG}))$ = ± 1.9 "WC

Calibrated Accuracy (CA) = ± 2.0 "WC

Temperature Differential (ΔT)

77 $^{\circ}\text{F}$ = 25.0 $^{\circ}\text{C}$ $\Rightarrow \Delta T = (25.0 - 25.0)^{\circ}\text{C} = 0.0\text{ }^{\circ}\text{C}$

104 $^{\circ}\text{F}$ = 40.0 $^{\circ}\text{C}$ $\Rightarrow \Delta T = (40.0 - 25.0)^{\circ}\text{C} = 15.0\text{ }^{\circ}\text{C}$

120 $^{\circ}\text{F}$ = 48.9 $^{\circ}\text{C}$ $\Rightarrow \Delta T = (48.9 - 25.0)^{\circ}\text{C} = 23.9\text{ }^{\circ}\text{C}$

Total Measurement Error (MTE)

$$\text{MTE} = \pm[(\text{CA}/2 + \text{TE}/2)^2 + (\text{MD}/4)^2]^{1/2} \quad [1\sigma]$$

Maximum Zone Temperature

MTE

77 $^{\circ}\text{F}$ ± 1.030776 "WC

104 $^{\circ}\text{F}$ ± 1.730652 "WC

120 $^{\circ}\text{F}$ ± 2.149835 "WC

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 42 of 191

10.0 CALIBRATION PROCEDURE DATA

The loop calibration procedures (Reference 3.5) provide the following information. Information on Nominal Trip Setpoint and Allowable Value (Tech Spec LCO) come from the Technical Specifications (Reference 3.7) or, for the RBM, the Core Operating Limits Reports (Reference 3.15).

10.1 Flow Transmitter Calibration

The calibrated span for all flow transmitters represents 0 to 55,000 GPM (Section 7.0).

For FT-1B33-N014A/B/C/D and FT-1B33-N024C/D

Test Inputs:	0 to 387.1" W.C.
Input Tolerance:	None Given
Desired Output:	4 to 20 mVdc
Output Tolerance:	±0.080 mV

For FT-1B33-N024A/B

Test Inputs:	25.5 to 272.9" W.C.
Input Tolerance:	None Given
Desired Output:	4 to 20 mVdc
Output Tolerance:	±0.080 mV

For FT-2B33-N014A/B

Test Inputs:	0 to 390.4" W.C.
Input Tolerance:	None Given
Desired Output:	4 to 20 mVdc
Output Tolerance:	±0.080 mV

For FT-2B33-N014C/D and FT-2B33-N024A/B

Test Inputs:	0 to 410.7" W.C.
Input Tolerance:	None Given

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345		PAGE 43 of 191	
Desired Output:		4 to 20 mVdc	
Output Tolerance:		±0.080 mV	
For FT-2B33-N024C/D			
Test Inputs:		0 to 448.7" W.C.	
Input Tolerance:		None Given	
Desired Output:		4 to 20 mVdc	
Output Tolerance:		±0.080 mV	
10.2 Square Root Converter Calibration			
Test Inputs:		4 to 20 mVdc	
Input Tolerance:		±0.050 mV	
Desired Output:		0 to 10 Vdc	
Output Tolerance:		±0.025 V	
10.3 Flow Summer Calibration			
<u>Analog Circuitry</u>			
Test Inputs:		7.660 Vdc 1.000 Vdc	
Input Tolerance:		±0.010 V	
Desired Output:		8.000 Vdc 1.044 Vdc	
Output Tolerance:		±0.010 V	
Correlation to Computer Calculated Flow		+0.0, -0.05 Vdc	
<u>Upscale Trip</u>			
Instrument Setpoint:		8.630 Vdc (increasing)	
Allowable Range:		8.530 to 8.730 Vdc (±0.10 Vdc)*	
Nominal Trip Setpoint:		≤108% Flow (8.640 Vdc)	
REVISION NO.	0	1	

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345		PAGE 44 of 191
--------------------------	--	----------------

Tech Spec LCO:	≤111% Flow (8.88 Vdc)
Analytic Limit:	≤116% Flow (Reference 3.27)
<u>Comparator Trip</u>	
Test Input:	8.000 Vdc (100% Flow)
Input Tolerance:	±0.010 V
Instrument Setpoint:	8.790 Vdc (increasing)
Allowable Range:	8.710 to 8.870 Vdc (±0.080 Vdc)*
Instrument Setpoint:	7.210 Vdc (decreasing)
Allowable Range:	7.130 to 7.290 Vdc (±0.080 Vdc)*
Nominal Trip Setpoint:	≤10% Flow Deviation (±0.8 Vdc)
Tech Spec LCO:	≤11% Flow Deviation (±0.88 Vdc)
Analytic Limit:	≤19% Flow (Reference 3.27)

*Note: The setting tolerance for theupscale (±0.1 Vdc) and comparator trip (±0.08 Vdc) are proposed values that will be analyzed by this calculation. The calibration procedure may incorporate tolerances less than or equal to the proposed values.

10.4 APRM Calibration - Note: The following reflects current information that will change as a result of this calculation and the implementation of power uprate (Reference 3.33).

AGAF Adjustment

AGAF Setpoint:	1.00
Allowable Range:	0.98 to 1.02 (±0.02)

Neutron Flux High (Rod Block) - Setdown

Instrument Setpoint:	0.920 Vdc (11.5%)
Allowable Range:	0.880 to 0.960 Vdc (±0.040 Vdc)
Nominal Trip Setpoint:	≤12%
Tech Spec LCO:	≤14% (1.120 Vdc)
Analytic Limit:	≤19% (Reference 3.27)

Neutron Flux High (Scram) - Setdown

Instrument Setpoint:	1.160 Vdc (14.5%)
Allowable Range:	1.120 to 1.200 Vdc (±0.040 Vdc)

REVISION NO.	0	2		
--------------	---	---	--	--

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345		PAGE 45 of 191	
<p>Nominal Trip Setpoint: ≤15%</p> <p>Tech Spec LCO: ≤20% (1.600 Vdc)</p> <p>Analytic Limit: 25% (Reference 3.27)</p> <p><u>Neutron Flux High (Scram)</u></p> <p>Instrument Setpoint: 9.400 Vdc (117.5%)</p> <p>Allowable Range: 9.360 to 9.440 Vdc (±0.040 Vdc)</p> <p>Nominal Trip Setpoint: ≤118%</p> <p>Tech Spec LCO: ≤120% (9.600 Vdc)</p> <p>Analytic Limit: 124.2% (Reference 3.27)</p> <p><u>Flow Biased Simulated Thermal Power - Upscale (Scram)</u></p> <p><u>Two Recirculation Loop Operation</u></p> <p>Instrument Setpoint: 8.390 Vdc (104.9%) (80% Flow)</p> <p>Allowable Range: 8.350 to 8.430 Vdc (±0.040 Vdc)</p> <p>Nominal Trip Setpoint: ≤0.58W + 59%</p> <p>Tech Spec LCO: ≤0.58W + 62%</p> <p>Analytic Limit: To be calculated in Section 13.</p> <p><u>Flow Biased Simulated Thermal Power - Upscale (Scram)</u></p> <p><u>Single Recirculation Loop Operation</u></p> <p>Instrument Setpoint: 8.010 Vdc (100.1%) (80% Flow)</p> <p>Allowable Range: 7.970 to 8.050 Vdc (±0.040 Vdc)</p> <p>Nominal Trip Setpoint: ≤0.58W + 54.3%</p> <p>Tech Spec LCO: ≤0.58W + 57.3%</p> <p>Analytic Limit: To be calculated in Section 13.</p> <p><u>Flow Biased Simulated Thermal Power - Upscale Clamp (Scram)</u></p> <p><u>Two Recirculation Loop Operation</u></p> <p>Instrument Setpoint: 9.040 Vdc (113%)</p>			
REVISION NO.	0		

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 46 of 191

Allowable Range: 9.000 to 9.080 Vdc (± 0.040 Vdc)

Nominal Trip Setpoint: $\leq 113.5\%$

Tech Spec LCO: $\leq 115.5\%$ (9.240 Vdc)

Analytic Limit: To be calculated in Section 13.

Flow Biased Simulated Thermal Power - Upscale Clamp (Scram)
Single Recirculation Loop Operation

Instrument Setpoint: 9.040 Vdc (113%)

Allowable Range: 9.000 to 9.080 Vdc (± 0.040 Vdc)

Nominal Trip Setpoint: $\leq 113.5\%$

Tech Spec LCO: $\leq 115.5\%$ (9.240 Vdc)

Analytic Limit: To be calculated in Section 13.

Flow Biased Simulated Thermal Power - Upscale (Rod Block)
Two Recirculation Loop Operation

Instrument Setpoint: 7.430 Vdc (92.9%)
(80% Flow)

Allowable Range: 7.390 to 7.470 Vdc (± 0.040 Vdc)

Nominal Trip Setpoint: $\leq 0.58W + 47\%$

Tech Spec LCO: $\leq 0.58W + 50\%$

Analytic Limit: To be calculated in Section 13.

Flow Biased Simulated Thermal Power - Upscale (Rod Block)
Single Recirculation Loop Operation

Instrument Setpoint: 7.050 Vdc (88.1%)
(80% Flow)

Allowable Range: 7.010 to 7.090 Vdc (± 0.040 Vdc)

Nominal Trip Setpoint: $\leq 0.58W + 42.3\%$

Tech Spec LCO: $\leq 0.58W + 45.3\%$

Analytic Limit: To be calculated in Section 13.

Neutron Flux Downscale (Rod Block)

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 47 of 191

Instrument Setpoint: 0.440 Vdc (5.5%)
 Allowable Range: 0.400 to 0.480 Vdc (± 0.040 Vdc)
 Nominal Trip Setpoint: $\geq 5\%$
 Tech Spec LCO: $\geq 3\%$ (0.240 Vdc)
 Analytic Limit: 0% (Reference 3.27)

10.5 RBM Calibration

RBM Upscale (Two Recirculation Loop Operation)

Instrument Setpoint: 8.84 Vdc (110.5%)
 (100% Flow)
 Allowable Range: 8.80 to 8.88 Vdc (± 0.040 Vdc)
 Nominal Trip Setpoint: $\leq 0.66W + 45\%$ (111%)
 (Reference 3.15)
 Tech Spec LCO: $\leq 0.66W + 48\%$ (114%)
 (Reference 3.15)
 Analytic Limit: To be calculated in Section 13.

RBM Upscale (Single Recirculation Loop Operation)

Instrument Setpoint: 8.09 Vdc (101.7%)
 (100% Flow)
 Allowable Range: 8.05 to 8.13 Vdc (± 0.040 Vdc)
 Nominal Trip Setpoint: $\leq 0.66W + 39.7\%$ (105.7%)
 (Reference 3.15)
 Tech Spec LCO: $\leq 0.66W + 42.7\%$ (108.7%)
 (Reference 3.15)
 Analytic Limit: To be calculated in Section 13.

RBM Downscale

Instrument Setpoint: 0.404 Vdc
 Allowable Range: 0.400 to 0.408 Vdc (± 0.004 Vdc)
 Nominal Trip Setpoint: $\geq 5\%$ (0.400)
 Tech Spec LCO: $\geq 3\%$ (0.240)
 Analytic Limit: 0% (Reference 3.27)

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 48 of 191

11.0 MODULE ERRORS

11.1 Module 1 (Flow Transmitter)

Classification of Module

Since Module 1 is a flow transmitter, its input and output are both analog signals. Therefore, Module 1 is classified as an analog module.

11.1.1 Module 1 Random Error (σ_1)

This section addresses random uncertainties that have the potential to be expressed in the output of Module 1.

11.1.1.1 Reference Accuracy (RA1)

Per Section 8.1.1 the reference accuracy for the flow transmitters is

$$RA1 = 0.25\% \text{ CS (calibrated span)}$$

Per Assumption 5.1, this is assumed to be a 2 sigma value. This is then converted to a 1 sigma value by dividing by 2.

$$RA1_{(1\sigma)} = \pm RA1/2 \% \text{ CS}$$

$$RA1_{(1\sigma)} = \pm 0.25/2 \% \text{ CS}$$

$$RA1_{(1\sigma)} = \pm 0.125\% \text{ CS}$$

11.1.1.2 Drift (RD1)

Per Reference 3.8 drift is considered a random variable for this calculation. Section 8.1.1 gives a value of $\pm 0.2\% \text{ UR}$ (upper range) per 30 months for vendor drift (RD_{FT}). In order to keep all error terms as a function of calibrated span, UR can be converted to CS by multiplying UR by CS/CS resulting in UR equaling $(UR/CS) * CS$. Using this gives

$$RD1 = \pm RD_{FT} \% * (UR/CS) * CS$$

$$RD1 = \pm 0.2 * (750/247.4) \% \text{ CS}$$

$$RD1 = \pm 0.606306\% \text{ CS}$$

Per Assumption 5.1, this is assumed to be a 2 sigma value. This is then converted to a 1 sigma value by dividing by 2.

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 49 of 191

$$RD1_{(1\sigma)} = \pm RD1/2 \% CS$$

$$RD1_{(1\sigma)} = \pm 0.606306/2 \% CS$$

$$RD1_{(1\sigma)} = \pm 0.303153\% CS$$

Table 4.3.6-1 of Reference 3.7 indicates a surveillance interval of 13 weeks (Quarterly) for this instrument loop. However, as stated in Section 2.1.b the drift error term will not be reduced even though the surveillance interval is shorter than the period for which the vendor drift value applies.

11.1.1.3 Calibration Uncertainty (CAL1)

The uncertainties associated with calibrating the flow transmitters are composed of the uncertainties in setting the input signal and the uncertainties in reading the output signal. References 3.5.s and 3.5.t do not give a particular instrument to be used for setting the input during calibration. Rather, they simply indicate a "Pneumatic Calibrator, 0-850" W.C. (accuracy: ± 2.0 " W.C., minimum)" is required. Per Assumption 5.11 LaSalle is assumed to be using a Wallace and Tiernan Model 65-120 instrument for this input monitoring function. For the maximum temperature applicable to this location the accuracy given by Reference 3.4 for this instrument is 2.149835" W.C. This is the value that will be used in this calculation. The reading error term ($REMTE1_{FT}$) is included in total MTE error term given in Reference 3.4. Therefore, a value of 0 will be used for $REMTE1_{FT}$ for this calculation.

The instrument specified by the procedures for measurement of the flow transmitter output is a Fluke 8600A DMM. For the voltage range of interest for this calculation the reference accuracy, from Reference 3.4, is 0.034961 mVdc. ($RAMTE2_{FT}$). Since this is a digital instrument, there is no reading error associated with its use ($REMTE2_{FT} = 0$).

The voltage at the flow transmitter output is measured across a precision one ohm resistor which Reference 3.16 indicates is accurate to 0.005%. This means that the maximum voltage error induced by the resistor is 0.00005×20 mV or 0.001 mV. Since vendor accuracies are considered two sigma values, it must be divided by 2 to be compared with the DMM accuracy value ($RAMTE2_{FT}$). The one sigma error is then 0.0005 mVdc. This is a factor of more than 30 less than the DMM error term so it can be ignored in the calculation.

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 50 of 191

From Reference 3.3,

$$MTE1 = [(\text{RAMTE1}/n)^2 + \text{REMTE1}^2]^{0.5}$$

where n is the number of standard deviations applicable to the error term. Reference 3.4 gives a value of 1 for n for both the input and output test instruments.

For this calculation

$$MTE1_{FT} = \pm [(\text{RAMTE1}_{FT}/n)^2 + \text{REMTE1}_{FT}^2]^{0.5} \text{ "WC}$$

$$MTE1_{FT} = \pm [(2.149835/1)^2 + 0^2]^{0.5} \text{ "WC}$$

$$MTE1_{FT} = \pm 2.149835 \text{ "WC}$$

In order to make this term compatible with the other error terms it must be converted to %CS by dividing by the span and multiplying by 100.

$$MTE1_{FT(CS)} = \pm (MTE1_{FT}/CS_{FT}) * 100 \% \text{ CS}$$

$$MTE1_{FT(CS)} = \pm (2.149835/247.4) * 100 \% \text{ CS}$$

$$MTE1_{FT(CS)} = \pm 0.868971\% \text{ CS}$$

The output error $MTE2_{FT}$ is determined in the same way as was the input error.

$$MTE2_{FT} = \pm [(\text{RAMTE2}_{FT}/n)^2 + \text{REMTE2}_{FT}^2]^{0.5} \text{ mVdc}$$

$$MTE2_{FT} = \pm [(0.034961/1)^2 + 0^2]^{0.5} \text{ mVdc}$$

$$MTE2_{FT} = \pm 0.034961 \text{ mVdc}$$

This also must be converted to % CS by dividing by the output span ($CS_{FT(OUT)}$) and multiplying by 100.

$$MTE2_{FT(CS)} = \pm (MTE2_{FT}/CS_{FT(OUT)}) * 100 \% \text{ CS}$$

$$MTE2_{FT(CS)} = \pm (0.034961/16) * 100 \% \text{ CS}$$

$$MTE2_{FT(CS)} = \pm 0.218506\% \text{ CS}$$

From Section 5.2 the error attributed to the calibration standards is considered negligible. Therefore, the only terms which contribute to CAL1 are MTE1 and MTE2. For this calculation

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 51 of 191

$$CAL1_{FT} = \pm [(MTE1_{FT(CS)})^2 + (MTE2_{FT(CS)})^2]^{0.5} \% CS$$

$$CAL1_{FT} = \pm [0.868971^2 + 0.218506^2]^{0.5}$$

$$CAL1_{FT} = \pm 0.896022\% CS$$

11.1.1.4 Setting Tolerance (ST1)

The setting tolerance for the flow transmitters is the combination of the input and output setting tolerances. From References 3.5.s and 3.5.t the setting tolerance for the flow transmitters' output ($ST_{FT(OUT)}$) is 0.08 mVdc. No setting tolerance is given in the procedures for the input instrument. Therefore, the input setting tolerance ($ST_{FT(IN)}$) used for this calculation will be one half of one minor division which, from References 3.4 and 3.16, would be 0.5" WC.

Both of these setting tolerance terms will now be converted to % CS by dividing by the appropriate span and multiplying by 100.

$$ST_{FT(IN)(CS)} = \pm (ST_{FT(IN)} / CS_{FT}) * 100 \% CS$$

$$ST_{FT(IN)(CS)} = \pm (0.5 / 247.4) * 100 \% CS$$

$$ST_{FT(IN)(CS)} = \pm 0.202102\% CS$$

$$ST_{FT(OUT)(CS)} = \pm (ST_{FT(OUT)} / CS_{FT(OUT)}) * 100 \% CS$$

$$ST_{FT(OUT)(CS)} = \pm (0.08 / 16) * 100 \% CS$$

$$ST_{FT(OUT)(CS)} = \pm 0.5\% CS$$

The total setting tolerance for the flow transmitters is the combination of these two terms by SRSS. Also, from Section 2.1.a these are considered 3 sigma values and must, therefore, be divided by 3 to make them compatible with the other 1 sigma error terms. The total setting tolerance $ST1_{(1\sigma)}$ is then

$$ST1_{(1\sigma)} = \pm [(ST_{FT(IN)(CS)} / 3)^2 + (ST_{FT(OUT)(CS)} / 3)^2]^{0.5} \% CS$$

$$ST1_{(1\sigma)} = \pm [(0.202102 / 3)^2 + (0.5 / 3)^2]^{0.5} \% CS$$

$$ST1_{(1\sigma)} = \pm 0.179767\% CS$$

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 52 of 191

11.1.1.5 Static Pressure Span Effect (Correction Uncertainty) ($SPSE_{FT}$)

References 3.5.s and 3.5.t state that a 1% of span correction has been included in the calibration to compensate for the static pressure span effect. However, Reference 3.14 states that there is a plus/minus correction uncertainty associated with this compensation. Therefore, this uncertainty will be included as a random error term in this calculation. Although the vendor gives this error term as a percent of reading, it will be considered as percent calibrated span which simplifies the calculation and is conservative.

$$SPSE_{FT} = \pm 0.25\% \text{ CS}/1000 \text{ psi}$$

Since the normal operating pressure is very near 1000 psi (1025 psi from Section 7.0) this value will be used as is.

This must now be divided by 2 since the manufacturer's data is considered a 2 sigma value.

$$SPSE_{FT(1\sigma)} = \pm SPSE_{FT}/2 \% \text{ CS}$$

$$SPSE_{FT(1\sigma)} = \pm 0.25/2 \% \text{ CS}$$

$$SPSE_{FT(1\sigma)} = \pm 0.125\% \text{ CS}$$

11.1.1.6 Static Pressure Zero Effect ($SPZE_{FT}$)

For this device the vendor lists a Static Pressure Zero Effect of $\pm 0.25\% \text{ UR}/2000 \text{ psi}$. This must be multiplied by the actual static pressure ($STAPR_{FT}$) to find the effect for this application. At this time it will also be converted to $\% \text{ CS}$ using the discussion from Section 11.1.2.2 below in order to make it compatible with the other error terms. In addition the result must be divided by 2 in order to make it a 1 sigma value. The result is:

$$SPZE_{FT(1\sigma)} = \pm (SPZE_{FT}/2) (STAPR_{FT}/2000) (UR_{FT}/CS_{FT}) \% \text{ CS}$$

$$SPZE_{FT(1\sigma)} = \pm (0.25/2) (1025/2000) (750/247.4) \% \text{ CS}$$

$$SPZE_{FT(1\sigma)} = \pm 0.194207\% \text{ CS}$$

11.1.1.7 Input Uncertainty (σ_{input1})

Since module 1 is the first module, there is no input from a previous module. However, per Reference 3.17, there is a 5% error associated with the elbow type flow element. If this

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345		PAGE 53 of 191
<p>is considered a two sigma value, the one sigma value would be 5/2 or 2.5%. This term will be considered the input error. Therefore,</p> $\sigma_{input1} = \pm 2.5\% \text{ CS}$ <p>Per Section 4.9 this is considered 0 for the Comparator Trip error analysis.</p> $\sigma_{input1c} = 0$ <p>11.1.1.8 Determination of Module Random Error (σ_1)</p> <p>Using the methodology of Reference 3.3,</p> $\sigma_1 = \pm [(RA1_{(1\sigma)})^2 + (RD1_{(1\sigma)})^2 + (CAL1_{FT})^2 + (ST1_{(1\sigma)})^2 + (SPSE_{FT(1\sigma)})^2 + (SPZE_{FT(1\sigma)})^2 + (\sigma_{input1})^2]^{0.5} \% \text{ CS}$ $\sigma_1 = \pm [(0.125)^2 + (0.303153)^2 + (0.896022)^2 + (0.179767)^2 + (0.125)^2 + (0.194207)^2 + 2.5^2]^{0.5} \% \text{ CS}$ $\sigma_1 = \pm 2.691847\% \text{ CS}$ <p>For the Comparator Trip:</p> $\sigma_{1c} = \pm [(RA1_{(1\sigma)})^2 + (RD1_{(1\sigma)})^2 + (CAL1_{FT})^2 + (ST1_{(1\sigma)})^2 + (SPSE_{FT(1\sigma)})^2 + (SPZE_{FT(1\sigma)})^2 + (\sigma_{input1c})^2]^{0.5} \% \text{ CS}$ $\sigma_{1c} = \pm [(0.125)^2 + (0.303153)^2 + (0.896022)^2 + (0.179767)^2 + (0.125)^2 + (0.194207)^2 + 0^2]^{0.5} \% \text{ CS}$ $\sigma_{1c} = \pm 0.998018\% \text{ CS}$		
REVISION NO.	0	

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345		PAGE 54 of 191
<p>11.1.2 Module 1 Non-Random Errors (Σe_1)</p> <p>11.1.2.1 Humidity Errors (e_{1H})</p> <p>Since Reference 3.14 does not identify a humidity error term a value of zero will be used per Section 4.3.</p> $e_{1H} = 0\% \text{ CS}$ <p>11.1.2.2 Temperature Error (e_{1T})</p> <p>From Section 8.1.1 the temperature effect (VTE_{FT}) error of the flow transmitters is a function of both the calibrated span (CS) and the upper range (UR) per 100°F temperature change. From Section 4.2 the maximum temperature at the transmitter during normal operation is expected to be 118°F ($MAXTEMP_{FT}$). From Section 4.6 the minimum calibration temperature for the flow transmitters is considered to be 60°F ($CALTEMP_{FT}$). Using the vendor's equation VTE_{FT} is then</p> $VTE_{FT} = \pm(0.5\%UR + 0.5\%CS) \text{ per } 100^\circ\text{F}$ <p>In order to keep all error terms as a function of calibrated span, UR can be converted to CS by multiplying UR by CS/CS resulting in UR equaling $(UR/CS)*CS$. Using this in the above equation gives</p> $VTE_{FT} = \pm[0.5\%(UR_{FT}/CS_{FT}) + 0.5] * [(MAXTEMP_{FT} - CALTEMP_{FT})/100]\%CS_{FT}$ <p>For this calculation VTE_{FT} equals e_{1T}. Therefore,</p> $e_{1T} = \pm[0.5\%(UR_{FT}/CS_{FT}) + 0.5] * [(MAXTEMP_{FT} - CALTEMP_{FT})/100]\% CS_{FT}$ $e_{1T} = \pm[0.5(750/247.4) + 0.5] * [(118-60)/100]\% CS$ $e_{1T} = \pm 1.169143\% CS$ <p>11.1.2.3 Radiation Error (e_{1R})</p> <p>Section 8.1.1 gives a radiation effect that is applicable to and following accident conditions. Since this calculation does not apply to accident conditions, and since the transmitters are being calibrated at an interval during which the TID is insignificant (maintenance personnel calibrate the transmitters in place) the radiation error for this calculation is insignificant and does not provide any</p>		
REVISION NO.	0	

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345		PAGE 55 of 191
<p>radiation induced error specifications. Therefore, per Assumption 5.2 these errors are assumed to be included within the vendor's accuracy terms.</p> <p style="padding-left: 40px;">$e_{1R} = 0\% \text{ CS}$</p> <p>11.1.2.4 Seismic Error (e_{1S})</p> <p>Per Section 4.7 seismic error for this module is considered negligible.</p> <p style="padding-left: 40px;">$e_{1S} = 0\% \text{ CS}$</p> <p>11.1.2.5 Static Pressure Effect (e_{1SP})</p> <p>From References 3.5.s and 3.5.t, these instruments have been compensated for static pressure effect during calibration. Therefore, static pressure effects are considered to be negligible.</p> <p style="padding-left: 40px;">$e_{1SP} = 0\% \text{ CS}$</p> <p>11.1.2.6 Pressure Error (e_{1P})</p> <p>From Section 8.1.2, these instruments are exposed to an environment whose pressure varies only slightly from ambient conditions (1 atmosphere). Therefore, pressure effects are considered to be negligible.</p> <p style="padding-left: 40px;">$e_{1P} = 0\% \text{ CS}$</p> <p>11.1.2.7 Process Errors(e_{1p})</p> <p>References 3.5.f and 3.5.o provide instructions on calibrating the total flow as measured by this instrumentation to the total flow as is calculated by the process computer. Therefore, any process error is compensated for by this calibration.</p> <p style="padding-left: 40px;">$e_{1p} = 0\% \text{ CS}$</p> <p>11.1.2.8 Power Supply Effects (e_{1V})</p> <p>From Section 8.1.1, the power supply effect (PSE_{FT}) given by the vendor is 0.005% CS per volt. References 3.5.s and 3.5.t allow a range (ΔV_{FT}) of 0.5 Vdc for the transmitter power supply, and Reference 3.19 gives this same value (0.02x24 Vdc) as a possible drift amount. This range will be considered the amount by which the power supply can vary.</p>		
REVISION NO.	0	

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 56 of 191

Therefore,

$$e1V = \pm PSE_{FT} * \Delta V_{FT} \% CS$$

$$e1V = \pm 0.005 * 0.5 \% CS$$

$$e1V = \pm 0.0025 \% CS$$

11.1.2.9 Non-Random Input Error (einput1)

Since this is the first module, the only input is from the flow element. Non-Random error from this device is considered to be zero.

$$einput1 = 0 \% CS$$

11.1.2.10 Non-Random Error ($\Sigma e1$)

From Reference 3.3 the non-random error is the algebraic sum of all the above terms.

$$\Sigma e1 = \pm (e1H + e1T + e1R + e1S + e1SP + e1P + e1p + e1V + einput1) \% CS$$

$$\Sigma e1 = \pm (0 + 1.169143 + 0 + 0 + 0 + 0 + 0 + 0.0025 + 0) \% CS$$

$$\Sigma e1 = \pm 1.171643 \% CS$$

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345		PAGE 57 of 191	
<p>11.2 Module 2 (Square Root Converter)</p> <p><u>Classification of Module</u></p> <p>Since Module 2 is a square root converter, its input and output are both analog signals. Therefore, Module 2 is classified as an analog module.</p> <p>11.2.1 Module 2 Random Error (σ_2)</p> <p>This section addresses random uncertainties that have the potential to be expressed in the output of Module 2.</p> <p>11.2.1.1 Reference Accuracy (RA2)</p> <p>Per Section 8.2.1 the reference accuracy for the square root converter is included in an overall RFM accuracy which will be applied at the output of the Flow Summer (Module 3). Therefore, the reference accuracy (RA2) for this module will be considered</p> $RA2 = 0\% \text{ CS}$ <p>Per Assumption 5.1, this is assumed to be a 2 sigma value. This is then converted to a 1 sigma value by dividing by 2.</p> $RA2_{(1\sigma)} = \pm RA2/2 \% \text{ CS}$ $RA2_{(1\sigma)} = \pm 0/2 \% \text{ CS}$ $RA2_{(1\sigma)} = \pm 0\% \text{ CS}$ <p>11.2.1.2 Drift (RD2)</p> <p>Per Section 8.2.1 the reference drift for the square root converter is included in an overall RFM accuracy which will be applied at the output of the Flow Summer (Module 3). Therefore, the reference drift (RD2) for this module will be considered</p> $RD2 = 0\% \text{ CS}$ <p>Per Assumption 5.1, this is assumed to be a 2 sigma value. This is then converted to a 1 sigma value by dividing by 2.</p> $RD2_{(1\sigma)} = RD2/2 \% \text{ CS}$ $RD2_{(1\sigma)} = 0/2 \% \text{ CS}$			
REVISION NO.	0		

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345		PAGE 58 of 191
<p data-bbox="435 317 716 352">$RD2_{(1\sigma)} = \pm 0\% \text{ CS}$</p> <p data-bbox="147 380 911 415">11.2.1.3 Calibration Uncertainty (CAL2)</p> <p data-bbox="337 443 1495 800">The uncertainties associated with calibrating the square root converters are composed of the uncertainties in setting the input signal and the uncertainties in reading the output signal. References 3.5.s and 3.5.t specify that Fluke 8600A DMMs be used for measurement of the input and output signals. In addition the input voltage is developed by running a current through a precision one ohm resistor. However, as was determined in Section 11.1.1.3 the uncertainty contributed by the precision resistor itself is much smaller than the uncertainty contributed by the DMM and, therefore, can be ignored.</p> <p data-bbox="337 827 1495 989">For the voltage range of interest for the DMM measuring the input voltage the reference accuracy, from Reference 3.4, is 0.017205 mVdc (RAMTE1_{SR}). Since this is a digital instrument, there is no reading error associated with its use (REMTE1_{SR} = 0).</p> <p data-bbox="337 1016 1495 1178">For the voltage range of interest for the DMM measuring the output voltage the reference accuracy, from Reference 3.4, is 0.001803 Vdc (RAMTE2_{SR}). Since this is a digital instrument, there is no reading error associated with its use (REMTE2_{SR} = 0).</p> <p data-bbox="337 1205 695 1241">From Reference 3.3,</p> <p data-bbox="435 1268 1024 1304">$MTE1 = [(RAMTE1/n)^2 + REMTE1^2]^{0.5}$</p> <p data-bbox="337 1331 1495 1430">where n is the number of standard deviations applicable to the error term. Reference 3.4 gives a value of 1 for n for both the input and output test instruments.</p> <p data-bbox="337 1457 716 1493">For this calculation</p> <p data-bbox="435 1520 1203 1556">$MTE1_{SR} = \pm [(RAMTE1_{SR}/n)^2 + REMTE1_{SR}^2]^{0.5} \text{ mVdc}$</p> <p data-bbox="435 1583 1101 1619">$MTE1_{SR} = \pm [(0.017205/1)^2 + 0^2]^{0.5} \text{ mVdc}$</p> <p data-bbox="435 1646 846 1682">$MTE1_{SR} = \pm 0.017205 \text{ mVdc}$</p> <p data-bbox="337 1709 1495 1871">Since the square root converter is not a linear module this value must be converted to an equivalent output value (MTE1_{SR(OUT)}) by one of the equations of Section 2.1.c. Also, these equations indicate that the conversion factor is a function of the operating point. Therefore, an operating</p>		
REVISION NO.	0	

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 59 of 191

point must be chosen at which the conversion will take place. For this calculation the operating point is considered to be 6 Vdc (OP_{SR}) at the output of the square root converters which is equal to approximately 75% Flow. Choosing this value is a compromise in that the error term is then conservative at flows greater than 75% but non-conservative at flows less than 75%.

Using Equation 3 from Section 2.1.c the conversion is

$$MTE1_{SR(OUT)} = (3.125 * MTE1_{SR}) / (OP_{SR}) \text{ Vdc}$$

$$MTE1_{SR(OUT)} = (3.125 * 0.017205) / 6 \text{ Vdc}$$

$$MTE1_{SR(OUT)} = \pm 0.008961 \text{ Vdc}$$

In order to make this term compatible with the other error terms it must be converted to %CS by dividing by the span and multiplying by 100.

$$MTE1_{SR(CS)} = \pm (MTE1_{SR(OUT)} / CS_{SR(OUT)}) * 100 \% \text{ CS}$$

$$MTE1_{SR(CS)} = \pm (0.008961 / 10) * 100 \% \text{ CS}$$

$$MTE1_{SR(CS)} = \pm 0.08961 \% \text{ CS}$$

The output error $MTE2_{SR}$ is determined in the same way as was the input error.

$$MTE2_{SR} = \pm [(RAMTE2_{SR}/n)^2 + REMTE2_{SR}^2]^{0.5} \text{ Vdc}$$

$$MTE2_{SR} = \pm [(0.001803/1)^2 + 0^2]^{0.5} \text{ Vdc}$$

$$MTE2_{SR} = \pm 0.001803 \text{ Vdc}$$

This also must be converted to % CS by dividing by the output span ($CS_{FT(OUT)}$) and multiplying by 100.

$$MTE2_{SR(CS)} = \pm (MTE2_{SR} / CS_{SR(OUT)}) * 100 \% \text{ CS}$$

$$MTE2_{SR(CS)} = \pm (0.001803 / 10) * 100 \% \text{ CS}$$

$$MTE2_{SR(CS)} = \pm 0.01803 \% \text{ CS}$$

From Section 5.2 the errors attributed to the calibration standards are considered negligible. Therefore, the only terms which contribute to CAL2 are MTE1 and MTE2. For this calculation

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 60 of 191

$$CAL2_{SR} = \pm [(MTE1_{SR(CS)})^2 + (MTE2_{SR(CS)})^2]^{0.5} \% CS$$

$$CAL2_{SR} = \pm [0.08961^2 + 0.01803^2]^{0.5} \% CS$$

$$CAL2_{SR} = \pm 0.091406\% CS$$

11.2.1.4 Setting Tolerance (ST2)

The setting tolerance for the square root converters is the combination of the input and output setting tolerances. From References 3.5.s and 3.5.t the setting tolerance for the square root converter's input ($ST_{SR(IN)}$) is 0.05 mVdc. The setting tolerance for the square root converter's output ($ST_{SR(OUT)}$) is given as 0.025 Vdc.

The input setting tolerance must now be converted to an equivalent output value as was done in Section 11.2.1.3. The same operating point will also be used. Using Equation 3 from Section 2.1.c, the input setting tolerance converted to the output ($ST_{SR(IN)(OUT)}$) is

$$ST_{SR(IN)(OUT)} = (3.125 * ST_{SR(IN)}) / OP_{SR} \text{ Vdc}$$

$$ST_{SR(IN)(OUT)} = (3.125 * 0.05) / 6 \text{ Vdc}$$

$$ST_{SR(IN)(OUT)} = 0.026042 \text{ Vdc}$$

Both of these setting tolerance terms will now be converted to % CS by dividing by the square root converter output span and multiplying by 100.

$$ST_{SR(IN)(CS)} = \pm (ST_{SR(IN)(OUT)} / CS_{SR(OUT)}) * 100 \% CS$$

$$ST_{SR(IN)(CS)} = \pm (0.026042 / 10) * 100 \% CS$$

$$ST_{SR(IN)(CS)} = \pm 0.26042\% CS$$

$$ST_{SR(OUT)(CS)} = \pm (ST_{SR(OUT)} / CS_{SR(OUT)}) * 100 \% CS$$

$$ST_{SR(OUT)(CS)} = \pm (0.025 / 10) * 100 \% CS$$

$$ST_{SR(OUT)(CS)} = \pm 0.25\% CS$$

The total setting tolerance for the square root converter is the combination of these two terms by SRSS. Also, from Section 2.1.a these are considered 3 sigma values and must, therefore, be divided by 3 to make them compatible with the other 1 sigma error terms. The total setting tolerance $ST2_{(1\sigma)}$ is then

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 61 of 191

$$ST2_{(1\sigma)} = \pm [(ST_{SR(IN)(CS)}/3)^2 + (ST_{SR(OUT)(CS)}/3)^2]^{0.5} \% CS$$

$$ST2_{(1\sigma)} = \pm [(0.26042/3)^2 + (0.25/3)^2]^{0.5} \% CS$$

$$ST2_{(1\sigma)} = \pm 0.120332\% CS$$

11.2.1.5 Input Uncertainty (σ_{input2})

In addition to its own error terms, Module 2 also operates on the error terms from Module 1. Therefore, the random error term (σ_1) from the flow transmitter must be transferred through the square root converter from input to output using the equations from Section 2.1.c. The resultant term will be σ_{input2} for this module. However, before this can be done σ_1 must be converted to a millivolt signal. This can be done by dividing σ_1 by 100 and multiplying by the input span $CS_{FT(OUT)}$.

$$\sigma_{1MV} = \pm (\sigma_1/100) * CS_{FT(OUT)} \text{ mVdc}$$

$$\sigma_{1MV} = \pm (2.691847/100) * 16 \text{ mVdc}$$

$$\sigma_{1MV} = \pm 0.430696 \text{ mVdc}$$

Transferring this through the square root converter using Equation 3 of Section 2.1.c gives

$$\sigma_{input2V} = \pm (3.125 * \sigma_{1MV}) / OP_{SR} \text{ Vdc}$$

$$\sigma_{input2V} = \pm (3.125 * 0.430696) / 6 \text{ Vdc}$$

$$\sigma_{input2V} = \pm 0.224321 \text{ Vdc}$$

Next this is changed into % CS by dividing by the output span and multiplying by 100.

$$\sigma_{input2} = \pm (\sigma_{input2V} / CS_{SR(OUT)}) * 100 \% CS$$

$$\sigma_{input2} = \pm (0.224321/10) * 100 \% CS$$

$$\sigma_{input2} = \pm 2.24321\% CS$$

For the Comparator Trip Loop the above nine equations become:

$$\sigma_{1MVC} = \pm (\sigma_{1C}/100) * CS_{FT(OUT)} \text{ mVdc}$$

$$\sigma_{1MVC} = \pm (0.998018/100) * 16 \text{ mVdc}$$

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 62 of 191

$$\sigma_{1_{MVC}} = \pm 0.159683 \text{ mVdc}$$

Transferring this through the square root converter using Equation 3 of Section 2.1.c gives

$$\sigma_{input2_{VC}} = \pm (3.125 * \sigma_{1_{MVC}}) / OP_{SR} \text{ Vdc}$$

$$\sigma_{input2_{VC}} = \pm (3.125 * 0.159683) / 6 \text{ Vdc}$$

$$\sigma_{input2_{VC}} = \pm 0.083168 \text{ Vdc}$$

Next this is changed into % CS by dividing by the output span and multiplying by 100.

$$\sigma_{input2_c} = \pm (\sigma_{input2_{VC}} / CS_{SR(OUT)}) * 100 \% \text{ CS}$$

$$\sigma_{input2_c} = \pm (0.083168 / 10) * 100 \% \text{ CS}$$

$$\sigma_{input2_c} = \pm 0.83168 \% \text{ CS}$$

11.2.1.6 Determination of Module Random Error (σ_2)

Using the methodology of Reference 3.3,

$$\sigma_2 = \pm [(RA2_{(1\sigma)})^2 + (RD2_{(1\sigma)})^2 + (CAL2_{SR})^2 + (ST2_{(1\sigma)})^2 + (\sigma_{input2})^2]^{0.5} \% \text{ CS}$$

$$\sigma_2 = \pm [(0)^2 + (0)^2 + (0.091406)^2 + (0.120332)^2 + (2.24321)^2]^{0.5} \% \text{ CS}$$

$$\sigma_2 = \pm 2.248294 \% \text{ CS}$$

For the Comparator Trip this becomes:

$$\sigma_{2_c} = \pm [(RA2_{(1\sigma)})^2 + (RD2_{(1\sigma)})^2 + (CAL2_{SR})^2 + (ST2_{(1\sigma)})^2 + (\sigma_{input2_c})^2]^{0.5} \% \text{ CS}$$

$$\sigma_{2_c} = \pm [(0)^2 + (0)^2 + (0.091406)^2 + (0.120332)^2 + (0.83168)^2]^{0.5} \% \text{ CS}$$

$$\sigma_{2_c} = \pm 0.845297 \% \text{ CS}$$

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345		PAGE 63 of 191	
11.2.2	Module 2 Non-Random Errors (Σe_2)		
	As is indicated in Section 8.2 the specifications for the square root converters are included in an overall recirculation flow monitor specification which will be applied at the output of the flow summer, Module 3. Therefore, all the non-random error terms will be considered to be 0 except for e_{input2} which is the non-random error from Module 1 (Σe_1).		
11.2.2.1	Humidity Errors (e_{2H})		
	Per Section 11.2.2 this error is considered to be zero.		
	$e_{2H} = 0\% \text{ CS}$		
11.2.2.2	Temperature Error (e_{2T})		
	Per Section 11.2.2 this error is considered to be zero.		
	$e_{2T} = 0\% \text{ CS}$		
11.2.2.3	Radiation Error (e_{2R})		
	Per Section 11.2.2 this error is considered to be zero.		
	$e_{2R} = 0\% \text{ CS}$		
11.2.2.4	Seismic Error (e_{2S})		
	Per Section 11.2.2 this error is considered to be zero.		
	$e_{2S} = 0\% \text{ CS}$		
11.2.2.5	Static Pressure Effect (e_{2SP})		
	Per Section 11.2.2 this error is considered to be zero.		
	$e_{2SP} = 0\% \text{ CS}$		
11.2.2.6	Pressure Error (e_{2P})		
	Per Section 11.2.2 this error is considered to be zero.		
	$e_{2P} = 0\% \text{ CS}$		
11.2.2.7	Process Errors(e_{2p})		
	Per Section 11.2.2 this error is considered to be zero.		
REVISION NO.	0		

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 64 of 191

$$e2p = 0\% \text{ CS}$$

11.2.2.8 Power Supply Effects (e2V)

Per Section 11.2.2 this error is considered to be zero.

$$e2V = 0\% \text{ CS}$$

11.2.2.9 Non-Random Input Error (einput2)

In addition to its own error terms, Module 2 also operates on the error terms from Module 1. Therefore, the non-random error term ($\Sigma e1$) from the flow transmitter must be transferred through the square root converter from input to output using the equations from Section 2.1.c. The resultant term will be einput2 for this module. However, before this can be done $\Sigma e1$ must be converted to a millivolt signal. This can be done by dividing $\Sigma e1$ by 100 and multiplying by the input span $CS_{FT(OUT)}$.

$$\Sigma e1_{MV} = \pm(\Sigma e1/100) * CS_{FT(OUT)} \text{ mVdc}$$

$$\Sigma e1_{MV} = \pm(1.171643/100) * 16 \text{ mVdc}$$

$$\Sigma e1_{MV} = \pm 0.187463 \text{ mVdc}$$

Transferring this through the square root converter using Equation 3 of Section 2.1.c gives

$$einput2_v = \pm(3.125 * \Sigma e1_{MV}) / OP_{SR} \text{ Vdc}$$

$$einput2_v = \pm(3.125 * 0.187463) / 6 \text{ Vdc}$$

$$einput2_v = \pm 0.097637 \text{ Vdc}$$

Next this is changed into % CS by dividing by the output span and multiplying by 100.

$$einput2 = \pm(einput2_v / CS_{SR(OUT)}) * 100 \% \text{ CS}$$

$$einput2 = \pm(0.097637/10) * 100 \% \text{ CS}$$

$$einput2 = \pm 0.97637\% \text{ CS}$$

11.2.2.10 Non-Random Error ($\Sigma e2$)

From Reference 3.3 the non-random error is the algebraic sum of all the above terms.

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345				PAGE 65 of 191
$\Sigma e2 = \pm(e2H + e2T + e2R + e2S + e2SP + e2P + e2p + e2V + einput2)\% CS$ $\Sigma e2 = \pm(0 + 0 + 0 + 0 + 0 + 0 + 0 + 0 + 0.97637)\% CS$ $\Sigma e2 = \pm 0.97637\% CS$				
REVISION NO.	0			

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345		PAGE 66 of 191	
<p>11.3 Module 3 (Flow Summer)</p> <p><u>Classification of Module</u></p> <p>Module 3 is an analog summer. As such its input and output are both analog signals. Therefore, Module 3 is classified as an analog module.</p> <p>11.3.1 Module 3 Random Error (σ_3)</p> <p>This section addresses random uncertainties that have the potential to be expressed in the output of Module 3.</p> <p>11.3.1.1 Reference Accuracy (RA3)</p> <p>Per Section 8.3.1 the reference accuracy applied to this module is the overall RFM accuracy which will be applied at the output of this module, the Flow Summer. Per Reference 3.18 the reference accuracy for this unit is $\pm 2\%$. Since the vendor does not state percent of what, this value will be considered percent of calibrated span. This is conservative and makes it compatible with the other error terms.</p> <p style="text-align: center;">$RA3 = 2\% \text{ CS}$</p> <p>Per Assumption 5.1, this is assumed to be a 2 sigma value. This is then converted to a 1 sigma value by dividing by 2.</p> <p style="text-align: center;">$RA3_{(1\sigma)} = \pm RA3/2 \% \text{ CS}$</p> <p style="text-align: center;">$RA3_{(1\sigma)} = \pm 2/2 \% \text{ CS}$</p> <p style="text-align: center;">$RA3_{(1\sigma)} = \pm 1\% \text{ CS}$</p> <p>11.3.1.2 Drift (RD3)</p> <p>Per Section 8.3.1 the reference drift applied to this module is the overall RFM drift which will be applied at the output of this module. Per Reference 3.18 the reference drift for this unit is $\pm 1.25\%$ per 700 Hrs. Since the vendor does not state percent of what, this value will be considered percent of calibrated span. This is conservative and makes it compatible with the other error terms.</p> <p>Reference 3.7, Table 4.3.1.1-1, Note (e) indicates that the RFM is adjusted weekly to a calibrated flow signal. Therefore, this drift term does not need to be extended to a longer period.</p>			
REVISION NO.	0		

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345		PAGE 67 of 191
<p>RD3 = 1.25% CS</p> <p>Per Assumption 5.1, this is assumed to be a 2 sigma value. This is then converted to a 1 sigma value by dividing by 2.</p> <p>RD3_(1σ) = RD3/2 % CS</p> <p>RD3_(1σ) = 1.25/2 % CS</p> <p>RD3_(1σ) = ±0.625% CS</p> <p>11.3.1.3 Calibration Uncertainty (CAL3)</p> <p>The uncertainties associated with calibrating the flow summer are composed of the uncertainties in setting the input signal and the uncertainties in reading the output signal. References 3.5.s and 3.5.t specify that Fluke 8600A DMMs be used for measurement of the input and output signals.</p> <p>Both input and output signals of the flow summer are 0 to 10 Vdc signals. Therefore, the MTE error terms will be the same for both of them. For the voltage range of interest for the DMMs measuring the input and output voltages the reference accuracy, from Reference 3.4, is 0.001803 Vdc (RAMTE1_{SUM}, RAMTE2_{SUM}). Since this is a digital instrument, there is no reading error associated with its use (REMTE1_{SUM} and REMTE2_{SUM} = 0).</p> <p>From Reference 3.3,</p> $MTE1 = [(RAMTE1/n)^2 + REMTE1^2]^{0.5}$ <p>where n is the number of standard deviations applicable to the error term. Reference 3.4 gives a value of 1 for n for both the input and output test instruments.</p> <p>For this calculation</p> $MTE1_{SUM} = \pm [(RAMTE1_{SUM}/n)^2 + REMTE1_{SUM}^2]^{0.5} \text{ Vdc}$ $MTE1_{SUM} = \pm [(0.001803/1)^2 + 0^2]^{0.5} \text{ Vdc}$ $MTE1_{SUM} = \pm 0.001803 \text{ Vdc}$ <p>In order to make this term compatible with the other error terms it must be converted to %CS by dividing by the span (CS_{SR(OUT)} will be used since the input span of the summer is the same as the output span of the square root converter)</p>		
REVISION NO.	0	

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 68 of 191

and multiplying by 100.

$$MTE1_{SUM(CS)} = \pm (MTE1_{SUM} / CS_{SR(OUT)}) * 100 \% CS$$

$$MTE1_{SUM(CS)} = \pm (0.001803 / 10) * 100 \% CS$$

$$MTE1_{SUM(CS)} = \pm 0.01803 \% CS$$

Since the input and output use the same instrument and have the same range the output MTE term ($MTE2_{SUM(CS)}$) is equal to the input term or

$$MTE2_{SUM(CS)} = MTE1_{SUM(CS)}$$

From Section 5.2 the errors attributed to the calibration standards are considered negligible. Therefore, the only terms which contribute to CAL3 are MTE1 and MTE2. For this calculation

$$CAL3_{SUM} = \pm [(MTE1_{SUM(CS)})^2 + (MTE2_{SUM(CS)})^2]^{0.5} \% CS$$

$$CAL3_{SUM} = \pm [0.01803^2 + 0.01803^2]^{0.5} \% CS$$

$$CAL3_{SUM} = \pm 0.025498 \% CS$$

11.3.1.4 Setting Tolerance (ST3)

The setting tolerance for the flow summer is the combination of the input and output setting tolerances. From References 3.5.s and 3.5.t the setting tolerance for the flow summer's input ($ST_{SUM(IN)}$) is 0.01 Vdc. The setting tolerance for the flow summer's output ($ST_{SUM(OUT)}$) is given as 0.01 Vdc.

Since both input and output have the same span, both of these setting tolerance terms will now be converted to % CS by dividing by the flow summer output span ($CS_{SUM(OUT)}$) and multiplying by 100.

$$ST_{SUM(IN)(CS)} = \pm (ST_{SUM(IN)} / CS_{SUM(OUT)}) * 100 \% CS$$

$$ST_{SUM(IN)(CS)} = \pm (0.01 / 10) * 100 \% CS$$

$$ST_{SUM(IN)(CS)} = \pm 0.1 \% CS$$

$$ST_{SUM(OUT)(CS)} = \pm (ST_{SUM(OUT)} / CS_{SUM(OUT)}) * 100 \% CS$$

$$ST_{SUM(OUT)(CS)} = \pm (0.01 / 10) * 100 \% CS$$

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 69 of 191

$$ST_{\text{SUM(OUT) (CS)}} = \pm 0.1\% \text{ CS}$$

The total setting tolerance for the flow summer is the combination of these two terms by SRSS. Also, from Section 2.1.a these are considered 3 sigma values and must, therefore, be divided by 3 to make them compatible with the other 1 sigma error terms. The total setting tolerance $ST3_{(1\sigma)}$ is then

$$ST3_{(1\sigma)} = \pm [(ST_{\text{SUM(IN) (CS)}}/3)^2 + (ST_{\text{SUM(OUT) (CS)}}/3)^2]^{0.5} \% \text{ CS}$$

$$ST3_{(1\sigma)} = \pm [(0.1/3)^2 + (0.1/3)^2]^{0.5} \% \text{ CS}$$

$$ST3_{(1\sigma)} = \pm 0.04714\% \text{ CS}$$

11.3.1.5 Input Uncertainty (σ_{input3})

In addition to its own error terms, Module 3 also operates on the error terms from Module 2. Therefore, the random error terms σ_2 and σ_{2c} from the square root converter must be transferred through the flow summer from input to output factoring in the gain of the summing circuit. The resultant terms will be σ_{input3} and σ_{input3c} for this module.

From References 3.5.s and 3.5.t the gain of the summer (G_{SUM}) is equal to 1.044386. Since the flow summer is adding the outputs of two square root converters, and since the output spans of the square root converters and the flow summer are the same, the effective gain from each input of the flow summer to its output is $G_{\text{SUM}}/2$. Therefore, the transfer of each input error through the summer is

$$\sigma_{2_3} = \pm \sigma_2 * (G_{\text{SUM}}/2) \% \text{ CS}$$

$$\sigma_{2_3} = \pm 2.248294 * (1.044386/2) \% \text{ CS}$$

$$\sigma_{2_3} = \pm 1.174043\% \text{ CS}$$

For the Comparator Trip this is:

$$\sigma_{2_{3c}} = \pm \sigma_{2c} * (G_{\text{SUM}}/2) \% \text{ CS}$$

$$\sigma_{2_{3c}} = \pm 0.845297 * (1.044386/2) \% \text{ CS}$$

$$\sigma_{2_{3c}} = \pm 0.441408\% \text{ CS}$$

For both inputs the resulting errors (σ_{input3} and σ_{input3c}) at the output of the summer would be

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 70 of 191

$$\sigma_{\text{input3}} = \pm[(\sigma_{2_3})^2 + (\sigma_{2_3})^2]^{0.5} \% \text{ CS}$$

$$\sigma_{\text{input3}} = \pm[(1.174043)^2 + (1.174043)^2]^{0.5} \% \text{ CS}$$

$$\sigma_{\text{input3}} = \pm 1.660348 \% \text{ CS}$$

For the Comparator Trip:

$$\sigma_{\text{input3}_c} = \pm[(\sigma_{2_{3c}})^2 + (\sigma_{2_{3c}})^2]^{0.5} \% \text{ CS}$$

$$\sigma_{\text{input3}_c} = \pm[(0.441408)^2 + (0.441408)^2]^{0.5} \% \text{ CS}$$

$$\sigma_{\text{input3}_c} = \pm 0.624245 \% \text{ CS}$$

11.3.1.6 Determination of Module Random Error (σ_3 and σ_{3_c})

Using the methodology of Reference 3.3, and converting to % Flow by multiplying by 125/100:

$$\sigma_3 = \pm(125/100) * [(\text{RA3}_{(1\sigma)})^2 + (\text{RD3}_{(1\sigma)})^2 + (\text{CAL3}_{\text{SUM}})^2 + (\text{ST3}_{(1\sigma)})^2 + (\sigma_{\text{input3}})^2]^{0.5} \% \text{ Flow}$$

$$\sigma_3 = \pm(125/100) * [(1)^2 + (0.625)^2 + (0.025498)^2 + (0.04714)^2 + (1.660348)^2]^{0.5} \% \text{ Flow}$$

$$\sigma_3 = \pm 2.546521 \% \text{ Flow}$$

For the Comparator Trip:

$$\sigma_{3_c} = \pm(125/100) * [(\text{RA3}_{(1\sigma)})^2 + (\text{RD3}_{(1\sigma)})^2 + (\text{CAL3}_{\text{SUM}})^2 + (\text{ST3}_{(1\sigma)})^2 + (\sigma_{\text{input3}_c})^2]^{0.5} \% \text{ Flow}$$

$$\sigma_{3_c} = \pm(125/100) * [(1)^2 + (0.625)^2 + (0.025498)^2 + (0.04714)^2 + (0.624245)^2]^{0.5} \% \text{ Flow}$$

$$\sigma_{3_c} = \pm 1.669197 \% \text{ Flow}$$

Per Reference 3.3 the Allowable Value calculation uses all error terms except those pertaining to the process. Therefore, since σ_{3_c} is the same as σ_3 except for the removal of the process terms, σ_{3_c} will also be used for the Allowable Value calculation.

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345		PAGE 71 of 191
<div style="margin-bottom: 10px;"> <p>11.3.2 Module 3 Non-Random Errors (Σe_3)</p> <p>Per Section 8.3.1 the errors applied to this module are the overall RFM error terms.</p> </div> <div style="margin-bottom: 10px;"> <p>11.3.2.1 Humidity Errors (e_{3H})</p> <p>Since Reference 3.18 does not identify a humidity error term a value of zero will be used per Section 4.3.</p> <p style="margin-left: 40px;">$e_{3H} = 0\% \text{ CS}$</p> </div> <div style="margin-bottom: 10px;"> <p>11.3.2.2 Temperature Error (e_{3T})</p> <p>Since Reference 3.18 does not identify a temperature error term a value of zero will be used per Section 4.3.</p> <p style="margin-left: 40px;">$e_{3T} = 0\% \text{ CS}$</p> </div> <div style="margin-bottom: 10px;"> <p>11.3.2.3 Radiation Error (e_{3R})</p> <p>Since Reference 3.18 does not identify a radiation error term a value of zero will be used per Section 4.3.</p> <p style="margin-left: 40px;">$e_{3R} = 0\% \text{ CS}$</p> </div> <div style="margin-bottom: 10px;"> <p>11.3.2.4 Seismic Error (e_{3S})</p> <p>Per Section 4.7 seismic error for this module is considered negligible.</p> <p style="margin-left: 40px;">$e_{3S} = 0\% \text{ CS}$</p> </div> <div style="margin-bottom: 10px;"> <p>11.3.2.5 Static Pressure Effect (e_{3SP})</p> <p>This module is an all electronic device that is not exposed to any pressure other than atmospheric. Therefore, there is no static pressure effect.</p> <p style="margin-left: 40px;">$e_{3SP} = 0\% \text{ CS}$</p> </div> <div> <p>11.3.2.6 Pressure Error (e_{3P})</p> <p>This module is an all electronic device that is not exposed to any pressure other than atmospheric. Therefore, there is no pressure effect.</p> <p style="margin-left: 40px;">$e_{3P} = 0\% \text{ CS}$</p> </div>		
REVISION NO.	0	

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345		PAGE 72 of 191
<p>11.3.2.7 Process Errors (e3p)</p> <p>This module is intermediate in the loop and, as such, is not exposed to any process parameters. Therefore, there are no process errors.</p> $e3p = 0\% \text{ CS}$ <p>11.3.2.8 Power Supply Effects (e3V)</p> <p>Since Reference 3.18 does not identify a power supply effect error term a value of zero will be used per Section 4.3.</p> $e3V = 0\% \text{ CS}$ <p>11.3.2.9 Non-Random Input Error (einput3)</p> <p>In addition to its own error terms, Module 3 also operates on the error terms from Module 2. Therefore, the non-random error term ($\Sigma e2$) from the square root converter must be transferred through the flow summer from input to output factoring in the gain of the summing circuit. The resultant term will be einput3 for this module.</p> <p>Using the discussion from Section 11.3.1.5 the input of a single square root converter is transferred through the flow summer as follows:</p> $\Sigma e2_3 = \pm \Sigma e2 * (G_{\text{SUM}}/2) \% \text{ CS}$ $\Sigma e2_3 = \pm 0.97637 * (1.044386/2) \% \text{ CS}$ $\Sigma e2_3 = \pm 0.509854 \% \text{ CS}$ <p>Since this is a non-random error the sum for both inputs at the output of the summer (einput3) would be the algebraic sum of the inputs.</p> $einput3 = \pm (\Sigma e2_3 + \Sigma e2_3) \% \text{ CS}$ $einput3 = \pm (0.509854 + 0.509854) \% \text{ CS}$ $einput3 = \pm 1.019708 \% \text{ CS}$		
REVISION NO.	0	

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 73 of 191

11.3.2.10 Non-Random Error (Σe_3)

From Reference 3.3 the non-random error is the algebraic sum of all the above terms. In addition, this term can be converted to % Flow by multiplying by 125/100. The result is;

$$\Sigma e_3 = \pm (125/100) * (e_{3H} + e_{3T} + e_{3R} + e_{3S} + e_{3SP} + e_{3P} + e_{3p} + e_{3V} + e_{input3}) \% \text{ Flow}$$

$$\Sigma e_3 = \pm (125/100) * (0 + 0 + 0 + 0 + 0 + 0 + 0 + 0 + 1.019708) \% \text{ Flow}$$

$$\Sigma e_3 = \pm 1.274635 \% \text{ Flow}$$

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345		PAGE 74 of 191
<p>11.3.3 Module 3A and 3B (RFM Trip Circuits)</p> <p><u>Classification of Module</u></p> <p>Module 3A receives an analog input from the Flow Summer (Module 3) and provides a bistable output, the state of which depends on the relative magnitudes of the input signal and the reference value. Therefore, Module 3A is a bistable module.</p> <p>There are actually two separate trip circuits in each flow unit. The Hi Flow trip looks at the output of the Flow Summer and compares its magnitude to a fixed reference value (Module 3A above). The Comparator Trip Circuit looks at the output of the Flow Summer and compares it to the output of a Flow Summer from another RFM (Module 3B) and provides a bistable output, the state of which depends on the relative magnitudes of the two input signals. Therefore, Module 3B is a bistable module. The Comparator Trip will have to combine the error terms from two Flow Summers.</p> <p>11.3.3.1 Module 3A and 3B Random Error (σ_{3A} and σ_{3B})</p> <p>This section addresses random uncertainties that have the potential to be expressed in the outputs of Modules 3A and 3B.</p> <p>11.3.3.1.1 Reference Accuracy (RA3A)</p> <p>Per Assumption 5.8 the reference accuracy for this module is included in the Module 3 accuracy term:</p> $RA_{3A} = 1\% \text{ CS}$ <p>Per Assumption 5.1, this is assumed to be a 2 sigma value. This is then converted to a 1 sigma value by dividing by 2. In the same step this will be converted to % Flow by multiplying by 125/100.</p> $RA_{3A(1\sigma)} = \pm (RA_{3A}/2) * (125/100) \% \text{ Flow}$ $RA_{3A(1\sigma)} = \pm (1/2) * (125/100) \% \text{ Flow}$ $RA_{3A(1\sigma)} = \pm 0.625\% \text{ Flow}$		
REVISION NO.	0	

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 75 of 191

11.3.3.1.2 Drift (RD3A)

Per Assumption 5.8 the reference drift for this module is included in the Module 3 drift term:

$$RD3A = 1\% \text{ CS}/700 \text{ HRS}$$

Table 4.3.6-1 of Reference 3.7 gives the surveillance interval (RD3ATSI) for these trip functions as 13 weeks (quarterly). In addition, a 25% late factor will added to the required value. Per Reference 3.8 drift is considered a random function and can be extended to a longer period by the square root of the ratio of the time periods per Section 2.2.5 of Reference 3.13.

Per Assumption 5.1, the drift value is assumed to be a 2 sigma value. This is then converted to a 1 sigma value by dividing by 2, and then to % Flow by multiplying by 125/100. RD3ATSI is converted to hours by multiplying by 168. The one sigma drift is then:

$$RD3A_{(1\sigma)} = \pm (RD3A/2) * (125/100) * [(1.25 * RD3ATSI * 168) / RD3AT]^{0.5} \% \text{ Flow}$$

$$RD3A_{(1\sigma)} = \pm (1/2) * (125/100) * [(1.25 * 13 * 168) / 700]^{0.5} \% \text{ Flow}$$

$$RD3A_{(1\sigma)} = \pm 1.234276\% \text{ Flow}$$

11.3.3.1.3 Calibration Uncertainty (CAL3A)

The uncertainties associated with calibrating the trip circuits are composed entirely of the uncertainties associated with the DMM used to set the input trip voltage. References 3.5.s and 3.5.t specify that A Fluke 8600A DMM be used for this measurement. From Section 9.1 the error associated with this instrument is 0.001803 Vdc (RAMTE1_{3A}). Since this is a digital instrument REMTE1_{3A} is equal to zero.

From Reference 3.3,

$$MTE1 = [(RAMTE1/n)^2 + REMTE1^2]^{0.5}$$

where n is the number of standard deviations applicable to the error term. The values of the error terms from Reference 9.1 are already expressed in one sigma terms. Therefore, the value of n is 1.

$$MTE1_{3A} = \pm [(RAMTE1_{3A}/1)^2 + REMTE1_{3A}^2]^{0.5} \text{ Vdc}$$

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 76 of 191

$$MTE1_{3A} = \pm[(0.001803/1)^2 + 0^2]^{0.5} \text{ Vdc}$$

$$MTE1_{3A} = \pm 0.001803 \text{ Vdc}$$

This can be converted to % Flow by dividing by the voltage span ($SPAN_{SUM}$) and multiplying by the full scale flow (125).

$$MTE1_{3A(PF)} = \pm[(MTE1_{3A}/SPAN_{SUM}) * 125] \% \text{ Flow}$$

$$MTE1_{3A(PF)} = \pm[(0.001803/10) * 125] \% \text{ Flow}$$

$$MTE1_{3A(PF)} = \pm 0.022538\% \text{ Flow}$$

From Section 5.2 the errors attributed to the calibration standards are considered negligible. Therefore, the only term which contributes to CAL3A is the MTE1 term. Therefore, for this section

$$CAL3A = \pm MTE1_{3A(PF)} = \pm 0.022538\% \text{ Flow}$$

11.3.3.1.4 Setting Tolerance (ST3A)

From Design Input 10.3, the setting tolerance to be evaluated for the upscale and comparator trip functions is $\pm 0.1 \text{ Vdc}$ and $\pm 0.08 \text{ Vdc}$, respectively. This can be converted to % Flow by dividing by the voltage span ($SPAN_{SUM}$) and multiplying by the full scale flow (125).

From Section 2.1.a the given setting tolerances are considered 3 sigma values. Therefore, ST3A must be divided by 3 to make it compatible with the other 1 sigma error terms. Combining this operation with the conversion to percent flow gives

$$ST3A_{(1\sigma)} = \pm[(ST3A/SPAN_{SUM}) * 125] / 3 \% \text{ Flow}$$

Upscale Trip:

$$ST3A_{A(1\sigma)} = \pm[(0.1/10) * 125] / 3 \% \text{ Flow}$$

$$ST3A_{A(1\sigma)} = \pm 0.416667\% \text{ Flow}$$

Comparator Trip:

$$ST3A_{B(1\sigma)} = \pm[(0.08/10) * 125] / 3 \% \text{ Flow}$$

$$ST3A_{B(1\sigma)} = \pm 0.333333\% \text{ Flow}$$

11.3.3.1.5 Input Uncertainty ($\sigma_{input3A}$, $\sigma_{input3B}$)

In addition to its own error terms, the error terms from Module 3 must also be considered. Since the trip circuits perform no function on the input signal $\sigma_{input3A}$ becomes

REVISION NO.

0

1

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 77 of 191

equal to the random input terms σ_3 for the Hi Flow trip. However, the Comparator Trip is also looking at the output of another RFM so both inputs also have a σ_{3c} term impressed on them. Therefore, the uncertainty term $\sigma_{input3B}$ for the Comparator Trip will combine two σ_{3c} terms by SRSS.

$$\sigma_{input3A} = \pm \sigma_3 = \pm 2.546521\% \text{ Flow}$$

And

$$\sigma_{input3B} = \pm (\sigma_{3c}^2 + \sigma_{3c}^2)^{0.5} \% \text{ Flow}$$

$$\sigma_{input3B} = \pm (1.669197^2 + 1.669197^2)^{0.5} \% \text{ Flow}$$

$$\sigma_{input3B} = \pm 2.360601\% \text{ Flow}$$

A new term ($\sigma_{input3A_{AV}}$) will be introduced at this time to account for errors associated only with the Allowable Value calculation. Per Reference 3.3 the Allowable Value determination involves all the error terms except those pertaining to the process. Therefore, $\sigma_{input3A_{AV}}$ will equal σ_{3c} since the difference between σ_{3c} and σ_3 is the absence of the flow element error.

$$\sigma_{input3A_{AV}} = \sigma_{3c} = 1.669197\% \text{ Flow}$$

11.3.3.1.6 Determination of Module Random Error (σ_{3A} , σ_{3B})

Using the methodology of Reference 3.3,

$$\sigma_{3A} = \pm [(\text{RA3A}_{(1\sigma)})^2 + (\text{RD3A}_{(1\sigma)})^2 + (\text{CAL3A})^2 + (\text{ST3A}_{A(1\sigma)})^2 + (\sigma_{input3A})^2]^{0.5} \% \text{ Flow}$$

$$\sigma_{3A} = \pm [(0.625)^2 + (1.234276)^2 + (0.022538)^2 + (0.416667)^2 + (2.546521)^2]^{0.5} \% \text{ Flow}$$

$$\sigma_{3A} = \pm 2.92796\% \text{ Flow}$$

And

$$\sigma_{3B} = \pm [(\text{RA3A}_{(1\sigma)})^2 + (\text{RD3A}_{(1\sigma)})^2 + (\text{CAL3A})^2 + (\text{ST3A}_{B(1\sigma)})^2 + (\sigma_{input3B})^2]^{0.5} \% \text{ Flow}$$

$$\sigma_{3B} = \pm (0.625^2 + 1.234276^2 + 0.022538^2 + 0.333333^2 + 2.360601^2)^{0.5} \% \text{ Flow}$$

$$\sigma_{3B} = \pm 2.756468\% \text{ Flow}$$

REVISION NO.

0

1

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345		PAGE 78 of 191	
<p>And</p> $\sigma 3A_{AV} = \pm [(RA3A_{(1\sigma)})^2 + (RD3A_{(1\sigma)})^2 + (CAL3A)^2 + (ST3A_{A(1\sigma)})^2 + (\sigma_{input}3A_{AV})^2]^{0.5} \% \text{ Flow}$ $\sigma 3A_{AV} = \pm [(0.625)^2 + (1.234276)^2 + (0.022538)^2 + (0.416667)^2 + (1.669197)^2]^{0.5} \% \text{ Flow}$ $\sigma 3A_{AV} = \pm 2.207804 \% \text{ Flow}$			
REVISION NO.	0	1	

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345		PAGE 79 of 191
<p>11.3.3.2 Module 3A Non-Random Errors (Σe_{3A})</p> <p>11.3.3.2.1 Humidity Errors (e_{3AH})</p> <p style="margin-left: 40px;">Since Reference 3.18 does not identify a humidity error term a value of zero will be used per Section 4.3.</p> <p style="margin-left: 80px;">$e_{3AH} = 0\% \text{ Flow}$</p> <p>11.3.3.2.2 Temperature Error (e_{3AT})</p> <p style="margin-left: 40px;">Since Reference 3.18 does not identify a temperature error term a value of zero will be used per Section 4.3.</p> <p style="margin-left: 80px;">$e_{3AT} = 0\% \text{ Flow}$</p> <p>11.3.3.2.3 Radiation Error (e_{3AR})</p> <p style="margin-left: 40px;">Since Reference 3.18 does not identify a radiation error term a value of zero will be used per Section 4.3.</p> <p style="margin-left: 80px;">$e_{3AR} = 0\% \text{ Flow}$</p> <p>11.3.3.2.4 Seismic Error (e_{3AS})</p> <p style="margin-left: 40px;">Per Section 4.7 seismic error for this module is considered negligible.</p> <p style="margin-left: 80px;">$e_{3AS} = 0\% \text{ Flow}$</p> <p>11.3.3.2.5 Static Pressure Effect (e_{3ASP})</p> <p style="margin-left: 40px;">This module is an all electronic device that is not exposed to any pressure other than atmospheric. Therefore, there is no static pressure effect.</p> <p style="margin-left: 80px;">$e_{3ASP} = 0\% \text{ Flow}$</p> <p>11.3.3.2.6 Pressure Error (e_{3AP})</p> <p style="margin-left: 40px;">This module is an all electronic device that is not exposed to any pressure other than atmospheric. Therefore, there is no pressure effect.</p> <p style="margin-left: 80px;">$e_{3AP} = 0\% \text{ Flow}$</p>		
REVISION NO.	0	

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345		PAGE 80 of 191	
<p>11.3.3.2.7 Process Errors(e3Ap)</p> <p>This module is intermediate in the loop and, as such, is not exposed to any process parameters. Therefore, there are no process errors.</p> <p style="padding-left: 40px;">e3Ap = 0% Flow</p> <p>11.3.3.2.8 Power Supply Effects (e3AV)</p> <p>Since Reference 3.18 does not identify a power supply effect error term a value of zero will be used per Section 4.3.</p> <p style="padding-left: 40px;">e3AV = 0% Flow</p> <p>11.3.3.2.9 Non-Random Input Error (einput3A, einput3B)</p> <p>In addition to its own error terms, the error terms from Module 3 must also be considered. Since the trip circuits perform no function on the input signal einput3A becomes equal to the non-random input term $\Sigma e3$ for the Hi Flow trip. However, the Comparator Trip is also looking at the output of another RFM so the reference input also has a $\Sigma e3$ term impressed on it. Since these are not random terms, it is expected that their magnitudes would be the same from each Module 3. However, the methodology of Reference 3.3 does not allow the cancellation of non-random terms. Therefore, the total error at the comparator will be the algebraic sum of two $\Sigma e3$ terms.</p> <p style="padding-left: 40px;">einput3A = $\pm \Sigma e3$ = $\pm 1.274635\%$ Flow</p> <p>And</p> <p style="padding-left: 40px;">einput3B = $\pm (\Sigma e3 + \Sigma e3) \% \text{ Flow}$</p> <p style="padding-left: 40px;">einput3B = $\pm (1.274635 + 1.274635)$</p> <p style="padding-left: 40px;">einput3B = $\pm 2.54927\%$ Flow</p>			
REVISION NO.	0		

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345		PAGE 81 of 191
<p>11.3.3.2.10 Non-Random Error ($\Sigma e3A$, $\Sigma e3B$)</p> <p>From Reference 3.3 the non-random error is the algebraic sum of all the above terms.</p> $\Sigma e3A = \pm(e3AH + e3AT + e3AR + e3AS + e3ASP + e3AP + e3Ap + e3AV + einput3A)\% \text{ Flow}$ $\Sigma e3A = \pm(0 + 0 + 0 + 0 + 0 + 0 + 0 + 0 + 1.274635)\% \text{ Flow}$ $\Sigma e3A = \pm 1.274635\% \text{ Flow}$ <p>And</p> $\Sigma e3B = \pm(e3AH + e3AT + e3AR + e3AS + e3ASP + e3AP + e3Ap + e3AV + einput3B)\% \text{ Flow}$ $\Sigma e3B = \pm(0 + 0 + 0 + 0 + 0 + 0 + 0 + 0 + 2.54927)\% \text{ Flow}$ $\Sigma e3B = \pm 2.54927\% \text{ Flow}$		
REVISION NO.	0	

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345	PAGE 82 of 191
--------------------------	----------------

11.4 Module 4 (APRM)

The APRM will be divided into four parts for this calculation; LPRM, APRM Averaging Circuitry, Trip Circuits (Fixed), and Trip Circuits (Flow Biased). These will be designated Module 4A, 4B, 4C, and 4D respectively. This separation is performed because the vendor lists the specifications for these items separately in References 3.9 and 3.11, and because the calibration procedures of Reference 3.5 effectively make this separation.

11.4.1 Module 4A (LPRM)

Classification of Module

Module 4A receives a current from an incore fission chamber and provides an analog voltage output that is proportional to the input current. Therefore, Module 4A is an analog module.

11.4.1.1 Module 4A Random Error (σ_{4A})

This section addresses random uncertainties that have the potential to be expressed in the output of Module 4.

11.4.1.1.1 Reference Accuracy (RA4A)

Per Section 8.4.1 the reference accuracy for this module is 0.8% CS. However, the reference also states that this is referred to a full scale value of 125% Power. Therefore, this value will be considered to be 0.8×125 or 1% Power.

$RA_{4A} = 1\% \text{ Power}$

Per Assumption 5.1, this is assumed to be a 2 sigma value. This is then converted to a 1 sigma value by dividing by 2.

$RA_{4A(1\sigma)} = \pm RA_{4A} / 2 \text{ \% Power}$

$RA_{4A(1\sigma)} = \pm 1/2 \text{ \% Power}$

$RA_{4A(1\sigma)} = \pm 0.5\% \text{ Power}$

11.4.1.1.2 Drift (RD4A)

Per Section 8.4.1 the reference drift for this module is 0.8% CS per 700 hours. However, the reference also states that this is referred to a full scale value of 125% Power. Therefore, this value will be considered to be 0.8×125 or 1% Power.

REVISION NO.	0			
--------------	---	--	--	--

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 83 of 191

$$RD4A = 1\% \text{ Power}/700 \text{ HRS}$$

Table 4.3.1.1-1 of Reference 3.7 states that "The LPRMs shall be calibrated at least once per 1000 effective full power hours (EFPH)." However, Table 4.3.1.1-1 of Reference 3.7 states that the APRM Gain Adjustment Factor (GAF) shall be calibrated weekly. This effectively calibrates out the LPRM drift term each week. Since this time period plus the 25% late factor is shorter than vendor specified drift time period, the vendor drift value will be used as is (Section 2.1.b). Therefore, the value used for the Surveillance Interval (RD4ATSI) will be 700 hours, thereby making the drift extension term equal to 1. Also, per Assumption 5.1, RD4A is assumed to be a 2 sigma value. This will be converted to a 1 sigma value by dividing by 2.

$$RD4A_{(1\sigma)} = \pm (RD4A/2) * (RD4ATSI/RD4AT)^{0.5} \% \text{ Power}$$

$$RD4A_{(1\sigma)} = \pm (1/2) * (700/700)^{0.5} \% \text{ Power}$$

$$RD4A_{(1\sigma)} = \pm 0.5\% \text{ Power}$$

11.4.1.1.3 Calibration Uncertainty (CAL4A)

The uncertainties associated with calibrating the LPRM Card are composed of the uncertainties in setting the input signal and the uncertainties in reading the output signal. Per References 3.5.h, and 3.5.q the DMM used should have an accuracy of at least ± 0.01 Vdc. If this is considered a two sigma value per Assumption 5.1, the one sigma requirement, which makes it compatible with the DMM data from Reference 3.4, would be $0.01/2$ or ± 0.005 Vdc. Since both uses of the DMM in measurements applicable to this calculation are to measure 10 Vdc, the span (RV4ACURS) is the same for both measurements. Converting this error term to % CS gives

$$RAMTE1_{4A(DMM)} = \pm (RA4A_{DMM}/RV4ACURS) * 100 \% \text{ CS}$$

$$RAMTE1_{4A(DMM)} = \pm (0.005/10) * 100 \% \text{ CS}$$

$$RAMTE1_{4A(DMM)} = \pm 0.05\% \text{ CS}$$

This value will also be used for $RAMTE2_{4A(DMM)}$ since the output span is also 10 Vdc.

The first use of the DMM is to set the reference voltage for the built-in input current source. Once the reference voltage is set the accuracy of the current source is $\pm 1.0\%$

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 84 of 191

(Reference 3.9). Since the procedures use the current source to make the LPRM read full scale, this error term will be considered $\pm 1\%$ CS.

Since the DMM is a digital instrument the reading error terms at both the input and output ($REMTE1_{4A(DMM)}$, $REMTE2_{4A(DMM)}$) are equal to 0% CS.

The input current source is also digital since the current is set by digital decade switches. Therefore, $REMTE1_{4A(CURS)}$ is also 0% CS.

From Reference 3.3,

$$MTE1 = [(\text{RAMTE1}/n)^2 + \text{REMTE1}^2]^{0.5}$$

where n is the number of standard deviations applicable to the error term. The DMM has been converted to a one sigma term in the text above; therefore, n is equal to 1 for this term. The current source, however, is a vendor specified error term and is, therefore, considered to be a two sigma term. MTE1 for this calculation is, therefore,

$$MTE1_{4A} = \pm [(\text{RAMTE1}_{4A(DMM)}/n)^2 + (\text{RAMTE1}_{4A(CURS)}/n)^2 + \text{REMTE1}_{4A(DMM)}^2 + \text{REMTE1}_{4A(CURS)}^2]^{0.5} \% \text{ CS}$$

$$MTE1_{4A} = \pm [(0.05/1)^2 + (1/2)^2 + 0^2 + 0^2]^{0.5} \% \text{ CS}$$

$$MTE1_{4A} = \pm 0.502494\% \text{ CS}$$

The output calibration uses only the DMM and its error terms have been discussed above. Therefore, the total output MTE error term is

$$MTE2_{4A} = \pm [(\text{RAMTE2}_{4A(DMM)})^2 + (\text{REMTE2}_{4A(DMM)})^2]^{0.5} \% \text{ CS}$$

$$MTE2_{4A} = \pm [(0.05)^2 + 0^2]^{0.5} \% \text{ CS}$$

$$MTE2_{4A} = \pm 0.05\% \text{ CS}$$

From Section 5.2 the errors attributed to the calibration standards are considered negligible. Therefore, the only terms which contribute to CAL4A are the MTE1 and MTE2 terms. For this calculation

$$\text{CAL4A} = \pm [(MTE1_{4A})^2 + (MTE2_{4A})^2]^{0.5} \% \text{ CS}$$

$$\text{CAL4A} = \pm [0.502494^2 + 0.05^2]^{0.5} \% \text{ CS}$$

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 85 of 191

$$CAL4A = \pm 0.504975\% \text{ CS}$$

11.4.1.1.4 Setting Tolerance (ST4A)

The setting tolerance for the LPRM is the combination of the input and output setting tolerances. However, References 3.5.h and 3.5.q give no setting tolerances for the three measurements used to calibrate the LPRM gain. From Assumption 5.4 the setting tolerance will, therefore, be assumed equal to the reference accuracy of the applicable test instrument.

For this particular application then the setting tolerances are:

$$ST4A_{DMM} = \pm RAMTE1_{4A(DMM)} = \pm RAMTE2_{4A(DMM)} = \pm 0.05\% \text{ CS}$$

$$ST4A_{CURS} = \pm RAMTE1_{4A(CURS)} = \pm 1\% \text{ CS}$$

The total setting tolerance for the LPRM is the combination of two input terms ($ST4A_{DMM}$ and $ST4A_{CURS}$) and one output term ($ST4A_{DMM}$) by SRSS. From Section 2.1.a the given setting tolerances are considered 3 sigma values. However, $ST4A_{DMM}$ is already the result of dividing the original procedural value by 2. Therefore, it must now be multiplied by 2/3 to make it a one sigma value for setting tolerance. $ST4A_{CURS}$ is still as it was given by the vendor and, therefore, must be divided by 3 to make it compatible with the other 1 sigma error terms. The total setting tolerance $ST4A_{(1\sigma)}$ is then

$$ST4A_{(1\sigma)} = \pm \{ [(ST4A_{DMM}) * (2/3)]^2 + (ST4A_{CURS}/3)^2 + [(ST4A_{DMM}) * (2/3)]^2 \}^{0.5} \% \text{ CS}$$

$$ST4A_{(1\sigma)} = \pm \{ [(0.05) * (2/3)]^2 + (1/3)^2 + [(0.05) * (2/3)]^2 \}^{0.5} \% \text{ CS}$$

$$ST4A_{(1\sigma)} = \pm 0.33665\% \text{ CS}$$

11.4.1.1.5 Input Uncertainty ($\sigma_{input4A}$)

In addition to its own error terms, Module 4A also operates on the error terms from an incore fission detector. From Section 4.5 of Reference 3.13 the primary element accuracy (PEA) for the incore fission detector is a combination of sensor sensitivity and sensor non-linearity uncertainties. The sensitivity of the detectors decreases with neutron fluence. The average sensitivity loss, and its two sigma variation, for all GE LPRM detectors has been determined to be:

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345		PAGE 86 of 191
<p>Sensor Sensitivity Loss (SSL_B) = 0.33% (bias term) (100% Power)</p> <p>Sensor Sensitivity Loss (SSL_R) = $\pm 0.20\%$ (random term) (100% Power)</p> <p>The detector non-linearity and its two sigma variation (in the power range) have been determined to be:</p> <p>Sensor Non-linearity (SNL_B) = 0.49% (bias term) (100% Power)</p> <p>Sensor Non-linearity (SNL_R) = $\pm 1\%$ (random term) (0 to 120% Power)</p> <p>The total sensor uncertainty can be obtained by adding the bias terms ($PEA_{4A(B)}$) and combining the random terms by SRSS ($PEA_{4A(R)}$). The result is:</p> <p>$PEA_{4A(B)} = SSL_B + SNL_B \% \text{ Power}$</p> <p>$PEA_{4A(B)} = 0.33 + 0.49 \% \text{ Power}$</p> <p>$PEA_{4A(B)} = 0.82 \% \text{ Power}$</p> <p>From Section 4.11, for the three low power trips, SNL_B will be set to zero leaving only SSL_B as the bias term for PEA.</p> <p>$PEA_{4A(LPB)} = SSL_B = 0.33\% \text{ Power}$</p> <p>Combining the random terms gives:</p> <p>$PEA_{4A(R)} = \pm [(SSL_R)^2 + (SNL_R)^2]^{0.5} \% \text{ Power}$</p> <p>$PEA_{4A(R)} = \pm [(0.2)^2 + (1)^2]^{0.5} \% \text{ Power}$</p> <p>$PEA_{4A(R)} = \pm 1.019804\% \text{ Power}$</p> <p>For the low power trips the random terms of PEA are the same as for the high power trips. Therefore,</p> <p>$PEA_{4A(LPR)} = PEA_{4A(R)} = 1.019804\% \text{ Power}$</p> <p>For this calculation the random uncertainty terms ($PEA_{4A(R)}$ and $PEA_{4A(LPR)}$) are equal to $\sigma_{input4A}$ and $\sigma_{input4A_{LP}}$ respectively. The bias uncertainty terms ($PEA_{4A(B)}$ and $PEA_{4A(LPB)}$) are equal to $e_{input4A}$ and $e_{input4A_{LP}}$ respectively. The bias terms will be covered in Section 11.4.1.2.9.</p>		
REVISION NO.	0	

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345		PAGE 87 of 191	
$\sigma_{\text{input4A}} = \pm \text{PEA}_{4A(R)} = \pm 1.019804\% \text{ Power}$ <p>And</p> $\sigma_{\text{input4A}_{LP}} = \pm \text{PEA}_{4A(LPR)} = \pm 1.019804\% \text{ Power}$ <p>Per Reference 3.3 the process errors are not included in the determination of Allowable Value. Therefore,</p> $\sigma_{\text{input4A}_{AV}} = 0\% \text{ Power}$ <p>11.4.1.1.6 Determination of Module Random Error (σ_{4A} and σ_{4A}_{LP})</p> <p>Using the methodology of Reference 3.3,</p> $\sigma_{4A} = \pm [(\text{RA}_{4A(1\sigma)})^2 + (\text{RD}_{4A(1\sigma)})^2 + (\text{CAL}_{4A})^2 + (\text{ST}_{4A(1\sigma)})^2 + (\sigma_{\text{input4A}})^2]^{0.5} \% \text{ CS}$ <p>However, since RA_{4A}, RD_{4A}, and σ_{input4A} are in terms of percent power while the other terms are percent calibrated span, these terms will be removed from the equation and carried through to the APRM Averaging Circuitry separately. Therefore, for this section the equation for σ_{4A} is:</p> $\sigma_{4A} = \pm [(\text{CAL}_{4A})^2 + (\text{ST}_{4A(1\sigma)})^2]^{0.5} \% \text{ CS}$ $\sigma_{4A} = \pm [(0.504975)^2 + (0.33665)^2]^{0.5} \% \text{ CS}$ $\sigma_{4A} = \pm 0.606904\% \text{ CS}$ <p>And</p> $\sigma_{4A_{PP}} = \pm [(\text{RA}_{4A(1\sigma)})^2 + (\text{RD}_{4A(1\sigma)})^2]^{0.5} \% \text{ Power}$ $\sigma_{4A_{PP}} = \pm [(0.5)^2 + (0.5)^2]^{0.5} \% \text{ Power}$ $\sigma_{4A_{PP}} = \pm 0.707107\% \text{ Power}$			
REVISION NO.	0		

COMMONWEALTH EDISON COMPANY

CALCULATION NO.	L-001345		PAGE	88 of 191
<p>11.4.1.2 Module 4A Non-Random Errors (Σe_{4A})</p> <p>11.4.1.2.1 Humidity Errors (e_{4AH})</p> <p>Since Reference 3.9 does not identify a humidity error term a value of zero will be used per Section 4.3.</p> <p>$e_{4AH} = 0\% \text{ CS}$</p> <p>11.4.1.2.2 Temperature Error (e_{4AT})</p> <p>Since Reference 3.9 does not identify a temperature error term a value of zero will be used per Section 4.3.</p> <p>$e_{4AT} = 0\% \text{ CS}$</p> <p>11.4.1.2.3 Radiation Error (e_{4AR})</p> <p>Since Reference 3.9 does not identify a radiation error term a value of zero will be used per Section 4.3.</p> <p>$e_{4AR} = 0\% \text{ CS}$</p> <p>11.4.1.2.4 Seismic Error (e_{4AS})</p> <p>Per Section 4.7 seismic error for this module is considered negligible.</p> <p>$e_{4AS} = 0\% \text{ CS}$</p> <p>11.4.1.2.5 Static Pressure Effect (e_{4ASP})</p> <p>This module is an all electronic device that is not exposed to any pressure other than atmospheric. Therefore, there is no static pressure effect.</p> <p>$e_{4ASP} = 0\% \text{ CS}$</p> <p>11.4.1.2.6 Pressure Error (e_{4AP})</p> <p>This module is an all electronic device that is not exposed to any pressure other than atmospheric. Therefore, there is no pressure effect.</p> <p>$e_{4AP} = 0\% \text{ CS}$</p>				
REVISION NO.	0			

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 89 of 191

11.4.1.2.7 Process Errors (e4Ap)

This module is intermediate in the loop and, as such, is not exposed to any process parameters. Therefore, there are no process errors.

$$e4Ap = 0\% \text{ CS}$$

11.4.1.2.8 Power Supply Effects (e4AV)

Since Reference 3.9 does not identify a power supply effect error term a value of zero will be used per Section 4.3.

$$e4AV = 0\% \text{ CS}$$

11.4.1.2.9 Non-Random Input Error (einput4A)

In addition to its own error terms, Module 4A also operates on the error terms from an incore fission detector. This was discussed in Section 11.4.1.1.5. The value of einput4A was determined to be:

$$einput4A = (PEA_{4A(B)}) = 0.82\% \text{ Power}$$

And

$$einput4A_{LP} = PEA_{4A(LPB)} = 0.33\% \text{ Power}$$

Per Reference 3.3 the process errors are not included in the determination of Allowable Value. Therefore,

$$einput4A_{AV} = 0\% \text{ Power}$$

11.4.1.2.10 Non-Random Error ($\Sigma e4A$)

From Reference 3.3 the non-random error is the algebraic sum of all the above terms.

$$\Sigma e4A = \pm(e4AH + e4AT + e4AR + e4AS + e4ASP + e4AP + e4Ap + e4AV + einput4A)\% \text{ CS}$$

However, since einput4A, einput4A_{AV}, and einput4A_{LP} are in terms of percent power while the other terms are percent calibrated span, these terms will be removed from the equation and carried through to the APRM Averaging Circuitry separately. Therefore, for this section the equation for $\Sigma e4A$ is:

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345				PAGE 90 of 191
$\Sigma e4A = \pm(e4AH + e4AT + e4AR + e4AS + e4ASP + e4AP + e4Ap + e4AV) \% CS$ $\Sigma e4A = \pm(0 + 0 + 0 + 0 + 0 + 0 + 0 + 0) \% CS$ $\Sigma e4A = \pm 0 \% CS$				
REVISION NO.	0			

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345		PAGE 91 of 191
<p>11.4.2 Module 4B (APRM Averaging Circuitry)</p> <p><u>Classification of Module</u></p> <p>Module 4B receives analog inputs from multiple LPRM cards. These signals are averaged and then operated on by an adjustable gain factor resulting in an analog output that is some multiple of the average of the input signals. Therefore, Module 4B is an analog module.</p> <p>11.4.2.1 Module 4B Random Error (σ_{4B})</p> <p>This section addresses random uncertainties that have the potential to be expressed in the output of Module 4B.</p> <p>11.4.2.1.1 Reference Accuracy (RA4B)</p> <p>Per Section 8.4.1 the reference accuracy for this module is:</p> $RA4B = 0.8\% \text{ CS}$ <p>Per Assumption 5.1, this is assumed to be a 2 sigma value. This is then converted to a 1 sigma value by dividing by 2.</p> $RA4B_{(1\sigma)} = \pm RA4B/2 \% \text{ CS}$ $RA4B_{(1\sigma)} = \pm 0.8/2 \% \text{ CS}$ $RA4B_{(1\sigma)} = \pm 0.4\% \text{ CS}$ <p>11.4.2.1.2 Drift (RD4B)</p> <p>Per Section 8.4.1 the reference drift for this module is:</p> $RD4B = 0.5\% \text{ CS}/700 \text{ Hrs}$ <p>Table 4.3.1.1-1 of Reference 3.7 states that the APRM Gain Adjustment Factor (GAF) shall be calibrated weekly. Since this time period is shorter than vendor specified drift time period, the vendor drift value will be used as is. Also, per Assumption 5.1, RD4B is assumed to be a 2 sigma value. This will be converted to a 1 sigma value by dividing by 2.</p> $RD4B_{(1\sigma)} = \pm (RD4B/2) \% \text{ CS}$ $RD4B_{(1\sigma)} = \pm (0.5/2) \% \text{ CS}$ $RD4B_{(1\sigma)} = \pm 0.25\% \text{ CS}$		
REVISION NO.	0	

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 92 of 191

11.4.2.1.3 Calibration Uncertainty (CAL4B)

The uncertainties associated with calibrating the APRM gain are composed entirely of the uncertainties associated with the process computer. The process computer determines the core thermal power by heat balance. This can be considered the input to the calibration. The process computer also reads the APRM output and compares the two. The result of the comparison is the APRM Gain Adjustment Factor term (AGAF). Therefore, for this calculation $RAMTE1_{4B}$ is the accuracy with which the process computer determines core thermal power, and $RAMTE2_{4B}$ is the accuracy with which the process computer reads the APRM output signal. Per Assumption 5.5, both of these terms are considered zero. In addition, since the output of the process computer is a digital printout, $REMTE1_{4B}$ and $REMTE2_{4B}$ are zero.

From Reference 3.3,

$$MTE1 = [(RAMTE1/n)^2 + REMTE1^2]^{0.5}$$

where n is the number of standard deviations applicable to the error term. If the reference accuracy terms for the process computer are considered two sigma values, MTE1 for this calculation is:

$$MTE1_{4B} = \pm [(RAMTE1_{4B}/2)^2 + REMTE1_{4B}^2]^{0.5} \% CS$$

$$MTE1_{4B} = \pm [(0/2)^2 + 0^2]^{0.5} \% CS$$

$$MTE1_{4B} = \pm 0 \% CS$$

Likewise, $MTE2_{4B}$ is:

$$MTE2_{4B} = \pm [(RAMTE2_{4B}/2)^2 + (REMTE2_{4B})^2]^{0.5} \% CS$$

$$MTE2_{4A} = \pm [(0/2)^2 + 0^2]^{0.5} \% CS$$

$$MTE2_{4A} = \pm 0 \% CS$$

From Section 5.2 the errors attributed to the calibration standards are considered negligible. Therefore, the only terms which contribute to CAL4B are the MTE1 and MTE2 terms. For this calculation

$$CAL4B = \pm [(MTE1_{4B})^2 + (MTE2_{4B})^2]^{0.5} \% CS$$

$$CAL4B = \pm [0^2 + 0^2]^{0.5} \% CS$$

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 93 of 191

$$CAL4B = \pm 0\% \text{ CS}$$

11.4.2.1.4 Setting Tolerance (ST4B)

The setting tolerance for the APRM gain calibration is the allowance in the AGAF setting. From References 3.5.g and 3.5.p this allowance (ST4B) is ± 0.02 from the ideal value of 1.00. Since the AGAF calibration is usually performed when the reactor is operating near 100% power this translates into an setting tolerance (ST4B_s) of $\pm 2\%$ Power. Since full scale output of the APRM is 125% this term can be converted to percent calibrated span by multiplying by 100/125.

From Section 2.1.a the given setting tolerances are considered 3 sigma values. Therefore, ST4B_s must be divided by 3 to make it compatible with the other 1 sigma error terms. Combining this operation with the conversion to percent calibrated span gives

$$ST4B_{(1\sigma)} = \pm ST4B_s * (100/125) / 3 \% \text{ CS}$$

$$ST4B_{(1\sigma)} = \pm 2 * (100/125) / 3 \% \text{ CS}$$

$$ST4B_{(1\sigma)} = \pm 0.533333\% \text{ CS}$$

11.4.2.1.5 Process Measurement Accuracy (PMA)

Section 4.5 of Reference 3.13 contains an error term called PMA which is applicable to the APRMs. PMA is a combination of APRM tracking error and the uncertainty due to neutron noise. This reference states that for the MSIV closure transient event, which is one of the more severe events, the APRM tracking error (TRAC) is 1.11% and the uncertainty due to neutron noise (NN) is typically 2.0% for fixed upscale trips. However, for trips primarily involved with slow transients (flow biased trips including STP, APRM Downscale, APRM Setdown Rod Block, and APRM Setdown Scram) the neutron noise will help the signal actuate the trip. Therefore, a value of zero will be used for neutron noise for these trips. The tracking error is the uncertainty of the maximum deviation of APRM readings with LPRM failures or bypasses during a power transient. For the low power trips the tracking accuracy is negligible. The neutron noise is the global neutron flux noise in the reactor core with a typical dominant frequency of approximately 0.3 to 0.5 Hertz and a typical maximum peak-to-peak amplitude of approximately 5 to 10 percent. Since both error terms are independent and random they can be combined by SRSS.

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 94 of 191

$$PMA = \pm (TRAC^2 + NN^2)^{0.5} \% \text{ Power}$$

$$PMA = \pm (1.11^2 + 2^2)^{0.5} \% \text{ Power}$$

$$PMA = \pm 2.287378\% \text{ Power}$$

And

$$PMA_{FB} = 1.11\% \text{ Power}$$

For the low power trips:

$$PMA_{LP} = 0\% \text{ Power}$$

These are considered to be a 2 sigma values and must be divided by 2 in order to make them compatible with the other error terms.

$$PMA_{1\sigma} = \pm PMA/2 \% \text{ Power}$$

$$PMA_{1\sigma} = \pm 2.287378/2 \% \text{ Power}$$

$$PMA_{1\sigma} = \pm 1.143689\% \text{ Power}$$

And

$$PMA_{FB(1\sigma)} = \pm PMA_{FB}/2 \% \text{ Power}$$

$$PMA_{FB(1\sigma)} = \pm 1.11/2 \% \text{ Power}$$

$$PMA_{FB(1\sigma)} = \pm 0.555\% \text{ Power}$$

Per Reference 3.3 the process errors are not included in the determination of Allowable Value. Therefore,

$$PMA_{AV} = 0\% \text{ Power}$$

11.4.2.1.6 Input Uncertainty ($\sigma_{input4B}$)

In addition to its own error terms, Module 4B also operates on the error terms from Module 4A. Therefore, the random error terms σ_{4A} , $\sigma_{4A_{PP}}$, $\sigma_{input4A}$, $\sigma_{input4A_{AV}}$, and $\sigma_{input4A_{LP}}$ from the LPRMs must be transferred through the Averaging Circuitry. The resultant terms will be $\sigma_{input4B}$, $\sigma_{input4B_{AV}}$, and $\sigma_{input4B_{LP}}$ for this module.

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 95 of 191

Since σ_{4A} is in % CS and $\sigma_{4A_{PP}}$, $\sigma_{input4A}$, $\sigma_{input4A_{AV}}$, and $\sigma_{input4A_{LP}}$ are in % power the terms must be treated differently when being transferred through the Averaging Circuitry.

If N LPRMs are being averaged the gain associated with each LPRM through the averaging circuit is $1/N$. This applies to σ_{4A} , $\sigma_{4A_{PP}}$, $\sigma_{input4A}$, $\sigma_{input4A_{AV}}$, and $\sigma_{input4A_{LP}}$. Following the averaging function there is a gain function (G_{APRM}) that is used for the AGAF adjustment. Since $\sigma_{4A_{PP}}$, $\sigma_{input4A}$, $\sigma_{input4A_{AV}}$, and $\sigma_{input4A_{LP}}$ are in % power and the output is also in % power the gain function has no effect. However, σ_{4A} is in % CS and the gain function has the effect of changing the calibrated span. Therefore, σ_{4A} must be multiplied by G_{APRM} . Based on this discussion then σ_{4A} is propagated through the Averaging Circuitry by the factor G_{APRM}/N while $\sigma_{input4A}$ is only operated on by $1/N$. If the random error terms from N LPRMs are combined by SRSS the result is:

$$\sigma_{input4B_{CS}} = \pm \{N[\sigma_{4A} * (G_{APRM}/N)]^2\}^{0.5} = \pm (\sigma_{4A} * G_{APRM}) / N^{0.5} \% \text{ CS}$$

and

$$\sigma_{input4B_{PP}} = \pm [N(\sigma_{input4A}/N)^2 + N(\sigma_{4A_{PP}}/N)^2]^{0.5} \% \text{ Power}$$

$$\sigma_{input4B_{PP}} = \pm [(\sigma_{input4A})^2 + (\sigma_{4A_{PP}})^2]^{0.5} / N^{0.5} \% \text{ Power}$$

From Table 3.3.1-1 of Reference 3.7 the minimum number of LPRMs which must be in the average in order for an APRM to be considered operable is 14. Using this value in the above equations gives:

$$\sigma_{input4B_{CS}} = \pm (\sigma_{4A} * G_{APRM}) / N^{0.5} \% \text{ CS}$$

$$\sigma_{input4B_{CS}} = \pm (0.606904 * 2.5) / 14^{0.5} \% \text{ CS}$$

$$\sigma_{input4B_{CS}} = \pm 0.405505 \% \text{ CS}$$

And

$$\sigma_{input4B_{PP}} = \pm [(\sigma_{input4A})^2 + (\sigma_{4A_{PP}})^2]^{0.5} / N^{0.5} \% \text{ Power}$$

$$\sigma_{input4B_{PP}} = \pm [(1.019804)^2 + (0.707107)^2] / 14^{0.5} \% \text{ Power}$$

$$\sigma_{input4B_{PP}} = \pm 0.331663 \% \text{ Power}$$

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 96 of 191

And

$$\sigma_{\text{input4B}_{\text{PP}(\text{LP})}} = \pm [(\sigma_{\text{input4A}_{\text{LP}}})^2 + (\sigma_{4\text{A}_{\text{PP}}})^2]^{0.5} / N^{0.5} \% \text{ Power}$$

$$\sigma_{\text{input4B}_{\text{PP}(\text{LP})}} = \pm [(1.019804)^2 + (0.707107)^2]^{0.5} / 14^{0.5} \% \text{ Power}$$

$$\sigma_{\text{input4B}_{\text{PP}(\text{LP})}} = \pm 0.331663 \% \text{ Power}$$

And

$$\sigma_{\text{input4B}_{\text{AV}}} = \pm [(\sigma_{\text{input4A}_{\text{AV}}})^2 + (\sigma_{4\text{A}_{\text{PP}}})^2]^{0.5} / N^{0.5} \% \text{ Power}$$

$$\sigma_{\text{input4B}_{\text{AV}}} = \pm [(0)^2 + (0.707107)^2]^{0.5} / 14^{0.5} \% \text{ Power}$$

$$\sigma_{\text{input4B}_{\text{AV}}} = \pm 0.188982 \% \text{ Power}$$

11.4.2.1.7 Determination of Module Random Error (σ_{4B})

Using the methodology of Reference 3.3,

$$\sigma_{4B} = \pm [(\text{RA4B}_{(1\sigma)})^2 + (\text{RD4B}_{(1\sigma)})^2 + (\text{CAL4B})^2 + (\text{ST4B}_{(1\sigma)})^2 + (\text{PMA}_{1\sigma})^2 + (\sigma_{\text{input4B}})^2]^{0.5} \% \text{ CS}$$

However, since $\sigma_{\text{input4B}_{\text{PP}}}$, $\sigma_{\text{input4B}_{\text{PP}(\text{LP})}}$, $\text{PMA}_{1\sigma}$, $\text{PMA}_{\text{FB}(1\sigma)}$, PMA_{LP} , and PMA_{AV} are in terms of percent power while the other terms are percent calibrated span, these terms will be removed from the equation until the combination of the first four terms, plus $\sigma_{\text{input4B}_{\text{CS}}}$, has been performed and the result converted to percent power by multiplying by 125/100. Then this result will be combined with $\sigma_{\text{input4B}_{\text{PP}}}$, $\sigma_{\text{input4B}_{\text{PP}(\text{LP})}}$, and $\text{PMA}_{1\sigma}$ using SRSS. Therefore, for this section the equation for σ_{4BI} is:

$$\sigma_{4BI} = \pm [(\text{RA4B}_{(1\sigma)})^2 + (\text{RD4B}_{(1\sigma)})^2 + (\text{CAL4B})^2 + (\text{ST4B}_{(1\sigma)})^2 + (\sigma_{\text{input4B}_{\text{CS}}})^2]^{0.5} \% \text{ CS}$$

$$\sigma_{4BI} = \pm [(0.4)^2 + (0.25)^2 + (0)^2 + (0.533333)^2 + (0.405505)^2]^{0.5} \% \text{ CS}$$

$$\sigma_{4BI} = \pm 0.819377 \% \text{ CS}$$

Converting this to percent power gives:

$$\sigma_{4BI_{\text{PP}}} = \pm \sigma_{4BI} * (125/100) \% \text{ Power}$$

$$\sigma_{4BI_{\text{PP}}} = \pm 0.819377 * (125/100) \% \text{ Power}$$

$$\sigma_{4BI_{\text{PP}}} = \pm 1.024221 \% \text{ Power}$$

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 97 of 191

Now this can be combined with $\sigma_{input4B}$ and $+ PMA_{1\sigma}$ using SRSS to obtain $\sigma4B$. $\sigma4B_{FB}$ will be created for use with the flow biased trips, $\sigma4B_{AV}$ will be created for use with the Allowable Value calculation, and $\sigma4B_{LP}$ will be created for use with the low power trips.

$$\sigma4B = \pm [(\sigma4BI_{PP})^2 + (\sigma_{input4B_{PP}})^2 + (PMA_{1\sigma})^2]^{0.5} \% \text{ Power}$$

$$\sigma4B = \pm [(1.024221)^2 + (0.331663)^2 + (1.143689)^2]^{0.5} \% \text{ Power}$$

$$\sigma4B = \pm 1.570686\% \text{ Power}$$

And

$$\sigma4B_{FB} = \pm [(\sigma4BI_{PP})^2 + (\sigma_{input4B_{PP}})^2 + (PMA_{FB(1\sigma)})^2]^{0.5} \% \text{ Power}$$

$$\sigma4B_{FB} = \pm [(1.024221)^2 + (0.331663)^2 + (0.555)^2]^{0.5} \% \text{ Power}$$

$$\sigma4B_{FB} = \pm 1.21122\% \text{ Power}$$

And

$$\sigma4B_{LP} = \pm [(\sigma4BI_{PP})^2 + (\sigma_{input4B_{PP(LP)}})^2 + (PMA_{LP})^2]^{0.5} \% \text{ Power}$$

$$\sigma4B_{LP} = \pm [(1.024221)^2 + (0.331663)^2 + (0)^2]^{0.5} \% \text{ Power}$$

$$\sigma4B_{LP} = \pm 1.076582\% \text{ Power}$$

And

$$\sigma4B_{AV} = \pm [(\sigma4BI_{PP})^2 + (\sigma_{input4B_{AV}})^2 + (PMA_{AV})^2]^{0.5} \% \text{ Power}$$

$$\sigma4B_{AV} = \pm [(1.024221)^2 + (0.188982)^2 + (0)^2]^{0.5} \% \text{ Power}$$

$$\sigma4B_{AV} = \pm 1.041510\% \text{ Power}$$

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345		PAGE 98 of 191
<p>11.4.2.2 Module 4B Non-Random Errors ($\Sigma e4B$)</p> <p>11.4.2.2.1 Humidity Errors ($e4BH$)</p> <p style="margin-left: 40px;">Since Reference 3.11 does not identify a humidity error term a value of zero will be used per Section 4.3.</p> <p style="margin-left: 80px;">$e4BH = 0\% \text{ CS}$</p> <p>11.4.2.2.2 Temperature Error ($e4BT$)</p> <p style="margin-left: 40px;">Since Reference 3.11 does not identify a temperature error term a value of zero will be used per Section 4.3.</p> <p style="margin-left: 80px;">$e4BT = 0\% \text{ CS}$</p> <p>11.4.2.2.3 Radiation Error ($e4BR$)</p> <p style="margin-left: 40px;">Since Reference 3.11 does not identify a radiation error term a value of zero will be used per Section 4.3.</p> <p style="margin-left: 80px;">$e4BR = 0\% \text{ CS}$</p> <p>11.4.2.2.4 Seismic Error ($e4BS$)</p> <p style="margin-left: 40px;">Per Section 4.7 seismic error for this module is considered negligible.</p> <p style="margin-left: 80px;">$e4BS = 0\% \text{ CS}$</p> <p>11.4.2.2.5 Static Pressure Effect ($e4BSP$)</p> <p style="margin-left: 40px;">This module is an all electronic device that is not exposed to any pressure other than atmospheric. Therefore, there is no static pressure effect.</p> <p style="margin-left: 80px;">$e4BSP = 0\% \text{ CS}$</p> <p>11.4.2.2.6 Pressure Error ($e4BP$)</p> <p style="margin-left: 40px;">This module is an all electronic device that is not exposed to any pressure other than atmospheric. Therefore, there is no pressure effect.</p> <p style="margin-left: 80px;">$e4BP = 0\% \text{ CS}$</p>		
REVISION NO.	0	

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345		PAGE 99 of 191
<p>11.4.2.2.7 Process Errors (e4Bp)</p> <p>This module is intermediate in the loop and, as such, is not exposed to any process parameters. Therefore, there are no process errors other than that previously discussed in Section 11.4.2.1.5.</p> <p style="padding-left: 40px;">e4Bp = 0% CS</p> <p>11.4.2.2.8 Power Supply Effects (e4BV)</p> <p>Since Reference 3.11 does not identify a power supply effect error term a value of zero will be used per Section 4.3.</p> <p style="padding-left: 40px;">e4BV = 0% CS</p> <p>11.4.2.2.9 Non-Random Input Error (einput4B)</p> <p>In addition to its own error terms, Module 4B also operates on the error terms from the LPRMs. The non-random error from the LPRMs was kept in two terms since one is in % CS ($\Sigma e4A$) and the other in % Power (einput4A). As was done for the random terms the % CS term must be operated on by the APRM gain (G_{APRM}) whereas the % Power term is not affected by the gain. For N LPRMs being averaged the result is:</p> <p style="padding-left: 40px;">einput4B_{CS} = $G_{APRM} * N * (1/N) * (\Sigma e4A) = G_{APRM} * \Sigma e4A$ % CS</p> <p style="padding-left: 40px;">einput4B_{CS} = 2.5*0 % CS</p> <p style="padding-left: 40px;">einput4B_{CS} = 0% CS</p> <p>And</p> <p style="padding-left: 40px;">einput4B_{PP} = $N * (1/N) * (einput4A) = einput4A$ % Power</p> <p style="padding-left: 40px;">einput4B_{PP} = 0.82% Power</p> <p>And</p> <p style="padding-left: 40px;">einput4B_{PP(LP)} = $N * (1/N) * (einput4A_{LP}) = einput4A_{LP}$ % Power</p> <p style="padding-left: 40px;">einput4B_{PP(LP)} = 0.33% Power</p> <p>And</p> <p style="padding-left: 40px;">einput4B_{AV} = $N * (1/N) * (einput4A_{AV}) = einput4A_{AV}$ % Power</p> <p style="padding-left: 40px;">einput4B_{AV} = 0% Power</p>		
REVISION NO.	0	

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 100 of 191

These four terms will be carried forward to the next section where they will be combined after the % CS terms are converted to % Power.

11.4.2.2.10 Non-Random Error ($\Sigma e4B$)

From Reference 3.3 the non-random error is the algebraic sum of all the above terms.

$$\Sigma e4B_{CS} = \pm(e4BH + e4BT + e4BR + e4BS + e4BSP + e4BP + e4Bp + e4BV + einput4B_{CS})\% CS$$

$$\Sigma e4B_{CS} = \pm(0 + 0 + 0 + 0 + 0 + 0 + 0 + 0 + 0)\% CS$$

$$\Sigma e4B_{CS} = \pm 0\% CS$$

This will now be converted to % Power and added to $einput4B_{PP}$ to obtain the total $\Sigma e4B$.

$$\Sigma e4B = \pm \Sigma e4B_{CS} * (125/100) + einput4B_{PP} \% Power$$

$$\Sigma e4B = \pm 0 * (125/100) + 0.82 \% Power$$

$$\Sigma e4B = \pm 0.82\% Power$$

And

$$\Sigma e4B_{LP} = \pm \Sigma e4B_{CS} * (125/100) + einput4B_{PP(LP)} \% Power$$

$$\Sigma e4B_{LP} = \pm 0 * (125/100) + 0.33 \% Power$$

$$\Sigma e4B_{LP} = \pm 0.33\% Power$$

And

$$\Sigma e4B_{AV} = \pm \Sigma e4B_{CS} * (125/100) + einput4B_{AV} \% Power$$

$$\Sigma e4B_{AV} = \pm 0 * (125/100) + 0 \% Power$$

$$\Sigma e4B_{AV} = \pm 0\% Power$$

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345		PAGE 101 of 191
<p>11.4.3 Module 4C (Trip Circuits - Fixed)</p> <p><u>Classification of Module</u></p> <p>Module 4C receives an analog input from the Averaging Circuitry and provides a bistable output, the state of which depends on the relative magnitudes of the input signal and the reference value. Therefore, Module 4C is a bistable module.</p> <p>11.4.3.1 Module 4C Random Error (σ_{4C})</p> <p>This section addresses random uncertainties that have the potential to be expressed in the output of Module 4C.</p> <p>11.4.3.1.1 Reference Accuracy (RA4C)</p> <p>Per Section 8.4.1 the reference accuracy for this module is:</p> $RA4C = 1\% \text{ CS}$ <p>Per Assumption 5.1, this is assumed to be a 2 sigma value. This is then converted to a 1 sigma value by dividing by 2. In the same step this will be converted to % Power by multiplying by 125/100.</p> $RA4C_{(1\sigma)} = \pm(RA4C/2) * (125/100) \% \text{ Power}$ $RA4C_{(1\sigma)} = \pm(1/2) * (125/100) \% \text{ Power}$ $RA4C_{(1\sigma)} = \pm 0.625\% \text{ Power}$ <p>11.4.3.1.2 Drift (RD4C)</p> <p>Per Section 8.4.1 the reference drift for this module is:</p> $RD4C = 1\% \text{ CS}/700 \text{ HRS}$ <p>Tables 4.3.1.1-1 and 4.3.6-1 of Reference 3.7 give the surveillance interval (RD4CTSI) for all trip functions as 26 weeks (semi-annually). In addition, a 25% late factor will be added to the required value. Per Reference 3.8 drift is considered a random function and can be extended to a longer period by the square root of the ratio of the time periods per Section 2.2.5 of Reference 3.13.</p> <p>Per Assumption 5.1, the drift value is assumed to be a 2 sigma value. This is then converted to a 1 sigma value by dividing by 2, and then to % Power by multiplying by</p>		
REVISION NO.	0	

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 102 of 191

125/100. RD4CTSI is converted to hours by multiplying by 168. The one sigma drift is then:

$$RD4C_{(1\sigma)} = \pm (RD4C/2) * (125/100) * [(1.25 * RD4CTSI * 168) / RD4CT]^{0.5} \% \text{ Power}$$

$$RD4C_{(1\sigma)} = \pm (1/2) * (125/100) * [(1.25 * 26 * 168) / 700]^{0.5} \% \text{ Power}$$

$$RD4C_{(1\sigma)} = \pm 1.74553 \% \text{ Power}$$

11.4.3.1.3 Calibration Uncertainty (CAL4C)

The uncertainties associated with calibrating the trip circuits are composed entirely of the uncertainties associated with the DMM used to set the input trip voltage. Per the applicable procedures of Reference 3.5 a Fluke Model 8500A is specified for this function. From Section 9.1 the error associated with this instrument is 0.00018 Vdc (RAMTE1_{4C}). Since this is a digital instrument REMTE1_{4C} is equal to zero.

From Reference 3.3,

$$MTE1 = [(RAMTE1/n)^2 + REMTE1^2]^{0.5}$$

where n is the number of standard deviations applicable to the error term. The values of the error terms from Reference 9.1 are already expressed in one sigma terms. Therefore, the value of n is 1.

$$MTE1_{4C} = \pm [(RAMTE1_{4C}/1)^2 + REMTE1_{4C}^2]^{0.5} \text{ Vdc}$$

$$MTE1_{4C} = \pm [(0.00018/1)^2 + 0^2]^{0.5} \text{ Vdc}$$

$$MTE1_{4C} = \pm 0.00018 \text{ Vdc}$$

This can be converted to % Power by dividing by the voltage span (SPAN4CIN) and multiplying by the full scale power (125).

$$MTE1_{4C(PP)} = \pm [(MTE1_{4C}/SPAN4CIN) * 125] \% \text{ Power}$$

$$MTE1_{4C(PP)} = \pm [(0.00018/10) * 125] \% \text{ Power}$$

$$MTE1_{4C(PP)} = \pm 0.00225 \% \text{ Power}$$

From Section 5.2 the errors attributed to the calibration standards are considered negligible. Therefore, the only term which contributes to CAL4C is the MTE1 term.

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 103 of 191

Therefore, for this section

$$CAL4C = \pm MTE1_{4C(PP)} = \pm 0.00225\% \text{ Power}$$

11.4.3.1.4 Setting Tolerance (ST4C)

The setting tolerance listed in the applicable procedures of Reference 3.5 for this function is 0.04 Vdc. This can be converted to % Power by dividing by the voltage span (SPAN4CIN) and multiplying by the full scale power (125).

From Section 2.1.a the given setting tolerances are considered 3 sigma values. Therefore, ST4C must be divided by 3 to make it compatible with the other 1 sigma error terms. Combining this operation with the conversion to percent power gives

$$ST4C_{(1\sigma)} = \pm [(ST4C/SPAN4CIN) * 125] / 3 \% \text{ Power}$$

$$ST4C_{(1\sigma)} = \pm [(0.04/10) * 125] / 3 \% \text{ Power}$$

$$ST4C_{(1\sigma)} = \pm 0.166667\% \text{ Power}$$

11.4.3.1.5 Input Uncertainty ($\sigma_{input4C}$ and $\sigma_{input4C_{LP}}$)

In addition to its own error terms, the error terms from Module 4B must also be considered. Since the trip circuits perform no function on the input signal $\sigma_{input4C}$ and $\sigma_{input4C_{LP}}$ become equal to the random input terms σ_{4B} and $\sigma_{4B_{LP}}$ respectively.

$$\sigma_{input4C} = \pm \sigma_{4B} = \pm 1.570686\% \text{ Power}$$

And

$$\sigma_{input4C_{LP}} = \pm \sigma_{4B_{LP}} = \pm 1.076582\% \text{ Power}$$

And

$$\sigma_{input4C_{AV}} = \pm \sigma_{4B_{AV}} = \pm 1.04151\% \text{ Power}$$

11.4.3.1.6 Determination of Module Random Error (σ_{4C} , $\sigma_{4C_{AV}}$, and $\sigma_{4C_{LP}}$)

Using the methodology of Reference 3.3,

$$\sigma_{4C} = \pm [(\sigma_{RA4C_{(1\sigma)}})^2 + (\sigma_{RD4C_{(1\sigma)}})^2 + (CAL4C)^2 + (ST4C_{(1\sigma)})^2 + (\sigma_{input4C})^2]^{0.5} \% \text{ Power}$$

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 104 of 191

$$\sigma 4C = \pm [(0.625)^2 + (1.74553)^2 + (0.00225)^2 + (0.166667)^2 + (1.570686)^2]^{0.5} \% \text{ Power}$$

$$\sigma 4C = \pm 2.435639\% \text{ Power}$$

And

$$\sigma 4C_{LP} = \pm [(RA4C_{(1\sigma)})^2 + (RD4C_{(1\sigma)})^2 + (CAL4C)^2 + (ST4C_{(1\sigma)})^2 + (\sigma_{input4C_{LP}})^2]^{0.5} \% \text{ Power}$$

$$\sigma 4C_{LP} = \pm [(0.625)^2 + (1.74553)^2 + (0.00225)^2 + (0.166667)^2 + (1.076582)^2]^{0.5} \% \text{ Power}$$

$$\sigma 4C_{LP} = \pm 2.150421\% \text{ Power}$$

And

$$\sigma 4C_{AV} = \pm [(RA4C_{(1\sigma)})^2 + (RD4C_{(1\sigma)})^2 + (CAL4C)^2 + (ST4C_{(1\sigma)})^2 + (\sigma_{input4C_{AV}})^2]^{0.5} \% \text{ Power}$$

$$\sigma 4C_{AV} = \pm [(0.625)^2 + (1.74553)^2 + (0.00225)^2 + (0.166667)^2 + (1.04151)^2]^{0.5} \% \text{ Power}$$

$$\sigma 4C_{AV} = \pm 2.133079\% \text{ Power}$$

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345		PAGE 105 of 191	
<p>11.4.3.2 Module 4C Non-Random Errors ($\Sigma e4C$, $\Sigma e4C_{AV}$, and $\Sigma e4C_{LP}$)</p> <p>11.4.3.2.1 Humidity Errors ($e4CH$)</p> <p>Since Reference 3.11 does not identify a humidity error term a value of zero will be used per Section 4.3.</p> <p>$e4CH = 0\% \text{ CS}$</p> <p>11.4.3.2.2 Temperature Error ($e4CT$)</p> <p>Since Reference 3.11 does not identify a temperature error term a value of zero will be used per Section 4.3.</p> <p>$e4CT = 0\% \text{ CS}$</p> <p>11.4.3.2.3 Radiation Error ($e4CR$)</p> <p>Since Reference 3.11 does not identify a radiation error term a value of zero will be used per Section 4.3.</p> <p>$e4CR = 0\% \text{ CS}$</p> <p>11.4.3.2.4 Seismic Error ($e4CS$)</p> <p>Per Section 4.7 seismic error for this module is considered negligible.</p> <p>$e4CS = 0\% \text{ CS}$</p> <p>11.4.3.2.5 Static Pressure Effect ($e4CSP$)</p> <p>This module is an all electronic device that is not exposed to any pressure other than atmospheric. Therefore, there is no static pressure effect.</p> <p>$e4CSP = 0\% \text{ CS}$</p> <p>11.4.3.2.6 Pressure Error ($e4CP$)</p> <p>This module is an all electronic device that is not exposed to any pressure other than atmospheric. Therefore, there is no pressure effect.</p> <p>$e4CP = 0\% \text{ CS}$</p>			
REVISION NO.	0		

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 106 of 191

11.4.3.2.7 Process Errors (e4Cp)

This module is intermediate in the loop and, as such, is not exposed to any process parameters. Therefore, there are no process errors.

$$e4Cp = 0\% \text{ CS}$$

11.4.3.2.8 Power Supply Effects (e4CV)

Since Reference 3.11 does not identify a power supply effect error term a value of zero will be used per Section 4.3.

$$e4CV = 0\% \text{ CS}$$

11.4.3.2.9 Non-Random Input Error (einput4C and einput4C_{LP})

In addition to its own error terms, the error terms from Module 4B must also be considered. Since the trip circuits perform no function on the input signal, einput4C and einput4C_{LP} become equal to the non-random input terms $\Sigma e4B$ and $\Sigma e4B_{LP}$ respectively.

$$einput4C = \pm \Sigma e4B = \pm 0.82\% \text{ Power}$$

And

$$einput4C_{LP} = \pm \Sigma e4B_{LP} = \pm 0.33\% \text{ Power}$$

And

$$einput4C_{AV} = \pm \Sigma e4B_{AV} = \pm 0\% \text{ Power}$$

11.4.3.2.10 Non-Random Error ($\Sigma e4C$)

From Reference 3.3 the non-random error is the algebraic sum of all the above terms. The % CS terms will also be converted to % Power by multiplying by 125/100.

$$\Sigma e4C = \pm (125/100) * (e4CH + e4CT + e4CR + e4CS + e4CSP + e4CP + e4Cp + e4CV) + einput4C\% \text{ Power}$$

$$\Sigma e4C = \pm (125/100) * (0 + 0 + 0 + 0 + 0 + 0 + 0 + 0) + 0.82\% \text{ Power}$$

$$\Sigma e4C = \pm 0.82\% \text{ Power}$$

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 107 of 191

And

$$\Sigma e4C_{LP} = \pm(125/100) * (e4CH + e4CT + e4CR + e4CS + e4CSP + e4CP + e4Cp + e4CV) + einput4C_{LP} \% \text{ Power}$$

$$\Sigma e4C_{LP} = \pm(125/100) * (0 + 0 + 0 + 0 + 0 + 0 + 0 + 0) + 0.33 \% \text{ Power}$$

$$\Sigma e4C_{LP} = \pm 0.33 \% \text{ Power}$$

And

$$\Sigma e4C_{AV} = \pm(125/100) * (e4CH + e4CT + e4CR + e4CS + e4CSP + e4CP + e4Cp + e4CV) + einput4C_{AV} \% \text{ Power}$$

$$\Sigma e4C_{AV} = \pm(125/100) * (0 + 0 + 0 + 0 + 0 + 0 + 0 + 0) + 0 \% \text{ Power}$$

$$\Sigma e4C_{AV} = \pm 0 \% \text{ Power}$$

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345		PAGE 108 of 191
<p>11.4.4 Module 4D (Trip Circuit - Flow Biased)</p> <p><u>Classification of Module</u></p> <p>Module 4D receives an analog input from the Averaging Circuitry and the Flow Summer (Module 3), and provides a bistable output, the state of which depends on the relative magnitudes of the input signal from the Averaging Circuitry and the reference value, which is a function of the Flow Summer signal. Therefore, Module 4D is a bistable module.</p> <p>11.4.4.1 Module 4D Random Error (σ_{4D})</p> <p>This section addresses random uncertainties that have the potential to be expressed in the output of Module 4D.</p> <p>11.4.4.1.1 Reference Accuracy (RA4D)</p> <p>Per Section 8.4.1 the reference accuracy for this module is:</p> <p style="margin-left: 40px;">$RA_{4D} = 1\% \text{ CS}$</p> <p>Per Assumption 5.1, this is assumed to be a 2 sigma value. This is then converted to a 1 sigma value by dividing by 2. In the same step this will be converted to % Power by multiplying by 125/100.</p> <p style="margin-left: 40px;">$RA_{4D(1\sigma)} = \pm(RA_{4D}/2) * (125/100) \% \text{ Power}$</p> <p style="margin-left: 40px;">$RA_{4D(1\sigma)} = \pm(1/2) * (125/100) \% \text{ Power}$</p> <p style="margin-left: 40px;">$RA_{4D(1\sigma)} = \pm 0.625\% \text{ Power}$</p> <p>11.4.4.1.2 Drift (RD4D)</p> <p>Per Section 8.4.1 the reference drift for this module is:</p> <p style="margin-left: 40px;">$RD_{4D} = 1\% \text{ CS}/700 \text{ HRS}$</p> <p>Table 4.3.1.1-1 and 4.3.6-1 of Reference 3.7 give the surveillance interval (RD4DTSI) for all trip functions as 26 weeks (semi-annually). In addition, a 25% late factor will be added to the required value. Per Reference 3.8 drift is considered a random function and can be extended to a longer period by the square root of the ratio of the time periods per Section 2.2.5 of Reference 3.13.</p> <p>Per Assumption 5.1, the drift value is assumed to be a 2 sigma value. This is then converted to a 1 sigma value by</p>		
REVISION NO.	0	

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 109 of 191

dividing by 2, and then to % Power by multiplying by 125/100. RD4DTSI is converted to hours by multiplying by 168. The one sigma drift is then:

$$RD4D_{(1\sigma)} = \pm (RD4D/2) * (125/100) * [(1.25 * RD4DTSI * 168) / RD4DT]^{0.5} \% \text{ Power}$$

$$RD4D_{(1\sigma)} = \pm (1/2) * (125/100) * [(1.25 * 26 * 168) / 700]^{0.5} \% \text{ Power}$$

$$RD4D_{(1\sigma)} = \pm 1.74553 \% \text{ Power}$$

11.4.4.1.3 Calibration Uncertainty (CAL4D)

The uncertainties associated with calibrating the trip circuits are composed entirely of the uncertainties associated with the DMM used to set the input trip voltage. Per the applicable procedures of Reference 3.5 a Fluke Model 8500A is specified for this function. From Section 9.1 the error associated with this instrument is 0.00018 Vdc (RAMTE1_{4D}). Since this is a digital instrument REMTE1_{4D} is equal to zero.

From Reference 3.3,

$$MTE1 = [(RAMTE1/n)^2 + REMTE1^2]^{0.5}$$

where n is the number of standard deviations applicable to the error term. The values of the error terms from Reference 9.1 are already expressed in one sigma terms. Therefore, the value of n is 1.

$$MTE1_{4D} = \pm [(RAMTE1_{4D}/1)^2 + REMTE1_{4D}^2]^{0.5} \text{ Vdc}$$

$$MTE1_{4D} = \pm [(0.00018/1)^2 + 0^2]^{0.5} \text{ Vdc}$$

$$MTE1_{4D} = \pm 0.00018 \text{ Vdc}$$

This can be converted to % Power by dividing by the voltage span (SPAN4CIN - Both Fixed and Flow Biased trips have the same input span) and multiplying by the full scale power (125).

$$MTE1_{4D(PP)} = \pm [(MTE1_{4D}/SPAN4CIN) * 125] \% \text{ Power}$$

$$MTE1_{4D(PP)} = \pm [(0.00018/10) * 125] \% \text{ Power}$$

$$MTE1_{4D(PP)} = \pm 0.00225 \% \text{ Power}$$

From Section 5.2 the errors attributed to the calibration

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 110 of 191

standards are considered negligible. Therefore, the only term which contributes to CAL4D is the MTE1 term. Therefore, for this section

$$CAL4D = \pm MTE1_{4D(PP)} = \pm 0.00225\% \text{ Power}$$

11.4.4.1.4 Setting Tolerance (ST4D)

The setting tolerance listed in the applicable procedures for this function is 0.04 Vdc. This can be converted to % Power by dividing by the voltage span (SPAN4CIN) and multiplying by the full scale power (125). From Section 2.1.a the given setting tolerances are considered 3 sigma values. Therefore, ST4D must be divided by 3 to make it compatible with the other 1 sigma error terms. Combining this operation with the conversion to percent power gives

$$ST4D_{(1\sigma)} = \pm [(ST4D/SPAN4CIN) * 125] / 3 \% \text{ Power}$$

$$ST4D_{(1\sigma)} = \pm [(0.04/10) * 125] / 3 \% = \pm 0.166667\% \text{ Power}$$

11.4.4.1.5 Input Uncertainty ($\sigma_{input4D}$)

The Module 4D input error ($\sigma_{input4D}$) is the SRSS combination of random input terms from Module 4B ($\sigma_{4B_{FB}}$) and Module 3 (σ_3). However, σ_3 must be converted from % Flow to % Power using the flow biased trip slope adjustment from Section 2.2 which accounts for setting uncertainties.

11.4.4.1.5.1 Two Loop Operation (TLO) - From Design Input 4.14, the TLO flow biased slope (FCS_{SP}) is 0.62 which is adjusted as

$$\begin{aligned} FCS &= FCS_{SP} + [(0.04+0.04)/0.08]/80 \\ &= 0.62 + [(0.04+0.04)/0.08]/80 = 0.6325 \end{aligned}$$

The module 4D input uncertainty for TLO is determined as

$$\begin{aligned} \sigma_{input4D} &= \pm [\sigma_{4B_{FB}}^2 + (FCS * \sigma_3)^2]^{0.5} \\ \sigma_{input4D} &= \pm [1.21122^2 + (0.6325 * 2.546521)^2]^{0.5} \end{aligned}$$

$$\sigma_{input4D} = \pm 2.015273\% \text{ Power}$$

And the module 4D AV uncertainty for TLO is determined as

$$\begin{aligned} \sigma_{input4D_{AV}} &= \pm [\sigma_{4B_{AV}}^2 + (FCS * \sigma_{3C})^2]^{0.5} \\ \sigma_{input4D_{AV}} &= \pm [(1.041510)^2 + (0.6325 * 1.669197)^2]^{0.5} \end{aligned}$$

$$\sigma_{input4D_{AV}} = \pm 1.483033\% \text{ Power}$$

REVISION NO.

0

2

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 111 of 191

11.4.4.1.5.2 Single Loop Operation (SLO) - From Design Input 4.14, the SLO flow biased slope (FCS_{SPSLO}) is 0.55 which is adjusted as

$$\begin{aligned} FCS_{SLO} &= FCS_{SPSLO} + [(0.04+0.04)/0.08]/80 \\ &= 0.55 + [(0.04+0.04)/0.08]/80 = 0.5625 \end{aligned}$$

The module 4D input uncertainty for SLO is determined as

$$\begin{aligned} \sigma_{input4D_{SLO}} &= \pm[\sigma 4B_{FB}^2 + (FCS_{SLO} * \sigma 3)^2]^{0.5} \\ \sigma_{input4D_{SLO}} &= \pm\{1.21122^2 + [(0.5625) * (2.546521)]^2\}^{0.5} \\ \sigma_{input4D_{SLO}} &= \pm 1.875867\% \text{ Power} \end{aligned}$$

And the module 4D AV uncertainty for SLO is determined as

$$\begin{aligned} \sigma_{input4D_{AVSLO}} &= \pm[\sigma 4B_{AV}^2 + (FCS_{SLO} * \sigma 3_c)^2]^{0.5} \\ \sigma_{input4D_{AVSLO}} &= \pm[(1.041510)^2 + (0.5625 * 1.669197)^2]^{0.5} \\ \sigma_{input4D_{AVSLO}} &= \pm 1.402255\% \text{ Power} \end{aligned}$$

11.4.4.1.6 Determination of Module Random Error

11.4.4.1.6.1 Two Loop Operation - Total module 4D random error is

$$\begin{aligned} \sigma 4D &= \pm[RA4D_{(1\sigma)}^2 + RD4D_{(1\sigma)}^2 + CAL4D^2 + ST4D_{(1\sigma)}^2 + \sigma_{input4D}^2]^{0.5} \\ \sigma 4D &= \pm[0.625^2 + 1.74553^2 + 0.00225^2 + 0.166667^2 + 2.015273^2]^{0.5} \\ \sigma 4D &= \pm 2.743466\% \text{ Power} \end{aligned}$$

And the module 4D AV random error is

$$\begin{aligned} \sigma 4D_{AV} &= \pm[RA4D_{(1\sigma)}^2 + RD4D_{(1\sigma)}^2 + CAL4D^2 + ST4D_{(1\sigma)}^2 + \sigma_{input4D_{AV}}^2]^{0.5} \\ \sigma 4D_{AV} &= \pm[0.625^2 + 1.74553^2 + 0.00225^2 + 0.166667^2 + 1.483033^2]^{0.5} \\ \sigma 4D_{AV} &= \pm 2.380057\% \text{ Power} \end{aligned}$$

11.4.4.1.6.2 Single Loop Operation - Total module 4D random error is

$$\begin{aligned} \sigma 4D_{SLO} &= \pm[RA4D_{(1\sigma)}^2 + RD4D_{(1\sigma)}^2 + CAL4D^2 + ST4D_{(1\sigma)}^2 + \sigma_{input4D_{SLO}}^2]^{0.5} \\ \sigma 4D_{SLO} &= \pm[0.625^2 + 1.74553^2 + 0.00225^2 + 0.166667^2 + 1.875867^2]^{0.5} \\ \sigma 4D_{SLO} &= \pm 2.642756\% \text{ Power} \end{aligned}$$

And the module 4D AV random error is

$$\begin{aligned} \sigma 4D_{AVSLO} &= \pm[RA4D_{(1\sigma)}^2 + RD4D_{(1\sigma)}^2 + CAL4D^2 + ST4D_{(1\sigma)}^2 + \sigma_{input4D_{AVSLO}}^2]^{0.5} \\ \sigma 4D_{AVSLO} &= \pm[0.625^2 + 1.74553^2 + 0.00225^2 + 0.166667^2 + 1.402255^2]^{0.5} \\ \sigma 4D_{AVSLO} &= \pm 2.330580\% \text{ Power} \end{aligned}$$

REVISION NO.

0

2

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345		PAGE 112 of 191
<p>11.4.4.2 Module 4D Non-Random Errors (Σe_{4D})</p> <p>11.4.4.2.1 Humidity Errors (e_{4DH})</p> <p style="margin-left: 40px;">Since Reference 3.11 does not identify a humidity error term a value of zero will be used per Section 4.3.</p> <p style="margin-left: 80px;">$e_{4DH} = 0\% \text{ CS}$</p> <p>11.4.4.2.2 Temperature Error (e_{4DT})</p> <p style="margin-left: 40px;">Since Reference 3.11 does not identify a temperature error term a value of zero will be used per Section 4.3.</p> <p style="margin-left: 80px;">$e_{4DT} = 0\% \text{ CS}$</p> <p>11.4.4.2.3 Radiation Error (e_{4DR})</p> <p style="margin-left: 40px;">Since Reference 3.11 does not identify a radiation error term a value of zero will be used per Section 4.3.</p> <p style="margin-left: 80px;">$e_{4DR} = 0\% \text{ CS}$</p> <p>11.4.4.2.4 Seismic Error (e_{4DS})</p> <p style="margin-left: 40px;">Per Section 4.7 seismic error for this module is considered negligible.</p> <p style="margin-left: 80px;">$e_{4DS} = 0\% \text{ CS}$</p> <p>11.4.4.2.5 Static Pressure Effect (e_{4DSP})</p> <p style="margin-left: 40px;">This module is an all electronic device that is not exposed to any pressure other than atmospheric. Therefore, there is no static pressure effect.</p> <p style="margin-left: 80px;">$e_{4DSP} = 0\% \text{ CS}$</p> <p>11.4.4.2.6 Pressure Error (e_{4DP})</p> <p style="margin-left: 40px;">This module is an all electronic device that is not exposed to any pressure other than atmospheric. Therefore, there is no pressure effect.</p> <p style="margin-left: 80px;">$e_{4DP} = 0\% \text{ CS}$</p>		
REVISION NO.	0	

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345		PAGE 113 of 191
<p>11.4.4.2.7 Process Errors (e4Dp)</p> <p>This module is intermediate in the loop and, as such, is not exposed to any process parameters. Therefore, there are no process errors.</p> <p>$e4Dp = 0\% \text{ CS}$</p> <p>11.4.4.2.8 Power Supply Effects (e4DV)</p> <p>Since Reference 3.11 does not identify a power supply effect error term a value of zero will be used per Section 4.3.</p> <p>$e4DV = 0\% \text{ CS}$</p> <p>11.4.4.2.9 Non-Random Input Error (einput4D)</p> <p>The module 4D input error (einput4D) is equal to the combination by algebraic addition of the non-random input terms from Module 4B ($\Sigma e4B$) and Module 3 ($\Sigma e3$). However, $\Sigma e3$ must be converted from % Flow to % Power using the same flow biased trip slope adjustments determined in Section 11.4.4.1.5.</p> <p>11.4.4.2.9.1 Two Loop Operation (TLO) - Using the FCS determined in Section 11.4.4.1.5.1, the module 4D input error for TLO is determined as</p> <p>$einput4D = \pm [\Sigma e4B + (FCS * \Sigma e3)]$ $einput4D = \pm [0.82 + (0.632500 * 1.274635)]$ $einput4D = \pm 1.626207\% \text{ Power}$ <p>And the module 4D AV error for TLO is determined as</p> <p>$einput4D_{AV} = \pm [\Sigma e4B_{AV} + (FCS * \Sigma e3)]$ $einput4D_{AV} = \pm [0 + (0.632500 * 1.274635)]$ $einput4D_{AV} = \pm 0.806207\% \text{ Power}$ <p>11.4.4.2.9.2 Single Loop Operation (SLO) - Using the FCS determined in Section 11.4.4.1.5.2, the module 4D input error for SLO is determined as</p> <p>$einput4D_{SLO} = \pm [\Sigma e4B + (FCS * \Sigma e3)]$ $einput4D_{SLO} = \pm [0.82 + (0.562500 * 1.274635)]$ $einput4D_{SLO} = \pm 1.536982\% \text{ Power}$</p> </p></p>		
REVISION NO.	0	2

COMMONWEALTH EDISON COMPANY

946

CALCULATION NO. L-001345

PAGE 114 of 191

And the module 4D AV error for SLO is determined as

$$\begin{aligned} \text{einput4D}_{\text{AVSLO}} &= \pm[\Sigma \text{e4B}_{\text{AV}} + (\text{FCS} * \Sigma \text{e3})] \\ \text{einput4D}_{\text{AVSLO}} &= \pm[0 + (0.562500 * 1.274635)] \\ \text{einput4D}_{\text{AVSLO}} &= \pm 0.716982\% \text{ Power} \end{aligned}$$

11.4.4.2.10 Module 4D Non-Random Error (Σe4D)

11.4.4.2.10.1 Two Loop Operation (TLO) - the module 4D total random error for TLO is

$$\begin{aligned} \Sigma \text{e4D} &= \pm(125/100) * (\text{e4DH} + \text{e4DT} + \text{e4DR} + \text{e4DS} + \text{e4DSP} + \\ &\quad \text{e4DP} + \text{e4Dp} + \text{e4DV}) + \text{einput4D} \\ \Sigma \text{e4D} &= \pm(125/100) * (0 + 0 + 0 + 0 + 0 + 0 + 0 + 0) + 1.626207 \\ \Sigma \text{e4D} &= \pm 1.626207 \% \text{ Power} \end{aligned}$$

And the module 4D AV error for TLO is determined as

$$\begin{aligned} \Sigma \text{e4D}_{\text{AV}} &= \pm(125/100) * (\text{e4DH} + \text{e4DT} + \text{e4DR} + \text{e4DS} + \text{e4DSP} + \\ &\quad \text{e4DP} + \text{e4Dp} + \text{e4DV}) + \text{einput4D}_{\text{AV}} \\ \Sigma \text{e4D}_{\text{AV}} &= \pm(125/100) * (0 + 0 + 0 + 0 + 0 + 0 + 0 + 0) + 0.806207 \\ \Sigma \text{e4D}_{\text{AV}} &= \pm 0.806207 \% \text{ Power} \end{aligned}$$

11.4.4.2.10.2 Single Loop Operation (SLO) - the module 4D total random error for SLO is

$$\begin{aligned} \Sigma \text{e4D}_{\text{SLO}} &= \pm(125/100) * (\text{e4DH} + \text{e4DT} + \text{e4DR} + \text{e4DS} + \text{e4DSP} + \\ &\quad \text{e4DP} + \text{e4Dp} + \text{e4DV}) + \text{einput4D}_{\text{SLO}} \\ \Sigma \text{e4D}_{\text{SLO}} &= \pm(125/100) * (0 + 0 + 0 + 0 + 0 + 0 + 0 + 0) + 1.536982 \\ \Sigma \text{e4D}_{\text{SLO}} &= \pm 1.536982 \% \text{ Power} \end{aligned}$$

And the module 4D AV error for SLO is determined as

$$\begin{aligned} \Sigma \text{e4D}_{\text{AVSLO}} &= \pm(125/100) * (\text{e4DH} + \text{e4DT} + \text{e4DR} + \text{e4DS} + \text{e4DSP} + \\ &\quad \text{e4DP} + \text{e4Dp} + \text{e4DV}) + \text{einput4D}_{\text{AVSLO}} \\ \Sigma \text{e4D}_{\text{AVSLO}} &= \pm(125/100) * (0 + 0 + 0 + 0 + 0 + 0 + 0 + 0) + 0.716982 \\ \Sigma \text{e4D}_{\text{AVSLO}} &= \pm 0.716982 \% \text{ Power} \end{aligned}$$

REVISION NO.

0

2

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 115 of 191

11.5 Module 5 (RBM)

The RBM will be divided into three parts for this calculation; RBM Averaging and Gain Change Circuitry, Trip Circuits (Fixed), and Trip Circuits (Flow Biased). These will be designated Module 5A, 5B, and 5C respectively. This separation is performed for convenience and because the calibration procedures of Reference 3.5 effectively make this separation.

11.5.1 Module 5A (RBM Averaging and Gain Change Circuitry)

Classification of Module

Module 5A receives analog inputs from multiple LPRM cards. These signals are averaged and then operated on by the Gain Change Circuitry resulting in an analog output that is some multiple of the average of the input signals. Therefore, Module 5A is an analog module.

11.5.1.1 Module 5A Random Error (σ_{5A})

This section addresses random uncertainties that have the potential to be expressed in the output of Module 5A.

11.5.1.1.1 Reference Accuracy (RA_{5A})

Per Section 8.5.1 the reference accuracy for this module is:

$$RA_{5A} = 0.8\% \text{ CS}$$

The vendor also lists another accuracy term called "Accuracy of Null". This is the accuracy with which the RBM can adjust its gain so that its output is equal to the output of the reference APRM. The value for this term is:

$$RA_{5A_{NULL}} = \pm 1\% \text{ of Point}$$

Since the maximum power at which the RBM is used is essentially 100% Power, this nulling error represents a maximum of 1% Power which can be converted to % CS by multiplying by 100/125. The nulling error and the reference accuracy can be combined using SRSS.

Per Assumption 5.1, these are assumed to be 2 sigma values. They are then converted to 1 sigma values by dividing by 2.

$$RA_{5A_{(1\sigma)}} = \pm \{ (RA_{5A}/2)^2 + [(100/125) * (RA_{5A_{NULL}}/2)]^2 \}^{0.5} \text{ CS}$$

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 116 of 191

$$RA5A_{(1\sigma)} = \pm \{ (0.8/2)^2 + [(100/125) * (1/2)]^2 \}^{0.5} \% \text{ CS}$$

$$RA5A_{(1\sigma)} = \pm 0.565685\% \text{ CS}$$

11.5.1.1.2 Drift (RD5A)

Per Section 8.5.1 the reference drift for this module is:

$$RD5A = 0.3\% \text{ CS/4 Hrs}$$

The RBM automatically performs a gain adjustment each time a control rod is selected. This control rod selection process occurs much more frequently than the drift interval. Therefore, per Section 2.1.b the vendor drift data can be used as is. Per Assumption 5.1, RD5A is assumed to be a 2 sigma value. This will be converted to a 1 sigma value by dividing by 2.

$$RD5A_{(1\sigma)} = \pm (RD5A/2) \% \text{ CS}$$

$$RD5A_{(1\sigma)} = \pm (0.3/2) \% \text{ CS}$$

$$RD5A_{(1\sigma)} = \pm 0.15\% \text{ CS}$$

11.5.1.1.3 Calibration Uncertainty (CAL5A)

The uncertainties associated with calibrating the RBM Averaging and Gain Change Circuitry are composed entirely of the uncertainties associated with the DMM used to measure the zero offset of the amplifier on the Driver Card. Per the applicable procedures of Reference 3.5 a Fluke Model 8500A is specified for this function. From Section 9.1 the error associated with this instrument is 0.00018 Vdc (RAMTE1_{5A}). Since this is a digital instrument REMTE1_{5A} is equal to zero.

From Reference 3.3,

$$MTE1 = [(RAMTE1/n)^2 + REMTE1^2]^{0.5}$$

where n is the number of standard deviations applicable to the error term. The values of the error terms from Reference 9.1 are already expressed in one sigma terms. Therefore, the value of n is 1.

$$MTE1_{5A} = \pm [(RAMTE1_{5A}/1)^2 + REMTE1_{5A}^2]^{0.5} \text{ Vdc}$$

$$MTE1_{4C} = \pm [(0.00018/1)^2 + 0^2]^{0.5} \text{ Vdc}$$

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 117 of 191

$$MTE1_{4C} = \pm 0.00018 \text{ Vdc}$$

From Section 5.2 the errors attributed to the calibration standards are considered negligible. Therefore, the only term which contributes to CAL5A is MTE1. In order to convert CAL5A to % CS, $MTE1_{5A}$ will be divided by the RBM span ($SPAN_{RBM}$) and multiplied by 100. For this calculation

$$CAL5A = \pm (MTE1_{5A} / SPAN_{RBM}) * 100 \% \text{ CS}$$

$$CAL5A = \pm (0.00018 / 10) * 100 \% \text{ CS}$$

$$CAL5A = \pm 0.0018 \% \text{ CS}$$

11.5.1.1.4 Setting Tolerance ($ST5A$)

The setting tolerance for the RBM Averaging and Gain Change Circuitry calibration is the allowance in setting the zero offset of the amplifier on the Driver Card. From the applicable procedures in Reference 3.5 this allowance ($ST5A$) is $\pm 0.025 \text{ Vdc}$. This can be converted to % CS by dividing by the RBM span ($SPAN_{RBM}$) and multiplying by 100.

From Section 2.1.a the given setting tolerances are considered 3 sigma values. Therefore, $ST5A$ must be divided by 3 to make it compatible with the other 1 sigma error terms. Combining this operation with the conversion to percent calibrated span gives

$$ST5A_{(1\sigma)} = \pm [(ST5A / SPAN_{RBM}) * 100] / 3 \% \text{ CS}$$

$$ST5A_{(1\sigma)} = \pm [(0.025 / 10) * 100] / 3 \% \text{ CS}$$

$$ST5A_{(1\sigma)} = \pm 0.083333 \% \text{ CS}$$

11.5.1.1.5 Process Measurement Accuracy (PMA_{RBM})

Section 4.5 of Reference 3.13 contains an error term called PMA of which part is applicable to the RBMs. Although primarily applicable to large and rapid transient events, the tracking portion of this error is considered applicable to the RBM. Therefore,

$$PMA_{RBM} = \pm 1.11 \% \text{ Power}$$

This is considered to be a 2 sigma value and must be divided by 2 in order to make it compatible with the other error terms.

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 118 of 191

$$PMA_{RBM(1\sigma)} = \pm PMA_{RBM}/2 \text{ \% Power}$$

$$PMA_{RBM(1\sigma)} = \pm 1.11/2 \text{ \% Power}$$

$$PMA_{RBM(1\sigma)} = \pm 0.555\% \text{ Power}$$

Per Reference 3.3 process terms are not to be included in the Allowable Value determination. Therefore,

$$PMA_{RBM(AV)} = 0\% \text{ Power}$$

11.5.1.1.6 Input Uncertainty ($\sigma_{input5A}$)

In addition to its own error terms, Module 5A also operates on the error terms from Module 4A. Therefore, the random error terms σ_{4A} , $\sigma_{4A_{PP}}$, $\sigma_{input4A_{AV}}$, and $\sigma_{input4A}$ from the LPRMs must be transferred through the Averaging and Gain Change Circuitry. The resultant term will be $\sigma_{input5A}$ for this module.

Since σ_{4A} is in % CS and $\sigma_{4A_{PP}}$, $\sigma_{input4A_{AV}}$, and $\sigma_{input4A}$ are in % power they term must be treated differently when being transferred through the Averaging and Gain Change Circuitry.

If N LPRMs are being averaged the gain associated with each LPRM through the averaging circuit is $1/N$. This applies to both σ_{4A} and $\sigma_{input4A}$. Following the averaging function there is a gain function (G_{RBM}) that adjusts the RBM output to read the same as the reference APRM (Section 4.8). Since $\sigma_{4A_{PP}}$, $\sigma_{input4A_{AV}}$, and $\sigma_{input4A}$ are in % power and the output is also in % power the gain function has no effect. However, σ_{4A} is in % CS and the gain function has the effect of changing the calibrated span. Therefore, σ_{4A} must be multiplied by G_{RBM} . Based on this discussion then σ_{4A} is propagated through the Averaging and Gain Change Circuitry by the factor G_{RBM}/N_{RBM} while $\sigma_{4A_{PP}}$, $\sigma_{input4A_{AV}}$, and $\sigma_{input4A}$ are only operated on by $1/N_{RBM}$. If the random error terms from N LPRMs are combined by SRSS the result is:

$$\begin{aligned}\sigma_{input5A_{CS}} &= \pm \{N_{RBM} * [\sigma_{4A} * (G_{RBM}/N_{RBM})]^2\}^{0.5} \\ &= \pm (\sigma_{4A} * G_{RBM}) / (N_{RBM})^{0.5} \text{ \% CS}\end{aligned}$$

and

$$\begin{aligned}\sigma_{input5A_{PP}} &= \pm \{N_{RBM} * [(\sigma_{input4A}/N_{RBM})^2 + (\sigma_{4A_{PP}}/N_{RBM})^2]\}^{0.5} \\ \sigma_{input5A_{PP}} &= \pm [(\sigma_{input4A})^2 + (\sigma_{4A_{PP}})^2]^{0.5} / (N_{RBM})^{0.5} \\ &\text{\% Power}\end{aligned}$$

From Section 4.5.6 of Reference 3.10 the minimum number of

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 119 of 191

LPRMs which must be in the average in order for an RBM to be considered operable is 2. Using this value in the above equations gives:

$$\sigma_{\text{input5A}_{\text{CS}}} = \pm (\sigma_{4A} * G_{\text{RBM}}) / (N_{\text{RBM}})^{0.5} \% \text{ CS}$$

$$\sigma_{\text{input5A}_{\text{CS}}} = \pm (0.606904 * 2.5) / 2^{0.5} \% \text{ CS}$$

$$\sigma_{\text{input5A}_{\text{CS}}} = \pm 1.072865 \% \text{ CS}$$

And

$$\sigma_{\text{input5A}_{\text{PP}}} = \pm [(\sigma_{\text{input4A}})^2 + (\sigma_{4A_{\text{PP}}})^2]^{0.5} / (N_{\text{RBM}})^{0.5} \% \text{ Power}$$

$$\sigma_{\text{input5A}_{\text{PP}}} = \pm [(1.019804)^2 + (0.707107)^2]^{0.5} / 2^{0.5} \% \text{ Power}$$

$$\sigma_{\text{input5A}_{\text{PP}}} = \pm 0.877496 \% \text{ Power}$$

And

$$\sigma_{\text{input5A}_{\text{AV}}} = \pm [(\sigma_{\text{input4A}_{\text{AV}}})^2 + (\sigma_{4A_{\text{PP}}})^2]^{0.5} / (N_{\text{RBM}})^{0.5} \% \text{ Power}$$

$$\sigma_{\text{input5A}_{\text{AV}}} = \pm [(0)^2 + (0.707107)^2]^{0.5} / 2^{0.5}$$

$$\sigma_{\text{input5A}_{\text{AV}}} = \pm 0.500000 \% \text{ Power}$$

Since the output of the Averaging and Gain Change Circuitry is the output of the RBM, it is desirable to have the terms in % Power. $\sigma_{\text{input5A}_{\text{CS}}}$ can be converted to % Power by multiplying by the output span (125%) and dividing by 100%. The result is:

$$\sigma_{\text{input5A}_{\text{CS(PP)}}} = \pm \sigma_{\text{input5A}_{\text{CS}}} (125/100) \% \text{ Power}$$

$$\sigma_{\text{input5A}_{\text{CS(PP)}}} = \pm 1.072865 * (125/100) \% \text{ Power}$$

$$\sigma_{\text{input5A}_{\text{CS(PP)}}} = \pm 1.341081 \% \text{ Power}$$

Now that all uncertainty terms are in % Power they may be combined by SRSS.

$$\sigma_{\text{input5A}} = \pm [(\sigma_{\text{input5A}_{\text{PP}}})^2 + (\sigma_{\text{input5A}_{\text{CS(PP)}}})^2]^{0.5} \% \text{ Power}$$

$$\sigma_{\text{input5A}} = \pm [(0.877496)^2 + (1.341081)^2]^{0.5} \% \text{ Power}$$

$$\sigma_{\text{input5A}} = \pm 1.602653 \% \text{ Power}$$

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 120 of 191

And

$$\sigma_{\text{input5AA}_{AV}} = \pm [(\sigma_{\text{input5A}_{AV}})^2 + (\sigma_{\text{input5A}_{CS(PP)}})^2]^{0.5} \% \text{ Power}$$

$$\sigma_{\text{input5AA}_{AV}} = \pm [(0.5)^2 + (1.341081)^2]^{0.5} \% \text{ Power}$$

$$\sigma_{\text{input5AA}_{AV}} = \pm 1.431258 \% \text{ Power}$$

11.5.1.1.7 Determination of Module Random Error (σ_{5A})

Using the methodology of Reference 3.3,

$$\sigma_{5A} = \pm [(\text{RA5A}_{(1\sigma)})^2 + (\text{RD5A}_{(1\sigma)})^2 + (\text{CAL5A})^2 + (\text{ST5A}_{(1\sigma)})^2 + (\text{PMA}_{\text{RBM}(1\sigma)})^2 + (\sigma_{\text{input5A}})^2]^{0.5} \% \text{ CS}$$

However, since σ_{input5A} and $\text{PMA}_{\text{RBM}(1\sigma)}$ are in terms of percent power while the other terms are percent calibrated span, these terms will be removed from the equation until the combination of the first four terms has been performed and the result converted to percent power by multiplying by 125/100. Then this result will be combined with σ_{input5A} and $\text{PMA}_{\text{RBM}(1\sigma)}$ using SRSS. Therefore, for this section the equation for σ_{5AI} is:

$$\sigma_{5AI} = \pm [(\text{RA5A}_{(1\sigma)})^2 + (\text{RD5A}_{(1\sigma)})^2 + (\text{CAL5A})^2 + (\text{ST5A}_{(1\sigma)})^2]^{0.5} \% \text{ CS}$$

$$\sigma_{5AI} = \pm [(0.565685)^2 + (0.15)^2 + (0.0018)^2 + (0.083333)^2]^{0.5} \% \text{ CS}$$

$$\sigma_{5AI} = \pm 0.591141 \% \text{ CS}$$

Converting this to percent power gives:

$$\sigma_{5AI_{PP}} = \pm \sigma_{5AI} * (125/100) \% \text{ Power}$$

$$\sigma_{5AI_{PP}} = \pm 0.591141 * (125/100) \% \text{ Power}$$

$$\sigma_{5AI_{PP}} = \pm 0.738926 \% \text{ Power}$$

Now this can be combined with σ_{input5A} and $\text{PMA}_{\text{RBM}(1\sigma)}$ using SRSS to obtain σ_{5A} .

$$\sigma_{5A} = \pm [(\sigma_{5AI_{PP}})^2 + (\sigma_{\text{input5A}})^2 + (\text{PMA}_{\text{RBM}(1\sigma)})^2]^{0.5} \% \text{ Power}$$

$$\sigma_{5A} = \pm [(0.738926)^2 + (1.602653)^2 + (0.555)^2]^{0.5} \% \text{ Power}$$

$$\sigma_{5A} = \pm 1.850009 \% \text{ Power}$$

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345				PAGE 121 of 191
<p>And</p> $\sigma 5A_{AV} = \pm [(\sigma 5AI_{PP})^2 + (\sigma input 5AA_{AV})^2 + (PMA_{RBM(AV)})^2]^{0.5} \% \text{ Power}$ $\sigma 5A_{AV} = \pm [(0.738926)^2 + (1.431258)^2 + (0)^2]^{0.5} \% \text{ Power}$ $\sigma 5A_{AV} = \pm 1.610749\% \text{ Power}$				
REVISION NO.	0			

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345		PAGE 122 of 191
<p>11.5.1.2 Module 5A Non-Random Errors (Σe_{5A})</p> <p>11.5.1.2.1 Humidity Errors (e_{5AH})</p> <p style="padding-left: 40px;">Since Reference 3.12 does not identify a humidity error term a value of zero will be used per Section 4.3.</p> <p style="padding-left: 80px;">$e_{5AH} = 0\% \text{ CS}$</p> <p>11.5.1.2.2 Temperature Error (e_{5AT})</p> <p style="padding-left: 40px;">Since Reference 3.12 does not identify a temperature error term a value of zero will be used per Section 4.3.</p> <p style="padding-left: 80px;">$e_{5AT} = 0\% \text{ CS}$</p> <p>11.5.1.2.3 Radiation Error (e_{5AR})</p> <p style="padding-left: 40px;">Since Reference 3.12 does not identify a radiation error term a value of zero will be used per Section 4.3.</p> <p style="padding-left: 80px;">$e_{5AR} = 0\% \text{ CS}$</p> <p>11.5.1.2.4 Seismic Error (e_{5AS})</p> <p style="padding-left: 40px;">Per Section 4.7 seismic error for this module is considered negligible.</p> <p style="padding-left: 80px;">$e_{5AS} = 0\% \text{ CS}$</p> <p>11.5.1.2.5 Static Pressure Effect (e_{5ASP})</p> <p style="padding-left: 40px;">This module is an all electronic device that is not exposed to any pressure other than atmospheric. Therefore, there is no static pressure effect.</p> <p style="padding-left: 80px;">$e_{5ASP} = 0\% \text{ CS}$</p> <p>11.5.1.2.6 Pressure Error (e_{5AP})</p> <p style="padding-left: 40px;">This module is an all electronic device that is not exposed to any pressure other than atmospheric. Therefore, there is no pressure effect.</p> <p style="padding-left: 80px;">$e_{5AP} = 0\% \text{ CS}$</p>		
REVISION NO.	0	

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345		PAGE 123 of 191
<p>11.5.1.2.7 Process Errors(e5Ap)</p> <p>This module is intermediate in the loop and, as such, is not exposed to any process parameters. Therefore, there are no process errors other than that previously discussed in Section 11.5.1.1.5.</p> <p style="padding-left: 40px;">e5Ap = 0% CS</p> <p>11.5.1.2.8 Power Supply Effects (e5AV)</p> <p>Since Reference 3.12 does not identify a power supply effect error term a value of zero will be used per Section 4.3.</p> <p style="padding-left: 40px;">e5AV = 0% CS</p> <p>11.5.1.2.9 Non-Random Input Error (einput5A)</p> <p>In addition to its own error terms, Module 5A also operates on the error terms from the LPRMs. The non-random error from the LPRMs was kept in three terms since one is in % CS ($\Sigma e4A$) and the other two in % Power (einput4A and einput4A_{AV}). As was done for the random terms the % CS term must be operated on by the RBM gain (G_{RBM}) whereas the % Power terms are not affected by the gain. For N LPRMs being averaged the result is:</p> <p style="padding-left: 40px;">einput5A_{CS} = $G_{RBM} * N * (1/N) * (\Sigma e4A)$ = $G_{RBM} * \Sigma e4A$ % CS</p> <p style="padding-left: 40px;">einput5A_{CS} = 2.5*0 % CS</p> <p style="padding-left: 40px;">einput5A_{CS} = 0% CS</p> <p>And</p> <p style="padding-left: 40px;">einput5A_{PP} = $N * (1/N) * (einput4A)$ = einput4A % Power</p> <p style="padding-left: 40px;">einput5A_{PP} = 0.82% Power</p> <p>And for the Allowable Value term:</p> <p style="padding-left: 40px;">einput5A_{AV} = $N * (1/N) * (einput4A_{AV})$ = einput4A_{AV} % Power</p> <p style="padding-left: 40px;">einput5A_{AV} = 0% Power</p> <p>These three terms will be carried forward to the next section where they will be combined after the % CS terms are converted to % Power.</p>		
REVISION NO.	0	

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 124 of 191

11.5.1.2.10 Non-Random Error ($\Sigma e5A$)

From Reference 3.3 the non-random error is the algebraic sum of all the above terms.

$$\Sigma e5A_{CS} = \pm(e5AH + e5AT + e5AR + e5AS + e5ASP + e5AP + e5Ap + e5AV + einput5A_{CS})\% CS$$

$$\Sigma e5A_{CS} = \pm(0 + 0 + 0 + 0 + 0 + 0 + 0 + 0 + 0)\% CS$$

$$\Sigma e5A_{CS} = \pm 0\% CS$$

This will now be converted to % Power and added to $einput5A_{PP}$ to obtain the total $\Sigma e5A$.

$$\Sigma e5A = \pm \Sigma e5A_{CS} * (125/100) + einput5A_{PP} \% Power$$

$$\Sigma e5A = \pm 0 * (125/100) + 0.82 \% Power$$

$$\Sigma e5A = \pm 0.82\% Power$$

And

$$\Sigma e5A_{AV} = \pm \Sigma e5A_{CS} * (125/100) + einput5A_{AV} \% Power$$

$$\Sigma e5A_{AV} = \pm 0 * (125/100) + 0 \% Power$$

$$\Sigma e5A_{AV} = \pm 0\% Power$$

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 125 of 191

11.5.2 Module 5B (Trip Circuit - Fixed)

Classification of Module

Module 5B receives an analog input from the Averaging and Gain Change Circuitry and provides a bistable output, the state of which depends on the relative magnitudes of the input signal and the reference value. Therefore, Module 5B is a bistable module.

11.5.2.1 Module 5B Random Error (σ_{5B})

This section addresses random uncertainties that have the potential to be expressed in the output of Module 5B.

11.5.2.1.1 Reference Accuracy (RA5B)

Per Section 8.5.1 the reference accuracy for this module is:

$$RA_{5B} = 1\% \text{ CS}$$

Per Assumption 5.1, this is assumed to be a 2 sigma value. This is then converted to a 1 sigma value by dividing by 2. In the same step this will be converted to % Power by multiplying by 125/100.

$$RA_{5B(1\sigma)} = \pm(RA_{5B}/2) * (125/100) \% \text{ Power}$$

$$RA_{5B(1\sigma)} = \pm(1/2) * (125/100) \% \text{ Power}$$

$$RA_{5B(1\sigma)} = \pm 0.625\% \text{ Power}$$

11.5.2.1.2 Drift (RD5B)

Per Section 8.5.1 the reference drift for this module is:

$$RD_{5B} = 1\% \text{ CS}/700 \text{ HRS}$$

Table 4.3.6-1 of Reference 3.7 gives the surveillance interval (RD5BTSI) for all trip functions as 13 weeks (quarterly). In addition, a 25% late factor will be added to the required value. Per Reference 3.8 drift is considered a random function and can be extended to a longer period by the square root of the ratio of the time periods per Section 2.2.5 of Reference 3.13.

Per Assumption 5.1, the drift value is assumed to be a 2 sigma value. This is then converted to a 1 sigma value by dividing by 2, and then to % Power by multiplying by

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 126 of 191

125/100. RD5BTSI is converted to hours by multiplying by 168. The one sigma drift is then:

$$RD5B_{(1\sigma)} = \pm (RD5B/2) * (125/100) * [(1.25 * RD5BTSI * 168) / RD5BT]^{0.5} \% \text{ Power}$$

$$RD5B_{(1\sigma)} = \pm (1/2) * (125/100) * [(1.25 * 13 * 168) / 700]^{0.5} \% \text{ Power}$$

$$RD5B_{(1\sigma)} = \pm 1.234276 \% \text{ Power}$$

11.5.2.1.3 Calibration Uncertainty (CAL5B)

The uncertainties associated with calibrating the trip circuits are composed entirely of the uncertainties associated with the DMM used to set the input trip voltage. Per the applicable procedures of Reference 3.5 a Fluke Model 8500A is specified for this function. From Section 9.1 the error associated with this instrument is 0.00018 Vdc (RAMTE1_{5B}). Since this is a digital instrument REMTE1_{5B} is equal to zero.

From Reference 3.3,

$$MTE1 = [(RAMTE1/n)^2 + REMTE1^2]^{0.5}$$

where n is the number of standard deviations applicable to the error term. The values of the error terms from Reference 9.1 are already expressed in one sigma terms. Therefore, the value of n is 1.

$$MTE1_{5B} = \pm [(RAMTE1_{5B}/1)^2 + REMTE1_{5B}^2]^{0.5} \text{ Vdc}$$

$$MTE1_{5B} = \pm [(0.00018/1)^2 + 0^2]^{0.5} \text{ Vdc}$$

$$MTE1_{5B} = \pm 0.00018 \text{ Vdc}$$

This can be converted to % Power by dividing by the voltage span (SPAN4CIN - the RBM output has the same span as does the APRM) and multiplying by the full scale power (125).

$$MTE1_{5B(PP)} = \pm [(MTE1_{5B}/SPAN4CIN) * 125] \% \text{ Power}$$

$$MTE1_{5B(PP)} = \pm [(0.00018/10) * 125] \% \text{ Power}$$

$$MTE1_{5B(PP)} = \pm 0.00225 \% \text{ Power}$$

From Section 5.2 the errors attributed to the calibration standards are considered negligible. Therefore, the only term which contributes to CAL5B is the MTE1 term.

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 127 of 191

Therefore, for this section

$$CAL5B = \pm MTE1_{5B(PP)} = \pm 0.00225\% \text{ Power}$$

11.5.2.1.4 Setting Tolerance (ST5B)

The setting tolerance listed in the applicable procedures for this function is 0.04 Vdc. This can be converted to % Power by dividing by the voltage span (SPAN4CIN) and multiplying by the full scale power (125).

From Section 2.1.a the given setting tolerances are considered 3 sigma values. Therefore, ST5B must be divided by 3 to make it compatible with the other 1 sigma error terms. Combining this operation with the conversion to percent power gives

$$ST5B_{(1\sigma)} = \pm [(ST5B/SPAN4CIN) * 125] / 3 \% \text{ Power}$$

$$ST5B_{(1\sigma)} = \pm [(0.04/10) * 125] / 3 \% \text{ Power}$$

$$ST5B_{(1\sigma)} = \pm 0.166667\% \text{ Power}$$

11.5.2.1.5 Input Uncertainty ($\sigma_{input5B}$ and $\sigma_{input5B_{AV}}$)

In addition to its own error terms, the error terms from Module 5A must also be considered. Since the trip circuits perform no function on the input signal $\sigma_{input5B}$ and $\sigma_{input5B_{AV}}$ become equal to the random input terms σ_{5A} and $\sigma_{5A_{AV}}$.

$$\sigma_{input5B} = \pm \sigma_{5A} = \pm 1.850009\% \text{ Power}$$

And

$$\sigma_{input5B_{AV}} = \pm \sigma_{5A_{AV}} = 1.610749\% \text{ Power}$$

11.5.2.1.6 Determination of Module Random Error (σ_{5B})

Using the methodology of Reference 3.3,

$$\sigma_{5B} = \pm [(\sigma_{RA5B(1\sigma)})^2 + (\sigma_{RD5B(1\sigma)})^2 + (CAL5B)^2 + (ST5B_{(1\sigma)})^2 + (\sigma_{input5B})^2]^{0.5} \% \text{ Power}$$

$$\sigma_{5B} = \pm [(0.625)^2 + (1.234276)^2 + (0.00225)^2 + (0.166667)^2 + (1.850009)^2]^{0.5} \% \text{ Power}$$

$$\sigma_{5B} = \pm 2.316113\% \text{ Power}$$

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 128 of 191

And

$$\sigma_{5B_{AV}} = \pm [(RA5B_{(1\sigma)})^2 + (RD5B_{(1\sigma)})^2 + (CAL5B)^2 + (ST5B_{(1\sigma)})^2 + (\sigma_{input5B_{AV}})^2]^{0.5} \% \text{ Power}$$

$$\sigma_{5B_{AV}} = \pm [(0.625)^2 + (1.234276)^2 + (0.00225)^2 + (0.166667)^2 + (1.610749)^2]^{0.5} \% \text{ Power}$$

$$\sigma_{5B_{AV}} = \pm 2.129873 \% \text{ Power}$$

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345		PAGE 129 of 191
<p>11.5.2.2 Module 5B Non-Random Errors (Σe_{5B})</p> <p>11.5.2.2.1 Humidity Errors (e_{5BH})</p> <p style="padding-left: 40px;">Since Reference 3.12 does not identify a humidity error term a value of zero will be used per Section 4.3.</p> <p style="padding-left: 80px;">$e_{5BH} = 0\% \text{ CS}$</p> <p>11.5.2.2.2 Temperature Error (e_{5BT})</p> <p style="padding-left: 40px;">Since Reference 3.12 does not identify a temperature error term a value of zero will be used per Section 4.3.</p> <p style="padding-left: 80px;">$e_{5BT} = 0\% \text{ CS}$</p> <p>11.5.2.2.3 Radiation Error (e_{5BR})</p> <p style="padding-left: 40px;">Since Reference 3.12 does not identify a radiation error term a value of zero will be used per Section 4.3.</p> <p style="padding-left: 80px;">$e_{5BR} = 0\% \text{ CS}$</p> <p>11.5.2.2.4 Seismic Error (e_{5BS})</p> <p style="padding-left: 40px;">Per Section 4.7 seismic error for this module is considered negligible.</p> <p style="padding-left: 80px;">$e_{5BS} = 0\% \text{ CS}$</p> <p>11.5.2.2.5 Static Pressure Effect (e_{5BSP})</p> <p style="padding-left: 40px;">This module is an all electronic device that is not exposed to any pressure other than atmospheric. Therefore, there is no static pressure effect.</p> <p style="padding-left: 80px;">$e_{5BSP} = 0\% \text{ CS}$</p> <p>11.5.2.2.6 Pressure Error (e_{5BP})</p> <p style="padding-left: 40px;">This module is an all electronic device that is not exposed to any pressure other than atmospheric. Therefore, there is no pressure effect.</p> <p style="padding-left: 80px;">$e_{5BP} = 0\% \text{ CS}$</p> <p>11.5.2.2.7 Process Errors(e_{5Bp})</p> <p style="padding-left: 40px;">This module is intermediate in the loop and, as such, is not</p>		
REVISION NO.	0	

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 130 of 191

exposed to any process parameters. Therefore, there are no process errors.

$$e5Bp = 0\% \text{ CS}$$

11.5.2.2.8 Power Supply Effects (e5BV)

Since Reference 3.12 does not identify a power supply effect error term a value of zero will be used per Section 4.3.

$$e5BV = 0\% \text{ CS}$$

11.5.2.2.9 Non-Random Input Error (einput5B)

In addition to its own error terms, the error terms from Module 5A must also be considered. Since the trip circuits perform no function on the input signal, einput5B and einput5B_{AV} become equal to the non-random input term $\Sigma e5A$ and $\Sigma e5A_{AV}$.

$$einput5B = \pm \Sigma e5A = \pm 0.82\% \text{ Power}$$

And

$$einput5B_{AV} = \pm \Sigma e5A_{AV} = \pm 0\% \text{ Power}$$

11.5.2.2.10 Non-Random Error ($\Sigma e5B$ and $\Sigma e5B_{AV}$)

From Reference 3.3 the non-random error is the algebraic sum of all the above terms.

$$\Sigma e5B = \pm (125/100) * (e5BH + e5BT + e5BR + e5BS + e5BSP + e5BP + e5Bp + e5BV) + einput5B\% \text{ Power}$$

$$\Sigma e5B = \pm (125/100) * (0 + 0 + 0 + 0 + 0 + 0 + 0 + 0) + 0.82\% \text{ Power}$$

$$\Sigma e5B = \pm 0.82\% \text{ Power}$$

And

$$\Sigma e5B_{AV} = \pm (125/100) * (e5BH + e5BT + e5BR + e5BS + e5BSP + e5BP + e5Bp + e5BV) + einput5B_{AV} \% \text{ Power}$$

$$\Sigma e5B_{AV} = \pm (125/100) * (0 + 0 + 0 + 0 + 0 + 0 + 0 + 0) + 0 \% \text{ Power}$$

$$\Sigma e5B_{AV} = \pm 0\% \text{ Power}$$

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345		PAGE 131 of 191
<p>11.5.3 Module 5C (Trip Circuit - Flow Biased)</p> <p style="margin-left: 40px;"><u>Classification of Module</u></p> <p style="margin-left: 40px;">Module 5C receives an analog input from the Averaging and Gain Change Circuitry and the Flow Summer (Module 3), and provides a bistable output, the state of which depends on the relative magnitudes of the input signal from the Averaging and Gain Change Circuitry and the reference value, which is a function of the Flow Summer signal. Therefore, Module 5c is a bistable module.</p> <p>11.5.3.1 Module 5C Random Error (σ5C)</p> <p style="margin-left: 40px;">This section addresses random uncertainties that have the potential to be expressed in the output of Module 5C.</p> <p>11.5.3.1.1 Reference Accuracy (RA5C)</p> <p style="margin-left: 40px;">Per Section 8.5.1 the reference accuracy for this module is:</p> <p style="margin-left: 80px;">RA5C = 1% CS</p> <p style="margin-left: 40px;">Per Assumption 5.1, this is assumed to be a 2 sigma value. This is then converted to a 1 sigma value by dividing by 2. In the same step this will be converted to % Power by multiplying by 125/100.</p> <p style="margin-left: 80px;">RA5C_(1σ) = \pm(RA5C/2)*(125/100) % Power</p> <p style="margin-left: 80px;">RA5C_(1σ) = \pm(1/2)*(125/100) % Power</p> <p style="margin-left: 80px;">RA5C_(1σ) = \pm0.625% Power</p> <p>11.5.3.1.2 Drift (RD5C)</p> <p style="margin-left: 40px;">Per Section 8.5.1 the reference drift for this module is:</p> <p style="margin-left: 80px;">RD5C = 1% CS/700 HRS</p> <p style="margin-left: 40px;">Table 4.3.6-1 of Reference 3.7 gives the surveillance interval (RD5CTSI) for all trip functions as 13 weeks (semi-annually). In addition, a 25% late factor will added to the required value. Per Reference 3.8 drift is considered a random function and can be extended to a longer period by the square root of the ratio of the time periods per Section 2.2.5 of Reference 3.13.</p> <p style="margin-left: 40px;">Per Assumption 5.1, the drift value is assumed to be a 2</p>		
REVISION NO.	0	

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 132 of 191

sigma value. This is then converted to a 1 sigma value by dividing by 2, and then to % Power by multiplying by 125/100. RD5CTSI is converted to hours by multiplying by 168. The one sigma drift is then:

$$RD5C_{(1\sigma)} = \pm (RD5C/2) * (125/100) * [(1.25 * RD5CTSI * 168) / RD5CT]^{0.5} \% \text{ Power}$$

$$RD5C_{(1\sigma)} = \pm (1/2) * (125/100) * [(1.25 * 13 * 168) / 700]^{0.5} \% \text{ Power}$$

$$RD5C_{(1\sigma)} = \pm 1.234276 \% \text{ Power}$$

11.5.3.1.3 Calibration Uncertainty (CAL5C)

The uncertainties associated with calibrating the trip circuits are composed entirely of the uncertainties associated with the DMM used to set the input trip voltage. Per the applicable procedures of Reference 3.5 a Fluke Model 8500A is specified for this function. From Section 9.1 the error associated with this instrument is 0.00018 Vdc (RAMTE1_{5C}). Since this is a digital instrument REMTE1_{5C} is equal to zero.

From Reference 3.3,

$$MTE1 = [(RAMTE1/n)^2 + REMTE1^2]^{0.5}$$

where n is the number of standard deviations applicable to the error term. The values of the error terms from Reference 9.1 are already expressed in one sigma terms. Therefore, the value of n is 1.

$$MTE1_{5C} = \pm [(RAMTE1_{5C}/1)^2 + REMTE1_{5C}^2]^{0.5} \text{ Vdc}$$

$$MTE1_{5C} = \pm [(0.00018/1)^2 + 0^2]^{0.5} \text{ Vdc}$$

$$MTE1_{5C} = \pm 0.00018 \text{ Vdc}$$

This can be converted to % Power by dividing by the voltage span (SPAN4CIN - Both Fixed and Flow Biased trips have the same input span as the APRM trip circuits) and multiplying by the full scale power (125).

$$MTE1_{5C(PP)} = \pm [(MTE1_{5C}/SPAN4CIN) * 125] \% \text{ Power}$$

$$MTE1_{5C(PP)} = \pm [(0.00018/10) * 125] \% \text{ Power}$$

$$MTE1_{5C(PP)} = \pm 0.00225 \% \text{ Power}$$

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 133 of 191

From Section 5.2 the errors attributed to the calibration standards are considered negligible. Therefore, the only term which contributes to CAL5C is the MTE1 term. Therefore, for this section

$$CAL5C = \pm MTE1_{5C(PP)} = \pm 0.00225\% \text{ Power}$$

11.5.3.1.4 Setting Tolerance (ST5C)

The setting tolerance listed in the applicable procedures for this function is 0.04 Vdc. This can be converted to % Power by dividing by the voltage span (SPAN4CIN) and multiplying by the full scale power (125).

From Section 2.1.a the given setting tolerances are considered 3 sigma values. Therefore, ST4D must be divided by 3 to make it compatible with the other 1 sigma error terms. Combining this operation with the conversion to percent power gives

$$ST5C_{(1\sigma)} = \pm [(ST5C/SPAN4CIN) * 125] / 3 \% \text{ Power}$$

$$ST5C_{(1\sigma)} = \pm [(0.04/10) * 125] / 3 \% \text{ Power}$$

$$ST5C_{(1\sigma)} = \pm 0.166667\% \text{ Power}$$

11.5.3.1.5 Input Uncertainty ($\sigma_{input5C}$)

In addition to its own error terms, the error terms from Module 5A and Module 3 must also be considered. Since the trip circuits perform no function on these input signals $\sigma_{input5C}$ and $\sigma_{input5C_{AV}}$ become equal to the combination by SRSS of the random input terms σ_{5A} and σ_3 , and $\sigma_{5A_{AV}}$ and σ_{3C} . However, before σ_{5A} and σ_3 , and $\sigma_{5A_{AV}}$ and σ_{3C} can be combined, σ_3 and σ_{3C} must be converted from % Flow to % Power by multiplying by the slope of the curve in the Flow Controlled Trip Reference Unit. From the applicable procedures in Reference 3.5 this slope ($FCS_{RBM(SP)}$) is equal to 0.66% Power per % Flow. However, per Section 2.2 this slope has been modified to account for setting uncertainties. Therefore,

$$\sigma_{input5C} = \pm [\sigma_{5A}^2 + (FCS_{RBM} * \sigma_3)^2]^{0.5} \% \text{ Power}$$

$$\sigma_{input5C} = \pm \{ (1.850009)^2 + [(0.668750) * (2.546521)]^2 \}^{0.5} \% \text{ Power}$$

$$\sigma_{input5C} = \pm 2.514497\% \text{ Power}$$

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 134 of 191

For the Allowable Value determination this becomes:

$$\sigma_{\text{input5C}_{\text{AV}}} = \pm [\sigma_{\text{5A}_{\text{AV}}}^2 + (\text{FCS}_{\text{RBM}} * \sigma_{\text{3C}})^2]^{0.5} \% \text{ Power}$$

$$\sigma_{\text{input5C}_{\text{AV}}} = \pm [1.610749^2 + (0.668750 * 1.669197)^2]^{0.5} \% \text{ Power}$$

$$\sigma_{\text{input5C}_{\text{AV}}} = \pm 1.959740 \% \text{ Power}$$

11.5.3.1.6 Determination of Module Random Error (σ_{5C} and $\sigma_{\text{5C}_{\text{AV}}}$)

Using the methodology of Reference 3.3,

$$\sigma_{\text{5C}} = \pm [(\text{RA5C}_{(1\sigma)})^2 + (\text{RD5C}_{(1\sigma)})^2 + (\text{CAL5C})^2 + (\text{ST5C}_{(1\sigma)})^2 + (\sigma_{\text{input5C}})^2]^{0.5} \% \text{ Power}$$

$$\sigma_{\text{5C}} = \pm [(0.625)^2 + (1.234276)^2 + (0.00225)^2 + (0.166667)^2 + (2.514497)^2]^{0.5} \% \text{ Power}$$

$$\sigma_{\text{5C}} = \pm 2.874811 \% \text{ Power}$$

And

$$\sigma_{\text{5C}_{\text{AV}}} = \pm [(\text{RA5C}_{(1\sigma)})^2 + (\text{RD5C}_{(1\sigma)})^2 + (\text{CAL5C})^2 + (\text{ST5C}_{(1\sigma)})^2 + (\sigma_{\text{input5C}_{\text{AV}}})^2]^{0.5} \% \text{ Power}$$

$$\sigma_{\text{5C}_{\text{AV}}} = \pm [(0.625)^2 + (1.234276)^2 + (0.00225)^2 + (0.166667)^2 + (1.95974)^2]^{0.5} \% \text{ Power}$$

$$\sigma_{\text{5C}_{\text{AV}}} = \pm 2.404668 \% \text{ Power}$$

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345		PAGE 135 of 191
<p>11.5.3.2 Module 5C Non-Random Errors ($\Sigma e5C$)</p> <p>11.5.3.2.1 Humidity Errors ($e5CH$)</p> <p style="margin-left: 40px;">Since Reference 3.12 does not identify a humidity error term a value of zero will be used per Section 4.3.</p> <p style="margin-left: 80px;">$e5CH = 0\% \text{ CS}$</p> <p>11.5.3.2.2 Temperature Error ($e5CT$)</p> <p style="margin-left: 40px;">Since Reference 3.12 does not identify a temperature error term a value of zero will be used per Section 4.3.</p> <p style="margin-left: 80px;">$e5CT = 0\% \text{ CS}$</p> <p>11.5.3.2.3 Radiation Error ($e5CR$)</p> <p style="margin-left: 40px;">Since Reference 3.12 does not identify a radiation error term a value of zero will be used per Section 4.3.</p> <p style="margin-left: 80px;">$e5CR = 0\% \text{ CS}$</p> <p>11.5.3.2.4 Seismic Error ($e5CS$)</p> <p style="margin-left: 40px;">Per Section 4.7 seismic error for this module is considered negligible.</p> <p style="margin-left: 80px;">$e5CS = 0\% \text{ CS}$</p> <p>11.5.3.2.5 Static Pressure Effect ($e5CSP$)</p> <p style="margin-left: 40px;">This module is an all electronic device that is not exposed to any pressure other than atmospheric. Therefore, there is no static pressure effect.</p> <p style="margin-left: 80px;">$e5CSP = 0\% \text{ CS}$</p> <p>11.5.3.2.6 Pressure Error ($e5CP$)</p> <p style="margin-left: 40px;">This module is an all electronic device that is not exposed to any pressure other than atmospheric. Therefore, there is no pressure effect.</p> <p style="margin-left: 80px;">$e5CP = 0\% \text{ CS}$</p>		
REVISION NO.	0	

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345		PAGE 136 of 191
<p>11.5.3.2.7 Process Errors (e5Cp)</p> <p>This module is intermediate in the loop and, as such, is not exposed to any process parameters. Therefore, there are no process errors.</p> <p style="padding-left: 40px;">e5Cp = 0% CS</p> <p>11.5.3.2.8 Power Supply Effects (e5CV)</p> <p>Since Reference 3.12 does not identify a power supply effect error term a value of zero will be used per Section 4.3.</p> <p style="padding-left: 40px;">e5CV = 0% CS</p> <p>11.5.3.2.9 Non-Random Input Error (einput5C)</p> <p>In addition to its own error terms, the error terms from Module 5A and Module 3 must also be considered. Since the trip circuits perform no function on these input signals einput5C becomes equal to the combination by algebraic addition of the non-random input terms $\Sigma e5A$ and $\Sigma e3$, and $\Sigma e5A_{AV}$ and $\Sigma e3_{AV}$. However, before $\Sigma e5A$ and $\Sigma e3$, and $\Sigma e5A_{AV}$ and $\Sigma e3_{AV}$ can be combined, $\Sigma e3$ and $\Sigma e3_{AV}$ must be converted from % Flow to % Power by multiplying by the slope of the curve in the Flow Controlled Trip Reference Unit. From the applicable procedures in Reference 3.5 this slope ($FCS_{RBM(SP)}$) is equal to 0.66 % Power per % Flow. However, per Section 2.2 this slope has been modified to account for setting uncertainties. Therefore,</p> <p style="padding-left: 40px;">einput5C = $\pm[\Sigma e5A + (FCS_{RBM} * \Sigma e3)]$ % Power</p> <p style="padding-left: 40px;">einput5C = $\pm[0.82 + (0.668750 * 1.274635)]$ % Power</p> <p style="padding-left: 40px;">einput5C = $\pm 1.672412\%$ Power</p> <p>And</p> <p style="padding-left: 40px;">einput5C_{AV} = $\pm[\Sigma e5A_{AV} + (FCS_{RBM} * \Sigma e3)]$ % Power</p> <p style="padding-left: 40px;">einput5C_{AV} = $\pm[0 + (0.668750 * 1.274635)]$ % Power</p> <p style="padding-left: 40px;">einput5C_{AV} = $\pm 0.852412\%$ Power</p>		
REVISION NO.	0	

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 137 of 191

11.5.3.2.10 Non-Random Error ($\Sigma e5C$)

From Reference 3.3 the non-random error is the algebraic sum of all the above terms.

$$\Sigma e5C = \pm(125/100) * (e5CH + e5CT + e5CR + e5CS + e5CSP + e5CP + e5Cp + e5CV) + einput5C\% \text{ Power}$$

$$\Sigma e5C = \pm(125/100) * (0 + 0 + 0 + 0 + 0 + 0 + 0 + 0) + 1.672412\% \text{ Power}$$

$$\Sigma e5C = \pm 1.672412\% \text{ Power}$$

And

$$\Sigma e5C_{AV} = \pm(125/100) * (e5CH + e5CT + e5CR + e5CS + e5CSP + e5CP + e5Cp + e5CV) + einput5C_{AV} \% \text{ Power}$$

$$\Sigma e5C_{AV} = \pm(125/100) * (0 + 0 + 0 + 0 + 0 + 0 + 0 + 0) + 0.852412 \% \text{ Power}$$

$$\Sigma e5C_{AV} = \pm 0.852412\% \text{ Power}$$

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345		PAGE 138 of 191
<p>11.6 ABB Flow Unit (Module 6)</p> <p><u>Classification of Module</u></p> <p>Module 6 receives analog inputs from flow transmitters and another flow unit, and provides an output that represents the sum of two flow loops in addition to two bistable outputs representing high flow and mismatch flow. Therefore, Module 6 is both an analog and a bistable module.</p> <p>11.6.1 Module 6 Analog Section</p> <p>This portion of the calculation evaluates the uncertainties associated with the square root converters and summer sections of the flow unit.</p> <p>11.6.1.1 Module 6 Random Error (σ_6)</p> <p>This section addresses random uncertainties that have the potential to be expressed in the output of Module 6.</p> <p>11.6.1.1.1 Reference Accuracy (RA6)</p> <p>Per Section 8.6.1 the reference accuracy applied to this module is the overall RFM accuracy. Per Reference 3.19 the reference accuracy for this unit is $\pm 1\%$.</p> <p style="padding-left: 40px;">$RA_6 = 1\% \text{ CS}$</p> <p>Per Assumption 5.1, this is assumed to be a 2 sigma value. This is then converted to a 1 sigma value by dividing by 2.</p> <p style="padding-left: 40px;">$RA_{6(1\sigma)} = \pm RA_6 / 2 \% \text{ CS}$</p> <p style="padding-left: 40px;">$RA_{6(1\sigma)} = \pm 1/2 \% \text{ CS}$</p> <p style="padding-left: 40px;">$RA_{6(1\sigma)} = \pm 0.5\% \text{ CS}$</p> <p>11.6.1.1.2 Drift (RD6)</p> <p>Per Section 8.6.1 the reference drift applied to this module is the overall RFM drift. Per Reference 3.19 the reference drift for this unit is $\pm 0.5\% \text{ CS}$ per 30 months. Since this interval is greater than the surveillance interval no adjustment needs to be made.</p> <p style="padding-left: 40px;">$RD_6 = 0.5\% \text{ CS}$</p> <p>Per Assumption 5.1, this is assumed to be a 2 sigma value.</p>		
REVISION NO.	0	

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 139 of 191

This is then converted to a 1 sigma value by dividing by 2.

$$RD6_{(1\sigma)} = RD6/2 \% CS$$

$$RD6_{(1\sigma)} = 0.5/2 \% CS$$

$$RD6_{(1\sigma)} = \pm 0.25\% CS$$

11.6.1.1.3 Calibration Uncertainty (CAL6)

The uncertainties associated with calibrating the flow summer are composed of the uncertainties in setting the input signal and the uncertainties in reading the output signal. Per Assumption 5.9 the calibration uncertainties for this module are assumed to be the same as those for Module 3. Therefore, CAL6 is equal to CAL3.

$$CAL6 = CAL3_{SUM} = \pm 0.025498\% CS$$

11.6.1.1.4 Setting Tolerance (ST6)

The setting tolerance for the flow summer is the combination of the input and output setting tolerances. Per Assumption 5.9 the setting tolerances for this module are assumed to be the same as those for Module 3. Therefore, ST6 is equal to ST3 and, consequently, $ST6_{(1\sigma)}$ is equal to $ST3_{(1\sigma)}$.

$$ST6_{(1\sigma)} = ST3_{(1\sigma)} = \pm 0.04714\% CS$$

11.6.1.1.5 Input Uncertainty (σ_{input6})

In addition to its own error terms, Module 6 also operates on the error terms from Module 1. Per Assumption 5.9 the calibration uncertainties for this module are assumed to be similar to those for Module 3. Also, since Module 2 had no error terms (RA2, RD2) of its own, its only errors were due to calibration and inputs from Module 1. Therefore, the random error terms σ_{input6} and σ_{input6_c} will be equal to σ_{input3} and σ_{input3_c} for this calculation.

$$\sigma_{input6} = \sigma_{input3} = \pm 1.660348\% CS$$

For the Comparator Trip:

$$\sigma_{input6_c} = \sigma_{input3_c} = \pm 0.624245\% CS$$

11.6.1.1.6 Determination of Module Random Error (σ_6)

Using the methodology of Reference 3.3, and converting to %

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 140 of 191

Flow by multiplying by 125/100:

$$\sigma_6 = \pm(125/100) * [(RA6_{(1\sigma)})^2 + (RD6_{(1\sigma)})^2 + (CAL6)^2 + (ST6_{(1\sigma)})^2 + (\sigma_{input6})^2]^{0.5} \% \text{ Flow}$$

$$\sigma_6 = \pm(125/100) * [(0.5)^2 + (0.25)^2 + (0.025498)^2 + (0.04714)^2 + (1.660348)^2]^{0.5} \% \text{ Flow}$$

$$\sigma_6 = \pm 2.190936\% \text{ Flow}$$

For the Comparator Trip:

$$\sigma_{6c} = \pm(125/100) * [(RA6_{(1\sigma)})^2 + (RD6_{(1\sigma)})^2 + (CAL6)^2 + (ST6_{(1\sigma)})^2 + (\sigma_{input6c})^2]^{0.5} \% \text{ Flow}$$

$$\sigma_{6c} = \pm(125/100) * [(0.5)^2 + (0.25)^2 + (0.025498)^2 + (0.04714)^2 + (0.624245)^2]^{0.5} \% \text{ Flow}$$

$$\sigma_{6c} = \pm 1.049594\% \text{ Flow}$$

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345		PAGE 141 of 191
<p>11.6.1.2 Module 6 Non-Random Errors (Σe_6)</p> <p>Per Section 8.6.1 the errors applied to this module are the overall RFM error terms.</p> <p>11.6.1.2.1 Humidity Errors (e_{6H})</p> <p>Since Reference 3.19 does not identify a humidity error term a value of zero will be used per Section 4.3.</p> <p>$e_{6H} = 0\% \text{ CS}$</p> <p>11.6.1.2.2 Temperature Error (e_{6T})</p> <p>Per Reference 3.19 the "Total Flow Voltage Output Temperature Effect" is</p> <p>$e_{6T} = 0.5\% \text{ CS}$</p> <p>11.6.1.2.3 Radiation Error (e_{6R})</p> <p>Since Reference 3.19 does not identify a radiation error term a value of zero will be used per Section 4.3.</p> <p>$e_{6R} = 0\% \text{ CS}$</p> <p>11.6.1.2.4 Seismic Error (e_{6S})</p> <p>Per Section 4.7 seismic error for this module is considered negligible.</p> <p>$e_{6S} = 0\% \text{ CS}$</p> <p>11.6.1.2.5 Static Pressure Effect (e_{6SP})</p> <p>This module is an all electronic device that is not exposed to any pressure other than atmospheric. Therefore, there is no static pressure effect.</p> <p>$e_{6SP} = 0\% \text{ CS}$</p> <p>11.6.1.2.6 Pressure Error (e_{6P})</p> <p>This module is an all electronic device that is not exposed to any pressure other than atmospheric. Therefore, there is no pressure effect.</p> <p>$e_{6P} = 0\% \text{ CS}$</p>		
REVISION NO.	0	

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345		PAGE 142 of 191
<p>11.6.1.2.7 Process Errors(e6p)</p> <p>This module is intermediate in the loop and, as such, is not exposed to any process parameters. Therefore, there are no process errors.</p> <p style="padding-left: 40px;">e6p = 0% CS</p> <p>11.6.1.2.8 Power Supply Effects (e6V)</p> <p>Since Reference 3.19 does not identify a power supply effect error term a value of zero will be used per Section 4.3.</p> <p style="padding-left: 40px;">e6V = 0% CS</p> <p>11.6.1.2.9 Non-Random Input Error (einput6)</p> <p>In addition to its own error terms, Module 6 also operates on the error terms from Module 1. Per Assumption 5.9 the calibration uncertainties for this module are assumed to be similar to those for Module 3. Also, since Module 2 had no error terms (e2H, e2T, e2R, e2S, e2SP, e2P, e2p, e2V) of its own, its only errors were due to calibration and inputs from Module 1. Therefore, the random error term einput6 will be equal to einput3 for this calculation.</p> <p style="padding-left: 40px;">einput6 = einput3 = ±1.019708% CS</p> <p>11.6.1.2.10 Non-Random Error (Σe3)</p> <p>From Reference 3.3 the non-random error is the algebraic sum of all the above terms. In addition, this term can be converted to % Flow by multiplying by 125/100. The result is;</p> <p style="padding-left: 40px;">Σe6 = ±(125/100)*(e6H + e6T + e6R + e6S + e6SP + e6P + e6p + e6V + einput6)% Flow</p> <p style="padding-left: 40px;">Σe6 = ±(125/100)*(0 + 0.5 + 0 + 0 + 0 + 0 + 0 + 0 + 1.019708)% Flow</p> <p style="padding-left: 40px;">Σe6 = ±1.899635% Flow</p>		
REVISION NO.	0	

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 143 of 191

11.6.2 Module 6A and 6B (ABB RFM Trip Circuits)

Classification of Module

Module 6A receives an analog input from the Flow Summer (Module 6) and provides a bistable output, the state of which depends on the relative magnitudes of the input signal and the reference value. Therefore, Module 6A is a bistable module.

There are actually two separate trip circuits in each flow unit. The Hi Flow trip looks at the output of the Flow Summer and compares its magnitude to a fixed reference value (Module 6A). The Comparator Trip Circuit looks at the output of the Flow Summer and compares it to the output of a Flow Summer from another RFM (Module 6B) and provides a bistable output, the state of which depends on the relative magnitudes of the two input signals. Therefore, Module 6B is a bistable module. The Comparator Trip will have to combine the error terms from two Flow Summers.

11.6.2.1 Module 6A Random Error (σ_{6A})

This section addresses random uncertainties that have the potential to be expressed in the output of Module 6A.

11.6.2.1.1 Reference Accuracy (RA_{6A})

Per Section 8.6.1 the reference accuracy for this module is:

$$RA_{6A} = 1\% \text{ CS}$$

Per Assumption 5.1, this is assumed to be a 2 sigma value. This is then converted to a 1 sigma value by dividing by 2. In the same step this will be converted to % Flow by multiplying by 125/100.

$$RA_{6A(1\sigma)} = \pm(RA_{6A}/2) * (125/100) \% \text{ Flow}$$

$$RA_{6A(1\sigma)} = \pm(1/2) * (125/100) \% \text{ Flow}$$

$$RA_{6A(1\sigma)} = \pm 0.625\% \text{ Flow}$$

11.6.2.1.2 Drift (RD_{6A})

Per Assumption 5.10 drift is assumed to be included in the reference accuracy term. Therefore:

$$RD_{6A} = 0\% \text{ CS}$$

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 144 of 191

Per Assumption 5.1, the drift value is assumed to be a 2 sigma value. This is then converted to a 1 sigma value by dividing by 2, and then to % Flow by multiplying by 125/100.

$$RD6A_{(1\sigma)} = \pm(RD6A/2) * (125/100) \% \text{ Flow}$$

$$RD6A_{(1\sigma)} = \pm(0/2) * (125/100) \% \text{ Flow}$$

$$RD6A_{(1\sigma)} = \pm 0\% \text{ Flow}$$

11.6.2.1.3 Calibration Uncertainty (CAL6A)

Per Assumption 5.9 the calibration uncertainties for this module are assumed to be the same as those for Module 3. Therefore, CAL6A is equal to CAL3A.

$$CAL6A = CAL3A = \pm 0.022538\% \text{ Flow}$$

11.6.2.1.4 Setting Tolerance (ST6A)

Per Assumption 5.9 the setting tolerances for this module are assumed to be the same as those for Module 3. Therefore, ST6A = ST3A, and consequently, $ST6A_{A(1\sigma)} = ST3A_{A(1\sigma)}$ and $ST6A_{B(1\sigma)} = ST3A_{B(1\sigma)}$.

Upscale Trip:

$$ST6A_{A(1\sigma)} = ST3A_{A(1\sigma)} = \pm 0.416667\% \text{ Flow}$$

Comparator Trip:

$$ST6A_{B(1\sigma)} = ST3A_{B(1\sigma)} = \pm 0.333333\% \text{ Flow}$$

11.6.2.1.5 Input Uncertainty ($\sigma_{input6A}$, $\sigma_{input6B}$)

In addition to its own error terms, the error terms from Module 6 must also be considered. Since the trip circuits perform no function on the input signal $\sigma_{input6A}$ becomes equal to the random input term σ_6 for the Hi Flow trip. However, the Comparator Trip is also looking at the output of another RFM so both inputs have a σ_{6c} term impressed on them. Therefore, the uncertainty term $\sigma_{input6B}$ for the Comparator Trip will combine two σ_{6c} terms by SRSS.

$$\sigma_{input6A} = \pm \sigma_6 = \pm 2.190936\% \text{ Flow}$$

And

$$\sigma_{input6B} = \pm (\sigma_{6c}^2 + \sigma_{6c}^2)^{0.5} \% \text{ Flow}$$

$$\sigma_{input6B} = \pm (1.049594^2 + 1.049594^2)^{0.5} \% \text{ Flow}$$

REVISION NO.

0

1

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 145 of 191

$$\sigma_{\text{input6B}} = \pm 1.48435\% \text{ Flow}$$

11.6.2.1.6 Determination of Module Random Error (σ_{6A} , σ_{6B})

Using the methodology of Reference 3.3,

$$\sigma_{6A} = \pm [(\text{RA}_{6A(1\sigma)})^2 + (\text{RD}_{6A(1\sigma)})^2 + (\text{CAL}_{6A})^2 + (\text{ST}_{6A_{A(1\sigma)}})^2 + (\sigma_{\text{input6A}})^2]^{0.5} \% \text{ Flow}$$

$$\sigma_{6A} = \pm [(0.625)^2 + (0)^2 + (0.022538)^2 + (0.416667)^2 + (2.190936)^2]^{0.5} \% \text{ Flow}$$

$$\sigma_{6A} = \pm 2.316235\% \text{ Flow}$$

And

$$\sigma_{6B} = \pm [(\text{RA}_{6B(1\sigma)})^2 + (\text{RD}_{6B(1\sigma)})^2 + (\text{CAL}_{6B})^2 + (\text{ST}_{6B_{B(1\sigma)}})^2 + (\sigma_{\text{input6B}})^2]^{0.5} \% \text{ Flow}$$

$$\sigma_{6B} = \pm [(0.625)^2 + 0^2 + 0.022538^2 + 0.333333^2 + 1.48435^2]^{0.5} \% \text{ Flow}$$

$$\sigma_{6B} = \pm 1.644852\% \text{ Flow}$$

REVISION NO.

0

1

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345		PAGE 146 of 191	
<p>11.6.2.2 Module 6A Non-Random Errors ($\Sigma e6A$)</p> <p>11.6.2.2.1 Humidity Errors ($e6AH$)</p> <p>Since Reference 3.19 does not identify a humidity error term a value of zero will be used per Section 4.3.</p> <p>$e6AH = 0\% \text{ CS}$</p> <p>11.6.2.2.2 Temperature Error ($e6AT$)</p> <p>Since Reference 3.19 does not identify a temperature error term a value of zero will be used per Section 4.3.</p> <p>$e6AT = 0\% \text{ CS}$</p> <p>11.6.2.2.3 Radiation Error ($e6AR$)</p> <p>Since Reference 3.19 does not identify a radiation error term a value of zero will be used per Section 4.3.</p> <p>$e6AR = 0\% \text{ CS}$</p> <p>11.6.2.2.4 Seismic Error ($e6AS$)</p> <p>Per Section 4.7 seismic error for this module is considered negligible.</p> <p>$e6AS = 0\% \text{ CS}$</p> <p>11.6.2.2.5 Static Pressure Effect ($e6ASP$)</p> <p>This module is an all electronic device that is not exposed to any pressure other than atmospheric. Therefore, there is no static pressure effect.</p> <p>$e6ASP = 0\% \text{ CS}$</p> <p>11.6.2.2.6 Pressure Error ($e6AP$)</p> <p>This module is an all electronic device that is not exposed to any pressure other than atmospheric. Therefore, there is no pressure effect.</p> <p>$e6AP = 0\% \text{ CS}$</p>			
REVISION NO.	0		

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345		PAGE 147 of 191
<p>11.6.2.2.7 Process Errors (e6Ap)</p> <p>This module is intermediate in the loop and, as such, is not exposed to any process parameters. Therefore, there are no process errors.</p> <p style="padding-left: 40px;">$e6Ap = 0\% \text{ CS}$</p> <p>11.6.2.2.8 Power Supply Effects (e6AV)</p> <p>Since Reference 3.19 does not identify a power supply effect error term a value of zero will be used per Section 4.3.</p> <p style="padding-left: 40px;">$e6AV = 0\% \text{ CS}$</p> <p>11.6.2.2.9 Non-Random Input Error (einput6A, einput6B)</p> <p>In addition to its own error terms, the error terms from Module 6 must also be considered. Since the trip circuits perform no function on the input signal einput6A becomes equal to the non-random input term $\Sigma e6$ for the Hi Flow trip. However, the Comparator Trip is also looking at the output of another RFM so the reference input also has a $\Sigma e6$ term impressed on it. Since these are not random terms, it is expected that their magnitudes would be the same from each Module 6. However, the methodology of Reference 3.3 does not allow the cancellation of non-random terms. Therefore, the total error at the comparator will be the algebraic sum of two $\Sigma e6$ terms.</p> <p style="padding-left: 40px;">$einput6A = \pm \Sigma e6 = \pm 1.899635\% \text{ Flow}$</p> <p>And</p> <p style="padding-left: 40px;">$einput6B = \pm (\Sigma e6 + \Sigma e6) \% \text{ Flow}$</p> <p style="padding-left: 40px;">$einput6B = \pm (1.899635 + 1.899635) \% \text{ Flow}$</p> <p style="padding-left: 40px;">$einput6B = \pm 3.799270\% \text{ Flow}$</p>		
REVISION NO.	0	

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 148 of 191

11.6.2.2.10 Non-Random Error ($\Sigma e6A$, $\Sigma e6B$)

From Reference 3.3 the non-random error is the algebraic sum of all the above terms. In addition, all terms except einput6A and einput6B are in % CS and must be multiplied by 125/100 to convert to % Flow.

$$\Sigma e6A = \pm(125/100) * (e6AH + e6AT + e6AR + e6AS + e6ASP + e6AP + e6Ap + e6AV) + \text{einput6A} \% \text{ Flow}$$

$$\Sigma e6A = \pm(125/100) * (0 + 0 + 0 + 0 + 0 + 0 + 0 + 0) + 1.899635 \% \text{ Flow}$$

$$\Sigma e6A = \pm 1.899635 \% \text{ Flow}$$

And

$$\Sigma e6B = \pm(125/100) * (e6AH + e6AT + e6AR + e6AS + e6ASP + e6AP + e6Ap + e6AV) + \text{einput6B} \% \text{ Flow}$$

$$\Sigma e6B = \pm(125/100) * (0 + 0 + 0 + 0 + 0 + 0 + 0 + 0) + 3.799270 \% \text{ Flow}$$

$$\Sigma e6B = \pm 3.799270 \% \text{ Flow}$$

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

gus

CALCULATION NO. L-001345

PAGE 149 of 191

12.0 INSTRUMENT CHANNEL TOTAL ERRORS

From Reference 3.3 total instrument error is determined by the following equation:

Total Loop Error - Normal Conditions (Ten)

$$Ten = \pm(2\sigma + \Sigma en)$$

For this calculation there are eight different groups of Ten terms. These terms are listed below:

Ten_{AFB}, Ten_{AFB(AV)} - APRM Flow Biased Trips, Two Loop

Ten_{AFBSLO}, Ten_{AFB(AV)SLO} - APRM Flow Biased Trips, Single Loop

Ten_{AF}, Ten_{AF(AV)} - APRM Fixed High Power Trips

Ten_{RFB}, Ten_{RFB(AV)} - RBM Flow Biased Trips

Ten_{RF}, Ten_{RF(AV)} - RBM Fixed Trip

Ten_{RFMU}, Ten_{RFMU(AV)} - Recirculation Flow Monitor - Upscale

Ten_{RFMC}, Ten_{RFMC(AV)} - Recirculation Flow Monitor - Comparator

Ten_{AFLP}, Ten_{AFLP(AV)} - APRM Fixed Low Power Trips

The above terms with an _(AV) subscript have had the error terms associated with the process removed and will, therefore, be used in the Allowable Value calculations. The terms without the _(AV) subscript are used in the Analytical Limit calculations.

12.1 APRM Flow Biased Trips

Ten_{AFB} and Ten_{AFB(AV)} are made up of the uncertainty terms from the APRM Flow Biased Trip Module 4D. These uncertainty terms include both the uncertainties associated with the APRM neutron signal and the Recirculation Flow Monitor.

12.1.1 Two Loop Operation (Ten_{AFB}, Ten_{AFB(AV)}) - Using errors from Sections 11.4.4.1.6.1 and 11.4.4.2.10.1 for TLO, the errors are

$$Ten_{AFB} = \pm(2 * \sigma_{4D} + \Sigma e_{4D})$$

$$Ten_{AFB} = \pm(2 * 2.743466 + 1.626207)$$

$$Ten_{AFB} = \pm 7.113139 \% \text{ Power}$$

REVISION NO.

0

2

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 150 of 191

And the AV total error for TLO is determined as

$$\begin{aligned} \text{Ten}_{\text{AFB (AV)}} &= \pm(2\sigma 4D_{\text{AV}} + \Sigma e 4D_{\text{AV}}) \\ \text{Ten}_{\text{AFB (AV)}} &= \pm(2 * 2.380057 + 0.806207) \\ \text{Ten}_{\text{AFB (AV)}} &= \pm 5.566321\% \text{ Power} \end{aligned}$$

12.1.2 Single Loop Operation (Ten_{AFB} , $\text{Ten}_{\text{AFB (AV)}}$) - Using errors from Sections 11.4.4.1.6.2 and 11.4.4.2.10.2 for SLO, the error is

$$\begin{aligned} \text{Ten}_{\text{AFBSLO}} &= \pm(2 * \sigma 4D_{\text{SLO}} + \Sigma e 4D_{\text{SLO}}) \\ \text{Ten}_{\text{AFBSLO}} &= \pm(2 * 2.642756 + 1.536982) \\ \text{Ten}_{\text{AFBSLO}} &= \pm 6.822494 \% \text{ Power} \end{aligned}$$

And the AV total error for SLO is determined as

$$\begin{aligned} \text{Ten}_{\text{AFB (AV) SLO}} &= \pm(2 * \sigma 4D_{\text{AVSLO}} + \Sigma e 4D_{\text{AVSLO}}) \\ \text{Ten}_{\text{AFB (AV) SLO}} &= \pm(2 * 2.330580 + 0.716982) \\ \text{Ten}_{\text{AFB (AV) SLO}} &= \pm 5.378142\% \text{ Power} \end{aligned}$$

12.2 APRM Fixed Trips - Ten_{AF} , $\text{Ten}_{\text{AF (AV)}}$

Ten_{AF} and $\text{Ten}_{\text{AF (AV)}}$ are made up of the uncertainty terms from APRM Fixed Trip Module 4C. From Sections 11.4.3.1.6 and 11.4.3.2.10:

$$\begin{aligned} \text{Ten}_{\text{AF}} &= \pm(2\sigma 4C + \Sigma e 4C)\% \text{ Power} \\ \text{Ten}_{\text{AF}} &= \pm(2 * 2.435639 + 0.82)\% \text{ Power} \\ \text{Ten}_{\text{AF}} &= \pm 5.691278\% \text{ Power} \end{aligned}$$

And

$$\begin{aligned} \text{Ten}_{\text{AF (AV)}} &= \pm(2\sigma 4C_{\text{AV}} + \Sigma e 4C_{\text{AV}})\% \text{ Power} \\ \text{Ten}_{\text{AF (AV)}} &= \pm(2 * 2.133079 + 0)\% \text{ Power} \\ \text{Ten}_{\text{AF (AV)}} &= \pm 4.266158\% \text{ Power} \end{aligned}$$

12.3 RBM Flow Biased Trips - Ten_{RFB} , $\text{Ten}_{\text{RFB (AV)}}$

Ten_{RFB} and $\text{Ten}_{\text{RFB (AV)}}$ are made up of the uncertainty terms from the RBM Flow Biased Trip Module 5C. These uncertainty terms include both the uncertainties associated with the RBM neutron signal and the Recirculation Flow Monitor. From Sections 11.5.3.1.6 and 11.5.3.2.10:

$$\begin{aligned} \text{Ten}_{\text{RFB}} &= \pm(2\sigma 5C + \Sigma e 5C)\% \text{ Power} \\ \text{Ten}_{\text{RFB}} &= \pm(2 * 2.874811 + 1.672412)\% \text{ Power} \\ \text{Ten}_{\text{RFB}} &= \pm 7.422034\% \text{ Power} \end{aligned}$$

And

$$\begin{aligned} \text{Ten}_{\text{RFB (AV)}} &= \pm(2\sigma 5C_{\text{AV}} + \Sigma e 5C_{\text{AV}})\% \text{ Power} \\ \text{Ten}_{\text{RFB (AV)}} &= \pm(2 * 2.404668 + 0.852412)\% \text{ Power} \\ \text{Ten}_{\text{RFB (AV)}} &= \pm 5.661747\% \text{ Power} \end{aligned}$$

REVISION NO.

0

2

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 151 of 191

12.4 RBM Fixed Trip - Ten_{RF} , $Ten_{RF(AV)}$

Ten_{RF} and $Ten_{RF(AV)}$ are made up of the uncertainty terms from RBM Fixed Trip Module 5B. From Sections 11.5.2.1.6 and 11.5.2.2.10:

$$Ten_{RF} = \pm(2\sigma_{5B} + \Sigma e_{5B})\% \text{ Power}$$

$$Ten_{RF} = \pm(2*2.316113 + 0.82) \% \text{ Power}$$

$$Ten_{RF} = \pm 5.452226\% \text{ Power}$$

And

$$Ten_{RF(AV)} = \pm(2\sigma_{5B_{AV}} + \Sigma e_{5B_{AV}})\% \text{ Power}$$

$$Ten_{RF(AV)} = \pm(2*2.129873 + 0)\% \text{ Power}$$

$$Ten_{RF(AV)} = \pm 4.259745\% \text{ Power}$$

12.5 Recirculation Flow Monitor - Upscale - Ten_{RFMU} , $Ten_{RFMU(AV)}$

Ten_{RFMU} and $Ten_{RFMU(AV)}$ are made up of the uncertainty terms from Recirculation Flow Monitor 3A. From Sections 11.3.3.1.6 and 11.3.3.2.10:

$$Ten_{RFMU} = \pm(2\sigma_{3A} + \Sigma e_{3A}) \% \text{ Flow}$$

$$Ten_{RFMU} = \pm(2*2.92796 + 1.274635)\% \text{ Flow}$$

$$Ten_{RFMU} = \pm 7.130555\% \text{ Flow}$$

And

$$Ten_{RFMU(AV)} = \pm(2\sigma_{3A_{AV}} + \Sigma e_{3A}) \% \text{ Flow}$$

$$Ten_{RFMU(AV)} = \pm(2*2.207804 + 1.274635) \% \text{ Flow}$$

$$Ten_{RFMU(AV)} = \pm 5.690244\% \text{ Flow}$$

Note that for the RFM loops there were no non-random terms associated with the process. Therefore, the non-random term Σe_{3A} is applicable to both the AL and AV total error terms.

12.6 Recirculation Flow Monitor - Upscale - Comparator - Ten_{RFMC} , $Ten_{RFMC(AV)}$

Ten_{RFMC} and $Ten_{RFMC(AV)}$ are made up of the uncertainty terms from Recirculation Flow Monitor 3B. From Sections 11.3.3.1.6 and 11.3.3.2.10:

REVISION NO.

0

1

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 152 of 191

$$\text{Ten}_{\text{RFMC}} = \pm(2\sigma_{3B} + \Sigma e_{3B})\% \text{ Flow}$$

$$\text{Ten}_{\text{RFMC}} = \pm(2*2.756468 + 2.54927)\% \text{ Flow}$$

$$\text{Ten}_{\text{RFMC}} = \pm 8.062206\% \text{ Flow}$$

Per Section 4.9 the process variables have already been removed from the uncertainty terms for the comparator trip. Therefore,

$$\text{Ten}_{\text{RFMC (AV)}} = \text{Ten}_{\text{RFMC}} = \pm 8.062206\% \text{ Flow}$$

12.7 APRM Fixed Low Power Trips - Ten_{AFLP} , $\text{Ten}_{\text{AFLP (AV)}}$

Ten_{AFLP} and $\text{Ten}_{\text{AFLP (AV)}}$ are made up of the uncertainty terms from APRM Fixed Trip Module $4C_{LP}$. From Sections 11.4.3.1.6 and 11.4.3.2.10:

$$\text{Ten}_{\text{AFLP}} = \pm(2\sigma_{4C_{LP}} + \Sigma e_{4C_{LP}})\% \text{ Power}$$

$$\text{Ten}_{\text{AFLP}} = \pm(2*2.150421 + 0.33)\% \text{ Power}$$

$$\text{Ten}_{\text{AFLP}} = \pm 4.630842\% \text{ Power}$$

For the Allowable Value calculation the uncertainties for the fixed low power trips are the same as for the fixed high power trip. Therefore,

$$\text{Ten}_{\text{AFLP (AV)}} = \text{Ten}_{\text{AF (AV)}} = \pm 4.266158\% \text{ Power}$$

REVISION NO.

0

1

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 153 of 191

13.0 ERROR ANALYSIS SUMMARY & CONCLUSIONS

The total uncertainties applicable to the ABB Flow Unit are smaller than those associated with the GE Flow Unit. Therefore, all calculations will be performed using those terms applicable to the GE Flow Unit since the results will then be conservative for operation using the ABB Flow Unit.

13.1 APRM Flow Biased Trips

The APRM Flow Biased Trips have a different total uncertainty term for both single (Ten_{AFBSLO}) and two (Ten_{AFB}) recirculation loop operation. This results from the difference in the flow biased trip slope for the analytical limits in design input 4.14.

13.1.1 Simulated Thermal Power Upscale (Scram) - Two Loop Operation

Using the Reference 3.34 methodology, the nominal trip setpoint for an upscale or increasing trip is determined as follows:

$$NTSP = AL - Ten$$

For this calculation this becomes:

$$NTSP_{STP2} = AL_{STP2} - Ten_{AFB}$$

For software reasons the AL and NTSP are broken into two parts:

$$AL_{STP2} = FCS_{SP} * W + AL_{STP2OS}$$

$$NTSP_{STP2} = FCS_{SP} * W + NTSP_{STP2OS}$$

Substituting the analytical limit from Design Input 4.14 and the total uncertainty from Section 12.1.1 yields:

$$NTSP_{STP2} = FCS_{SP} * W + (AL_{STP2OS} - Ten_{AFB})$$

$$NTSP_{STP2} = 0.62W + (70.9 - 7.113139)$$

$$NTSP_{STP2} = 0.62W + 63.786861\%, \text{ rounded to } 0.62W + 63.7\% \text{ Power}$$

In a similar fashion the Allowable Value can be calculated using the applicable uncertainty (5.566321% Power) from Section 12.1.1.

$$AV_{STP2} = FCS_{SP} * W + NTSP_{STP2OS} + Ten_{AFB(AV)}$$

$$AV_{STP2} = 0.62W + 63.786861\% \text{ Power} + 5.566321$$

$$AV_{STP2} = 0.62W + 69.353182\%, \text{ rounded to } 0.62W + 69.3\% \text{ Power}$$

REVISION NO.

0

2

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 154 of 191

13.1.2 Simulated Thermal Power Upscale (Scram)-Single Loop Operation

Using the Reference 3.34 methodology, the nominal trip setpoint for an upscale or increasing trip is determined as follows:

$$NTSP = AL - Ten$$

For this calculation this becomes:

$$NTSP_{STP1} = AL_{STP1} - Ten_{AFB}$$

For software reasons the AL and NTSP are broken into two parts:

$$AL_{STP1} = FCS_{SP} * W + AL_{STP10S}$$

$$NTSP_{STP1} = FCS_{SP} * W + NTSP_{STP10S}$$

Substituting the analytical limit from Design Input 4.14 and the total uncertainty from Section 12.1.2 yields:

$$NTSP_{STP1} = FCS_{SP} * W + AL_{STP10S} - Ten_{AFB} \% \text{ Power}$$

$$NTSP_{STP1} = 0.55W + 58.33 - 6.822494 \% \text{ Power}$$

$$NTSP_{STP1} = 0.55W + 51.507506\%, \text{ rounded to } 0.55W + 51.5 \% \text{ Power}$$

In a similar fashion the Allowable Value can be calculated using the applicable uncertainty (5.378142% Power) from Section 12.1.2.

$$AV_{STP1} = FCS_{SP} * W + NTSP_{STP10S} + Ten_{AFB(AV)} \% \text{ Power}$$

$$AV_{STP1} = 0.55W + 51.507506 + 5.378142 \% \text{ Power}$$

$$AV_{STP1} = 0.55W + 56.885648\%, \text{ rounded to } 0.55W + 56.8\%$$

13.1.3 Simulated Thermal Power Upscale (Rod Block)-Two Loop Operation

Using the Reference 3.34 methodology, the nominal trip setpoint for an upscale or increasing trip is determined as follows:

$$NTSP = AL - Ten$$

For this calculation this becomes:

$$NTSP_{STP2RB} = AL_{STP2RB} - Ten_{AFB}$$

REVISION NO.

0

2

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 155 of 191

For software reasons the AL and NTSP are broken into two parts:

$$AL_{STP2RB} = FCS_{SP} * W + AL_{STP2RBOS}$$

$$NTSP_{STP2RB} = FCS_{SP} * W + NTSP_{STP2RBOS}$$

Substituting the analytical limit from Design Input 4.14 and the total uncertainty from Section 12.1.1 yields:

$$NTSP_{STP2RB} = FCS_{SP} * W + AL_{STP2RBOS} - Ten_{AFB}$$

$$NTSP_{STP2RB} = 0.62W + 59.47 - 7.113139$$

$$NTSP_{STP2RB} = 0.62W + 52.356861\%, \text{ rounded to } 0.62W + 52.3 \%$$

In a similar fashion the Allowable Value can be calculated using the applicable uncertainty (5.566321% Power) from Section 12.1.1.

$$AV_{STP2RB} = FCS_{SP} * W + NTSP_{STP2RBOS} + Ten_{AFB(AV)}$$

$$AV_{STP2RB} = 0.62W + 52.356861 + 5.566321$$

$$AV_{STP2RB} = 0.62W + 57.923182\%, \text{ rounded to } 0.62W + 57.9\%$$

13.1.4 Simulated Thermal Power Upscale (Rod Block) - Single Loop

Using the Reference 3.34 methodology, the nominal trip setpoint for an upscale or increasing trip is determined as follows:

$$NTSP = AL - Ten$$

For this calculation this becomes:

$$NTSP_{STP1RB} = AL_{STP1RB} - Ten_{AFB}$$

For software reasons the AL and NTSP are broken into two parts:

$$AL_{STP1RB} = FCS_{SP} * W + AL_{STP1RBOS}$$

$$NTSP_{STP1RB} = FCS_{SP} * W + NTSP_{STP1RBOS}$$

Substituting the analytical limit from Design Input 4.14 and the total uncertainty from Section 12.1.2 yields:

$$NTSP_{STP1RB} = FCS_{SP} * W + AL_{STP1RBOS} - Ten_{AFB}$$

$$NTSP_{STP1RB} = 0.55W + 46.9 - 6.822494$$

$$NTSP_{STP1RB} = 0.55W + 40.077506\%, \text{ rounded to } 0.55W + 40.0 \%$$

REVISION NO.

0

2

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345		PAGE 156 of 191	
<p>In a similar fashion the Allowable Value can be calculated using the applicable uncertainty (5.378142% Power) from Section 12.1.2.</p> $AV_{STP1RB} = FCS_{SP} * W + NTSP_{STP1RBOS} + Ten_{AFB(AV)} \% \text{ Power}$ $AV_{STP1RB} = 0.55W + 40.077506 + 5.378142 \% \text{ Power}$ $AV_{STP1RB} = 0.55W + 45.455648\%, \text{ rounded to } 0.55W + 45.4\%$			
REVISION NO.	0	2	

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 157 of 191

13.2 APRM Fixed Trips

The APRM Fixed Trips are divided into two groups, High Power Level Trips and Low Power Level Trips. The uncertainty terms for these trips are Ten_{AF} and Ten_{AFLP} respectively.

13.2.1 Neutron Flux High (Scram)

From Section 10.4 the existing Technical Specifications Nominal Trip Setpoint (NTSP) for this function is $\leq 118\%$ Power. For this calculation this will be the starting point and the resulting Analytical Limit will be calculated.

From Section 12.2 the total uncertainty for this function is $\pm 5.691278\%$ Power. From Reference 3.3 the relationship between NTSP and AL for an upscale trip is:

$$AL = NTSP + Ten$$

For this calculation this becomes:

$$AL_{FS} = NTSP_{FS} + Ten_{AF} \% \text{ Power}$$

$$AL_{FS} = 118 + 5.691278 \% \text{ Power}$$

$$AL_{FS} = 123.691278\% \text{ Power}$$

In a similar fashion the Allowable Value can be calculated using the applicable uncertainty (4.266158% Power) from Section 12.2.

$$AV_{FS} = NTSP_{FS} + Ten_{AF(AV)} \% \text{ Power}$$

$$AV_{FS} = 118 + 4.266158 \% \text{ Power}$$

$$AV_{FS} = 122.266158\% \text{ power}$$

13.2.2 Neutron Flux High - Setdown (Scram)

From Section 10.4 the existing Technical Specifications Nominal Trip Setpoint (NTSP) for this function is $\leq 15\%$ Power. For this calculation this will be the starting point and the resulting Analytical Limit will be calculated.

From Section 12.7 the total uncertainty for this function is $\pm 4.630842\%$ Power. From Reference 3.3 the relationship between NTSP and AL for an upscale trip is:

$$AL = NTSP + Ten$$

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 158 of 191

For this calculation this becomes:

$$AL_{FSS} = NTSP_{FSS} + Ten_{AFLP} \% \text{ Power}$$

$$AL_{FSS} = 15 + 4.630842 \% \text{ Power}$$

$$AL_{FSS} = 19.630842\% \text{ Power}$$

In a similar fashion the Allowable Value can be calculated using the applicable uncertainty (4.266158% Power) from Section 12.7.

$$AV_{FSS} = NTSP_{FSS} + Ten_{AF(AV)} \% \text{ Power}$$

$$AV_{FSS} = 15 + 4.266158 \% \text{ Power}$$

$$AV_{FSS} = 19.266158\% \text{ Power}$$

These values for AL and AV will not support the existing Tech Spec AV of $\leq 20 \% \text{ Power}$. Therefore, the calculation will be performed using the AL provided in Section 4.14 (and Reference 3.27) ($\leq 25 \% \text{ Power}$).

For an upscale trip:

$$NTSP = AL - Ten$$

For this calculation:

$$NTSP_{FSSN} = AL_{FSSN} - Ten_{AFLP} \% \text{ Power}$$

$$NTSP_{FSSN} = 25 - 4.630842 \% \text{ Power}$$

$$NTSP_{FSSN} = 20.369158\% \text{ Power}$$

From this a new AV can be calculated:

$$AV_{FSSN} = NTSP_{FSSN} + Ten_{AF(AV)} \% \text{ Power}$$

$$AV_{FSSN} = 20.369158 + 4.266158 \% \text{ Power}$$

$$AV_{FSSN} = 24.635316\% \text{ Power}$$

13.2.3 Neutron Flux High - Setdown (Rod Block)

From Section 10.4 the existing Technical Specifications Nominal Trip Setpoint (NTSP) for this function is $\leq 12\% \text{ Power}$. For this calculation this will be the starting point and the resulting Analytical Limit will be calculated.

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 159 of 191

From Section 12.7 the total uncertainty for this function is $\pm 4.630842\%$ Power. From Reference 3.3 the relationship between NTSP and AL for an upscale trip is:

$$AL = NTSP + Ten$$

For this calculation this becomes:

$$AL_{RBS} = NTSP_{RBS} + Ten_{AFLP} \% \text{ Power}$$

$$AL_{RBS} = 12 + 4.630842 \% \text{ Power}$$

$$AL_{RBS} = 16.630842\% \text{ Power}$$

In a similar fashion the Allowable Value can be calculated using the applicable uncertainty (4.266158% Power) from Section 12.7.

$$AV_{RBS} = NTSP_{RBS} + Ten_{AF(AV)} \% \text{ Power}$$

$$AV_{RBS} = 12 + 4.266158 \% \text{ Power}$$

$$AV_{RBS} = 16.266158\% \text{ Power}$$

These values for AL and AV will not support the existing Tech Spec AV of $\leq 14\%$ Power. Therefore, the calculation will be performed using the AL provided in Section 4.14 (and Reference 3.27) ($\leq 19\%$ Power).

For an upscale trip:

$$NTSP = AL - Ten$$

For this calculation:

$$NTSP_{RBSN} = AL_{RBSN} - Ten_{AFLP} \% \text{ Power}$$

$$NTSP_{RBSN} = 19 - 4.630842 \% \text{ Power}$$

$$NTSP_{RBSN} = 14.369158\% \text{ Power}$$

From this a new AV can be calculated:

$$AV_{RBSN} = NTSP_{RBSN} + Ten_{AF(AV)} \% \text{ Power}$$

$$AV_{RBSN} = 14.369158 + 4.266158 \% \text{ Power}$$

$$AV_{RBSN} = 18.635316\% \text{ Power}$$

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

946

CALCULATION NO. L-001345		PAGE 160 of 191
<p>13.2.4 Neutron Flux Downscale (Rod Block)</p> <p>From Section 10.4 the existing Technical Specifications Nominal Trip Setpoint (NTSP) for this function is $\geq 5\%$ Power. For this calculation this will be the starting point and the resulting Analytical Limit will be calculated.</p> <p>From Section 12.7 the total uncertainty for this function is $\pm 4.630842\%$ Power. From Reference 3.3 the relationship between NTSP and AL for a downscale trip is:</p> $AL = NTSP - Ten$ <p>For this calculation this becomes:</p> $AL_{DS} = NTSP_{DS} - Ten_{AFLP} \% \text{ Power}$ $AL_{DS} = 5 - 4.630842 \% \text{ Power}$ $AL_{DS} = 0.369158\% \text{ Power}$ <p>In a similar fashion the Allowable Value can be calculated using the applicable uncertainty (4.266158% Power) from Section 12.7.</p> $AV_{DS} = NTSP_{DS} - Ten_{AF(AV)} \% \text{ Power}$ $AV_{DS} = 5 - 4.266158 \% \text{ Power}$ $AV_{DS} = 0.733842\% \text{ Power}$ <p>13.2.5 Neutron Flux High Flow Clamped - Two Loop Operation (Scram)</p> <p>From Section 10.4 the existing Technical Specifications Nominal Trip Setpoint (NTSP) for this function is $\leq 113.5\%$ Power. For this calculation this will be the starting point and the resulting Analytical Limit will be calculated.</p> <p>From Section 12.2 the total uncertainty for this function is $\pm 5.691278\%$ Power. From Reference 3.3 the relationship between NTSP and AL for an upscale trip is:</p> $AL = NTSP + Ten$ <p>For this calculation this becomes:</p> $AL_{HFC} = NTSP_{HFC} + Ten_{AF} \% \text{ Power}$ $AL_{HFC} = 113.5 + 5.691278 \% \text{ Power}$		
REVISION NO.	0	2

COMMONWEALTH EDISON COMPANY

945

CALCULATION NO. L-001345

PAGE 161 of 191

$$AL_{HFC} = 119.19128\% \text{ Power}$$

In a similar fashion the Allowable Value can be calculated using the applicable uncertainty (4.266158% Power) from Section 12.2.

$$AV_{HFC} = NTSP_{HFC} + Ten_{AF(AV)} \% \text{ Power}$$

$$AV_{HFC} = 113.5 + 4.266158 \% \text{ Power}$$

$$AV_{HFC} = 117.766158\% \text{ Power}$$

13.2.6 Neutron Flux High Flow Clamped - Single Loop Operation (Scram)

From Design Input 4.14, the revised Analytical Limit (AL) resulting from Power Uprate for this function is 113.8% Power. Using this and the total uncertainty for this function from Section 12.2 of $\pm 5.691278\%$ Power, the resulting Nominal Trip Setpoint (NTSP) will be calculated. From Reference 3.34 the relationship between NTSP and AL for an upscale trip is:

$$NTSP = AL - Ten$$

For this calculation this becomes:

$$NTSP_{HFCSLO} = AL_{HFCSLO} - Ten_{AF} \% \text{ Power}$$

$$NTSP_{HFCSLO} = 113.8 \% - 5.691278\%$$

$$NTSP_{HFCSLO} = 108.108722\%, \text{ rounded to } 108.1\%$$

In a similar fashion the Allowable Value can be calculated using the applicable uncertainty (4.266158% Power) from Section 12.2.

$$AV_{HFCSLO} = NTSP_{HFCSLO} + Ten_{AF(AV)} \% \text{ Power}$$

$$AV_{HFCSLO} = 108.108722 + 4.266158 \% \text{ Power}$$

$$AV_{HFCSLO} = 112.37488 \% \text{ Power, rounded to } 112.3 \% \text{ Power}$$

REVISION NO.

0

2

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 162 of 191

13.3 RBM Flow Biased Trips

The RBM Flow Biased Trips have the same total uncertainty term (Ten_{RFB}) whether in Two Recirculation Loop Operation or Single Recirculation Loop Operation. This is because there are no changes made to the method of operation of the Recirculation Flow Monitor for either Single or Two Loop Operation. Therefore, the error analysis for the RFB is the same.

13.3.1 Upscale Trip - Two Loop Operation

From Section 10.5 the existing Nominal Trip Setpoint (NTSP) for this function is $\leq 0.66W + 45\%$ Power. For this calculation this will be the starting point and the resulting Analytical Limit will be calculated.

From Section 12.3 the total uncertainty for this function is $\pm 7.422034\%$ Power. From Reference 3.3 the relationship between NTSP and AL for an upscale trip is:

$$AL = NTSP + Ten$$

For this calculation this becomes:

$$AL_{RBM2} = NTSP_{RBM2} + Ten_{RFB}$$

For software reasons the AL and NTSP are broken into two parts:

$$AL_{RBM2} = FCS_{RBM(SP)} * W + AL_{RBM2OS}$$

$$NTSP_{RBM2} = FCS_{RBM(SP)} * W + NTSP_{RBM2OS}$$

Substituting and solving yields:

$$AL_{RBM2} = FCS_{RBM(SP)} * W + NTSP_{RBM2OS} + Ten_{RFB} \% \text{ Power}$$

$$AL_{RBM2} = 0.66W + 45 + 7.422034 \% \text{ Power}$$

$$AL_{RBM2} = 0.66W + 52.422034 \% \text{ Power}$$

In a similar fashion the Allowable Value can be calculated using the applicable uncertainty (5.661747% Power) from Section 12.3.

$$AV_{RBM2} = FCS_{RBM(SP)} * W + NTSP_{RBM2OS} + Ten_{RFB(AV)} \% \text{ Power}$$

$$AV_{RBM2} = 0.66W + 45 + 5.661747 \% \text{ Power}$$

$$AV_{RBM2} = 0.66W + 50.661747\% \text{ Power}$$

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 163 of 191

13.3.2 Upscale Trip - Single Loop Operation

From Section 10.5 the existing Nominal Trip Setpoint (NTSP) for this function is $\leq 0.66W + 39.7\%$ Power. For this calculation this will be the starting point and the resulting Analytical Limit will be calculated.

From Section 12.3 the total uncertainty for this function is $\pm 7.422034\%$ Power. From Reference 3.3 the relationship between NTSP and AL for an upscale trip is:

$$AL = NTSP + Ten$$

For this calculation this becomes:

$$AL_{RBM1} = NTSP_{RBM1} + Ten_{RFB}$$

For software reasons the AL and NTSP are broken into two parts:

$$AL_{RBM1} = FCS_{RBM(SP)} * W + AL_{RBM1OS}$$

$$NTSP_{RBM1} = FCS_{RBM(SP)} * W + NTSP_{RBM1OS}$$

Substituting and solving yields:

$$AL_{RBM1} = FCS_{RBM(SP)} * W + NTSP_{RBM1OS} + Ten_{RFB} \% \text{ Power}$$

$$AL_{RBM1} = 0.66W + 39.7 + 7.422034 \% \text{ Power}$$

$$AL_{RBM1} = 0.66W + 47.122034 \% \text{ Power}$$

In a similar fashion the Allowable Value can be calculated using the applicable uncertainty (5.661747% Power) from Section 12.3.

$$AV_{RBM1} = FCS_{RBM(SP)} * W + NTSP_{RBM1OS} + Ten_{RFB(AV)} \% \text{ Power}$$

$$AV_{RBM1} = 0.66W + 39.7 + 5.661747 \% \text{ Power}$$

$$AV_{RBM1} = 0.66W + 45.361747\% \text{ Power}$$

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 164 of 191

13.4 RBM Downscale Trip

From Section 10.4 the existing Technical Specifications Nominal Trip Setpoint (NTSP) for this function is $\geq 5\%$ Power. For this calculation this will be the starting point and the resulting Analytical Limit will be calculated.

From Section 12.4 the total uncertainty for this function is $\pm 5.452226\%$ Power. From Reference 3.3 the relationship between NTSP and AL for a downscale trip is:

$$AL = NTSP - Ten$$

For this calculation this becomes:

$$AL_{RBMS} = NTSP_{RBMS} - Ten_{RF} \% \text{ Power}$$

$$AL_{RBMS} = 5 - 5.452226 \% \text{ Power}$$

$$AL_{RBMS} = -0.452226\% \text{ Power}$$

In a similar fashion the current Allowable Value can be calculated using the applicable uncertainty (4.259745% Power) from Section 12.4. The starting point will be the current NTSP.

$$AV_{RBMS} = NTSP_{RBMS} - Ten_{RF(AV)} \% \text{ Power}$$

$$AV_{RBMS} = 5 - 4.259745 \% \text{ Power}$$

$$AV_{RBMS} = 0.740255\% \text{ Power}$$

Since a negative power is not possible a new calculation will be performed starting with AL equal to 0 (Section 4.14 and Reference 3.27) and determining a new NTSP.

$$NTSP_{DSN} = AL_0 + Ten_{RF} \% \text{ Power}$$

$$NTSP_{DSN} = 0 + 5.452226 \% \text{ Power}$$

$$NTSP_{DSN} = 5.452226\% \text{ Power}$$

In a similar fashion the Allowable Value can be calculated using the applicable uncertainty (4.259745% Power) from Section 12.4. For ease of calibration, the new NTSP will be selected to be 5.5% , $NTSP_{RBMS}$, and this will be the starting point.

$$AV_{RBMS} = NTSP_{RBMS} - Ten_{RF(AV)} \% \text{ Power}$$

$$AV_{RBMS} = 5.5 - 4.259745 \% \text{ Power}$$

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 165 of 191

$AV_{RBMS} = 1.240255\%$ Power

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 166 of 191

13.5 Recirculation Flow Monitor - Upscale

From Section 10.3 the existing Technical Specifications Nominal Trip Setpoint (NTSP) for this function is $\leq 108\%$ Flow. For this calculation this will be the starting point and the resulting Analytical Limit (AL) will be calculated.

From Section 12.5 the total uncertainty for this function is $\pm 7.130555\%$ Flow. From Reference 3.3 the relationship between NTSP and AL for an upscale trip is:

$$AL = NTSP + Ten$$

For this calculation this becomes:

$$AL_{RFMU} = NTSP_{RFMU} + Ten_{RFMU} \% \text{ Flow}$$

$$AL_{RFMU} = 108 + 7.130555 \% \text{ Flow}$$

$$AL_{RFMU} = 115.130555\% \text{ Flow}$$

In a similar fashion the Allowable Value can be calculated using the applicable uncertainty (5.690244% Flow) from Section 12.5.

$$AV_{RFMU} = NTSP_{RFMU} + Ten_{RFMU(AV)} \% \text{ Flow}$$

$$AV_{RFMU} = 108 + 5.690244 \% \text{ Flow}$$

$$AV_{RFMU} = 113.690244\% \text{ Flow}$$

REVISION NO.

0

1

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 167 of 191

13.6 Recirculation Flow Monitor - Comparator

From Section 10.3 the existing Technical Specifications Nominal Trip Setpoint (NTSP) for this function is $\leq 10\%$ Flow. For this calculation this will be the starting point and the resulting Analytical Limit (AL) will be calculated.

From Section 12.6 the total uncertainty for this function is $\pm 8.062206\%$ Flow. From Reference 3.3 the relationship between NTSP and AL for an upscale trip is:

$$AL = NTSP + Ten$$

For this calculation this becomes:

$$AL_{RFMC} = NTSP_{RFMC} + Ten_{RFMC} \% \text{ Flow}$$

$$AL_{RFMC} = 10 + 8.062206 \% \text{ Flow}$$

$$AL_{RFMC} = 18.062206\% \text{ Flow}$$

Per Section 4.9 the process term has already been removed from the uncertainty terms for the comparator trip. Therefore,

$$AV_{RFMC} = AL_{RFMC} = 18.062206\% \text{ Flow}$$

REVISION NO.

0

1

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 168 of 191

14.0 CONCLUSIONS

This calculation indicates that the following Nominal Trip Setpoints and Allowable Values are acceptable except for the RBM Downscale Trip function for which a new setpoint needed to be calculated. Use of the setpoint values either validated or determined by this calculation provides a high degree of confidence that the Allowable Values will not be exceeded during normal operating conditions.

14.1 APRM Flow Biased Trips

14.1.1 Simulated Thermal Power Upscale (Scram) - Two Loop Operation

Analytical Limit: 0.62W + 70.9 % Power
Tech Spec AV: 0.62W + 69.3 % Power
Tech Spec NTSP: 0.62W + 63.7 % Power

Calibration setpoint: Since the setpoint is calibrated at a specific drive flow, the nominal setpoint should be set at least 0.04 Vdc below the corresponding Tech Spec NTSP with a tolerance of +/- 0.04 Vdc. For example, with an 80% drive flow, the Tech Spec NTSP is 113.3% ($0.62 \times 80 + 63.7$). Since 113.3% on a 125% scale corresponds to 9.064 Vdc on a 10 Vdc scale [$10\text{Vdc} \times 113.3\% / 125\%$], a setpoint of 9.020 +/- 0.04 Vdc is recommended for 80% drive flow.

14.1.2 Simulated Thermal Power Upscale (Scram) Single Loop Operation

Analytical Limit: 0.55W + 58.33 % Power
Tech Spec AV: 0.55W + 56.8 % Power
Tech Spec NTSP: 0.55W + 51.5 % Power

Calibration setpoint: Since the setpoint is calibrated at a specific drive flow, the nominal setpoint should be set at least 0.04 Vdc below the corresponding Tech Spec NTSP with a tolerance of +/- 0.04 Vdc. For example, with an 80% drive flow, the Tech Spec NTSP is 95.5% ($0.55 \times 80 + 51.5$). Since 95.5% on a 125% scale corresponds to 7.640 Vdc on a 10 Vdc scale [$10\text{Vdc} \times 95.5\% / 125\%$], a setpoint of 7.600 +/- 0.04 Vdc is recommended for 80% drive flow.

14.1.3 Simulated Thermal Power Upscale (Rod Block) Two Loop Operation

Analytical Limit: 0.62W + 59.47 % Power
Tech Spec AV: 0.62W + 57.9 % Power
Tech Spec NTSP: 0.62W + 52.3 % Power

Calibration setpoint: Since the setpoint is calibrated at a specific drive flow, the nominal setpoint should be set at least 0.04 Vdc below the corresponding Tech Spec NTSP with a tolerance of +/- 0.04 Vdc. For example, with an 80% drive flow, the Tech Spec NTSP is 101.9% ($0.62 \times 80 + 52.3$). Since 101.9% on a 125% scale corresponds to 8.152 Vdc on a 10 Vdc scale [$10\text{Vdc} \times 101.9\% / 125\%$], a setpoint of 8.110 +/- 0.04 Vdc is recommended for 80% drive flow.

REVISION NO.

0

2

COMMONWEALTH EDISON COMPANY

gab

CALCULATION NO. L-001345

PAGE 169 of 191

14.1.4 Simulated Thermal Power Upscale (Rod Block) Single Loop Operation

Analytical Limit: 0.55W + 46.9 % Power
Tech Spec AV: 0.55W + 45.4 % Power
Tech Spec NTSP: 0.55W + 40 % Power

Calibration setpoint: Since the setpoint is calibrated at a specific drive flow, the nominal setpoint should be set at least 0.04 Vdc below the corresponding Tech Spec NTSP with a tolerance of +/- 0.04 Vdc. For example, with an 80% drive flow, the Tech Spec NTSP is 84.0% (0.55*80 +40.0). Since 84.0% on a 125% scale corresponds to 6.720 Vdc on a 10 Vdc scale [10Vdc*84.0%/125%], a setpoint of 6.680 +/- 0.04 Vdc is recommended for 80% drive flow.

14.2 APRM Fixed Trips

14.2.1 Neutron Flux High (Scram)

Tech Spec NTSP: 118 % Power
Tech Spec AV: 120 % Power
Calculated AV: 122.27 % Power
Calculated AL: 123.69 % Power

Reference 3.27 requested that these values be evaluated against two Analytical Limits, 122.4 and 124.2 % Power. As shown above this calculation will not support an AL of 122.4. It does show, however, that there is positive margin between the calculated AL and 124.2 % Power. The Reload Analysis must be changed to justify the use of a new AL of 124.2 % Power.

14.2.2 Neutron Flux High - Setdown (Scram)

Tech Spec NTSP: 15 % Power
Tech Spec AV: 20 % Power
Calculated AV: 19.27 % Power
Calculated AL: 19.63 % Power

REVISION NO.

0

2

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 170 of 191

AL: 25 % Power
(from Ref. 3.27)

Calculated NTSP: 20.37 % Power
(from Ref. 3.27 AL)

Calculated AV: 24.64 % Power
(from Ref. 3.27 AL)

This calculation shows that an AL as low as approximately 20.5 % Power would support the existing Tech Spec NTSP and AV. However, using an AL of 25 % Power gives a positive margin of more than 4 % Power between the existing AV and the AV calculated from an AL of 25 % Power.

14.2.3 Neutron Flux High - Setdown (Rod Block)

Tech Spec NTSP: 12 % Power

Tech Spec AV: 14 % Power

Calculated AV: 16.27 % Power

Calculated AL: 16.63 % Power

AL: 19 % Power
(from Ref. 3.27)

Calculated NTSP: 14.37 % Power
(from Ref. 3.27 AL)

Calculated AV: 18.64 % Power
(from Ref. 3.27 AL)

This calculation shows that the existing Tech Spec NTSP and AV are supported by an AL of 16.63 % Power. Therefore, there is greater than 2 % Power positive margin between the calculated AL and that proposed in Reference 3.27.

14.2.4 Neutron Flux Downscale (Rod Block)

Tech Spec NTSP: 5 % Power

Tech Spec AV: 3 % Power

Calculated AV: 0.73 % Power

Calculated AL: 0.37 % Power

Reference 3.27 proposed an AL of 0% Power for this function.

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 171 of 191

This calculation shows that there is a 0.37 % Power positive margin between the this and the calculated AL.

14.2.5 Neutron Flux High Flow Clamped - Two Loop Operation (Scram)

Tech Spec NTSP:	113.5 % Power
Tech Spec AV:	115.5 % Power
Calculated AV:	117.77 % Power
Calculated AL:	119.19 % Power

Reference 3.27 requests that these results be evaluated against ALs of 115.5% Power and 119.5% Power. As shown above this calculation will not support an AL of 115.5. However, there is a positive margin of about 0.3% Power between the calculated AL and the 119.5% Power value proposed by Reference 3.27. The Reload Analysis must be changed to justify the use of a new AL of 119.5 % Power.

14.2.6 Neutron Flux High Flow Clamped-Single Loop Operation (Scram)

Analytical Limit:	113.8 %
Tech Spec NTSP:	108.1 %
Tech Spec AV:	112.3 %

The calibration setpoint should be at least 0.04 Vdc below the Tech Spec NTSP with a tolerance of +/- 0.04 Vdc. Since 108.1% on a 125% scale corresponds with 8.648 Vdc on a 10 Vdc scale, $[10\text{Vdc} \times 108.1\% / 125\%]$, a setpoint of 8.600 +/- 0.04 Vdc is recommended.

14.3 RBM Flow Biased Trips

14.3.1 Upscale Trip - Two Loop Operation

Tech Spec NTSP:	0.66W + 45 % Power
Tech Spec AV:	0.66W + 48 % Power
Calculated AV:	0.66W + 50.66 % Power
Calculated AL:	0.66W + 52.42 % Power

This shows a positive margin of over 2.5 % Power between the calculated AV and Tech Spec AV for the current NTSP, and a positive margin of over 1.5 % Power between the calculated AL and the calculated AV. From Reference 3.27, current LaSalle transient analyses do not take credit for this AL. Therefore, this calculated AL is considered acceptable.

14.3.2 Upscale Trip - Single Loop Operation

Tech Spec NTSP:	0.66W + 39.7 % Power
Tech Spec AV:	0.66W + 42.7 % Power
Calculated AV:	0.66W + 45.36 % Power

REVISION NO.

0

2

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345		PAGE 172 of 191	
Calculated AL: 0.66W + 47.12 % Power			
This shows a positive margin of over 2.5 % Power between the calculated AV and Tech Spec AV for the current NTSP, and a positive margin of over 1.5 % Power between the calculated AL and the calculated AV. From Reference 3.27, current LaSalle transient analyses do not take credit for this AL. Therefore, this calculated AL is considered acceptable.			
14.4 RBM Downscale Trip			
Tech Spec NTSP:		5 % Power	
Tech Spec AV:		3 % Power	
Calculated AL:		-0.452226 % Power	
AL: (from Ref. 3.27)		0 % Power	
Calculated NTSP: (from Ref. 3.27 AL)		5.45 % Power	
Selected NTSP: (from Section 13.4)		5.50 % Power	
Calculated AV: (from Ref. 3.27 AL and selected setpoint)		1.24 % Power	
The present procedural setpoint for this function is 0.404 Vdc which is equivalent to 5.05% Power. Therefore, this should be changed to at least 5.5% Power in order to be compatible with the uncertainties evaluated in this calculation (Section 13.4).			
14.5 Recirculation Flow Monitor - Upscale			
Tech Spec NTSP:		108 % Flow	
Tech Spec AV:		111 % Flow	
Calculated AV:		113.69 % Flow	
Calculated AL:		115.13 % Flow	
Reference 3.27 requested that these values be evaluated against an AL of 116% Flow. As the calculation shows there is a positive margin of about 0.87% Flow between the calculated AL and that of Reference 3.27.			
REVISION NO.	0	1	

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345		PAGE 173 of 191								
<p>14.6 Recirculation Flow Monitor - Comparator</p> <table style="margin-left: 40px; border: none;"> <tr> <td style="padding-right: 20px;">Tech Spec NTSP:</td> <td>10 % Flow</td> </tr> <tr> <td>Tech Spec AV:</td> <td>11 % Flow</td> </tr> <tr> <td>Calculated AV:</td> <td>18.06 % Flow</td> </tr> <tr> <td>Calculated AL:</td> <td>18.06 % Flow</td> </tr> </table> <p>Reference 3.27 requested that these values be evaluated against an AL of 19% Flow. This calculation indicates that there is positive margin between the calculated AL and the value from Reference 3.27.</p> <p>14.7 From References 3.5.s and 3.5.t, the required accuracy for the pneumatic calibrator is specified as ± 2.0" W.C. For the normal temperatures involved in the Reactor Building, i.e., up to 118 °F, the calculated accuracy of the Wallace and Tiernan pneumatic calibrator exceeds this value (Section 9.2). Therefore, the calibration procedures should be revised to indicate the increased uncertainty or to limit the ambient temperature allowed during calibration.</p> <p>14.8 In accordance with Design Input 10.3, the recirculation flow monitor upscale trip setpoint calibration tolerance shall not exceed ± 0.1 Vdc and the recirculation flow monitor comparator trip setpoint calibration tolerance shall not exceed ± 0.08 Vdc.</p>			Tech Spec NTSP:	10 % Flow	Tech Spec AV:	11 % Flow	Calculated AV:	18.06 % Flow	Calculated AL:	18.06 % Flow
Tech Spec NTSP:	10 % Flow									
Tech Spec AV:	11 % Flow									
Calculated AV:	18.06 % Flow									
Calculated AL:	18.06 % Flow									
REVISION NO.	0	1								

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 174 of 191

15.0 CALCULATION SPREADSHEET

Symbol	Formula or Input Value	Value	Units
RA_{FE}	1	1	% CS
$CS_{FT(MIN)}$	247.4	247.4	"WC
$CS_{FT(MAX)}$	448.7	448.7	"WC
CS_{FT}	$CS_{FT(MIN)}$	247.4	"WC
UR_{FT}	750	750	"WC
$UR_{FT(CS)}$	UR_{FT}/CS_{FT}	3.031528	CS
RA_1	0.25	0.25	% CS
$CALTEMP_{FT}$	60	60	°F
$MAXTEMP_{FT}$	118	118	°F
e_{1T}	$(0.5 * UR_{FT(CS)} + 0.5) * (MAXTEMP_{FT} - CALTEMP_{FT}) / 100$	1.169143	% CS
$RA_{1(1\sigma)}$	$RA_1 / 2$	0.125	% CS
RD_{FT}	0.2	0.2	% UR/ 30 mo.
RD_1	$UR_{FT(CS)} * RD_{FT}$	0.606306	% CS
$RD_{1(1\sigma)}$	$RD_1 / 2$	0.303153	% CS
PSE_{FT}	0.005	0.005	%CS/V
ΔV_{FT}	0.5 Vdc	0.5	Vdc
$SPZE_{FT}$	0.25	0.25	%UR/200 0 PSI
$SPZE_{FT(1\sigma)}$	$(SPZE_{FT}/2) * (STAPR_{FT}/2000) * (UR_{FT}/CS_{FT})$	0.194207	% CS
$STAPR_{FT}$	1025	1025	PSI
$SPSE_{FT}$	0.25	0.25	%CS/100 0 PSI
$SPSE_{FT(1\sigma)}$	$SPSE_{FT}/2$	0.125	% CS
SE_{FT}	0.25	0.25	% UR

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 175 of 191

$SE_{FT(CS)}$	$UR_{FT(CS)} * SE_{FT}$	0.757882	% CS
$CS_{FT(OUT)}$	16	16	mVdc
$RAMTE1_{FT}$	2.149835	2.149835	" WC
$REMTE1_{FT}$	0	0	" WC
$RAMTE2_{FT}$	0.034961	0.034961	mVdc
$REMTE2_{FT}$	0	0	mVdc
$MTE1_{FT}$	$((RAMTE1_{FT}/1)^2 + REMTE1_{FT}^2)^{0.5}$	2.149835	" WC
$MTE1_{FT(CS)}$	$(MTE1_{FT}/CS_{FT}) * 100$	0.868971	% CS
$MTE2_{FT}$	$((RAMTE2_{FT}/1)^2 + REMTE2_{FT}^2)^{0.5}$	0.034961	mVdc
$MTE2_{FT(CS)}$	$(MTE2_{FT}/CS_{FT(OUT)}) * 100$	0.218506	% CS
$CAL1_{FT}$	$(MTE1_{FT(CS)}^2 + MTE2_{FT(CS)}^2)^{0.5}$	0.896022	% CS
$ST_{FT(IN)}$	0.5	0.5	" WC
$ST_{FT(IN)(CS)}$	$(ST_{FT(IN)}/CS_{FT}) * 100$	0.202102	% CS
$ST_{FT(OUT)}$	0.08	0.08	mVdc
$ST_{FT(OUT)(CS)}$	$(ST_{FT(OUT)}/CS_{FT(OUT)}) * 100$	0.500000	% CS
$ST1_{(1\sigma)}$	$[(ST_{FT(IN)(CS)}/3)^2 + (ST_{FT(OUT)(CS)}/3)^2]^{0.5}$	0.179767	% CS
σ_{input1}	2.5	2.5	% CS
$\sigma_{input1c}$	0	0	% CS
σ_1	$[(RA1_{(1\sigma)})^2 + (RD1_{(1\sigma)})^2 + (CAL1_{FT})^2 + (ST1_{(1\sigma)})^2 + (SPSE_{FT(1\sigma)})^2 + (SPZE_{FT(1\sigma)})^2 + (\sigma_{input1})^2]^{0.5}$	2.691847	% CS
σ_{1c}	$[(RA1_{(1\sigma)})^2 + (RD1_{(1\sigma)})^2 + (CAL1_{FT})^2 + (ST1_{(1\sigma)})^2 + (SPSE_{FT(1\sigma)})^2 + (SPZE_{FT(1\sigma)})^2 + (\sigma_{input1c})^2]^{0.5}$	0.998018	% CS
e1H	0	0	% CS
e1R	0	0	% CS
e1S	0	0	% CS
e1SP	0	0	% CS
e1P	0	0	% CS

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 176 of 191

e1p	0	0	% CS
e1V	$PSE_{FT} * \Delta V_{PS}$	0.002500	% CS
einput1	0	0	% CS
$\Sigma e1$	$e1H + e1T + e1R + e1S + e1SP + e1P + e1p + e1V + einput1$	1.171643	% CS
RA2	0	0	% CS
$RA2_{(1\sigma)}$	$RA2/2$	0	% CS
RD2	0	0	% CS
$RD2_{(1\sigma)}$	$RD2/2$	0	% CS
$RAMTE1_{SR}$	0.017205	0.017205	mVdc
$REMTE1_{SR}$	0	0	mVdc
$RAMTE2_{SR}$	0.001803	0.001803	Vdc
$REMTE2_{SR}$	0	0	Vdc
$MTE1_{SR}$	$((RAMTE1_{SR}/1)^2 + REMTE1_{SR}^2)^{0.5}$	0.017205	mVdc
$MTE1_{SR(CS)}$	$(MTE1_{SR(OUT)}/CS_{SR(OUT)}) * 100$	0.089610	% CS
$CS_{SR(OUT)}$	10	10	Vdc
OP_{SR}	6	6	Vdc
$MTE1_{SR(OUT)}$	$(3.125 * MTE1_{SR}) / OP_{SR}$	0.008961	Vdc
$MTE2_{SR}$	$((RAMTE2_{SR}/n)^2 + REMTE2_{SR}^2)^{0.5}$	0.001803	Vdc
$MTE2_{SR(CS)}$	$(MTE2_{SR}/CS_{SR(OUT)}) * 100$	0.018030	% CS
$CAL2_{SR}$	$((MTE1_{SR(CS)})^2 + (MTE2_{SR(CS)})^2)^{0.5}$	0.091406	% CS
$ST_{SR(IN)}$	0.05	0.05	mVdc
$ST_{SR(OUT)}$	0.025	0.025	Vdc
$ST_{SR(IN)(OUT)}$	$(3.125 * ST_{SR(IN)}) / OP_{SR}$	0.026042	Vdc
$ST_{SR(IN)(CS)}$	$(ST_{SR(IN)(OUT)}/CS_{SR(OUT)}) * 100$	0.260420	% CS
$ST_{SR(OUT)(CS)}$	$(ST_{SR(OUT)}/CS_{SR(OUT)}) * 100$	0.250000	% CS
$ST2_{(1\sigma)}$	$((ST_{SR(IN)(CS)}/3)^2 + (ST_{SR(OUT)(CS)}/3)^2)^{0.5}$	0.120332	% CS
$\sigma1_{MV}$	$(\sigma1/100) * CS_{FT(OUT)}$	0.430696	mVdc
$\sigma1_{MVC}$	$(\sigma1_c/100) * CS_{FT(OUT)}$	0.159683	mVdc

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 177 of 191

σ_{input2_v}	$(3.125 * \sigma_{1_{MV}}) / OP_{SR}$	0.224321	Vdc
$\sigma_{input2_{VC}}$	$(3.125 * \sigma_{1_{MVC}}) / OP_{SR}$	0.083168	Vdc
σ_{input2}	$(\sigma_{input2_v} / CS_{SR(OUT)}) * 100$	2.243210	% CS
σ_{input2_c}	$(\sigma_{input2_{VC}} / CS_{SR(OUT)}) * 100$	0.831680	% CS
σ_2	$[(RA2_{(1\sigma)})^2 + (RD2_{(1\sigma)})^2 + (CAL2)^2 + (ST2_{(1\sigma)})^2 + (\sigma_{input2})^2]^{0.5}$	2.248294	% CS
σ_{2_c}	$[(RA2_{(1\sigma)})^2 + (RD2_{(1\sigma)})^2 + (CAL2_{SR})^2 + (ST2_{(1\sigma)})^2 + (\sigma_{input2_c})^2]^{0.5}$	0.845297	% CS
$\Sigma e_{1_{MV}}$	$(\Sigma e_1 / 100) * CS_{PT(OUT)}$	0.187463	mVdc
e_{input2_v}	$(3.125 * \Sigma e_{1_{MV}}) / OP_{SR}$	0.097637	Vdc
e_{input2}	$(e_{input2_v} / CS_{SR(OUT)}) * 100$	0.976370	% CS
Σe_2	e_{input2}	0.976370	% CS
RA3	2	2	% CS
$RA3_{(1\sigma)}$	$RA3 / 2$	1	% CS
RD3	1.25	1.25	% CS
$RD3_{(1\sigma)}$	$RD3 / 2$	0.625	% CS
$RAMTE1_{SUM}$	0.001803	0.001803	Vdc
$REMTE1_{SUM}$	0	0	Vdc
$MTE1_{SUM}$	$(RAMTE1_{SUM} / n)^2 + REMTE1_{SUM}^2]^{0.5}$	0.001803	Vdc
$MTE1_{SUM(CS)}$	$(MTE1_{SUM} / CS_{SR(OUT)}) * 100$	0.018030	% CS
$MTE2_{SUM(CS)}$	$MTE1_{SUM(CS)}$	0.018030	% CS
$CAL3_{SUM}$	$[(MTE1_{SUM(CS)})^2 + (MTE2_{SUM(CS)})^2]^{0.5}$	0.025498	% CS
$ST_{SUM(IN)}$	0.01	0.01	Vdc
$ST_{SUM(OUT)}$	0.01	0.01	Vdc
$CS_{SUM(OUT)}$	10	10	Vdc
$ST_{SUM(IN)(CS)}$	$(ST_{SUM(IN)} / CS_{SUM(OUT)}) * 100$	0.100000	% CS
$ST_{SUM(OUT)(CS)}$	$(ST_{SUM(OUT)} / CS_{SUM(OUT)}) * 100$	0.100000	% CS
$ST3_{(1\sigma)}$	$[(ST_{SUM(IN)(CS)} / 3)^2 + (ST_{SUM(OUT)(CS)} / 3)^2]^{0.5}$	0.047140	% CS

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 178 of 191

$V_{SUM(IN)}$	7.66	7.66	Vdc
$V_{SUM(OUT)}$	8	8	Vdc
G_{SUM}	$V_{SUM(OUT)} / V_{SUM(IN)}$	1.044386	V/V
σ_{2_3}	$\sigma_2 * (G_{SUM}/2)$	1.174043	% CS
$\sigma_{2_{3C}}$	$\sigma_{2C} * (G_{SUM}/2)$	0.441408	% CS
σ_{input3}	$[(\sigma_{2_3})^2 + (\sigma_{2_{3C}})^2]^{0.5}$	1.660348	% CS
σ_{input3_c}	$[(\sigma_{2_{3C}})^2 + (\sigma_{2_{3C}})^2]^{0.5}$	0.624245	% CS
σ_3	$(125/100) * [(RA3_{(1\sigma)})^2 + (RD3_{(1\sigma)})^2 + (CAL3)^2 + (ST3_{(1\sigma)})^2 + (\sigma_{input3})^2]^{0.5}$	2.546521	% Flow
σ_{3C}	$(125/100) * [(RA3_{(1\sigma)})^2 + (RD3_{(1\sigma)})^2 + (CAL3_{SUM})^2 + (ST3_{(1\sigma)})^2 + (\sigma_{input3_c})^2]^{0.5}$	1.669197	% Flow
e_{input3}	$\Sigma e_{2_3} + \Sigma e_{2_3}$	1.019708	% CS
Σe_{2_3}	$\Sigma e_2 * (G_{SUM}/2)$	0.509854	% CS
Σe_3	$(125/100) * (e_{input3})$	1.274635	% Flow
RA3A	1	1	% CS
$RA3A_{(1\sigma)}$	$\pm ROUND[(RA3A/2) * (125/100), 6]$	0.625	% Flow
RD3A	1	1	% CS
RD3AT	RD4CT	700	HRS
RD3ATSI	13	13	Weeks
$RD3A_{(1\sigma)}$	$(RD3A/2) * (125/100) * [(1.25 * RD3ATSI * 168) / RD3AT]^{0.5}$	1.234276	% Flow
$RAMTE1_{3A}$	$RAMTE1_{SUM}$	0.001803	Vdc
$REMTE1_{3A}$	$REMTE1_{SUM}$	0	Vdc
$MTE1_{3A}$	$[(RAMTE1_{3A}/1)^2 + REMTE1_{3A}^2]^{0.5}$	0.001803	Vdc
$SPAN_{SUM}$	10	10	Vdc
$MTE1_{3A(PF)}$	$(MTE1_{3A} / SPAN_{SUM}) * 125$	0.022538	% Flow
CAL3A	$MTE1_{3A(PF)}$	0.022538	% Flow
ST3AA	0.1	0.1	Vdc
$ST3AA_{(1\sigma)}$	$[(ST3AA / SPAN_{SUM}) * 125] / 3$	0.416667	% Flow
ST3AB	0.08	0.08	Vdc
$ST3AB_{(1\sigma)}$	$[(ST3AB / SPAN_{SUM}) * 125] / 3$	0.333333	% Flow

REVISION NO.

0

1

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 179 of 191

$\sigma_{input3A}$	σ_3	2.546521	% Flow
$\sigma_{input3A_v}$	σ_{3_c}	1.669197	% Flow
$\sigma_{input3B}$	$(\sigma_{3_c}^2 + \sigma_{3_c}^2)^{0.5}$	2.360601	% Flow
σ_3A	$[(RA3A_{(1\sigma)})^2 + (RD3A_{(1\sigma)})^2 + (CAL3A)^2 + (ST3AA_{(1\sigma)})^2 + (\sigma_{input3A})^2]^{0.5}$	2.927960	% Flow
σ_3B	$[(RA3A_{(1\sigma)})^2 + (RD3A_{(1\sigma)})^2 + (CAL3A)^2 + (ST3AB_{(1\sigma)})^2 + (\sigma_{input3B})^2]^{0.5}$	2.756468	% Flow
σ_3A_{AV}	$[(RA3A_{(1\sigma)})^2 + (RD3A_{(1\sigma)})^2 + (CAL3A)^2 + (ST3AA_{(1\sigma)})^2 + (\sigma_{input3A_{AV}})^2]^{0.5}$	2.207804	% Flow
$e_{input3A}$	Σe_3	1.274635	% Flow
$e_{input3B}$	$\Sigma e_3 + \Sigma e_3$	2.54927	% Flow
Σe_3A	$e_{input3A}$	1.274635	% Flow
Σe_3B	$e_{input3B}$	2.54927	% Flow
$RA4A$	1	1	% Power
$RA4A_{(1\sigma)}$	$RA4A/2$	0.5	% Power
$RD4A$	1	1	% Power
$RD4AT$	700	700	HRS
$RD4ATSI$	700	700	HRS
$RD4A_{(1\sigma)}$	$(RD4A/2) (1250/700)^{0.5}$	0.5	% Power
$RV4ACURS$	10	10	Vdc
$RA4A_{DMM}$	0.005	0.005	Vdc
$RAMTE1_{4A(DMM)}$	$(RA4A_{DMM}/RV4ACURS) * 100$	0.05	% CS
$RAMTE2_{4A(DMM)}$	$RAMTE1_{4A(DMM)}$	0.05	% CS
$RAMTE1_{4A(CURS)}$	1	1	% CS
$MTE1_{4A}$	$[(RAMTE1_{4A(DMM)}/1)^2 + (RAMTE1_{4A(CURS)}/2)^2 + (REMTE1_{4A(DMM)})^2 + (REMTE1_{4A(CURS)})^2]^{0.5}$	0.502494	% CS
$REMTE1_{4A(DMM)}$	0	0	% CS

REVISION NO.

0

1

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 180 of 191

REMTE1 _{4A(C} URS)	0	0	% CS
REMTE2 _{4A(D} MM)	0	0	% CS
MTE2 _{4A}	$(RAMTE2_{4A(DMM)})^2 + (REMTE2_{4A(DMM)})^2$	0.05	% CS
CAL4A	$[(MTE1_{4A})^2 + (MTE2_{4A})^2]^{0.5}$	0.504975	% CS
ST4A _{DMM}	RAMTE1 _{4A(DMM)}	0.05	% CS
ST4A _{CURS}	RAMTE1 _{4A(CURS)}	1	% CS
ST4A _(1σ)	$\{[(ST4A_{DMM}) * (2/3)]^2 + (ST4A_{CURS}/3)^2 + [(ST4A_{DMM}) * (2/3)]^2\}^{0.5}$	0.336650	% CS
SSL _B	0.33	0.33	% Power
SNL _B	0.49	0.49	% Power
SSL _R	0.20	0.2	% Power
SNL _R	1	1	% Power
PEA _{4A(B)}	SSL _B + SNL _B	0.82	% Power
LPR	ROUND(15/100, 6)	0.15	%/%
PEA _{4A(LPB)}	SSL _B	0.33	% Power
PEA _{4A(R)}	$[(SSL_R)^2 + (SNL_R)^2]^{0.5}$	1.019804	% Power
PEA _{4A(LPR)}	PEA _{4A(R)}	1.019804	% Power
σinput4A	PEA _{4A(R)}	1.019804	% Power
σinput4A _L P	PEA _{4A(LPR)}	1.019804	% Power
σinput4A _A V	0	0	% Power
einput4A	PEA _{4A(B)}	0.82	% Power
einput4A _L P	PEA _{4A(LPB)}	0.33	% Power
einput4A _A V	0	0.000000	% Power
σ4A	$[(CAL4A)^2 + (ST4A_{(1σ)})^2]^{0.5}$	0.606904	% CS
σ4A _{PP}	$[(RA4A_{(1σ)})^2 + (RD4A_{(1σ)})^2]^{0.5}$	0.707107	% Power
Σe4A	0	0	% CS

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 181 of 191

RA4B	0.8	0.8	% CS
RD4B	0.5	0.5	% CS
RA4B _(1σ)	RA4B/2	0.4	% CS
RD4B _(1σ)	RD4B/2	0.25	% CS
G _{APRM}	2.5	2.5	(None)
RAMTE1 _{4B}	0	0	% CS
REMTE1 _{4B}	0	0	% CS
RAMTE2 _{4B}	0	0	% CS
REMTE2 _{4B}	0	0	% CS
MTE1 _{4B}	$[(RAMTE1_{4B}/2)^2 + REMTE1_{4B}^2]^{0.5}$	0	% CS
MTE2 _{4B}	$[(RAMTE2_{4B}/2)^2 + REMTE2_{4B}^2]^{0.5}$	0	% CS
CAL4B	$[(MTE1_{4B})^2 + (MTE2_{4B})^2]^{0.5}$	0	% CS
ST4B	0.02	0.02	(None)
ST4B _‡	ST4B*100	2	% Power
ST4B _(1σ)	ST4B _‡ *(100/125)/3	0.533333	% CS
TRAC	1.11	1.11	% Power
NN	2.0	2	% Power
PMA	$(TRAC^2 + NN^2)^{0.5}$	2.287378	% Power
PMA _{1σ}	PMA/2	1.143689	% Power
PMA _{FB}	TRAC	1.11	% Power
PMA _{FB(1σ)}	PMA _{FB} /2	0.555	% Power
PMA _{LP}	0	0	% Power
PMA _{AV}	0	0	% Power
N	14	14	LPRM
σ _{input4B_C} _S	$(σ4A * G_{APRM}) / N^{0.5}$	0.405505	% CS
σ _{input4B_P} _P	$[(σinput4A)^2 + (σ4A_{PP})^2]^{0.5} / N^{0.5}$	0.331663	% Power
σ _{input4B_P} _{P(LP)}	$[(σinput4A_{LP})^2 + (σ4A_{PP})^2]^{0.5} / N^{0.5}$	0.331663	% Power

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345		PAGE 182 of 191	
$\sigma_{input4B_A}$ v	$[(\sigma_{input4A_{AV}})^2 + (\sigma_{4A_{PP}})^2]^{0.5}/N^{0.5}$	0.188982	% Power
σ_{4BI}	$[(RA_{4B(1\sigma)})^2 + (RD_{4B(1\sigma)})^2 + (CAL_{4B})^2 + (ST_{4B(1\sigma)})^2 + (\sigma_{input4B_{CS}})^2]^{0.5}$	0.819377	% CS
$\sigma_{4BI_{PP}}$	$\sigma_{4BI} * (125/100)$	1.024221	% Power
σ_{4B}	$[(\sigma_{4BI_{PP}})^2 + (\sigma_{input4B_{PP}})^2 + (PMA_{1\sigma})^2]^{0.5}$	1.570686	% Power
$\sigma_{4B_{FB}}$	$[(\sigma_{4BI_{PP}})^2 + (\sigma_{input4B_{PP}})^2 + (PMA_{FB(1\sigma)})^2]^{0.5}$	1.211220	% Power
$\sigma_{4B_{LP}}$	$[(\sigma_{4BI_{PP}})^2 + (\sigma_{input4B_{PP(LP)}})^2 + (PMA_{LP})^2]^{0.5}$	1.076582	% Power
$\sigma_{4B_{AV}}$	$[(\sigma_{4BI_{PP}})^2 + (\sigma_{input4B_{AV}})^2 + (PMA_{AV})^2]^{0.5}$	1.041510	% Power
$e_{input4B_C}$ s	$G_{APRM} * \Sigma e_{4A}$	0	% CS
$e_{input4B_P}$ P	$e_{input4A}$	0.82	% Power
$e_{input4B_P}$ P(LP)	$e_{input4A_{LP}}$	0.33	% Power
$e_{input4B_A}$ v	$e_{input4A_{AV}}$	0	% Power
$\Sigma e_{4B_{CS}}$	$e_{input4B_{CS}}$	0	% CS
Σe_{4B}	$\Sigma e_{4B_{CS}} * (125/100) + e_{input4B_{PP}}$	0.82	% Power
$\Sigma e_{4B_{LP}}$	$\Sigma e_{4B_{CS}} * (125/100) + e_{input4B_{PP(LP)}}$	0.33	% Power
$\Sigma e_{4B_{AV}}$	$\Sigma e_{4B_{CS}} * (125/100) + e_{input4B_{AV}}$	0	% Power
RA4C	1	1	% CS
RA4C _(1σ)	$(RA_{4C}/2) * (125/100)$	0.625	% Power
RD4C	1	1	% CS
RD4CT	700	700	HRS
RD4CTSI	26	26	weeks
RD4C _(1σ)	$(RD_{4C}/2) * (125/100) * [(1.25 * RD_{4CTSI} * 168) / RD_{4CT}]^{0.5}$	1.745530	% Power
RAMTE1 _{4C}	0.000180	0.000180	Vdc
REMTE1 _{4C}	0	0	Vdc
MTE1 _{4C}	$[(RAMTE1_{4C}/1)^2 + REMTE1_{4C}^2]^{0.5}$	0.000180	Vdc
MTE1 _{4C(PP)}	$(MTE1_{4C}/SPAN_{4CIN}) * 125$	0.002250	% Power
REVISION NO. 0			

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 183 of 191

SPAN4CIN	10	10	Vdc
CAL4C	MTE1 _{4C(PP)}	0.002250	% Power
ST4C	0.04	0.04	Vdc
ST4C _(1σ)	$[(ST4C/SPAN4CIN) * 125] / 3$	0.166667	% Power
σinput4C	σ4B	1.570686	% Power
σinput4C _L _P	σ4B _{LP}	1.076582	% Power
σinput4C _A _V	σ4B _{AV}	1.041510	% Power
σ4C	$[(RA4C_{(1σ)})^2 + (RD4C_{(1σ)})^2 + (CAL4C)^2 + (ST4C_{(1σ)})^2 + (σinput4C)^2]^{0.5}$	2.435639	% Power
σ4C _{LP}	$[(RA4C_{(1σ)})^2 + (RD4C_{(1σ)})^2 + (CAL4C)^2 + (ST4C_{(1σ)})^2 + (σinput4C_{LP})^2]^{0.5}$	2.150421	% Power
σ4C _{AV}	$[(RA4C_{(1σ)})^2 + (RD4C_{(1σ)})^2 + (CAL4C)^2 + (ST4C_{(1σ)})^2 + (σinput4C_{AV})^2]^{0.5}$	2.133079	% Power
einput4C	Σe4B	0.82	% Power
einput4C _L _P	Σe4B _{LP}	0.33	% Power
einput4C _A _V	Σe4B _{AV}	0	% Power
Σe4C	einput4C	0.82	% Power
Σe4C _{LP}	einput4C _{LP}	0.33	% Power
Σe4C _{AV}	einput4C _{AV}	0	% Power
RA4D	1	1	% CS
RA4D _{1σ}	$(RA4D/2) * (125/100)$	0.625	% Power
RD4D	1	1	% CS
RD4DT	700	700	HRS
RD4DTSI	26	26	Weeks
RD4D _(1σ)	$(RD4D/2) * (125/100) * [(1.25 * RD4DTSI * 168) / RD4DT]^{0.5}$	1.745530	% Power
RAMTE1 _{4D}	RAMTE1 _{4C}	0.000180	Vdc
REMTE1 _{4D}	0	0	Vdc

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

945

CALCULATION NO. L-001345

PAGE 184 of 191

MTE1 _{4D}	$(RAMTE1_{4D}/1^2 + REMTE1_{4D}^2)^{0.5}$	0.000180	Vdc
MTE1 _{4D(PP)}	$(MTE1_{4D}/SPAN4CIN) * 125$	0.002250	% Power
CAL4D	MTE1 _{4D(PP)}	0.002250	% Power
ST4D	0.04	0.04	Vdc
ST4D _(1σ)	$[(ST4D/SPAN4CIN) * 125] / 3$	0.166667	% Power
FCS _{SPTLO}	0.62	0.62	% Pow/ % Flow
FCS	$FCS_{SP} + [(0.04+0.04)/0.08]/80$	0.632500	% Pow/ % Flow
σinput4D	$[\sigma 4B_{FB}^2 + (FCS * \sigma 3)^2]^{0.5}$	2.015273	% Power
σinput4D _{AV}	$[\sigma 4B_{AV}^2 + (FCS * \sigma 3_c)^2]^{0.5}$	1.483033	% Power
σ4D	$[(RA4D_{(1σ)})^2 + (RD4D_{(1σ)})^2 + (CAL4D)^2 + (ST4D_{(1σ)})^2 + (\sigma input4D)^2]^{0.5}$	2.743466	% Power
σ4D _{AV}	$[(RA4D_{(1σ)})^2 + (RD4D_{(1σ)})^2 + (CAL4D)^2 + (ST4D_{(1σ)})^2 + (\sigma input4D_{AV})^2]^{0.5}$	2.380057	% Power
einput4D	$\Sigma e4B + (FCS * \Sigma e3)$	1.626207	% Power
einput4D _{AV}	$\Sigma e4B_{AV} + (FCS * \Sigma e3)$	0.806207	% Power
Σe4D	einput4D	1.626207	% Power
Σe4D _{AV}	einput4D _{AV}	0.806207	% Power
RA5A	0.8	0.8	% CS
RA5A _{NULL}	1	1	% Point
RA5A _(1σ)	$\{ (RA5A/2)^2 + [(100/125) * (RA5A_{NULL}/2)]^2 \}^{0.5}$	0.565685	% CS
RD5A	0.3	0.3	% CS
RD5A _(1σ)	RD5A/2	0.15	% CS
RAMTE1 _{5A}	0.000180	0.000180	Vdc
REMTE1 _{5A}	0	0	Vdc
MTE1 _{5A}	$[(RAMTE1_{5A}/1)^2 + REMTE1_{5A}^2]^{0.5}$	0.000180	Vdc
SPAN _{RBM}	10	10	Vdc

REVISION NO.

0

2

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 185 of 191

CAL5A	$(MTE1_{5A}/SPAN_{RBM}) * 100,$	0.001800	% CS
ST5A	0.025	0.025	Vdc
ST5A _(1σ)	$[(ST5A/SPAN_{RBM}) * 100] / 3$	0.083333	% CS
PMA _{RBM}	1.11	1.11	% Power
PMA _{RBM(1σ)}	$PMA_{RBM} / 2$	0.555	% Power
PMA _{RBM(AV)}	0	0	% Power
N _{RBM}	2	2	LPRM
G _{RBM}	G _{APRM}	2.5	(None)
σinput5A _C S	$(\sigma 4A * G_{RBM}) / (N_{rbm})^{0.5}$	1.072865	% CS
σinput5A _P	$[(\sigma input4A)^2 + (\sigma 4A_{PP})^2]^{0.5} / (N_{RBM})^{0.5}$	0.877497	% Power
σinput5A _A V	$[(\sigma input4A_{AV})^2 + (\sigma 4A_{PP})^2]^{0.5} / (N_{RBM})^{0.5}$	0.500000	% Power
σinput5A _C S(PP)	σinput5A _{CS} (125/100)	1.341081	% Power
σinput5A	$[(\sigma input5A_{PP})^2 + (\sigma input5A_{CS(PP)})^2]^{0.5}$	1.602653	% Power
σinput5A A _{AV}	$[(\sigma input5A_{AV})^2 + (\sigma input5A_{CS(PP)})^2]^{0.5}$	1.431258	% Power
σ5AI	$[(RA5A_{(1σ)})^2 + (RD5A_{(1σ)})^2 + (CAL5A)^2 + (ST5A_{(1σ)})^2]^{0.5}$	0.591141	% CS
σ5AI _{PP}	σ5AI * (125/100)	0.738926	% Power
σ5A	$[(\sigma 5AI_{PP})^2 + (\sigma input5A)^2 + (PMA_{RBM(1σ)})^2]^{0.5}$	1.850009	% Power
σ5A _{AV}	$[(\sigma 5AI_{PP})^2 + (\sigma input5A_{AV})^2 + (PMA_{RBM(AV)})^2]^{0.5}$	1.610749	% Power
einput5A _C S	G _{RBM} * Σe4A	0	% CS
einput5A _P	einput4A	0.82	% Power
einput5A _A V	einput4A _{AV}	0	% Power
Σe5A _{CS}	einput5A _{CS}	0	% CS
Σe5A	Σe5A _{CS} * (125/100) + einput5A _{PP}	0.82	% Power

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 186 of 191

$\Sigma e5A_{AV}$	$\Sigma e5A_{CS} * (125/100) + einput5A_{AV}$	0	% Power
RA5B	RA4C	1	% CS
$RA5B_{(1\sigma)}$	$(RA5B/2) * (125/100)$	0.625	% Power
RD5B	RD4C	1	% CS
RD5BT SI	13	13	Weeks
RD5BT	RD4CT	700	HRS
$RD5B_{(1\sigma)}$	$(RD5B/2) * (125/100) * [(1.25 * RD5BT SI * 168) / RD5BT]^{0.5}$	1.234276	% Power
$RAMTE1_{5B}$	$RAMTE1_{4C}$	0.000180	Vdc
$REMTE1_{5B}$	$REMTE1_{4C}$	0	Vdc
$MTE1_{5B}$	$[(RAMTE1_{5B}/1)^2 + REMTE1_{5B}^2]^{0.5}$	0.000180	Vdc
$MTE1_{5B(PP)}$	$(MTE1_{5B}/SPAN4CIN) * 125$	0.002250	% Power
CAL5B	$MTE1_{5B(PP)}$	0.002250	% Power
ST5B	0.04	0.04	Vdc
$ST5B_{(1\sigma)}$	$(ST5B/SPAN4CIN) * 125 / 3$	0.166667	% Power
$\sigma input5B$	$\sigma 5A$	1.850009	% Power
$\sigma input5B_A$ v	$\sigma 5A_{AV}$	1.610749	% Power
$\sigma 5B$	$[(RA5B_{(1\sigma)})^2 + (RD5B_{(1\sigma)})^2 + (CAL5B)^2 + (ST5B_{(1\sigma)})^2 + (\sigma input5B)^2]^{0.5}$	2.316113	% Power
$\sigma 5B_{AV}$	$[(RA5B_{(1\sigma)})^2 + (RD5B_{(1\sigma)})^2 + (CAL5B)^2 + (ST5B_{(1\sigma)})^2 + (\sigma input5B_{AV})^2]^{0.5}$	2.129873	% Power
$einput5B$	$\Sigma e5A$	0.82	% Power
$einput5B_A$ v	$\Sigma e5A_{AV}$	0	% Power
$\Sigma e5B$	$einput5B$	0.82	% Power
$\Sigma e5B_{AV}$	$einput5B_{AV}$	0	% Power
RA5C	RA4D	1	% CS
$RA5C_{(1\sigma)}$	$(RA5C/2) * (125/100)$	0.625	% Power
RD5C	RD4D	1	% CS

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

6
9/15

CALCULATION NO. L-001345

PAGE 187 of 191

RD5CT	RD4DT	700	HRS
RD5CTSI	RD5BTSI	13	Weeks
$RD5C_{(1\sigma)}$	$(RD5C/2) * (125/100) * [(1.25 * RD5CTSI * 168) / RD5CT]^{0.5}$	1.234276	% Power
$RAMTE1_{5C}$	0.00018	0.000180	Vdc
$REMTE1_{5C}$	0	0	Vdc
$MTE1_{5C}$	$(RAMTE1_{5C}/1)^2 + REMTE1_{5C}^2]^{0.5}$	0.000180	Vdc
$MTE1_{5C(PP)}$	$(MTE1_{5C}/SPAN4CIN) * 125$	0.002250	% Power
CAL5C	$MTE1_{5C(PP)}$	0.002250	% Power
ST5C	0.04	0.04	Vdc
$ST5C_{(1\sigma)}$	$[(ST5C/SPAN4CIN) * 125] / 3$	0.166667	% Power
$FCS_{RBM(SP)}$	0.66	0.66	% Pow/ % Flow
FCS_{RBM}	$FCS_{RBM(SP)} + [(0.04 + 0.03) / 0.08] / 100$	0.668750	%Pow/ %Flow
$\sigma input5C_{AV}$	$[\sigma 5A_{AV}^2 + (FCS_{RBM} * \sigma 3C)^2]^{0.5}$	1.959740	% Power
$\sigma input5C$	$[\sigma 5A^2 + (FCS_{RBM} * \sigma 3)^2]^{0.5}$	2.514497	% Power
$\sigma 5C$	$(RA5C_{(1\sigma)})^2 + (RD5C_{(1\sigma)})^2 + (CAL5C)^2 + (ST5C_{(1\sigma)})^2 + (\sigma input5C)^2]^{0.5}$	2.874811	% Power
$\sigma 5C_{AV}$	$[(RA5C_{(1\sigma)})^2 + (RD5C_{(1\sigma)})^2 + (CAL5C)^2 + (ST5C_{(1\sigma)})^2 + (\sigma input5C_{AV})^2]^{0.5}$	2.404668	% Power
$einput5C$	$\Sigma e5A + (FCS_{RBM} * \Sigma e3)$	1.672412	% Power
$einput5C_{AV}$	$\Sigma e5A_{AV} + (FCS_{RBM} * \Sigma e3)$	0.852412	% Power
$\Sigma e5C$	$einput5C$	1.672412	% Power
$\Sigma e5C_{AV}$	$einput5C_{AV}$	0.852412	% Power
Ten_{AFB}	$2\sigma 4D + \Sigma e4D$	7.113139	% Power
$Ten_{AFB(AV)}$	$2\sigma 4D_{AV} + \Sigma e4D_{AV}$	5.566321	% Power
Ten_{AF}	$2\sigma 4C + \Sigma e4C$	5.691278	% Power
$Ten_{AF(AV)}$	$2\sigma 4C_{AV} + \Sigma e4C_{AV}$	4.266158	% Power

REVISION NO.

0

2

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 188 of 191

Ten_{AFLP}	$2\sigma 4C_{LP} + \Sigma e 4C_{LP}$	4.630842	% Power
$Ten_{AFLP(AV)}$	$Ten_{AF(AV)}$	4.266158	% Power
Ten_{RFB}	$2\sigma 5C + \Sigma e 5C$	7.422034	% Power
$Ten_{RFB(AV)}$	$2\sigma 5C_{AV} + \Sigma e 5C_{AV}$	5.661747	% Power
Ten_{RF}	$2\sigma 5B + \Sigma e 5B$	5.452226	% Power
$Ten_{RF(AV)}$	$2\sigma 5B_{AV} + \Sigma e 5B_{AV}$	4.259745	% Power
Ten_{RFMU}	$2\sigma 3A + \Sigma e 3A$	7.130555	% Flow
$Ten_{RFMU(AV)}$	$2\sigma 3A_{AV} + \Sigma e 3A$	5.690244	% Flow
Ten_{RFMC}	$2\sigma 3B + \Sigma e 3B$	8.062206	% Flow
$Ten_{RFMC(AV)}$	Ten_{RFMC}	8.062206	% Flow
AL_{STP2OS}	70.9	70.9	% Power
$NTSP_{STP2OS}$	$AL_{STP2OS} - Ten_{AFB}$	63.786861	63.7
AV_{STP2}	$NTSP_{STP2OS} + Ten_{AFB(AV)}$	69.353182	69.3
AL_{STP1OS}	58.33	58.33	% Power
$NTSP_{STP1OS}$	$AL_{STP1OS} - Ten_{AFE}$	51.507506	51.5
AV_{STP1}	$NTSP_{STP1OS} + Ten_{AFB(AV)}$	56.885648	56.8
$AL_{STP2RBOS}$	59.47	59.47	% Power
$NTSP_{STP2RBOS}$	$AL_{STP2RBOS} - Ten_{AFB}$	52.36	52.3
AV_{STP2RB}	$NTSP_{STP2RBOS} + Ten_{AFB(AV)}$	57.923182	57.9
$AL_{STP1RBOS}$	46.9	46.90	% Power
$NTSP_{STP1RBOS}$	$AL_{STP1RBOS} - Ten_{AFB}$	40.077506	40.0
AV_{STP1RB}	$NTSP_{STP1RBOS} + Ten_{AFB(AV)}$	45.4556	45.4
$NTSP_{FS}$	118	118	% Power
AL_{FS}	$NTSP_{FS} + Ten_{AF}$	123.691278	% Power
AV_{FS}	$NTSP_{FS} + Ten_{AF(AV)}$	122.266158	% Power
$NTSP_{FSS}$	15	15	% Power

REVISION NO.

0

2

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 189 of 191

AL_{FSS}	$NTSP_{FSS} + Ten_{AFLP}$	19.630842	% Power
AV_{FSS}	$NTSP_{FSS} + Ten_{AF(AV)}$	19.266158	% Power
AL_{FSSN}	25	25	% Power
$NTSP_{FSSN}$	$AL_{FSSN} - Ten_{AFLP}$	20.369158	% Power
AV_{FSSN}	$NTSP_{FSSN} + Ten_{AF(AV)}$	24.635316	% Power
$NTSP_{RBS}$	12	12	% Power
AL_{RBS}	$NTSP_{RBS} + Ten_{AFLP}$	16.630842	% Power
AV_{RBS}	$NTSP_{RBS} + Ten_{AF(AV)}$	16.266158	% Power
AL_{RBSN}	19	19	% Power
$NTSP_{RBSN}$	$AL_{RBSN} - Ten_{AFLP}$	14.369158	% Power
AV_{RBSN}	$NTSP_{RBSN} + Ten_{AF(AV)}$	18.635316	% Power
$NTSP_{DS}$	5	5	% Power
AL_{DS}	$NTSP_{DS} - Ten_{AFLP}$	0.369158	% Power
AV_{DS}	$NTSP_{DS} - Ten_{AF(AV)}$	0.733842	% Power
$NTSP_{HFC}$	113.5	113.5	% Power
AL_{HFC}	$NTSP_{HFC} + Ten_{AF}$	119.191278	% Power
AV_{HFC}	$NTSP_{HFC} + Ten_{AF(AV)}$	117.766158	% Power
$NTSP_{RBM2OS}$	45	45	% Power
AL_{RBM2OS}	$NTSP_{RBM2OS} + Ten_{RFB}$	52.422034	% Power
AV_{RBM2}	$NTSP_{RBM2OS} + Ten_{RFB(AV)}$	50.661747	% Power
$NTSP_{RBM1OS}$	39.7	39.7	% Power
AL_{RBM1OS}	$NTSP_{RBM1OS} + Ten_{RFB}$	47.122034	% Power
AV_{RBM1}	$NTSP_{RBM1OS} + Ten_{RFB(AV)}$	45.361747	% Power
$NTSP_{RBMDS}$	5	5	% Power
AL_{RBMDS}	$NTSP_{RBMDS} - Ten_{RF}$	-0.452226	% Power
AL_0	0	0	% Power
$NTSP_{DSN}$	$AL_0 + Ten_{RF}$	5.452226	% Power

REVISION NO.

0

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 190 of 191

AV _{RBMDSS}	NTSP _{RBMDSS} - Ten _{RF(AV)}	1.240255	% Power
NTSP _{RFMU}	108	108	% Flow
AL _{RFMU}	NTSP _{RFMU} + Ten _{RFMU}	115.13055 5	% Flow
AV _{RFMU}	NTSP _{RFMU} + Ten _{RFMU(AV)}	113.69024 4	% Flow
NTSP _{RFMC}	10	10	% Flow
AL _{RFMC}	NTSP _{RFMC} + Ten _{RFMC}	18.062206	% Flow
AV _{RFMC}	AL _{RFMC}	18.062206	% Flow
RA6	1	1	% CS
RA6 _{1σ}	RA6/2	0.5	% CS
RD6	0.5	0.5	% CS
RD6 _{1σ}	RD6/2	0.25	% CS
CAL6	CAL3 _{SUM}	0.025498	% CS
ST6 _(1σ)	ST3 _(1σ)	0.047140	% CS
σinput6	σinput3	1.660348	% CS
σinput6 _c	σinput3 _c	0.624245	% CS
σ6	$(125/100) * [(RA6_{(1σ)})^2 + (RD6_{(1σ)})^2 + (CAL6)^2 + (ST6_{(1σ)})^2 + (σinput6)^2]^{0.5}$	2.190936	% Flow
σ6 _c	$(125/100) * [(RA6_{(1σ)})^2 + (RD6_{(1σ)})^2 + (CAL6)^2 + (ST6_{(1σ)})^2 + (σinput6_c)^2]^{0.5}$	1.049594	% Flow
e6T	0.5	0.5	% CS
einput6	einput3	1.019708	% CS
Σe6	(125/100) * (e6T + einput6)	1.899635	% Flow
RA6A	1	1	% CS
RA6A _(1σ)	(RA6A/2) * (125/100)	0.625	% Flow
RD6A	0	0	% CS
RD6A _(1σ)	(RD6A/2) * (125/100)	0	% Flow
CAL6A	CAL3A	0.022538	% Flow
ST6AA _(1σ)	ST3AA _(1σ)	0.416667	% Flow
ST6AB _(1σ)	ST3AB _(1σ)	0.333333	% Flow

REVISION NO.

0

1

COMMONWEALTH EDISON COMPANY

CALCULATION NO. L-001345

PAGE 191 of 191

$\sigma_{input6A}$	σ_6	2.190936	% Flow
$\sigma_{input6B}$	$(\sigma_6^2 + \sigma_6^2)^{0.5}$	1.484350	% Flow
σ_6A	$[(RA6A_{(1\sigma)})^2 + (RD6A_{(1\sigma)})^2 + (CAL6A)^2 + (ST6A_{(1\sigma)})^2 + (\sigma_{input6A})^2]^{0.5}$	2.316235	% Flow
σ_6B	$[(RA6A_{(1\sigma)})^2 + (RD6A_{(1\sigma)})^2 + (CAL6A)^2 + (ST6A_{(1\sigma)})^2 + (\sigma_{input6B})^2]^{0.5}$	1.644852	% Flow
$e_{input6A}$	Σe_6	1.899635	% Flow
$e_{input6B}$	$\Sigma e_6 + \Sigma e_6$	3.799270	% Flow
Σe_6A	$e_{input6A}$	1.899635	% Flow
Σe_6B	$e_{input6B}$	3.799270	% Flow
AV_{RBMDS}	$NTSP_{RBMDS} - Ten_{RF(AV)}$	0.740255	% Power
$NTSP_{RBMDS}$	5.5	5.500000	% Power
FCS_{SPSLO}	0.55	0.55	%Pwr/%Flo
FCS_{SLO}	$FCS_{SPSLO} + [(0.04+0.04)/0.08]/80$	0.562500	%Pwr/%Flo
$\sigma_{input4D_{SLO}}$	$[\sigma_4B_{FB}^2 + (FCS_{SLO} * \sigma_3)^2]^{0.5}$	1.875867	% Power
$\sigma_{input4D_{AVSLO}}$	$[\sigma_4B_{AV}^2 + (FCS_{SLO} * \sigma_3)^2]^{0.5}$	1.402255	% Power
σ_4D_{SLO}	$[(RA4D_{(1\sigma)})^2 + (RD4D_{(1\sigma)})^2 + (CAL4D)^2 + (ST4D_{(1\sigma)})^2 + (\sigma_{input4D_{SLO}})^2]^{0.5}$	2.642756	% Power
σ_4D_{AVSLO}	$[(RA4D_{(1\sigma)})^2 + (RD4D_{(1\sigma)})^2 + (CAL4D)^2 + (ST4D_{(1\sigma)})^2 + (\sigma_{input4D_{AVSLO}})^2]^{0.5}$	2.330580	% Power
$e_{input4D_{SLO}}$	$\Sigma e_4B + (FCS * \Sigma e_3)$	1.536982	% Power
$e_{input4D_{AVSLO}}$	$\Sigma e_4B_{AV} + (FCS * \Sigma e_3)$	0.716982	% Power
Σe_4D_{SLO}	$e_{input4D_{SLO}}$	1.536982	% Power
Σe_4D_{AVSLO}	$e_{input4D_{AVSLO}}$	0.716982	% Power
Ten_{AFBSLO}	$2\sigma_4D_{SLO} + \Sigma e_4D_{SLO}$	6.822494	% Power
$Ten_{AFBAVSLO}$	$2\sigma_4D_{AVSLO} + \Sigma e_4D_{AVSLO}$	5.378142	% Power
$AL_{HFC SLO}$	113.8	113.8	% Power
$NTSP_{HFC SLO}$	$AL_{HFC SLO} - Ten_{AF}$	108.108722	108.1
$AV_{HFC SLO}$	$NTSP_{HFC SLO} + Ten_{AF(AV)}$	112.374880	112.3

FINAL

REVISION NO.

0

2

DESIGN ANALYSIS NO.: L-001345

PAGE NO. 1 of 9

Major REV Number:

2

Minor Rev Number: A

☐ BRAIDWOOD STATION
☐ BYRON STATION
☐ CLINTON STATION
☐ DRESDEN STATION
☒ LASALLE CO. STATION
☐ QUAD CITIES STATION

DESCRIPTION

CODE:(C018)

I04

DISCIPLINE CODE: (C011)

I

SYSTEM CODE: (C011)

C51

TITLE: Average Power Range Monitor (APRM), Rod Block Monitor (RBM) and
Recirculation Flow Monitor (RFM) Bistable Loop Accuracy for Rod Block and Scram
Functions

☒ Safety Related☐ Augmented Quality☐ Non-Safety Related

ATTRIBUTES (C016)

TYPE	VALUE	TYPE	VALUE
Elevation	N/A		
Software	N/A		

COMPONENT EPN: (C014 Panel)

EPN TYPE

DOCUMENT NUMBERS: (C012 Panel) (Design Analyses References)

Type/Sub

Document Number

Input (Y/N)

See Calculation
Section 1

CALC/ENG

L-001345 Revision 2 Yes

/

/

/

/

/

/

REMARKS:

Page 2 of 2

Revision Summary (including EC's incorporated): This revision will incorporate a new limit for the RBM flow biased setpoint. Sections 3.5, 3.7, 3.15, 3.34, 3.35, 4.14, 10.5, 12.3, 12.4, 13.3, 14.3 and 15.0 have been changed.

N/A

Reviewed by: W. C. Kirchhoff / *W. C. Kirchhoff* / 8/31/01
 Method of Review: ☒ Detailed ☐ Summary

This Design Analysis supersedes: _____ in its entirety.

Additional Reviewer or Special Review Team Leader: _____ / _____ / _____
 Print Sign Date

Team: (N/A for Additional Review)

Special Review

Reviewers: 1) _____ / _____ / _____
 Print Sign Date
2) _____ / _____ / _____
 Print Sign Date
3) _____ / _____ / _____
 Print Sign Date
4) _____ / _____ / _____
 Print Sign Date

Approved by: Mark Murskyj / 8/31/01 / [Signature]
Print Sign Date

Reviewed by: _____ / _____ / _____
 Print _____ Sign _____ Date _____ **Approved by:** _____
 _____ / _____ / _____
 Print _____ Sign _____ Date _____

Do any ASSUMPTIONS / ENGINEERING JUDGEMENTS require later verification? ☐ Yes ☒ No Tracked
By: AT#, EC# etc.)

CALCULATION TABLE OF CONTENTS

CALCULATION NO.	L-001345	REV. NO. 2A	PAGE NO. 3 OF 9
SECTION:	PAGE NO.	SUB-PAGE NO.	
TABLE OF CONTENTS	3		
PURPOSE / OBJECTIVE	4		
METHODOLOGY AND ACCEPTANCE CRITERIA	N/A		
ASSUMPTIONS / ENGINEERING JUDGEMENTS	N/A		
DESIGN INPUT	N/A		
REFERENCES	N/A		
CALCULATIONS	4 - 9		
SUMMARY AND CONCLUSIONS	N/A		
ATTACHMENTS	N/A		

CALCULATION PAGE**CALCULATION NO. L-001345****REVISION NO. 2A PAGE NO. 4 OF 9****Purpose/Objective**

In April 2001 both the Unit 1 and Unit 2 COLR were revised for the implementation of Improved Technical Specifications. As part of that COLR change, the Rod Withdrawal Error accident was analyzed assuming that the RBM would not cause a rod block, and it set a new value of the Trip Setpoint (TS) and Allowable Value (AV) for the RBM flow biased setpoint.

This calculation will revise the setpoint calculation for the RBM flow biased trip to incorporate this new information from the COLR.

Calculations

1. Revise section 3.5

3.5 LaSalle Station Procedures

Subsections e. and n. to read:

- e. **LIS-NR-105A, Rev. 12, "Unit 1 Rod Block Monitor Calibration."**
LIS-NR-105B, Rev. 10, "Unit 1 Rod Block Monitor Calibration."
- n. **LIS-NR-205A, Rev. 5, 'Unit 2 Rod Block Monitor Calibration.'**
LIS-NR-205B, Rev. 5, 'Unit 2 Rod Block Monitor Calibration.'

2. Revise section 3.7 to read as follows:

- 3.7 **LaSalle Station Technical Specification Unit 1, Amendment No. 147, dated March 30, 2001 and Technical Specification Unit 2, Amendment No. 133, dated March 30, 2001**

3. Revise section 3.15 to read as follows:

- 3.15 **Technical Reference Manual LaSalle 1 and 2; Appendix I, Core Operating Limits Report, LaSalle Unit 1 Cycle 9 dated May 2001, and Appendix J, Core Operating Limits Report, LaSalle Unit 2 Cycle 9 dated August 2001 .**

4. Revise section 3.34 to read as follows:

- 3.34 **NES-EIC-20.04, Revision 3, "Analysis of Instrument Channel Setpoint Error and Instrument Loop Accuracy."**

5. Add new reference

- 3.35 **ER-AA-520, INSTRUMENT PERFORMANCE TRENDING, Revision 0**

CALCULATION PAGE

CALCULATION NO. L-001345

REVISION NO. 2A PAGE NO. 5 OF 9

6. Revise Section 4.14 and applicable table entrees as follows:

4.14 Analytical Limits and Allowable Values Inputs

From References 3.27 and 3.33, Analytical Limit inputs are provided for all non-flow biased setpoints and the APRM Flow Biased Trip functions (flow biased and clamp). Reference 3.15 provides the Allowable Values for the RBM Upscale Trips. There is no Analytical Limit, as the rod block is not considered in the Rod Withdrawal Error Analysis as stated in Reference 3.15. The information provided by References 3.15, 3.27, and 3.33 is summarized below:

Bistable	AL	AV	Reference
Rod Block Monitor Trips			
RBM Upscale (Rod Block), Two Recirc Loop Operation	None	0.66W + 54 % *	3.15
RBM Upscale (Rod Block), Single Recirc Loop Operation	None	0.66W + 48.7% *	3.15

* Clamped with the Allowable Value not to exceed the AV For recirculation loop flow (W) of 100%.

7. Revise section 10.5 for the Upscale setpoints as follows:
10.5 RBM Calibration

RBM Upscale (Two Recirculation Loop Operation)

Instrument Setpoint: (100% Flow)	9.320Vdc (116.5%)
Allowable Range:	9.280 to 9.360 Vdc (± 0.040 Vdc)
Calibrated Trip Setpoint: (Section 13.3.1)	$\leq 0.66W + 50.5 \%$ (116.5 %)
Nominal Trip Setpoint: (Reference 3.15)	$\leq 0.66W + 51.0 \%$ (117.0 %)
Tech Spec LCO: (Reference 3.15)	$\leq 0.66W + 54.0 \%$ (120.0 %)
Analytic Limit:	Clamped \leq the AV for 100% Flow None

CALCULATION PAGE

CALCULATION NO. L-001345

REVISION NO. 2A PAGE NO. 6 OF 9

RBM Upscale (Single Recirculation Loop Operation)

Instrument Setpoint: (100% Flow)	8.880 Vdc (111.0%)
Allowable Range:	8.840 to 8.920 Vdc (± 0.040 Vdc)
Calibration Trip Setpoint: (Section 13.3.2)	$\leq 0.66W + 45.0\%$ (111.0%)
Nominal Trip Setpoint: (Reference 3.15)	$\leq 0.66W + 45.7\%$ (111.7%)
Tech Spec LCO: (Reference 3.15)	$\leq 0.66W + 48.7\%$ (114.7%)
Analytic Limit:	Clamped \leq the AV for 100% Flow None

8. Revise section 12.3 and 12.4 as indicated below:

12.3 RBM Flow Biased Trips - Ten_{RFB} , $Ten_{RFB(AV)}$

Ten_{RFB} and $Ten_{RFB(AV)}$ are made up of the uncertainty terms from the RBM Flow Biased Trip Module 5C. Because the RBM is not used in the COLR for accident or transient analysis this setpoint is a Level 2 setpoint as defined in Reference 3.34 Appendix D, thus the uncertainty is computed as follows.

$$Ten_{RFB} = \pm(\sigma 5C + \Sigma e 5C)\% \text{ Power} \quad [\text{Ref 3.34}]$$

$$Ten_{RFB(AV)} = \pm(\sigma 5C_{AV} + \Sigma e 5C_{AV})\% \text{ Power} \quad [\text{Ref 3.34}]$$

These uncertainty terms include both the uncertainties associated with the RBM neutron signal and the Recirculation Flow Monitor. From Sections 11.5.3.1.6 and 11.5.3.2.10:

$$Ten_{RFB} = \pm(2.874811 + 1.672412)\% \text{ Power}$$

$$Ten_{RFB} = \pm 4.55\% \text{ Power}$$

And

$$Ten_{RFB(AV)} = \pm(2.404668 + 0.852412)\% \text{ Power}$$

$$Ten_{RFB(AV)} = \pm 3.26\% \text{ Power}$$

CALCULATION PAGE

CALCULATION NO. L-001345

REVISION NO. 2A PAGE NO. 7 OF 9

12.4 RBM Fixed Trip - Ten_{RF} , $Ten_{RF(AV)}$

Because the RBM is not used in the COLR for accident or transient analysis this setpoint is a Level 2 setpoint as defined in Reference 3.34 Appendix D, thus the uncertainty is computed as follows:

$$Ten_{RF} = \pm(\sigma 5B + \Sigma e 5B) \% \text{ Power} \quad [\text{Ref 3.34}]$$

$$Ten_{RF(AV)} = \pm(\sigma 5B_{AV} + \Sigma e 5B_{AV}) \% \text{ Power} \quad [\text{Ref 3.34}]$$

Ten_{RF} and $Ten_{RF(AV)}$ are made up of the uncertainty terms from RBM Fixed Trip Module 5B. From Sections 11.5.2.1.6 and 11.5.2.2.10:

$$Ten_{RF} = \pm(2.316113 + 0.82) \% \text{ Power}$$

$$Ten_{RF} = \pm 3.14 \% \text{ Power}$$

And

$$Ten_{RF(AV)} = \pm(2.129873 + 0) \% \text{ Power}$$

$$Ten_{RF(AV)} = \pm 2.13 \% \text{ Power}$$

9. Revise section 13.3 as indicated below:

13.3 RBM Flow Biased Trips

The RBM Flow Biased Trips have the same total uncertainty term (Ten_{RFB}) whether in Two Recirculation Loop Operation or Single Recirculation Loop Operation. This is because there are no changes made to the method of operation of the Recirculation Flow Monitor for either Single or Two Loop Operation. Therefore, the error analysis for the RFB is the same.

13.3.1 Upscale Trip - Two Loop Operation

From Section 10.5 the existing Technical Specification Nominal Trip Setpoint (NTSP) for this function is $\leq 0.66W + 51\%$ Power with the setpoint clamped at a value corresponding to when $W=100\%$ Flow. Because this setpoint is not used in safety analysis, as specified in Reference 3.15, the Trip Setpoint listed in Reference 3.15 will be considered as a nominal setpoint. The setpoint will be checked against the AV listed in Reference 3.15 to ensure that the as-found value when calibrating the Upscale trip will not exceed the AV.

$$AV_{RBM2} = NTSP + Ten_{RFB(AV)} \% \text{ Power}$$

$$AV_{RBM2} = 0.66*W + 51 + Ten_{RFB(AV)} \% \text{ Power}$$

CALCULATION PAGE

CALCULATION NO. L-001345

REVISION NO. 2A PAGE NO. 8 OF 9

$$AV_{RBM2} = 0.66W + 51 + 3.26 \% \text{ Power}$$

$$AV_{RBM2} = 0.66W + 54.26 \% \text{ Power}$$

Because the computed AV is in excess of the Reference 3.15 value, the fixed offset of the final NTSP should be lowered at least 0.26 %. For conservatism, the final calibration NTSP should be:

$$NTSP_{RBM2} = 0.66W + 50.5 \% \text{ Power}$$

The RBM backup trip value should be calibrated in such a manner as to ensure that it is always higher than the required value needed for the NTSP.

13.3.2 Upscale Trip - Single Loop Operation

From Section 10.5 the existing Technical Specification Nominal Trip Setpoint (NTSP) for this function is $\leq 0.66W + 45.7\% \text{ Power}$ with the setpoint clamped at a value corresponding to when $W=100\% \text{ Flow}$. Because this setpoint is not used in safety analysis, as specified in Reference 3.15, the Trip Setpoint listed in Reference 3.15 will be considered as a nominal setpoint. The setpoint will be checked against the AV listed in Reference 3.15 to ensure that the as-found value when calibrating the Upscale trip will not exceed the AV.

$$AV_{RBM1} = NTSP + Ten_{RFB(AV)} \% \text{ Power}$$

$$AV_{RBM1} = 0.66*W + 45.7 + Ten_{RFB(AV)} \% \text{ Power}$$

$$AV_{RBM1} = 0.66W + 45.7 + 3.26 \% \text{ Power}$$

$$AV_{RBM1} = 0.66W + 48.96 \% \text{ Power}$$

Because the computed AV is in excess of the Reference 3.15 value, the fixed offset of the final NTSP should be lowered at least 0.26 %. For conservatism, the final calibration NTSP should be:

$$NTSP_{RBM1} = 0.66W + 45.0 \% \text{ Power}$$

The RBM backup trip value should be calibrated in such a manner as to ensure that it is always higher than the required value needed for the NTSP.

10. Revise section 14.3 as indicated below:

CALCULATION PAGE**CALCULATION NO. L-001345****REVISION NO. 2A PAGE NO. 9 OF 9****14.3 RBM Flow Biased Trips****14.3.1 Upscale Trip - Two Loop Operation**

Calibrated NTSP	0.66W + 50.5% Power
Tech Spec NTSP:	0.66W + 51 % Power
Tech Spec AV:	0.66W + 54 % Power
Extended Tolerance	± 0.75% Power

Extended tolerance selected at 1.5 times setting tolerance to provide an ET value for Trending as described in ER-AA-520.

14.3.2 Upscale Trip - Single Loop Operation

Calibrated NTSP	0.66W + 45.0 % Power
Tech Spec NTSP:	0.66W + 45.7 % Power
Tech Spec AV:	0.66W + 48.7 % Power
Extended Tolerance	± 0.75% Power

Extended tolerance selected at 1.5 times setting tolerance to provide an ET value for trending as described in ER-AA-520.

11. Revise the applicable sections of 15.0 as follows:

15.0 CALCULATION SPREADSHEET

Symbol	Formula or Input Value	Value	Units
NTSP _{RBM2OS}	51	51	% Power
AL _{RBM2OS}	(Deleted)		
AV _{RBM2}	NTSP _{RBM2OS} + Ten _{RFB(AV)}	54.26	% Power
NTSP _{RBM1OS}	45.7	45.7	% Power
AL _{RBM1OS}	(Deleted)		
AV _{RBM1}	NTSP _{RBM1OS} + Ten _{RFB(AV)}	48.96	% Power

ATTACHMENT 1
Design Analysis Approval
Page 1 of 2

DESIGN ANALYSIS NO.: L-001345		PAGE NO. 1 OF 4																																									
Major REV Number: 002		Minor Rev Number: B																																									
<div style="display: flex; flex-direction: column; gap: 5px;"> <div><input type="checkbox"/> BRAIDWOOD STATION</div> <div><input type="checkbox"/> BYRON STATION</div> <div><input type="checkbox"/> CLINTON STATION</div> <div><input type="checkbox"/> DRESDEN STATION</div> <div><input checked="" type="checkbox"/> LASALLE CO. STATION</div> <div><input type="checkbox"/> QUAD CITIES STATION</div> </div> <div style="margin-top: 5px;"> Unit: <input type="checkbox"/> 0 <input checked="" type="checkbox"/> 1 <input checked="" type="checkbox"/> 2 <input type="checkbox"/> 3 </div>	<div style="display: flex; flex-direction: column; gap: 10px;"> <div> DESCRIPTION CODE:(C018) I04 </div> <div> DISCIPLINE CODE: (C011) I </div> <div> SYSTEM CODE: (C011) C51 </div> </div>																																										
TITLE: Average Power Range Monitor (APRM), Rod Block Monitor (RBM), and Recirculation Flow Monitor (RFM) Bistable Loop Accuracy for Rod Block and Scram Functions.																																											
<div style="display: flex; justify-content: space-between;"> <input checked="" type="checkbox"/> Safety Related <input type="checkbox"/> Augmented Quality <input type="checkbox"/> Non-Safety Related </div>																																											
ATTRIBUTES (C016)																																											
TYPE	VALUE	TYPE	VALUE																																								
Elevation	Misc																																										
Software																																											
COMPONENT EPN: (C014 Panel) <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th style="width:50%;">EPN</th> <th style="width:50%;">TYPE</th> </tr> <tr> <td>See Section 1.0 of Rev. 2</td> <td></td> </tr> <tr><td> </td><td> </td></tr> <tr><td> </td><td> </td></tr> <tr><td> </td><td> </td></tr> <tr><td> </td><td> </td></tr> <tr><td> </td><td> </td></tr> <tr><td> </td><td> </td></tr> </table>		EPN	TYPE	See Section 1.0 of Rev. 2														DOCUMENT NUMBERS: (C012 Panel) (Design Analyses References) <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th style="width:25%;">Type/Sub</th> <th style="width:40%;">Document Number</th> <th style="width:35%;">Input (Y/N)</th> </tr> <tr> <td>CAL/ENG</td> <td>L-002884</td> <td align="center">Y</td> </tr> <tr> <td>DCD/EC-1A <i>[Signature]</i></td> <td>EC-338271</td> <td align="center">Y</td> </tr> <tr><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td></tr> </table>		Type/Sub	Document Number	Input (Y/N)	CAL/ENG	L-002884	Y	DCD/EC-1A <i>[Signature]</i>	EC-338271	Y															
EPN	TYPE																																										
See Section 1.0 of Rev. 2																																											
Type/Sub	Document Number	Input (Y/N)																																									
CAL/ENG	L-002884	Y																																									
DCD/EC-1A <i>[Signature]</i>	EC-338271	Y																																									
REMARKS:																																											

DESIGN ANALYSIS NO. L-001345	REV: 002B	PAGE NO.
		2 OF 4

Revision Summary (including EC's incorporated):

The purpose of this minor Revision 002B is to add calculation L-002884, Rev. 000, "Measurement and Test Equipment (M&TE) Acceptability Evaluation" prepared for EC-338271 as a reference in Section 3.0 – REFERENCES and Section 9.0 – CALIBRATION INSTRUMENT DATA. This minor revision will also establish cross-reference between these two calculations.

Electronic Calculation Data Files: See Attachments C and D.
(Program Name, Version, File Name extension/size/date/hour/min)

Design impact review completed? ☐ Yes ☒ N/A, Per EC#: **EC-338271**

(If yes, attach impact review sheet)

Prepared by: R. H. LOW / [Signature] / 08/10/02

Print Sign Date

Reviewed by: T. VAN WYK / [Signature] / 08/11/02

Print Sign Date

Method of Review: ☒ Detailed ☐ Alternate ☐ Test

This Design Analysis supersedes: N/A in its entirety.

Supplemental Review Required? ☐ Yes ☒ No

☐ Additional Review ☐ Special Review Team

Additional Reviewer or Special Review Team Leader: _____

Print Sign Date

Special Review Team: (N/A for Additional Review)

Reviewers: 1) _____ / _____ / _____ 2) _____ / _____ / _____

Print Sign Date Print Sign Date

3) _____ / _____ / _____ 4) _____ / _____ / _____

Print Sign Date Print Sign Date

Supplemental Review Results:

Approved by: : L. Campo / [Signature] / 8-12-02

Print Sign Date

External Design Analysis Review (Attachment 3 Attached)

Reviewed by: R. FREDRICKSON / [Signature] / 8/12/02

Print Sign Date

Approved by: Mark Morsky / [Signature] / 8/14/02

Print Sign Date

Do any ASSUMPTIONS / ENGINEERING JUDGEMENTS require later verification? ☐ Yes ☒ No

(Tracked By: AT#, EC# etc.)

CALCULATION TABLE OF CONTENTS

CALCULATION NO. L-001345			REV. NO. 002B	PAGE NO. 3
SECTION:	PAGE NO.	SUB-PAGE NO.		
TABLE OF CONTENTS	3			
1. PURPOSE / OBJECTIVE	NA			
2. METHODOLOGY AND ACCEPTANCE CRITERIA	NA			
3. ASSUMPTIONS / ENGINEERING JUDGEMENTS	NA			
4. DESIGN INPUT	NA			
5. REFERENCES	4			
6. CALCULATIONS	4			
7. SUMMARY AND CONCLUSIONS	NA			
8. ATTACHMENTS	NA			

E-FORM

CALCULATION PAGE

CALCULATION NO. L-001345

REVISION NO. 002B

PAGE NO. 4 of 4

NOTE:

Section numbers referred to in the section headers in this minor revision are in accordance with the calculation format in use at the time of this minor revision. Section numbers referred to in the body of each section are the actual section numbers in the record calculation.

5.0 References

Add calculation L-002884, Rev. 000, "Measurement and Test Equipment (M&TE) Acceptability Evaluation" as the last reference in Section 3.0.

6.0 Calculations

Add the following sentence to the end of the second paragraph of Section 9.0, Calibration Instrument Data.

"Refer to calculation L-002884 for use of M&TE less accurate than that listed."

Final
[Last Page]

E-FORM

Analysis No. L-001345		Last Page No. 4											
EC/ECR No. EC 331766		Revision 2C Revision 0											
Title: Average Power Range Monitor (APRM), Rod Block Monitor (RBM), and Recirculation Flow Monitor (RFM) Bistable Loop Accuracy for Rod Block and Scram Functions													
Station(s) LaSalle Unit No.: 1 and 2 Safety Class SR System Code C51	Is this Design Analysis Safeguards? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Does this Design Analysis Contain Unverified Assumptions? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> ATI/AR#												
Description of Change Section 14.1 is revised to change the examples for the flow bias calibration setpoints to indicate the corresponding values at a drive flow of 75% instead of 80%. References for the calibration procedures are also revised.													
Disposition of Changes (include additional pages as required) Add pages 1 through 4 of minor revision 002C.													
<table style="width: 100%;"> <tr> <td style="width: 40%;"> Preparer W. Kirchhoff <div style="text-align: right; font-size: small;">Print Name</div> </td> <td style="width: 60%;"> <div style="text-align: right; font-size: small;">Sign Name</div> </td> </tr> <tr> <td> Reviewer V. Shah <div style="text-align: right; font-size: small;">Print Name</div> </td> <td> <div style="text-align: right; font-size: small;">Sign Name</div> </td> </tr> <tr> <td colspan="2"> Method of Review <input checked="" type="checkbox"/> Detailed Review <input type="checkbox"/> Alternate Calculations <input type="checkbox"/> Testing </td> </tr> <tr> <td colspan="2"> Review Notes: </td> </tr> <tr> <td> Approver BYRON GINTER <div style="text-align: right; font-size: small;">Print Name</div> </td> <td> <div style="text-align: right; font-size: small;">Sign Name</div> </td> </tr> </table>				Preparer W. Kirchhoff <div style="text-align: right; font-size: small;">Print Name</div>	 <div style="text-align: right; font-size: small;">Sign Name</div>	Reviewer V. Shah <div style="text-align: right; font-size: small;">Print Name</div>	 <div style="text-align: right; font-size: small;">Sign Name</div>	Method of Review <input checked="" type="checkbox"/> Detailed Review <input type="checkbox"/> Alternate Calculations <input type="checkbox"/> Testing		Review Notes:		Approver BYRON GINTER <div style="text-align: right; font-size: small;">Print Name</div>	 <div style="text-align: right; font-size: small;">Sign Name</div>
Preparer W. Kirchhoff <div style="text-align: right; font-size: small;">Print Name</div>	 <div style="text-align: right; font-size: small;">Sign Name</div>												
Reviewer V. Shah <div style="text-align: right; font-size: small;">Print Name</div>	 <div style="text-align: right; font-size: small;">Sign Name</div>												
Method of Review <input checked="" type="checkbox"/> Detailed Review <input type="checkbox"/> Alternate Calculations <input type="checkbox"/> Testing													
Review Notes:													
Approver BYRON GINTER <div style="text-align: right; font-size: small;">Print Name</div>	 <div style="text-align: right; font-size: small;">Sign Name</div>												
<small>(For External Analyses Only)</small> Exelon Reviewer _____ <div style="text-align: right; font-size: small;">Print Name</div> <div style="text-align: right; font-size: small;">Sign Name</div>													
Approver _____ <div style="text-align: right; font-size: small;">Print Name</div> <div style="text-align: right; font-size: small;">Sign Name</div>													

CALCULATION TABLE OF CONTENTS

CALCULATION NO. L-001345		REV. NO. 002C	PAGE NO. 2
SECTION:	PAGE NO.	SUB-PAGE NO.	
TITLE PAGE	1		
TABLE OF CONTENTS	2		
PURPOSE / OBJECTIVE	3		
METHODOLOGY AND ACCEPTANCE CRITERIA	NA		
ASSUMPTIONS / ENGINEERING JUDGEMENTS	NA		
DESIGN INPUT	NA		
REFERENCES	3		
CALCULATIONS	NA		
CONCLUSIONS	3		
ATTACHMENTS	NA		
COMPUTER PROGRAMS	NA		

CALCULATION PAGE

CALCULATION NO. L-001345

REVISION NO. 002C PAGE NO. 3 of 4

1.0 Purpose/Scope

The purpose of this revision is to revise the discussion related to the calibration setpoints in section 14.0 Conclusions for APRM Flow Biased Trips. Section 14.1 is revised to change the examples for the flow bias calibration setpoints to indicate the corresponding values at a drive flow of 75% instead of 80%. This change is being made for consistency with the calibration procedures (references 3.5u, 3.5v, 3.5w, 3.5x) which currently use a simulated drive flow of 75%. The change was made to the calibration procedures because at 80% flow the transition from the flow biased line to the fixed clamped setpoint occurs. This transition was found to interfere with the calibration. The change does not affect the calibration setpoint. References for the calibration procedures are also revised.

3.0 References

References 3.5.a, b, c, d and 3.5 j, k, m, n are superseded by the references indicated below:

- 3.5.u LIS-NR-103A Revision 7, UNIT 1 AVERAGE POWER RANGE MONITOR CHANNELS A, C, AND E ROD BLOCK AND SCRAM CALIBRATION
- 3.5.v LIS-NR-103B Revision 6, UNIT 1 AVERAGE POWER RANGE MONITOR CHANNELS B, D, AND F ROD BLOCK AND SCRAM CALIBRATION
- 3.5.w LIS-NR-203A Revision 6, UNIT 2 AVERAGE POWER RANGE MONITOR CHANNELS A, C, AND E ROD BLOCK AND SCRAM CALIBRATION
- 3.5.x LIS-NR-203A Revision 6, UNIT 2 AVERAGE POWER RANGE MONITOR CHANNELS B, D, AND F ROD BLOCK AND SCRAM CALIBRATION

14.0 Conclusion

Replace section 14.1 with the following:

14.1. APRM Flow Biased Trips

14.1.1 Simulated Thermal Power Upscale (Scram) – Two Loop Operation

Analytical Limit:	0.62W + 70.9 % Power
Tech Spec AV:	0.62W + 69.3 % Power
Tech Spec NTSP:	0.62W + 63.7 % Power

Calibration setpoint: Since the setpoint is calibrated at a specific drive flow, the nominal setpoint should be set at least 0.04 Vdc below the corresponding Tech Spec NTSP with a tolerance of +/- 0.04 Vdc. For example, with a 75% drive flow, the Tech Spec NTSP is 110.2% ($0.62 \times 75 + 63.7$). Since 110.2% on a 125% scale corresponds to 8.816 Vdc on a 10 Vdc scale [$10\text{Vdc} \times 110.2\% / 125\%$], a setpoint of 8.776 +/- 0.04 Vdc is recommended for 75% drive flow.

CALCULATION PAGE

CALCULATION NO. L-001345

REVISION NO. 002C PAGE NO. 4 of 4

14.1.2 Simulated Thermal Power Upscale (Scram) – Single Loop Operation

Analytical Limit:	$0.55W + 58.33 \% \text{ Power}$
Tech Spec AV:	$0.55W + 56.8 \% \text{ Power}$
Tech Spec NTSP:	$0.55W + 51.5 \% \text{ Power}$

Calibration setpoint: Since the setpoint is calibrated at a specific drive flow, the nominal setpoint should be set at least 0.04 Vdc below the corresponding Tech Spec NTSP with a tolerance of +/- 0.04 Vdc. For example, with a 75% drive flow, the Tech Spec NTSP is 92.75% ($0.55*75 + 51.5$). Since 92.75% on a 125% scale corresponds to 7.420 Vdc on a 10 Vdc scale [$10Vdc*92.75\%/125\%$], a setpoint of 7.38 +/- 0.04 Vdc is recommended for 75% drive flow.

14.1.3 Simulated Thermal Power Upscale (Rod Block) – Two Loop Operation

Analytical Limit:	$0.62W + 59.47 \% \text{ Power}$
Tech Spec AV:	$0.62W + 57.9 \% \text{ Power}$
Tech Spec NTSP:	$0.62W + 52.3 \% \text{ Power}$

Calibration setpoint: Since the setpoint is calibrated at a specific drive flow, the nominal setpoint should be set at least 0.04 Vdc below the corresponding Tech Spec NTSP with a tolerance of +/- 0.04 Vdc. For example, with a 75% drive flow, the Tech Spec NTSP is 98.8 % ($0.62*75 + 52.3$). Since 98.8 % on a 125% scale corresponds to 7.904 Vdc on a 10 Vdc scale [$10Vdc*98.8\%/125\%$], a setpoint of 7.864 +/- 0.04 Vdc is recommended for 75% drive flow.

14.1.4 Simulated Thermal Power Upscale (Rod Block) – Single Loop Operation

Analytical Limit:	$0.55W + 46.9 \% \text{ Power}$
Tech Spec AV:	$0.55W + 45.4 \% \text{ Power}$
Tech Spec NTSP:	$0.55W + 40.0 \% \text{ Power}$

Calibration setpoint: Since the setpoint is calibrated at a specific drive flow, the nominal setpoint should be set at least 0.04 Vdc below the corresponding Tech Spec NTSP with a tolerance of +/- 0.04 Vdc. For example, with a 75% drive flow, the Tech Spec NTSP is 81.25% ($0.55*75 + 40.0$). Since 81.25% on a 125% scale corresponds to 6.500 Vdc on a 10 Vdc scale [$10Vdc*81.25\%/125\%$], a setpoint of 6.460 +/- 0.04 Vdc is recommended for 75% drive flow.

ATTACHMENT 2

Design Analysis Minor Revision Cover Sheet

Design Analysis (Minor Revision)		Last Page No. ⁶ 49	
Analysis No.: ¹ L-001345		Revision: ² 002D	
Title: ³ Average Power Range Monitor (APRM), Rod Block Monitor (RBM), and Recirculation Flow Monitor (RFM) Bistable Loop Accuracy for Rod Block and Scram Functions			
EC/ECR No.: ⁴ 377849 375883		Revision: ⁵ 0	
Station(s): ⁷ LaSalle			
Unit No.: ⁸ 1 and 2			
Safety/QA Class: ⁹ SR			
System Code(s): ¹⁰ C51			
Is this Design Analysis Safeguards Information? ¹¹		Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> If yes, see SY-AA-101-106	
Does this Design Analysis contain Unverified Assumptions? ¹²		Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> If yes, AT/AR#: _____	
This Design Analysis SUPERCEDES: ¹³		in its entirety.	
Description of Changes (list affected pages): ¹⁴ 1) Determine Tech Spec AV's and NTSP's for the APRM flow biased trips based on analytical limit changes due to thermal power optimization. 2) Determine ALT/AFT for APRM flow biased trips for use in instrument performance trending. 3) Determine total uncertainty based on the replacement ABB RFM uncertainties instead of the previously installed GE Flow Units. 4) Determine flow biased APRM trip errors based on 75% calibration flow. 5) Deleted section 15.0 (calculation spreadsheet), 6) Corrected a computation error in Section 11.5.3.1.5. 7) Corrected the application of vendor provided performance specifications for the ABB RFM upscale and comparator trip functions.			
List of Affected Pages: This minor revision affects numerous pages of revision 2 which includes the following sections: 1.0, 2.0, 3.0, 4.0, 5.0, 7.0, 8.0, 9.0, 11.0, 12.0, 13.0, 14.0, and 15.0. The following sections of minor revision 2A are affected: reference 3.4, and sections 12.3, 13.3.1, and 13.3.2. The following sections of minor revision 2C are also affected: sections 14.1.1, 14.1.2, 14.1.3, and 14.1.4.			
Disposition of Changes: ¹⁵ This minor calculation revision is in support of Thermal Power Optimization and identifies permanent calculation changes required during the next major revision to this calculation.			
Preparer: ¹⁶ David Cujko (Sargent & Lundy)		Signature: <i>for D. Cujko</i> _____ Sign Name Date 12-07-09	
Method of Review: ¹⁷ Detailed Review <input checked="" type="checkbox"/> Alternate Calculations <input type="checkbox"/> Testing <input type="checkbox"/>			
Reviewer: ¹⁸ AMARTEJ S. LUTHRA		Signature: <i>AMARTEJ S. LUTHRA</i> _____ Sign Name Date 12-07-09	
Review Notes: ¹⁹		Independent review <input checked="" type="checkbox"/> Peer review <input type="checkbox"/>	
(For External Analyses Only)			
External Approver: ²⁰ W.A. BARASA		Signature: <i>W.A. Barasa</i> _____ Sign Name Date 12-07-09	
Exelon Reviewer ²¹ TACARUS J. VAN WYK		Signature: <i>TACARUS J. VAN WYK</i> _____ Sign Name Date 12/9/09	
Exelon Approver: ²² Vikram Shah		Signature: <i>Vikram Shah</i> _____ Sign Name Date 12/15/09	

TABLE OF CONTENTS

SECTION:	PAGE NO.
TITLE PAGE	1
TABLE OF CONTENTS	2
SECTION 1.0 PURPOSE AND OBJECTIVE	3
SECTION 2.0 METHODOLOGY AND ACCEPTANCE CRITERIA	4
SECTION 3.0 REFERENCES	5
SECTION 4.0 DESIGN INPUTS	6
SECTION 5.0 ASSUMPTIONS	9
SECTION 6.0 INSTRUMENT CHANNEL CONFIGURATION	N/A
SECTION 7.0 PROCESS PARAMETERS	10
SECTION 8.0 LOOP ELEMENT DATA	11
SECTION 9.0 CALIBRATION INSTRUMENT DATA	12
SECTION 10.0 CALIBRATION PROCEDURE DATA	N/A
SECTION 11.0 MODULE ERRORS	13
SECTION 12.0 INSTRUMENT CHANNEL TOTAL ERROR	32
SECTION 13.0 ERROR ANALYSIS SUMMARY	34
SECTION 14.0 CONCLUSIONS	46
SECTION 15.0 CALCULATION SPREADSHEET	49
ATTACHMENTS	N/A

1.0 PURPOSE AND OBJECTIVE

The purpose of this Minor Revision is listed below:

1. The Unit 1 and Unit 2 analytical limits for the APRM flow biased trips are being revised per the thermal power optimization project. This revision recalculates the Technical Specification allowable values (AV's) and nominal trip setpoints (NTSP's) for the APRM flow biased trips based on the analytical limit changes.
2. This revision determines as-left / as-found tolerances for the APRM flow biased trips for use in instrument performance trending.
3. Subsequent to the issuance of analysis L-001345, revision 2, the GE recirculation flow units have been replaced with ABB recirculation flow monitors (RFM's). All results that are dependent on recirculation flow measurement uncertainties are impacted by the ABB RFM replacements. Therefore, this minor revision re-determines total instrument uncertainty and results for the following functions: a) APRM flow biased trips, b) RBM flow biased trips, and c) RFM upscale and comparator trip results.
4. Revise Section 2.2 (and subsequently impacted sections) to address the calibration flow rate change from 80% to 75% as detailed in minor revision 2C.
5. Section 15.0, "Calculation Spreadsheet", is being deleted. This spreadsheet was included for reference, and it was utilized for verifying computations. It is no longer required and is therefore being deleted.
6. The value determined for FCS_{RBM} (0.668750) in Section 11.5.3.1.5 will be revised to correct a previous computation error.
7. Corrected the application of vendor provided performance specifications for the ABB RFM upscale and comparator trip functions.

NOTE: Changes or revisions to existing portions of the calculation are identified by a combination of either bold, underlined, or italic text in lieu of revision bars. Added text or new text or sections are indicated as such, and are NOT identified by bold, underlined, or italic text.

2.0 METHODOLOGY AND ACCEPTANCE CRITERIA

1. Revise Section 2.1.d as follows:

d. Static Pressure Span Effects

References 3.5.s, 3.5.t, and 3.5.y, 3.5.z state that a 1% of span correction has been included in the calibration to compensate for the static pressure span effect. However, Reference 3.14 states that there is a plus/minus correction uncertainty associated with this compensation. Therefore, this uncertainty will be included as a random error term in this calculation. Although the vendor gives this error term as a percent of reading, it will be considered as percent calibrated span which simplifies the calculation and is conservative.

2. Revise Section 2.2 to address the calibration flow rate change from 80% to 75% as detailed in minor revision 2C.

$$\text{Slope}_{\text{NEW}} = \text{Slope}_{\text{SP}} + [(T^+ + T^-)/0.08]/\Delta\text{Flow}$$

This will be used for both APRM and RBM flow biased error calculations. For the APRM's, the tolerance (T^+ , T^-) is ± 0.04 Vdc and the calibration flow (ΔFlow) is 75% flow (Section 10.4). For the RBM's, the tolerance (T^+ , T^-) is ± 0.04 Vdc and the calibration flow (ΔFlow) is 100% flow (Section 10.5).

3. Add new Section 2.4 as indicated below:

2.4 The methodology for determining as-left / as-found tolerances for APRM flow biased trip calibrations and surveillances, for each individually calibrated component or circuit (or module), is as follows:

Module As-Left Tolerance (ALT):

$$\text{ALT} = \pm [RA^2 + MTE^2 + RE_{MTE}^2]^{0.5}$$

Module As-Found Tolerance (AFT):

$$\text{AFT} = \pm [RA^2 + RD^2 + MTE^2 + RE_{MTE}^2]^{0.5}$$

where,

RA = Module Reference Accuracy
 RD = Module Vendor Specified Instrument Drift
 MTE = Module Measurement and Test Equipment (M&TE) Error
 RE_{MTE} = Module M&TE Readability

If a particular calibrated component or circuit (or module) is not provided with a reference accuracy specification, the setting tolerance applied during module calibration will be used in place of the reference accuracy specification.

3.0 REFERENCES

1. Add new references as indicated below:

3.5.y LIS-RR-101A, Rev. 12, "Unit 1 Recirculation Flow Converter A Calibration."
LIS-RR-101B, Rev. 12, "Unit 1 Recirculation Flow Converter B Calibration."
LIS-RR-101C, Rev. 11, "Unit 1 Recirculation Flow Converter C Calibration."
LIS-RR-101D, Rev. 14, "Unit 1 Recirculation Flow Converter D Calibration."

3.5.z LIS-RR-201A, Rev. 12, "Unit 2 Recirculation Flow Converter A Calibration."
LIS-RR-201B, Rev. 11, "Unit 2 Recirculation Flow Converter B Calibration."
LIS-RR-201C, Rev. 11, "Unit 2 Recirculation Flow Converter C Calibration."
LIS-RR-201D, Rev. 12, "Unit 2 Recirculation Flow Converter D Calibration."

2. Revise Reference 3.34 as follows: (Note that this supersedes the minor rev 2A change to this reference)

3.34 NES-EIC-20.04, Rev. 5, "Analysis of Instrument Channel Setpoint Error and Instrument Loop Accuracy."

3. Add new reference as indicated below: (Note: see minor rev 2A for reference 3.35, "ER-AA-520 and minor rev 2B for reference 3.35.a, "L-002884")

3.36 GE Task Report 0000-0106-6103-R0, DRF 0000-0096-1158, Rev.0. Class III, November 2009 "Project Task Report, Exelon Nuclear, LaSalle Units 1 and 2 Thermal Power Optimization, Task T0506: TS Instrument Setpoints."

3.37 Fluke 45 User Manual, PN855981, January 1989, Rev. 4, 7/97

4.0 DESIGN INPUTS

1. Revise Section 4.1 as follows:

4.1 Accuracy for Flow Transmitters

The procedures of References 3.5.s, 3.5.t, and 3.5.y, 3.5.z indicate that there are five different calibrated spans for the 16 flow transmitters covered by this calculation. Since some of the uncertainty terms depend on the calibrated span and/or the transmitters upper range, the lowest value of the calibrated span will be used for all flow loops since this will produce conservative results.

2. Revise Section 4.14 and applicable table entrees as follows:

4.14 Analytical Limits and Allowable Values Inputs

From References 3.27, 3.33, and 3.36 Analytical Limit inputs are provided for all non-flow biased setpoints and the APRM Flow Biased Trip functions (flow biased and clamp). Reference 3.15 provides the Allowable Values for the RBM Upscale Trips. There is no Analytical Limit, as the rod block is not considered in the Rod Withdrawal Error Analysis as stated in Reference 3.15. The information provided by References 3.15, 3.27, 3.33, and 3.36 is summarized below:

Bistable	AL	AV	Reference
APRM Flow Biased Trips			
Flow Biased STP Scram -TLO	<u>$0.61W + 69.76\%$</u>		<u>3.36</u>
Flow Biased STP Scram -SLO	<u>$0.54W + 57.39\%$</u>		<u>3.36</u>
Flow Biased STP Rod Block -TLO	<u>$0.61W + 58.51\%$</u>		<u>3.36</u>
Flow Biased STP Rod Block -SLO	<u>$0.54W + 46.14\%$</u>		<u>3.36</u>

3. Add new Section 4.15 as follows:

4.15 References 3.5.y and 3.5.z indicate the original GE recirculation flow units have been replaced with ABB recirculation flow monitors (RFM's). Therefore, all total channel errors that are dependent on recirculation flow measurement uncertainties will be based on the ABB RFM's. This applies to the following functions: a) APRM flow biased trips, b) RBM flow biased trips, and c) RFM upscale and comparator trip results.

4. Add new Section 4.16

4.16 Error Propagation through ABB RFM Square Root Converter

With Reference to Appendix B of Reference 3.34, input errors are propagated through the ABB RFM square root converter circuit as follows:

$$\begin{aligned}\sigma_{OUT} &= (k)(\sigma_{ERROR})/[2(x)^{0.5}] \\ e_{OUT} &= (k)(e_{ERROR})/[2(x)^{0.5}]\end{aligned}$$

where,

σ_{OUT} = random output error
 e_{OUT} = non-random output error
 k = gain
 σ_{ERROR} = random input error
 e_{ERROR} = non-random input error
 x = input span

Determining the value of k:

Per Appendix B of Reference 3.34, the equation for a square root converter is,

$$y = k(x)^{0.5}$$

In Units of Vdc: where y is the output span (10 Vdc) and x is the input span (10 Vdc) per References 3.5.y and 3.5.z. Solving for k,

$$\begin{aligned}
 k &= y/(x)^{0.5} \\
 &= 10 \text{ Vdc} / (10 \text{ Vdc})^{0.5} \\
 &= 3.162278 \text{ Vdc/Vdc}^{0.5}
 \end{aligned}$$

From Section 4.10, the point of interest is 75% Flow. The input span (x) at 75% Flow is determined as follows:

$$\begin{aligned}
 (75\% \text{ Flow}) / (125\% \text{ Flow}) &= [(x_{75\%})^{0.5}] / [10 \text{ Vdc}]^{0.5} \\
 x_{75\%} &= 3.6 \text{ Vdc}
 \end{aligned}$$

In Units of % CS: where y is the output span (100 % CS) and x is the input span (100 % CS) per References 3.5.y and 3.5.z. Solving for k,

$$\begin{aligned}
 k &= y/(x)^{0.5} \\
 &= 100 \% \text{ CS} / (100 \% \text{ CS})^{0.5} \\
 &= 10 \% \text{ CS} / \% \text{ CS}^{0.5}
 \end{aligned}$$

From Section 4.10, the point of interest is 75% Flow. The input span (x) at 75% Flow is determined as follows:

$$\begin{aligned}
 (75\% \text{ Flow}) / (125\% \text{ Flow}) &= [(x_{75\%})^{0.5}] / [100 \% \text{ CS}]^{0.5} \\
 x_{75\%} &= 36 \% \text{ CS}
 \end{aligned}$$

5. Add new Section 4.17

4.17 Error Propagation through ABB RFM Summer

With Reference to Appendix B of Reference 3.34, input errors are propagated through the ABB RFM summer circuit as follows:

$$\begin{aligned}
 \sigma_{OUT} &= [(k1 * \sigma_{ERROR X})^2 + (k2 * \sigma_{ERROR Y})^2]^{0.5} \\
 e_{OUT} &= (k1 * e_{ERROR X}) + (k2 * e_{ERROR Y})
 \end{aligned}$$

where,

$$\sigma_{OUT} = \text{random output error}$$

e_{OUT}	= non-random output error
k_1	= gain input 1
k_2	= gain input 2
$\sigma_{ERROR X}$	= random input error X
$\sigma_{ERROR Y}$	= random input error Y
$e_{ERROR X}$	= non-random input error X
$e_{ERROR Y}$	= non-random input error Y

The summer inputs are equally weighted, therefore, $k_1 = k_2 = 0.5$.

5.0 ASSUMPTIONS

1. Delete Section 5.7 as follows:

~~Since the ABB designed flow unit has not yet been installed, it will be assumed that this flow unit will be mounted in the same general area as is the present flow unit. Therefore, the environmental parameters for the current flow unit will be assumed to be applicable to the new ABB flow units.~~

2. Delete Section 5.9 as follows:

~~Since there have been no procedures generated for calibrating the ABB designed flow unit it will be assumed that, when developed, they will be similar to those used to calibrate the GE designed flow unit. Therefore, the MTE and ST terms derived for the GE flow units will be assumed applicable to the calibration of the ABB flow unit.~~

3. Revise Section 5.11 as follows:

Based on the information contained in References 3.4 and 3.16 it will be assumed that LaSalle is using a Wallace and Tiernan Model 65-120 instrument when the procedures of References 3.5.s, 3.5.t and 3.5.y, 3.5.z call for a Pneumatic Calibrator.

7.0 PROCESS PARAMETERS

1. Revise Section 7.0 as follows:

The temperature of the fluid has, however, dropped to reactor building ambient temperature by the time it reached the location of the transmitters. Based on References 3.5.s, 3.5.t and 3.5.y, 3.5.z, 100% Flow in these flow loops is equal to 55,000 GPM.

8.6.2 Environmental Parameters at Flow Unit Location (Zone LC1A from EWCS) (Reference 3.6, Table 3.11-24) ~~It is assumed that this flow unit will be mounted in the same general area as is the present flow unit~~

9.0 CALIBRATION INSTRUMENT DATA

1. ABB RFM calibration procedures (References 3.5.y and 3.5.z), invokes use of a Fluke 45 to calibrate the recirculation flow transmitters. Therefore, revise the table in section 9.0 by adding the following MTE error information for a Fluke 45, slow reading rate, (100 mVdc Rng) as follows: (see section 9.1 changes below for determination of this uncertainty,). The ± 0.012141 mVdc uncertainty value is utilized, because the maximum reading will be 20 mVdc at the transmitter location, and the environment during calibration should not exceed 104°F.

<u>Calibration Instrument</u>	<u>MTE Error [1σ]</u>	<u>Evaluation Parameters</u>
<u>MTE for all DMM Calibrations</u>		
<u><i>Fluke 45 Slow (100 mVdc Rng)</i></u>	<u><i>± 0.012141 mVdc</i></u>	<u><i>@20 mVdc, 104°F</i></u>

2. Revise Section 9.2 as follows:

9.2 Pressure Measurement Error Evaluation

References 3.5.s, 3.5.t and 3.5.y, 3.5.z specify the use of a “Pneumatic Calibrator, 0-850”W.C. (Accuracy: ± 2.0 ”W.C., minimum).”

3. Section 9.1: Add the following DMM measurement error evaluation for a Fluke 45, slow reading rate, (100 mVdc Range) as follows under Section 9.1:

FLUKE 45 SLOW READING RATE RANGE: 100 mVdc

Manufacturer's Specifications (from Reference 3.37)

Reference Accuracy (RA) [†]	=	$\pm(0.025\%(\text{RDG}) + 6(\text{digits}))$	[2 σ]
Resolution (RES)	=	0.001 mV	
Temperature Effect* (TE)	=	$\pm(0.1(\text{Accuracy Spec.})/^\circ\text{C})(\Delta T)$	[2 σ]

[†] 1 Year Accuracy Specification

* From 0°C to 18°C and 28°C to 50°C

Temperature Differential (ΔT)

64.4 → 82.4°F (18 → 28°C)	Temperature Effect Not Applicable		
104°F = 40.0°C →	ΔT	= (40.0 – 28.0)°C	= 12.0°C
122°F = 50.0°C →	ΔT	= (50.0 – 28.0)°C	= 22.0°C

Total Measurement Error (MTE)

$$\text{MTE} = \pm[(\text{RA}/2 + \text{TE}/2)^2 + \text{RES}^2]^{1/2} \quad [1\sigma]$$

<u>Maximum Zone Temp.</u>	<u>MTE at RDG = 20 mV</u>	<u>MTE at RDG = 50 mV</u>
64.4 → 82.4°F	± 0.005590 mV	± 0.009304 mV
104°F	± 0.012141 mV	± 0.020375 mV
122°F	± 0.017628 mV	± 0.029617 mV

11.0 MODULE ERRORS

11.1 MODULE 1 (FLOW TRANSMITTER)

1. Revise Section 11.1.1.3 as follows:

11.1.1.3 Calibration Uncertainty (CAL1)

The uncertainties associated with calibrating the flow transmitters are composed of the uncertainties in setting the input signal and the uncertainties in reading the output signal. References 3.5.s, 3.5.t and 3.5.y, 3.5.z do not give a particular instrument to be used for setting the input during calibration. Rather, they simply indicate a "Pneumatic Calibrator, 0-850" W.C. (accuracy: ± 2.0 " W.C., minimum)" is required. Per Assumption 5.11 LaSalle is assumed to be using a Wallace and Tiernan Model 65-120 instrument for this input monitoring function. For the maximum temperature applicable to this location the accuracy given by Reference 3.4 for this instrument is 2.149835" W.C. This is the value that will be used in this calculation. The reading error term ($REMTE_{1FT}$) is included in total MTE error term given in Reference 3.4. Therefore, a value of 0 will be used for $REMTE_{1FT}$ for this calculation.

The instrument specified by the procedures (References 3.5.s and 3.5.t) for measurement of the flow transmitter output is a Fluke 8600A DMM. For the voltage range of interest for this calculation the reference accuracy, from Reference 3.4, is 0.034961 mVdc. ($RAMTE_{2FT}$). Since this is a digital instrument, there is no reading error associated with its use ($REMTE_{2FT} = 0$). *The instrument specified by the procedures (References 3.5.y and 3.5.z) for measurement of the flow transmitter output is a Fluke 45 DMM. For the voltage range of interest, for this calculation, the reference accuracy, from Section 9.0, is ± 0.012141 mVdc. The Fluke 45 is a digital output device, and therefore, the reading error is considered to be the least significant increment of the display (or resolution) (see Reference 3.34). Per section 9.1, reading error is included in the uncertainty value. Since the uncertainty of a Fluke 8600A bounds the uncertainty of a Fluke 45, the Fluke 8600A will be evaluated in the following analysis.*

2. Revise Section 11.1.1.4 as follows:

11.1.1.4 Setting Tolerance (ST1)

From References 3.5.s, 3.5.t and 3.5.y, 3.5.z the setting tolerance for the flow transmitters' output ($ST_{FT(OUT)}$) is 0.08 mVdc.

3. Revise Section 11.1.1.5 as follows:

11.1.1.5 Static Pressure Span Effect (Correction Uncertainty) ($SPSE_{FT}$)

References 3.5.s, 3.5.t and 3.5.y, 3.5.z state that a 1% of span correction has been included in the calibration to compensate for the static pressure span effect.

4. Revise Section 11.1.2.5 as follows:

11.1.2.5 Static Pressure Effect (e_{1SP})

From References 3.5.s, 3.5.t and 3.5.y, 3.5.z, these instruments have been compensated for static pressure effect during calibration.

11.4.4 Module 4D (Trip Circuit – Flow Biased)

1. Revise section 11.4.4 as follows:

Module 4D receives an analog input from the Averaging Circuitry and the ABB RFM (Module 6), and provides a bistable output, the state of which depends on the relative magnitudes of the input signal from the Averaging Circuitry and the reference value, which is a function of the ABB RFM flow signal. Therefore, Module 4D is a bistable module.

2. Revise section 11.4.4.1.5 as follows to evaluate uncertainties from the ABB RFM instead of uncertainties from the GE Flow Units. Refer to section 11.6 of this minor revision for determination of ABB RFM uncertainties.

11.4.4.1.5 Input Uncertainty (σ_{input4D})

The Module 4D input error (σ_{input4D}) is the SRSS combination of random input terms from Module 4B ($\sigma_{4B_{FB}}$) and Module 6 (σ_6) (per section 4.15). However, σ_6 must be converted from % Flow to % Power using the flow biased trip slope adjustment from Section 2.2 which accounts for setting uncertainties.

3. Revise section 11.4.4.1.5.1 as follows to a) evaluate uncertainties from the ABB RFM (σ_6 and σ_{6c} values from section 11.6.1.1.6) instead of uncertainties from the GE Flow Units, b) evaluate the AL value per Reference 3.36, and c) apply the 75% calibration flow rate as detailed previously per section 2.2 changes:

11.4.4.1.5.1 Two Loop Operation (TLO) – From Design Input 4.14, the TLO flow biased slope (FCS_{SP}) is 0.61 which is adjusted as

$$\begin{aligned} FCS &= FCS_{SP} + [(0.04+0.04) / 0.08] / 75 \\ &= \mathbf{0.61 + [(0.04+0.04) / 0.08] / 75} \\ &= \mathbf{0.623333} \end{aligned}$$

The module 4D input uncertainty for TLO is determined as

$$\begin{aligned} \sigma_{\text{input4D}} &= \pm[\sigma_{4B_{FB}}^2 + (FCS * \sigma_6)^2]^{0.5} \\ \sigma_{\text{input4D}} &= \pm[1.21122^2 + (0.623333 * 2.112581)^2]^{0.5} \\ \sigma_{\text{input4D}} &= \mathbf{\pm 1.789169 \text{ Power}} \end{aligned}$$

And the module 4D AV uncertainty for TLO is determined as

$$\begin{aligned} \sigma_{\text{input4D}_{AV}} &= \pm[\sigma_{4B_{AV}}^2 + (FCS * \sigma_{6c})^2]^{0.5} \\ \sigma_{\text{input4D}_{AV}} &= \pm[1.041510^2 + (0.623333 * 1.035450)^2]^{0.5} \\ \sigma_{\text{input4D}_{AV}} &= \mathbf{\pm 1.225285 \% \text{ Power}} \end{aligned}$$

4. Revise section 11.4.4.1.5.2 as follows to a) evaluate uncertainties from the ABB RFM (σ_6 and σ_{6C} values from section 11.6.1.1.6) instead of uncertainties from the GE Flow Units, b) evaluate the AL value per Reference 3.36, and c) apply the 75% calibration flow rate as detailed previously per section 2.2 changes:

11.4.4.1.5.2 Single Loop Operation (SLO) – From Design Input 4.14, the SLO flow biased slope (FCS_{SPSLO}) is 0.54 which is adjusted as

$$\begin{aligned} FCS_{SLO} &= FCS_{SPSLO} + [(0.04+0.04) / 0.08] / 75 \\ &= 0.54 + [(0.04+0.04) / 0.08] / 75 \\ &= 0.553333 \end{aligned}$$

The module 4D input uncertainty for SLO is determined as

$$\begin{aligned} \sigma_{input4D_{SLO}} &= \pm[\sigma_4 B_{FB}^2 + (FCS_{SLO} * \sigma_6)^2]^{0.5} \\ \sigma_{input4D_{SLO}} &= \pm[1.21122^2 + (0.553333 * 2.112581)^2]^{0.5} \\ \sigma_{input4D_{SLO}} &= \pm 1.683307 \% \text{ Power} \end{aligned}$$

And the module 4D AV uncertainty for SLO is determined as

$$\begin{aligned} \sigma_{input4D_{AVSLO}} &= \pm[\sigma_4 B_{AV}^2 + (FCS_{SLO} * \sigma_{6C})^2]^{0.5} \\ \sigma_{input4D_{AVSLO}} &= \pm[1.041510^2 + (0.553333 * 1.035450)^2]^{0.5} \\ \sigma_{input4D_{AVSLO}} &= \pm 1.188702 \% \text{ Power} \end{aligned}$$

5. Revise section 11.4.4.1.6.1 as follows:

$$\begin{aligned} \sigma_{4D} &= \pm[RA4D_{(1\sigma)}^2 + RD4D_{(1\sigma)}^2 + CAL4D^2 + ST4D_{(1\sigma)}^2 + \sigma_{input4D}^2]^{0.5} \\ \sigma_{4D} &= \pm[0.625^2 + 1.74553^2 + 0.00225^2 + 0.166667^2 + 1.789169^2]^{0.5} \\ \sigma_{4D} &= \pm 2.581939 \% \text{ Power} \end{aligned}$$

And the module 4D AV random error is

$$\begin{aligned} \sigma_{4D_{AV}} &= \pm[RA4D_{(1\sigma)}^2 + RD4D_{(1\sigma)}^2 + CAL4D^2 + ST4D_{(1\sigma)}^2 + \sigma_{input4D_{AV}}^2]^{0.5} \\ \sigma_{4D_{AV}} &= \pm[0.625^2 + 1.74553^2 + 0.00225^2 + 0.166667^2 + 1.225285^2]^{0.5} \\ \sigma_{4D_{AV}} &= \pm 2.228588 \% \text{ Power} \end{aligned}$$

6. Revise section 11.4.4.1.6.2 as follows:

$$\begin{aligned} \sigma_{4D_{SLO}} &= \pm[RA4D_{(1\sigma)}^2 + RD4D_{(1\sigma)}^2 + CAL4D^2 + ST4D_{(1\sigma)}^2 + \sigma_{input4D_{SLO}}^2]^{0.5} \\ \sigma_{4D_{SLO}} &= \pm[0.625^2 + 1.74553^2 + 0.00225^2 + 0.166667^2 + 1.683307^2]^{0.5} \\ \sigma_{4D_{SLO}} &= \pm 2.509742 \% \text{ Power} \end{aligned}$$

And the module 4D AV random error is

$$\begin{aligned} \sigma_{4D_{AVSLO}} &= \pm[RA4D_{(1\sigma)}^2 + RD4D_{(1\sigma)}^2 + CAL4D^2 + ST4D_{(1\sigma)}^2 + \sigma_{input4D_{AVSLO}}^2]^{0.5} \\ \sigma_{4D_{AVSLO}} &= \pm[0.625^2 + 1.74553^2 + 0.00225^2 + 0.166667^2 + 1.188702^2]^{0.5} \end{aligned}$$

$$\sigma_{4D_{AVSLO}} = \pm 2.208686\% \text{ Power}$$

7. Revise section 11.4.4.2.9.1 as follows to evaluate uncertainties from the ABB RFM ($\Sigma 6$ value from section 11.6.1.2.10) instead of uncertainties from the GE Flow Units:

$$\begin{aligned} \text{einput4D} &= \pm[\Sigma e4B + (FCS * \Sigma e6)] \\ \text{einput4D} &= \pm[0.82 + (0.623333 * 1.845461)] \\ \text{einput4D} &= \pm 1.970337\% \text{ Power} \end{aligned}$$

And the module 4D AV error for TLO is determined as

$$\begin{aligned} \text{einput4D}_{AV} &= \pm[\Sigma e4B_{AV} + (FCS * \Sigma e6)] \\ \text{einput4D}_{AV} &= \pm[0 + (0.623333 * 1.845461)] \\ \text{einput4D}_{AV} &= \pm 1.150337\% \text{ Power} \end{aligned}$$

8. Revise section 11.4.4.2.9.2 as follows to evaluate uncertainties from the ABB RFM ($\Sigma 6$ value from section 11.6.1.2.10) instead of uncertainties from the GE Flow Units:

$$\begin{aligned} \text{einput4D}_{SLO} &= \pm[\Sigma e4B + (FCS * \Sigma e6)] \\ \text{einput4D}_{SLO} &= \pm[0.82 + (0.553333 * 1.845461)] \\ \text{einput4D}_{SLO} &= \pm 1.841154\% \text{ Power} \end{aligned}$$

And the module 4D AV error for SLO is determined as

$$\begin{aligned} \text{einput4D}_{AVSLO} &= \pm[\Sigma e4B_{AV} + (FCS * \Sigma e6)] \\ \text{einput4D}_{AVSLO} &= \pm[0 + (0.553333 * 1.845461)] \\ \text{einput4D}_{AVSLO} &= \pm 1.021154\% \text{ Power} \end{aligned}$$

9. Revise section 11.4.4.2.10.1 as follows:

$$\Sigma e4D = \pm(125/100) * (e4DH + e4DT + e4DR + e4DS + e4DSP + e4DP + e4Dp + e4DV) + \text{einput4D}$$

$$\Sigma e4D = \pm(125/100) * (0 + 0 + 0 + 0 + 0 + 0 + 0 + 0) + 1.970337$$

$$\Sigma e4D = \pm 1.970337\% \text{ Power}$$

And the module 4D AV error for TLO is determined as

$$\Sigma e4D_{AV} = \pm(125/100) * (e4DH + e4DT + e4DR + e4DS + e4DSP + e4DP + e4Dp + e4DV) + \text{einput4D}_{AV}$$

$$\Sigma e4D_{AV} = \pm(125/100) * (0 + 0 + 0 + 0 + 0 + 0 + 0 + 0) + 1.150337$$

$$\Sigma e4D_{AV} = \pm 1.150337\% \text{ Power}$$

10. Revise section 11.4.4.2.10.2 as follows:

$$\Sigma e4D_{SLO} = \pm(125/100)*(e4DH + e4DT + e4DR + e4DS + e4DSP + e4DP + e4Dp + e4DV) + einput4D_{SLO}$$

$$\Sigma e4D_{SLO} = \pm(125/100)*(0 + 0 + 0 + 0 + 0 + 0 + 0 + 0) + 1.841154$$

$$\Sigma e4D_{SLO} = \pm 1.841154 \% \text{ Power}$$

And the module 4D AV error for SLO is determined as

$$\Sigma e4D_{AVSLO} = \pm(125/100)*(e4DH + e4DT + e4DR + e4DS + e4DSP + e4DP + e4Dp + e4DV) + einput4D_{AVSLO}$$

$$\Sigma e4D_{AVSLO} = \pm(125/100)*(0 + 0 + 0 + 0 + 0 + 0 + 0 + 0) + 1.021154$$

$$\Sigma e4D_{AVSLO} = \pm 1.021154 \% \text{ Power}$$

11.5.3 Module 5C (Trip Circuit – Flow Biased)

1. Revise section 11.5.3 as follows:

Module 5C receives an analog input from the Averaging Circuitry and Gain Change Circuitry the **ABB RFM (Module 6)**, and provides a bistable output, the state of which depends on the relative magnitudes of the input signal from the Averaging and Gain Change Circuitry and the reference value, which is a function of the **ABB RFM flow** signal. Therefore, Module 5C is a bistable module.

2. Revise section 11.5.3.1.5 as follows to evaluate uncertainties from the ABB RFM (σ_6 and σ_{6C} values from section 11.6.1.1.6) instead of uncertainties from the GE Flow Units. Refer to section 11.6 of this minor revision for determination of ABB RFM uncertainties. This minor revision also corrects the computation of FCS_{RBM} .

11.5.3.1.5 Input Uncertainty ($\sigma_{input5C}$)

In addition to its own error terms, the error terms from Module 5A and **Module 6** must also be considered. Since the trip circuits perform no function on these input signals $\sigma_{input5C}$ and $\sigma_{input5CAV}$ become equal to the combination by SRSS of the random input terms σ_{5A} and σ_6 , and σ_{5AAV} and σ_{6C} . However, before σ_{5A} and σ_6 , and σ_{5AAV} and σ_{6C} can be combined, σ_6 and σ_{6C} must be converted from % Flow to % Power by multiplying by the slope of the curve in the Flow Controlled Trip Reference Unit. From the applicable procedures in Reference 3.5 this slope ($FCS_{RBM(SP)}$) is equal to 0.66% Power per % Flow. However, per Section 2.2 this slope has been modified to account for setting uncertainties. Therefore,

$$\begin{aligned} FCS_{RBM} &= FCS_{RBM(SP)} + [(0.04+0.04) / 0.08] / 100 \\ &= 0.66 + [(0.04+0.04) / 0.08] / 100 \\ &= 0.670000 \end{aligned}$$

therefore,

$$\begin{aligned}\sigma_{\text{input5C}} &= \pm[\sigma 5A^2 + (\text{FCS}_{\text{RBM}} * \sigma 6)^2]^{0.5} \% \text{ Power} \\ \sigma_{\text{input5C}} &= \pm[1.850009^2 + (0.670000 * 2.112581)^2]^{0.5} \% \text{ Power} \\ \sigma_{\text{input5C}} &= \pm 2.329372 \% \text{ Power}\end{aligned}$$

For the Allowable Value Determination this becomes:

$$\begin{aligned}\sigma_{\text{input5C}_{\text{AV}}} &= \pm[\sigma 5A_{\text{AV}}^2 + (\text{FCS}_{\text{RBM}} * \sigma 6)^2]^{0.5} \% \text{ Power} \\ \sigma_{\text{input5C}_{\text{AV}}} &= \pm[1.610749^2 + (0.670000 * 1.0354501)^2]^{0.5} \% \text{ Power} \\ \sigma_{\text{input5C}_{\text{AV}}} &= \pm 1.753797 \% \text{ Power}\end{aligned}$$

3. Revise section 11.5.3.1.6 as follows:

$$\begin{aligned}\sigma 5C &= \pm[(\text{RA}5C_{(1\sigma)})^2 + (\text{RD}5C_{(1\sigma)})^2 + (\text{CAL}5C)^2 + (\text{ST}5C_{(1\sigma)})^2 + (\sigma_{\text{input5C}})^2]^{0.5} \% \text{ Power} \\ \sigma 5C &= \pm[(0.625)^2 + (1.234276)^2 + (0.00225)^2 + (0.166667)^2 + (2.329372)^2]^{0.5} \% \text{ Power} \\ \sigma 5C &= \pm 2.714373 \% \text{ Power}\end{aligned}$$

And,

$$\begin{aligned}\sigma 5C_{\text{AV}} &= \pm[(\text{RA}5C_{(1\sigma)})^2 + (\text{RD}5C_{(1\sigma)})^2 + (\text{CAL}5C)^2 + (\text{ST}5C_{(1\sigma)})^2 + (\sigma_{\text{input5C}_{\text{AV}}})^2]^{0.5} \% \text{ Power} \\ \sigma 5C_{\text{AV}} &= \pm[(0.625)^2 + (1.234276)^2 + (0.00225)^2 + (0.166667)^2 + (1.753797)^2]^{0.5} \% \text{ Power} \\ \sigma 5C_{\text{AV}} &= \pm 2.240011 \% \text{ Power}\end{aligned}$$

4. Revise section 11.5.3.2.9 as follows to evaluate uncertainties from the ABB RFM ($\Sigma 6$ value from section 11.6.1.2.10) instead of uncertainties from the GE Flow Units. Also corrected the computation of FCS_{RBM} :

11.5.3.2.9 Non-Random Input Error (einput5C)

In addition to its own error terms, the error terms from Module 5A and Module 6 must also be considered. Since the trip circuits perform no function on these input signals einput5C and $\Sigma \text{input5C}_{\text{AV}}$ become equal to the combination by SRSS of the random input terms $\Sigma \text{e}5A$ and $\Sigma \text{e}6$, and $\Sigma \text{e}5A_{\text{AV}}$ and $\Sigma \text{e}6_{\text{AV}}$. However, before $\Sigma \text{e}5A$ and $\Sigma \text{e}6$, and $\Sigma \text{e}5A_{\text{AV}}$ and $\Sigma \text{e}6_{\text{AV}}$ can be combined, $\Sigma \text{e}6$ and $\Sigma \text{e}6_{\text{AV}}$ must be converted from % Flow to % Power by multiplying by the slope of the curve in the Flow Controlled Trip Reference Unit. From the applicable procedures in Reference 3.5 this slope ($\text{FCS}_{\text{RBM}(\text{SP})}$) is equal to 0.66% Power per % Flow. However, per Section 2.2 this slope has been modified to account for setting uncertainties. Therefore,

$$\begin{aligned}\text{einput5C} &= \pm[\Sigma \text{e}5A + (\text{FCS}_{\text{RBM}} * \Sigma \text{e}6)] \% \text{ Power} \\ \text{einput5C} &= \pm[0.82 + (0.670000 * 1.845461)] \% \text{ Power} \\ \text{einput5C} &= \pm 2.056459 \% \text{ Power}\end{aligned}$$

And

$$\begin{aligned}\text{einput5C}_{\text{AV}} &= \pm[\Sigma \text{e}5A_{\text{AV}} + (\text{FCS}_{\text{RBM}} * \Sigma \text{e}6)] \% \text{ Power} \\ \text{einput5C}_{\text{AV}} &= \pm[0 + (0.670000 * 1.845461)] \% \text{ Power} \\ \text{einput5C}_{\text{AV}} &= \pm 1.236459 \% \text{ Power}\end{aligned}$$

5. Revise section 11.5.3.2.10 as follows:

$$\Sigma e5C = \pm(125/100)*(e5CH + e5CT + e5CR + e5CS + e5CSP + e5CP + e5Cp + e5CV) + einput5C \% \text{ Power}$$

$$\Sigma e5C = \pm(125/100)*(0 + 0 + 0 + 0 + 0 + 0 + 0 + 0) + 2.056459 \% \text{ Power}$$

$$\Sigma e5C = \pm 2.056459 \% \text{ Power}$$

And

$$\Sigma e5C_{AV} = \pm(125/100)*(e5CH + e5CT + e5CR + e5CS + e5CSP + e5CP + e5Cp + e5CV) + einput5C_{AV} \% \text{ Power}$$

$$\Sigma e5C_{AV} = \pm(125/100)*(0 + 0 + 0 + 0 + 0 + 0 + 0 + 0) + 1.236459 \% \text{ Power}$$

$$\Sigma e5C_{AV} = \pm 1.236459 \% \text{ Power}$$

11.6.1 Module 6 Analog Section

1. Section 11.6.1.1.3: Delete existing text under section 11.6.1.1.3 and replace with the following new text as follows:

11.6.1.1.3 Calibration Uncertainty (CAL6)

Per References 3.5.y and 3.5.z, this module contains circuits which are calibrated individually. These circuits consists of: 1) input isolators (one for each recirculation flow loop), 2) square root converters, 3) a summer, and 4) an analog output isolator (which provides the total output flow signal).

The uncertainties associated with calibrating the ABB RFM circuits consist of the uncertainties in setting the input signal and the uncertainties in reading the output signal. References 3.5.y and 3.5.z specify use of Fluke 45 DMM's for measurement of voltage input and output signals. For the voltage range of interest for this calculation (0 – 10 Vdc and with control room environments per References 3.5.y and 3.5.z), the reference accuracy for a Fluke 45 is ± 0.002462 Vdc (see section 9.0). The Fluke 45 is a digital output device, and therefore, the reading error is considered to be the least significant increment of the display (or resolution) (see Reference 3.34). Per section 9.1, reading error is included in the ± 0.002462 Vdc uncertainty value.

From Section 5.2, errors attributed to calibration standards are considered negligible. Therefore, the only terms which contribute to calibration uncertainty (CAL) are uncertainties associated with measuring input calibration signals (MTE1) and output calibration signals (MTE2).

Calibration uncertainties associated with the ABB RFM is determined below:

a) Input Isolators

The input isolators are calibrated by applying a measured pressure input signal into the flow transmitter while measuring the output of the isolator with a Fluke 45. The uncertainty associated with measuring the transmitter input signal is determined in Section 11.1.1.3 and is listed below:

$$MTE1_{II(CS)} = MTE1_{FT(CS)} = \pm 0.868971 \% CS \quad [1\sigma]$$

The uncertainty associated with measuring the output from the isolator is determined above as,

$$MTE2_{II} = MTE_{45} = \pm 0.002462 Vdc \quad [1\sigma]$$

These uncertainties are converted to equivalent output values at the square root converter and then to equivalent output values at the summer. However, $MTE1_{II(CS)}$ is first converted to a voltage value by multiplying it by the input isolator calibration span (10 Vdc) and dividing by 100%.

$$\begin{aligned} MTE1_{II} &= (MTE1_{II(CS)}) * (10 Vdc / 100 \% CS) \\ &= \pm (0.868971 \% CS) * (10 Vdc / 100 \% CS) \\ &= \pm 0.086897 Vdc \end{aligned} \quad [1\sigma]$$

Convert to equivalent square root converter output value by utilizing equations and the operating point of interest (75% flow = 3.6 Vdc) determined in Section 4.16:

$$y = (k)(\sigma_{ERROR})/[2(x)^{0.5}]$$

by substitution,

$$\begin{aligned} MTE1_{II(SR OUT)} &= \pm [(3.162278 Vdc/Vdc^{0.5}) * (MTE1_{II})] / [2(3.6 Vdc)^{0.5}] \\ &= \pm [(3.162278 Vdc/Vdc^{0.5}) * (0.086897 Vdc)] / [2(3.6 Vdc)^{0.5}] \\ &= \pm 0.072414 Vdc \end{aligned} \quad [1\sigma]$$

$$\begin{aligned} MTE2_{II(SR OUT)} &= \pm [(3.162278 Vdc/Vdc^{0.5}) * (MTE2_{II})] / [2(3.6 Vdc)^{0.5}] \\ &= \pm [(3.162278 Vdc/Vdc^{0.5}) * (0.002462 Vdc)] / [2(3.6 Vdc)^{0.5}] \\ &= \pm 0.002052 Vdc \end{aligned} \quad [1\sigma]$$

Convert to equivalent summer output value by utilizing equations determined in Section 4.17:

$$\sigma_{OUT} = [(k1 * \sigma_{ERROR X})^2 + (k2 * \sigma_{ERROR Y})^2]^{0.5}$$

by substitution,

$$\begin{aligned} MTE1_{II(SUM OUT)} &= \pm [(k1 * MTE1_{II(SR OUT)})^2 + (k2 * MTE1_{II(SR OUT)})^2]^{0.5} \\ &= \pm [(0.5 * 0.072414 Vdc)^2 + (0.5 * 0.072414 Vdc)^2]^{0.5} \\ &= \pm 0.051204 Vdc \end{aligned} \quad [1\sigma]$$

$$\begin{aligned} MT2_{II(SUM OUT)} &= \pm [(k1 * MTE2_{II(SR OUT)})^2 + (k2 * MTE2_{II(SR OUT)})^2]^{0.5} \\ &= \pm [(0.5 * 0.002052 Vdc)^2 + (0.5 * 0.002052 Vdc)^2]^{0.5} \\ &= \pm 0.001451 Vdc \end{aligned} \quad [1\sigma]$$

Note that $MTE1_{II}$ is already included in the determination of Module 1 random input uncertainty (1σ) determined in Section 11.1.1.8 and will therefore not be included in the determination of CAL6.

b) Square Root Converters

The square root converters are calibrated by applying a measured input signal with a Fluke 45 while measuring the output of the converter with another Fluke 45. The uncertainties associated with measuring

the square root converter input and output signals (MTE1 and MTE2, respectively) was determined above as:

$$\begin{aligned} \text{MTE1}_{\text{SR}} &= \text{MTE}_{45} = \pm 0.002462 \text{ Vdc} & [1\sigma] \\ \text{MTE2}_{\text{SR}} &= \text{MTE}_{45} = \pm 0.002462 \text{ Vdc} & [1\sigma] \end{aligned}$$

Convert MTE1_{SR} to an equivalent square root converter output value by utilizing equations and the operating point of interest (75% flow = 3.6 Vdc) determined Section 4.16:

$$y = (k)(\sigma_{\text{ERROR}})/[2(x)^{0.5}]$$

by substitution,

$$\begin{aligned} \text{MTE1}_{\text{SR (SR OUT)}} &= \pm[(3.162278 \text{ Vdc/Vdc}^{0.5}) * (\text{MTE1}_{\text{SR}})]/[2(3.6 \text{ Vdc})^{0.5}] \\ &= \pm[(3.162278 \text{ Vdc/Vdc}^{0.5}) * (0.002462 \text{ Vdc})]/[2(3.6 \text{ Vdc})^{0.5}] \\ &= \pm 0.002052 \text{ Vdc} & [1\sigma] \end{aligned}$$

Convert to equivalent summer output value by utilizing equations determined in Section 4.17:

$$\sigma_{\text{OUT}} = [(k1 * \sigma_{\text{ERROR X}})^2 + (k2 * \sigma_{\text{ERROR Y}})^2]^{0.5}$$

by substitution,

$$\begin{aligned} \text{MTE1}_{\text{SR (SUM OUT)}} &= \pm[(k1 * \text{MTE1}_{\text{SR (SR OUT)}})^2 + (k2 * \text{MTE1}_{\text{SR (SR OUT)}})^2]^{0.5} \\ &= \pm[(0.5 * 0.002052 \text{ Vdc})^2 + (0.5 * 0.002052 \text{ Vdc})^2]^{0.5} \\ &= \pm 0.001451 \text{ Vdc} & [1\sigma] \end{aligned}$$

$$\begin{aligned} \text{MTE2}_{\text{SR (SUM OUT)}} &= \pm[(k1 * \text{MTE2}_{\text{SR}})^2 + (k2 * \text{MTE2}_{\text{SR}})^2]^{0.5} \\ &= \pm[(0.5 * 0.002462 \text{ Vdc})^2 + (0.5 * 0.002462 \text{ Vdc})^2]^{0.5} \\ &= \pm 0.001741 \text{ Vdc} & [1\sigma] \end{aligned}$$

c) Summer

The summer is calibrated by applying two measured input signals with two Fluke 45's (MTE1_{SUM}) while measuring the output of the summer with a third Fluke 45 (MTE2_{SUM}). The uncertainties associated with measuring the summer input and output signals (MTE1_{SUM} and MTE2_{SUM} , respectively) was determined above as:

$$\begin{aligned} \text{MTE1}_{\text{SUM}} &= \text{MTE}_{45} = \pm 0.002462 \text{ Vdc} & [1\sigma] \\ \text{MTE2}_{\text{SUM}} &= \text{MTE}_{45} = \pm 0.002462 \text{ Vdc} & [1\sigma] \end{aligned}$$

Convert to equivalent summer output value by utilizing equations determined in Section 4.17:

$$\sigma_{\text{OUT}} = [(k1 * \sigma_{\text{ERROR X}})^2 + (k2 * \sigma_{\text{ERROR Y}})^2]^{0.5}$$

by substitution,

$$\begin{aligned} \text{MTE1}_{\text{SUM (SUM OUT)}} &= \pm[(k1 * \text{MTE1}_{\text{SUM}})^2 + (k2 * \text{MTE1}_{\text{SUM}})^2]^{0.5} \\ &= \pm[(0.5 * 0.002462 \text{ Vdc})^2 + (0.5 * 0.002462 \text{ Vdc})^2]^{0.5} \\ &= \pm 0.001741 \text{ Vdc} & [1\sigma] \end{aligned}$$

d) Output Isolator

The output isolator is calibrated by applying a measured input signal with a Fluke 45 while measuring the output with another Fluke 45. The uncertainties associated with measuring the isolator input and output signals (MTE1 and MTE2, respectively) was determined above as:

$$\begin{aligned} \text{MTE1}_{\text{OI}} &= \text{MTE}_{45} = \pm 0.002462 \text{ Vdc} & [1\sigma] \\ \text{MTE2}_{\text{OI}} &= \text{MTE}_{45} = \pm 0.002462 \text{ Vdc} & [1\sigma] \end{aligned}$$

e) Determine Total Calibration Uncertainty (CAL6):

Using the methodology of Reference 3.34:

$$\begin{aligned} \text{CAL6}_{\text{VDC}} &= \pm [(\text{MTE2}_{\text{II (SUM OUT)}})^2 + (\text{MTE1}_{\text{SR (SUM OUT)}})^2 + (\text{MTE2}_{\text{SR (SUM OUT)}})^2 \\ &\quad + (\text{MTE1}_{\text{SUM (SUM OUT)}})^2 + (\text{MTE2}_{\text{SUM}})^2 + (\text{MTE1}_{\text{OI}})^2 + (\text{MTE2}_{\text{OI}})^2]^{0.5} \\ &= \pm [(0.001451 \text{ Vdc})^2 + (0.001451 \text{ Vdc})^2 + (0.001741 \text{ Vdc})^2 \\ &\quad + (0.001741 \text{ Vdc})^2 + (0.002462 \text{ Vdc})^2 + (0.002462 \text{ Vdc})^2 + (0.002462 \text{ Vdc})^2 + (0.002462 \text{ Vdc})^2]^{0.5} \\ &= \pm 0.005335 \text{ Vdc} & [1\sigma] \end{aligned}$$

Convert to % CS by multiplying by 100% and dividing by 10 Vdc

$$\begin{aligned} \text{CAL6} &= \pm (0.005335 \text{ Vdc})(100\% \text{ CS} / 10 \text{ Vdc}) \\ &= \pm 0.053350 \% \text{ CS} & [1\sigma] \end{aligned}$$

2. Section 11.6.1.1.4: Delete existing text under section 11.6.1.1.4 and replace with the following new text as follows:

11.6.1.1.4 Setting Tolerance (ST6)

Per References 3.5.y and 3.5.z, this module contains circuits which are calibrated individually. These circuits consists of: 1) input isolators (one for each recirculation flow loop), 2) square root converters, 3) a summer, and 4) an analog output isolator (which provides the total output flow signal). The setting tolerances associated with calibrating the ABB RFM circuits consist of a combination of the input calibration tolerances (T1) and output calibration tolerances (T2). Setting tolerance uncertainties associated with the ABB RFM is determined below:

a) Input Isolators

Per References 3.5.y and 3.5.z, calibration tolerances associated with calibrating the input isolator are,

$$\begin{aligned} \text{T1}_{\text{II}} &= 0 \\ \text{T2}_{\text{II}} &= \pm 0.05 \text{ Vdc} \end{aligned}$$

These uncertainties are 3 σ values and must be converted to 1 σ values by dividing by three. These uncertainties are converted to equivalent output values at the square root converter and then to equivalent output values at the summer. Convert to equivalent square root converter output value by utilizing equations and the operating point of interest (75% flow = 3.6 Vdc) determined in Section 4.16:

$$y = (k)(\sigma_{\text{ERROR}})/[2(x)^{0.5}]$$

by substitution,

$$\begin{aligned}
T_{2II(SR OUT)} &= \pm[(3.162278 \text{ Vdc/Vdc}^{0.5}) * (T_{2II}/3)]/[2(3.6 \text{ Vdc})^{0.5}] \\
&= \pm[(3.162278 \text{ Vdc/Vdc}^{0.5}) * (0.05 \text{ Vdc}/3)]/[2(3.6 \text{ Vdc})^{0.5}] \\
&= \pm 0.013889 \text{ Vdc}
\end{aligned}
\quad [1\sigma]$$

Convert to equivalent summer output value by utilizing equations determined in Section 4.17:

$$\sigma_{OUT} = [(k1 * \sigma_{ERROR X})^2 + (k2 * \sigma_{ERROR Y})^2]^{0.5}$$

by substitution,

$$\begin{aligned}
T_{2II(SUM OUT)} &= \pm[(k1 * T_{2II(SR OUT)})^2 + (k2 * T_{2II(SR OUT)})^2]^{0.5} \\
&= \pm[(0.5 * 0.013889 \text{ Vdc})^2 + (0.5 * 0.013889 \text{ Vdc})^2]^{0.5} \\
&= \pm 0.009821 \text{ Vdc}
\end{aligned}
\quad [1\sigma]$$

b) Square Root Converters

Per References 3.5.y and 3.5.z, calibration tolerances associated with calibrating the square root converters are,

$$\begin{aligned}
T_{1SR} &= \pm 0.050 \text{ Vdc} \\
T_{2SR} &= \pm 0.025 \text{ Vdc}
\end{aligned}$$

These uncertainties are 3σ values and must be converted to 1σ values by dividing by three. Convert T1_{SR} to an equivalent square root converter output value by utilizing equations and the operating point of interest (75% flow = 3.6 Vdc) determined Section 4.16:

$$y = (k)(\sigma_{ERROR})/[2(x)^{0.5}]$$

by substitution,

$$\begin{aligned}
T_{1SR(SR OUT)} &= \pm[(3.162278 \text{ Vdc/Vdc}^{0.5}) * (T_{1SR}/3)]/[2(3.6 \text{ Vdc})^{0.5}] \\
&= \pm[(3.162278 \text{ Vdc/Vdc}^{0.5}) * (0.050 \text{ Vdc}/3)]/[2(3.6 \text{ Vdc})^{0.5}] \\
&= \pm 0.013889 \text{ Vdc}
\end{aligned}$$

Convert to equivalent summer output value by utilizing equations determined in Section 4.17:

$$\sigma_{OUT} = [(k1 * \sigma_{ERROR X})^2 + (k2 * \sigma_{ERROR Y})^2]^{0.5}$$

by substitution,

$$\begin{aligned}
T_{1SR(SUM OUT)} &= \pm[(k1 * T_{1SR(SR OUT)})^2 + (k2 * T_{1SR(SR OUT)})^2]^{0.5} \\
&= \pm[(0.5 * 0.013889 \text{ Vdc})^2 + (0.5 * 0.013889 \text{ Vdc})^2]^{0.5} \\
&= \pm 0.009821 \text{ Vdc}
\end{aligned}
\quad [1\sigma]$$

$$\begin{aligned}
T_{2SR(SUM OUT)} &= \pm[(k1 * T_{2SR})^2 + (k2 * T_{2SR})^2]^{0.5} \\
&= \pm[(0.5 * 0.025 \text{ Vdc}/3)^2 + (0.5 * 0.025 \text{ Vdc}/3)^2]^{0.5} \\
&= \pm 0.005893 \text{ Vdc}
\end{aligned}
\quad [1\sigma]$$

c) Summer

Per References 3.5.y and 3.5.z, calibration tolerances associated with calibrating the summer are,

$$\begin{aligned} T1_{\text{SUM}} &= 0 \\ T2_{\text{SUM}} &= \pm 0.010 \text{ Vdc} \end{aligned}$$

These uncertainties are 3σ values and must be converted to 1σ values by dividing by three.

$$\begin{aligned} T2_{\text{SUM}} &= \pm 0.010 \text{ Vdc} / 3 \\ &= \pm 0.003333 \text{ Vdc} \end{aligned} \quad [1\sigma]$$

d) Output Isolator

Per References 3.5.y and 3.5.z, calibration tolerances associated with calibrating the output isolator are,

$$\begin{aligned} T1_{\text{OI}} &= 0 \\ T2_{\text{OI}} &= \pm 0.010 \text{ Vdc} \end{aligned}$$

These uncertainties are 3σ values and must be converted to 1σ values by dividing by three.

$$\begin{aligned} T2_{\text{OI}} &= \pm 0.010 \text{ Vdc} / 3 \\ &= \pm 0.003333 \text{ Vdc} \end{aligned} \quad [1\sigma]$$

e) Determine Total Setting Tolerance Uncertainty (ST6):

Using the methodology of Reference 3.34:

$$\begin{aligned} ST6_{\text{VDC}} &= \pm [(T2_{\text{II (SUM OUT)}})^2 + (T1_{\text{SR (SUM OUT)}})^2 + (T2_{\text{SR (SUM OUT)}})^2 \\ &\quad + (T2_{\text{SUM}})^2 + (T2_{\text{OI}})^2]^{0.5} \\ &= \pm [(0.009821 \text{ Vdc})^2 + (0.009821 \text{ Vdc})^2 + (0.005893 \text{ Vdc})^2 + (0.003333 \text{ Vdc})^2 \\ &\quad + (0.003333 \text{ Vdc})^2]^{0.5} \\ &= \pm 0.015807 \text{ Vdc} \end{aligned} \quad [1\sigma]$$

Convert to % CS by multiplying by 100% and dividing by 10 Vdc

$$\begin{aligned} ST6 &= \pm (0.015807 \text{ Vdc})(100\% \text{ CS} / 10 \text{ Vdc}) \\ &= \pm 0.158070 \% \text{ CS} \end{aligned} \quad [1\sigma]$$

3. Section 11.6.1.1.5: Delete existing text under section 11.6.1.1.5 and replace with the following new text as follows:

11.6.1.1.5 Input Uncertainty (σ_{input6})

In addition to its own error terms, Module 6 also operates on the error terms from Module 1. Therefore, the random error term (1σ) from the flow transmitter must be transferred through the ABB RFM from input to output per Section 4.16 and 4.17. The resultant term will be σ_{input6} and σ_{input6c} for this module. From Section 11.1.1.8,

$$\sigma_1 = \pm 2.691847 \% \text{ CS} \quad [1\sigma]$$

For the Comparator Trip

$$\sigma_{1C} = \pm 0.998018\% \text{ CS} \quad [1\sigma]$$

The errors are transferred through the ABB RFM as follows:

Per References 3.5.y and 3.5.z, this module contains circuits which contain square root converters and a summer. These uncertainties are converted to equivalent output values at the square root converters and then to equivalent output values at the summer. Convert to equivalent square root converter output value by utilizing equations and the operating point of interest (75% flow = 36 % CS) determined in Section 4.16:

$$y = (k)(\sigma_{\text{ERROR}})/[2(x)^{0.5}]$$

by substitution,

$$\begin{aligned} \sigma_{\text{input6(SR)}} &= \pm[(10\% \text{ CS}/\% \text{ CS}^{0.5}) * (\sigma_1)]/[2(36\% \text{ CS})^{0.5}] \\ &= \pm[(10\% \text{ CS}/\% \text{ CS}^{0.5}) * (2.691847\% \text{ CS})]/[2(36\% \text{ CS})^{0.5}] \\ &= \pm 2.243206\% \text{ CS} \quad [1\sigma] \end{aligned}$$

$$\begin{aligned} \sigma_{\text{input6C(SR)}} &= \pm[(10\% \text{ CS}/\% \text{ CS}^{0.5}) * (\sigma_{1C})]/[2(36\% \text{ CS})^{0.5}] \\ &= \pm[(10\% \text{ CS}/\% \text{ CS}^{0.5}) * (0.998018\% \text{ CS})]/[2(36\% \text{ CS})^{0.5}] \\ &= \pm 0.831682\% \text{ CS} \quad [1\sigma] \end{aligned}$$

Convert to equivalent summer output value by utilizing equations determined in Section 4.17:

$$\sigma_{\text{OUT}} = [(k_1 * \sigma_{\text{ERROR X}})^2 + (k_2 * \sigma_{\text{ERROR Y}})^2]^{0.5}$$

by substitution,

$$\begin{aligned} \sigma_{\text{input6}} &= \pm[(k_1 * \sigma_{\text{input6(SR)}})^2 + (k_2 * \sigma_{\text{input6(SR)}})^2]^{0.5} \\ &= \pm[(0.5 * 2.243206\% \text{ CS})^2 + (0.5 * 2.243206\% \text{ CS})^2]^{0.5} \\ &= \pm 1.586186\% \text{ CS} \quad [1\sigma] \end{aligned}$$

$$\begin{aligned} \sigma_{\text{input6C}} &= \pm[(k_1 * \sigma_{\text{input6C(SR)}})^2 + (k_2 * \sigma_{\text{input6C(SR)}})^2]^{0.5} \\ &= \pm[(0.5 * 0.831682\% \text{ CS})^2 + (0.5 * 0.831682\% \text{ CS})^2]^{0.5} \\ &= \pm 0.588088\% \text{ CS} \quad [1\sigma] \end{aligned}$$

4. Revise section 11.6.1.1.6 as follows:

11.6.1.1.6 Determination of Module Random Error (σ_6)

Using the methodology of Reference 3.3, and converting to % Flow by multiplying by 125/100:

$$\begin{aligned} \sigma_6 &= \pm(125/100) * [(RA6_{(1\sigma)})^2 + (RD6_{(1\sigma)})^2 + (CAL6)^2 + (ST6_{(1\sigma)})^2 + (\sigma_{\text{input6}})^2]^{0.5} \% \text{ Flow} \\ &= \pm(125/100) * [(0.5)^2 + (0.25)^2 + (0.053350)^2 + (0.158070)^2 + (1.586186)^2]^{0.5} \% \text{ Flow} \\ &= \pm 2.112581\% \text{ Flow} \quad [1\sigma] \end{aligned}$$

For the Comparator Trip:

$$\sigma_{6C} = \pm(125/100) * [(RA6_{(1\sigma)})^2 + (RD6_{(1\sigma)})^2 + (CAL6)^2 + (ST6_{(1\sigma)})^2 + (\sigma_{\text{input6C}})^2]^{0.5} \% \text{ Flow}$$

$$\begin{aligned}
&= \pm(125/100)*[(0.5)^2 + (0.25)^2 + (0.053350)^2 + (0.158070)^2 + (0.588088)^2]^{0.5} \% \text{ Flow} \\
&= \pm 1.035450 \% \text{ Flow} \quad [1\sigma]
\end{aligned}$$

11.6.1.2 Module 6 Non-Random Errors (Σe_6)

1. Section 11.6.1.2.9: Delete existing text under section 11.6.1.2.9 and replace with the following new text as follows:

11.6.1.2.9 Non-Random Input Error ($e_{\text{input}6}$)

In addition to its own error terms, Module 6 also operates on the error terms from Module 1. Therefore, the non-random error term (Σe_1) from the flow transmitter must be transferred through the ABB RFM from input to output per Section 4.16 and 4.17. The resultant term will be $e_{\text{input}6}$ for this module. From Section 11.1.2.10,

$$\Sigma e_1 = 1.171643 \% \text{ CS}$$

The errors are transferred through the ABB RFM as follows:

Per References 3.5.y and 3.5.z, this module contains circuits which contain square root converters and a summer. These uncertainties are converted to equivalent output values at the square root converters and then to equivalent output values at the summer. Convert to equivalent square root converter output value by utilizing equations and the operating point of interest (75% flow = 36 % CS) determined in Section 4.16:

$$y = (k)(e_{\text{ERROR}})/[2(x)^{0.5}]$$

by substitution,

$$\begin{aligned}
e_{\text{input}6(\text{SR})} &= \pm[(10 \% \text{ CS}/\% \text{ CS}^{0.5})*(\Sigma e_1)]/[2(36 \% \text{ CS})^{0.5}] \\
&= \pm[(10 \% \text{ CS}/\% \text{ CS}^{0.5})*(1.171643 \% \text{ CS})]/[2(36 \% \text{ CS})^{0.5}] \\
&= \pm 0.976369 \% \text{ CS}
\end{aligned}$$

Convert to equivalent summer output value by utilizing equations determined in Section 4.17:

$$e_{\text{OUT}} = (k_1 * e_{\text{ERROR X}}) + (k_2 * e_{\text{ERROR Y}})$$

by substitution,

$$\begin{aligned}
e_{\text{input}6} &= \pm(k_1 * e_{\text{input}6(\text{SR})}) + (k_2 * e_{\text{input}6(\text{SR})}) \\
&= \pm(0.5 * 0.976369 \% \text{ CS}) + (0.5 * 0.976369 \% \text{ CS}) \\
&= \pm 0.976369 \% \text{ CS}
\end{aligned}$$

2. Revise 11.6.1.2.10 as follows:

11.6.1.2.10 Non-Random Error (Σe_6)

From Reference 3.3 the non-random error is the algebraic sum of all the above terms. In addition, this term can be converted to % Flow by multiplying by 125/100. The result is;

$$\begin{aligned}
\Sigma e_6 &= \pm(125/100) * (e_{6H} + e_{6T} + e_{6R} + e_{6S} + e_{6SP} + e_{6P} + e_{6p} + e_{6V} + e_{input6}) \% \text{ Flow} \\
&= \pm(125/100) * (0 + 0.5 + 0 + 0 + 0 + 0 + 0 + 0 + 0.976369) \% \text{ Flow} \\
&= \pm 1.845461 \% \text{ Flow}
\end{aligned}$$

11.6.2.1 Module 6A Random Error (σ_{6A})

1. Revise Section 11.6.2.1.1 as follows to correct RA6A reference accuracy determination:

Per Section 8.6.1, the reference accuracy for this module is:

$$RA_{6A} = \pm 2 \% \text{ CS (based on 1\% trip setpoint error plus 1\% total flow signal error)}$$

Per Assumption 5.1, this is assumed to be a 2 sigma value. This is then converted to a 1 sigma value by dividing by 2. In the same step this will be converted to % Flow by multiplying by 125/100.

$$\begin{aligned}
RA_{6A(1\sigma)} &= \pm(RA_{6A}/2 * (125/100) \% \text{ Flow} \\
RA_{6A(1\sigma)} &= \pm(2 \% \text{ CS}/2) * (125/100) \% \text{ Flow} \\
RA_{6A(1\sigma)} &= \pm 1.25 \% \text{ Flow (overall RFM uncertainty from input through actuation)}
\end{aligned}$$

2. Section 11.6.2.1.3: Delete existing text under section 11.6.2.1.3 and replace with the following new text as follows:

11.6.2.1.3 Calibration Uncertainty (CAL6A and CAL6B)

CAL6A:

Per References 3.5.y and 3.5.z, this module is a bistable, and it specifies use of a Fluke 45 DMM for measurement of voltage input signals while monitoring the module for actuation. For the voltage range of interest for this calculation (0 – 10 Vdc and with control room environments per References 3.5.y and 3.5.z), the reference accuracy for a Fluke 45 is ± 0.002462 Vdc (from Section 9.0). The Fluke 45 is a digital output device, and therefore, the reading error is considered to be the least significant increment of the display (or resolution) (see Reference 3.34). Per section 9.1, reading error is included in the uncertainty value. From Section 5.2, errors attributed to calibration standards are considered negligible. Therefore, the only terms which contribute to calibration uncertainty (CAL) are uncertainties associated with measuring input calibration signals (MTE1) and output calibration signals (MTE2).

Since there is only one MTE used to calibrate this module,

$$CAL_{6A_{VDC}} = MTE_{45} = \pm 0.002462 \text{ Vdc} \quad [1\sigma]$$

Convert to % Flow by multiplying by 125% Flow and dividing by 10 Vdc.

$$\begin{aligned}
CAL_{6A} &= \pm(0.002462 \text{ Vdc})(125\% \text{ Flow} / 10 \text{ Vdc}) \\
&= \pm 0.030775 \% \text{ Flow} \quad [1\sigma]
\end{aligned}$$

CAL6B:

Per References 3.5.y and 3.5.z, this module is a bistable that compares two input signals and actuates upon specified deviations. References 3.5.y and 3.5.z specifies use of two Fluke 45 DMM's for measurement of voltage input signals while monitoring the module for actuation. For the voltage range of

interest for this calculation (0 – 10 Vdc and with control room environments per References 3.5.y and 3.5.z), the reference accuracy for a Fluke 45 is ± 0.002462 Vdc (from Section 9.0) which includes reading error.

This module is modeled as a summer to combine the two measured input signals by utilizing equations determined in Section 4.17. It is calibrated by applying two measured input signals with two Fluke 45 DMM's (MTE1_D and MTE2_D) while monitoring it for actuation. The uncertainties associated with measuring the input and signals (MTE1_D and MTE2_D) was determined above as:

$$\begin{aligned} \text{MTE1}_D &= \text{MTE}_{45} = \pm 0.002462 \text{ Vdc} & [1\sigma] \\ \text{MTE2}_D &= \text{MTE}_{45} = \pm 0.002462 \text{ Vdc} & [1\sigma] \end{aligned}$$

Utilizing equations in Section 4.17,

$$\sigma_{\text{OUT}} = [(k1 * \sigma_{\text{ERROR X}})^2 + (k2 * \sigma_{\text{ERROR Y}})^2]^{0.5}$$

by substitution,

$$\begin{aligned} \text{CAL6B}_{\text{VDC}} &= \pm [(k1 * \text{MTE1}_D)^2 + (k2 * \text{MTE2}_D)^2]^{0.5} \\ &= \pm [(0.5 * 0.002462 \text{ Vdc})^2 + (0.5 * 0.002462 \text{ Vdc})^2]^{0.5} \\ &= \pm 0.001741 \text{ Vdc} & [1\sigma] \end{aligned}$$

Convert to % Flow by multiplying by 125% Flow and dividing by 10 Vdc.

$$\begin{aligned} \text{CAL6B} &= \pm (0.001741 \text{ Vdc})(125\% \text{ Flow} / 10 \text{ Vdc}) \\ &= \pm 0.021763 \% \text{ Flow} & [1\sigma] \end{aligned}$$

3. Section 11.6.1.1.4: Delete existing text under section 11.6.1.1.4 and replace with the following new text as follows:

11.6.2.1.4 Setting Tolerance (ST6A and ST6B)

ST6A:

Per References 3.5.y and 3.5.z, the calibration tolerance for setting this module is,

$$\text{T6A} = \pm 0.1 \text{ Vdc}$$

This uncertainty is a 3 σ values and must be converted to 1 σ values by dividing by three.

$$\begin{aligned} \text{ST6A}_{\text{VDC}} &= \pm (\text{T6A})/3 \\ &= \pm (0.1 \text{ Vdc})/3 \\ &= \pm 0.033333 \text{ Vdc} & [1\sigma] \end{aligned}$$

Convert to % Flow by multiplying by 125% Flow and dividing by 10 Vdc.

$$\begin{aligned} \text{ST6A} &= \pm (0.033333 \text{ Vdc})(125 \% \text{ Flow} / 10 \text{ Vdc}) \\ &= \pm 0.416663 \% \text{ Flow} & [1\sigma] \end{aligned}$$

ST6B:

Per References 3.5.y and 3.5.z, this module is a bistable that compares two input signals and actuates upon specified deviations. From References 3.5.y and 3.5.z, the calibration tolerances for setting the two inputs signals are:

$$\begin{aligned} T6B1 &= \pm 0.1 \text{ Vdc} \\ T6B2 &= \pm 0.01 \text{ Vdc} \end{aligned}$$

These uncertainties are a 3σ values and must be converted to 1σ values by dividing by three.

$$\begin{aligned} ST6B1_{VDC} &= \pm(T6B1)/3 \\ &= \pm(0.1 \text{ Vdc})/3 \\ &= \pm 0.033333 \text{ Vdc} \end{aligned} \quad [1\sigma]$$

$$\begin{aligned} ST6B2_{VDC} &= \pm(T6B2)/3 \\ &= \pm(0.01 \text{ Vdc})/3 \\ &= \pm 0.003333 \text{ Vdc} \end{aligned} \quad [1\sigma]$$

This module is modeled as a summer to combine the two measured input tolerances by utilizing equations determined in Section 4.17.

$$\sigma_{OUT} = [(k1 * \sigma_{ERROR X})^2 + (k2 * \sigma_{ERROR Y})^2]^{0.5}$$

by substitution,

$$\begin{aligned} ST6B_{VDC} &= \pm[(k1 * ST6B1_{VDC})^2 + (k2 * ST6B2_{VDC})^2]^{0.5} \\ &= \pm[(0.5 * 0.033333 \text{ Vdc})^2 + (0.5 * 0.003333 \text{ Vdc})^2]^{0.5} \\ &= \pm 0.016750 \text{ Vdc} \end{aligned} \quad [1\sigma]$$

Convert to % Flow by multiplying by 125% Flow and dividing by 10 Vdc.

$$\begin{aligned} ST6B &= \pm(0.016750 \text{ Vdc})(125\% \text{ Flow} / 10 \text{ Vdc}) \\ &= \pm 0.209375 \% \text{ Flow} \end{aligned} \quad [1\sigma]$$

4. Section 11.6.2.1.5: Delete existing text under section 11.6.2.1.5 and replace with the following new text as follows:

11.6.2.1.5 Input Uncertainty ($\sigma_{input6A}$ and $\sigma_{input6B}$)

In addition to its own error terms, Modules 6A and 6B also operate on the error terms from Module 6. Therefore, the random error terms (σ_6 and σ_{6C}) from Module 6 must be transferred through Modules 6A and 6B. The resultant terms will be $\sigma_{input6A}$ and $\sigma_{input6B}$ for this module. However since σ_6 and σ_{6C} includes the total flow Reference Accuracy ($RA_{6(1\sigma)}$) as noted in section 11.6.1.1.6, $RA_{6(1\sigma)}$ will be subtracted from the values of σ_6 and σ_{6C} to determine $\sigma_{input6A}$ and $\sigma_{input6B}$. This is because the reference accuracy of Module 6A (RA_{6A}) is expressed in terms of total overall uncertainty.

$$\begin{aligned} \sigma_{input6A} &= \pm (125\% \text{ Flow} / 100\% \text{ CS}) [[(100\% \text{ CS} / 125\% \text{ Flow}) * (\sigma_6)]^2 - (RA_{6(1\sigma)})^2]^{0.5} \\ &= \pm (125\% \text{ Flow} / 100\% \text{ CS}) [[(100\% \text{ CS} / 125\% \text{ Flow}) * (2.112581)]^2 - (0.5 \% \text{ CS})^2]^{0.5} \\ &= \pm 2.018012 \% \text{ Flow} \end{aligned}$$

$$\begin{aligned} \sigma_{input6A_{AV}} &= \pm (125\% \text{ Flow} / 100\% \text{ CS}) [[(100\% \text{ CS} / 125\% \text{ Flow}) * (\sigma_{6C})]^2 - (RA_{6(1\sigma)})^2]^{0.5} \\ &= \pm (125\% \text{ Flow} / 100\% \text{ CS}) [[(100\% \text{ CS} / 125\% \text{ Flow}) * (1.035450)]^2 - (0.5 \% \text{ CS})^2]^{0.5} \end{aligned}$$

$$= \pm 0.825549 \% \text{ Flow}$$

For the Comparator Trip, input errors are combined by modeling the comparator as a summer per equations in section 4.17, because the comparator is influenced by two input uncertainties. As such, the process errors will cancel each other (see section 4.9). Therefore, $\sigma_{\text{input6A}_{AV}}$ will be utilized to determine σ_{input6B} as follows:

$$\begin{aligned}\sigma_{\text{input6B}} &= \pm [(k_1 * \sigma_{\text{input6A}_{AV}})^2 + (k_2 * \sigma_{\text{input6A}_{AV}})^2]^{0.5} \\ &= \pm [(0.5 * 0.825549 \% \text{ Flow})^2 + (0.5 * 0.825549 \% \text{ Flow})^2]^{0.5} \\ &= \pm 0.583751 \% \text{ Flow} \quad [1\sigma]\end{aligned}$$

(Note that use of σ_6 and σ_{6C} values in this determination is slightly conservative, because the values of σ_6 and σ_{6C} includes calibration and setting tolerance uncertainties associated with the ABB RFM output isolator, and the output isolator does not contribute uncertainty to the bistable circuits. Impact due to this conservatism is negligible compared to the other error terms.)

5. Section 11.6.2.1.6: Delete existing text under section 11.6.2.1.6 and replace with the following new text as follows:

11.6.2.1.6 Determination of Module Random Error (σ_6A , σ_6B)

Using the methodology of Reference 3.3,

$$\begin{aligned}\sigma_6A &= \pm [(RA_6A_{(1\sigma)})^2 + (RD_6A_{(1\sigma)})^2 + (CAL_6A)^2 + (ST_6A_{(1\sigma)})^2 + (\sigma_{\text{input6A}})^2]^{0.5} \% \text{ Flow} \\ &= \pm [(1.25)^2 + (0)^2 + (0.030775)^2 + (0.416663)^2 + (2.018012)^2]^{0.5} \% \text{ Flow} \\ &= \pm 2.410275 \% \text{ Flow} \quad [1\sigma]\end{aligned}$$

$$\begin{aligned}\sigma_6A_{AV} &= \pm [(RA_6A_{(1\sigma)})^2 + (RD_6A_{(1\sigma)})^2 + (CAL_6A)^2 + (ST_6A_{(1\sigma)})^2 + (\sigma_{\text{input6A}_{AV}})^2]^{0.5} \% \text{ Flow} \\ &= \pm [(1.25)^2 + (0)^2 + (0.030775)^2 + (0.416663)^2 + (0.825549)^2]^{0.5} \% \text{ Flow} \\ &= \pm 1.555180 \% \text{ Flow} \quad [1\sigma]\end{aligned}$$

$$\begin{aligned}\sigma_6B &= \pm [(RA_6A_{(1\sigma)})^2 + (RD_6A_{(1\sigma)})^2 + (CAL_6B)^2 + (ST_6B_{(1\sigma)})^2 + (\sigma_{\text{input6B}})^2]^{0.5} \% \text{ Flow} \\ &= \pm [(1.25)^2 + (0)^2 + (0.021763)^2 + (0.209375)^2 + (0.583751)^2]^{0.5} \% \text{ Flow} \\ &= \pm 1.395556 \% \text{ Flow} \quad [1\sigma]\end{aligned}$$

11.6.2.2 Module 6A Non-Random Errors (Σe_6A)

1. Section 11.6.2.2.9: Delete existing text under section 11.6.2.2.9 and replace with the following new text as follows:

11.6.2.2.9 Non-Random Input Error (e_{input6A} and e_{input6B})

In addition to its own error terms, Modules 6A and 6B also operate on the error terms from Module 6. Therefore, the non-random error term (Σe_6) from the Module 6 must be transferred through the ABB Bitable from input to output. The resultant terms will be e_{input6A} and e_{input6B} . From Section 11.1.2.10,

$$e_{\text{input6A}} = \Sigma e_6 \pm 1.845461 \% \text{ Flow}$$

For the Comparator Trip, input errors are combined by modeling the comparator as a summer per equations in section 4.17.

$$\begin{aligned}
 \text{einput6B} &= \pm(k_1 * \Sigma e_6) + (k_2 * \Sigma e_6) \\
 &= \pm(0.5 * 1.845461 \% \text{ Flow}) + (0.5 * 1.845461 \% \text{ Flow}) \\
 &= \pm 1.845461 \% \text{ Flow} \quad [1\sigma]
 \end{aligned}$$

2. Revise section 11.6.2.2.10 as follows:

11.6.2.2.10 Non-Random Error (Σe_6A , Σe_6B)

From Reference 3.3 the non-random error is the algebraic sum of all the above terms. In addition, all terms except einput6A and einput6B are in % CS and must be multiplied by 125/100 to convert to % Flow.

$$\begin{aligned}
 \Sigma e_6A &= \pm(125/100) * (e_6AH + e_6AT + e_6AR + e_6AS + e_6ASP + e_6AP + e_6Ap + e_6AV) \\
 &\quad + \text{einput6A} \% \text{ Flow} \\
 &= \pm(125/100) * (0 + 0 + 0 + 0 + 0 + 0 + 0 + 0) + 1.845461 \% \text{ Flow} \\
 &= \pm 1.845461 \% \text{ Flow}
 \end{aligned}$$

$$\begin{aligned}
 \Sigma e_6B &= \pm(125/100) * (e_6AH + e_6AT + e_6AR + e_6AS + e_6ASP + e_6AP + e_6Ap + e_6AV) \\
 &\quad + \text{einput6B} \% \text{ Flow} \\
 &= \pm(125/100) * (0 + 0 + 0 + 0 + 0 + 0 + 0 + 0) + 1.845461 \% \text{ Flow} \\
 &= \pm 1.845461 \% \text{ Flow}
 \end{aligned}$$

12.0 INSTRUMENT CHANNEL TOTAL ERRORS

1. Revise section 12.1.1 as follows by applying the recalculated module errors:

$$\begin{aligned} \text{Ten}_{\text{AFB}} &= \pm(2 * \sigma 4D + \Sigma e 4D) \\ \text{Ten}_{\text{AFB}} &= \pm(2 * 2.581939 + 1.970337) \\ \text{Ten}_{\text{AFB}} &= \pm 7.134215 \% \text{ Power} \end{aligned}$$

And the AV total error for TLO is determined as

$$\begin{aligned} \text{Ten}_{\text{AFB(AV)}} &= \pm(2 * \sigma 4D_{\text{AV}} + \Sigma e 4D_{\text{AV}}) \\ \text{Ten}_{\text{AFB(AV)}} &= \pm(2 * 2.228588 + 1.150337) \\ \text{Ten}_{\text{AFB(AV)}} &= \pm 5.607513 \% \text{ Power} \end{aligned}$$

2. Revise section 12.1.2 as follows by applying the recalculated module errors:

$$\begin{aligned} \text{Ten}_{\text{AFBSLO}} &= \pm(2 * \sigma 4D_{\text{SLO}} + \Sigma e 4D_{\text{SLO}}) \\ \text{Ten}_{\text{AFBSLO}} &= \pm(2 * 2.509742 + 1.841154) \\ \text{Ten}_{\text{AFBSLO}} &= \pm 6.860638 \% \text{ Power} \end{aligned}$$

And the AV total error for SLO is determined as

$$\begin{aligned} \text{Ten}_{\text{AFB(AV) SLO}} &= \pm(2 * \sigma 4D_{\text{AVSLO}} + \Sigma e 4D_{\text{AVSLO}}) \\ \text{Ten}_{\text{AFB(AV) SLO}} &= \pm(2 * 2.208686 + 1.021154) \\ \text{Ten}_{\text{AFB(AV) SLO}} &= \pm 5.438526 \% \text{ Power} \end{aligned}$$

3. Revise section 12.3 as follows by applying the recalculated module errors and Level 2 methodology defined in minor revision 2A:

$$\begin{aligned} \text{Ten}_{\text{RFB}} &= \pm(\sigma 5C + \Sigma e 5C) \% \text{ Power} & [\text{Ref 3.34}] \\ \text{Ten}_{\text{RFB(AV)}} &= \pm(\sigma 5C_{\text{AV}} + \Sigma e 5C_{\text{AV}}) \% \text{ Power} & [\text{Ref 3.34}] \end{aligned}$$

These uncertainty terms include both the uncertainties associated with the RBM neutron signal and the Recirculation Flow Monitor. From Sections 11.5.3.1.6 and 11.5.3.2.10:

$$\begin{aligned} \text{Ten}_{\text{RFB}} &= \pm(2.714373 + 2.056459) \% \text{ Power} \\ \text{Ten}_{\text{RFB}} &= \pm 4.770832 \% \text{ Power} \end{aligned}$$

And

$$\begin{aligned} \text{Ten}_{\text{RFB(AV)}} &= \pm(2.240011 + 1.236459) \% \text{ Power} \\ \text{Ten}_{\text{RFB(AV)}} &= \pm 3.476470 \% \text{ Power} \end{aligned}$$

4. Revise section 12.5 as follows by applying the errors from the ABB RFM

Ten_{RFMU} and $Ten_{RFMU(AV)}$ are made up of the uncertainty terms from Recirculation Flow Monitor 6A.
From Sections 11.6.2.1.6 and 11.6.2.2.10:

$$\begin{aligned} Ten_{RFMU} &= \pm(2\sigma_{6A} + \Sigma e_{6A}) \% \text{ Flow} \\ Ten_{RFMU} &= \pm(2 * 2.410275 + 1.845461) \% \text{ Flow} \\ Ten_{RFMU} &= \pm 6.666011 \% \text{ Flow} \end{aligned}$$

And

$$\begin{aligned} Ten_{RFMU(AV)} &= \pm(2\sigma_{6A_{AV}} + \Sigma e_{6A}) \% \text{ Flow} \\ Ten_{RFMU(AV)} &= \pm(2 * 1.555180 + 1.845461) \% \text{ Flow} \\ Ten_{RFMU(AV)} &= \pm 4.955821 \% \text{ Flow} \end{aligned}$$

Note that for the RFM loops there were no non-random terms associated with the process. Therefore, the non-random term Σe_{6A} is applicable to both the AL and AV total error terms.

5. Revise section 12.6 as follows by applying the errors from the ABB RFM

Ten_{RFMC} and $Ten_{RFMC(AV)}$ are made up of the uncertainty terms from Recirculation Flow Monitor 6B.
From Sections 11.6.2.1.6 and 11.6.2.2.10:

$$\begin{aligned} Ten_{RFMC} &= \pm(2\sigma_{6B} + \Sigma e_{6B}) \% \text{ Flow} \\ Ten_{RFMC} &= \pm(2 * 1.516003 + 1.845461) \% \text{ Flow} \\ Ten_{RFMC} &= \pm 4.877467 \% \text{ Flow} \end{aligned}$$

Per Section 4.9, the process variables have already been removed from the uncertainty terms for the comparator trip. Therefore,

$$Ten_{RFMC(AV)} = Ten_{RFMC} = \pm 4.877467 \% \text{ Flow}$$

13.0 ERROR ANALYSIS SUMMARY

1. Delete section 13.0 and replace with the following:

~~*The total uncertainties applicable to the ABB Flow Unit are smaller than those associated with the GE Flow Unit. Therefore, all calculations will be performed using those terms applicable to the GE Flow Unit since the results will then be conservative for operation using the ABB Flow Unit.*~~

Per section 4.15, the GE Flow Units have been replaced with ABB RFM Flow Units. Therefore, calculation results are based on ABB RFM Flow Unit uncertainties.

2. Revise section 13.1.1 as follows:

$$\begin{aligned} \text{NTSP}_{\text{STP2}} &= \text{FCS}_{\text{SP}} * W + (\text{AL}_{\text{STP2OS}} - \text{T}_{\text{enAFB}}) \\ \text{NTSP}_{\text{STP2}} &= 0.61 * W + (69.76 - 7.134215) \\ \text{NTSP}_{\text{STP2}} &= 0.61 * W + 62.625785, \text{ rounded to } 0.61W + 62.6 \% \text{ Power} \end{aligned}$$

In similar fashion the Allowable Value can be calculated using the applicable uncertainty (5.607513 % Power) from Section 12.1.1

$$\begin{aligned} \text{AV}_{\text{STP2}} &= \text{FCS}_{\text{SP}} * W + \text{NTSP}_{\text{STP2OS}} + \text{T}_{\text{enAFB(AV)}} \\ \text{AV}_{\text{STP2}} &= 0.61 * W + 62.625785 + 5.607513 \\ \text{AV}_{\text{STP2}} &= 0.61 * W + 68.233298, \text{ rounded to } 0.61W + 68.2 \% \text{ Power} \end{aligned}$$

3. Revise section 13.1.2 as follows:

$$\begin{aligned} \text{NTSP}_{\text{STP1}} &= \text{FCS}_{\text{SP}} * W + (\text{AL}_{\text{STP1OS}} - \text{T}_{\text{enAFB}}) \\ \text{NTSP}_{\text{STP1}} &= 0.54 * W + (57.39 - 6.860638) \\ \text{NTSP}_{\text{STP1}} &= 0.54 * W + 50.529362, \text{ rounded to } 0.54W + 50.5 \% \text{ Power} \end{aligned}$$

In similar fashion the Allowable Value can be calculated using the applicable uncertainty (5.438526 % Power) from Section 12.1.2

$$\begin{aligned} \text{AV}_{\text{STP1}} &= \text{FCS}_{\text{SP}} * W + \text{NTSP}_{\text{STP1OS}} + \text{T}_{\text{enAFB(AV)}} \\ \text{AV}_{\text{STP1}} &= 0.54 * W + 50.529362 + 5.438526 \\ \text{AV}_{\text{STP1}} &= 0.54 * W + 55.967888, \text{ rounded to } 0.54W + 55.9 \% \text{ Power} \end{aligned}$$

4. Revise section 13.1.3 as follows:

$$\begin{aligned} \text{NTSP}_{\text{STP2RB}} &= \text{FCS}_{\text{SP}} * W + (\text{AL}_{\text{STP2RBOS}} - \text{T}_{\text{enAFB}}) \\ \text{NTSP}_{\text{STP2RB}} &= 0.61 * W + (58.51 - 7.134215) \\ \text{NTSP}_{\text{STP2RB}} &= 0.61 * W + 51.375785, \text{ rounded to } 0.61W + 51.3 \% \text{ Power} \end{aligned}$$

In similar fashion the Allowable Value can be calculated using the applicable uncertainty (5.607513 % Power) from Section 12.1.1

$$\begin{aligned} \text{AV}_{\text{STP2RB}} &= \text{FCS}_{\text{SP}} * W + \text{NTSP}_{\text{STP2RBOS}} + \text{T}_{\text{enAFB(AV)}} \\ \text{AV}_{\text{STP2RB}} &= 0.61 * W + 51.375785 + 5.607513 \\ \text{AV}_{\text{STP2RB}} &= 0.61 * W + 56.983298, \text{ rounded to } 0.61W + 56.9 \% \text{ Power} \end{aligned}$$

5. Revise section 13.1.4 as follows:

$$\begin{aligned} \text{NTSP}_{\text{STPIRB}} &= \text{FCS}_{\text{SP}} * W + (\text{AL}_{\text{STPIRBOS}} - \text{Ten}_{\text{AFB}}) \\ \text{NTSP}_{\text{STPIRB}} &= 0.54 * W + (46.14 - 6.860638) \\ \text{NTSP}_{\text{STPIRB}} &= 0.54 * W + 39.279362, \text{ rounded to } 0.54W + 39.2 \% \text{ Power} \end{aligned}$$

In similar fashion the Allowable Value can be calculated using the applicable uncertainty (5.438526 % Power) from Section 12.1.2

$$\begin{aligned} \text{AV}_{\text{STPIRB}} &= \text{FCS}_{\text{SP}} * W + \text{NTSP}_{\text{STPIRBOS}} + \text{Ten}_{\text{AFB(AV)}} \\ \text{AV}_{\text{STPIRB}} &= 0.54 * W + 39.279362 + 5.438526 \\ \text{AV}_{\text{STPIRB}} &= 0.54 * W + 44.717888, \text{ rounded to } 0.54W + 44.7 \% \text{ Power} \end{aligned}$$

6. Revise section 13.3.1 as follows with new total uncertainty and in accordance with minor revision 2A of this analysis:

$$\begin{aligned} \text{AV}_{\text{RBM2}} &= \text{NTSP} + \text{Ten}_{\text{RFB(AV)}} \% \text{ Power} \\ \text{AV}_{\text{RBM2}} &= 0.66 * W + 51 + 3.476470 \% \text{ Power} \\ \text{AV}_{\text{RBM2}} &= 0.66 * W + 54.476470 \% \text{ Power} \end{aligned}$$

Because the computed AV is in excess of the Reference 3.15 value, the fixed offset of the final NTSP should be lowered at least 0.48 %. For conservatism, the final calibration NTSP should be:

$$\text{NTSP}_{\text{RBM2}} = 0.66W + 50.5\% \text{ Power}$$

7. Revise section 13.3.2 as follows with new total uncertainty and in accordance with minor revision 2A of this analysis:

$$\begin{aligned} \text{AV}_{\text{RBM1}} &= \text{NTSP} + \text{Ten}_{\text{RFB(AV)}} \% \text{ Power} \\ \text{AV}_{\text{RBM1}} &= 0.66 * W + 45.7 + 3.476470 \% \text{ Power} \\ \text{AV}_{\text{RBM1}} &= 0.66 * W + 49.176470 \% \text{ Power} \end{aligned}$$

Because the computed AV is in excess of the Reference 3.15 value, the fixed offset of the final NTSP should be lowered at least 0.48 %. For conservatism, the final calibration NTSP should be:

$$\text{NTSP}_{\text{RBM1}} = 0.66W + 45.0\% \text{ Power}$$

8. Revise section 13.5 as follows:

From Section 12.5 the total uncertainty for this function is $\pm 6.666011\%$ Flow. From Reference 3.3 the relationship between NTSP and AL for an upscale trip is:

$$\begin{aligned} \text{AL}_{\text{RFMU}} &= \text{NTSP}_{\text{RFMU}} + \text{Ten}_{\text{RFMU}} \% \text{ Flow} \\ \text{AL}_{\text{RFMU}} &= 108 + 6.666011 \% \text{ Flow} \\ \text{AL}_{\text{RFMU}} &= 114.666011 \% \text{ Flow} \end{aligned}$$

In similar fashion the Allowable Value can be calculated using the applicable uncertainty (4.955821 % Flow) from Section 12.5.

$$\text{AV}_{\text{RFMU}} = \text{NTSP}_{\text{RFMU}} + \text{Ten}_{\text{RFMU(AV)}} \% \text{ Flow}$$

$$\begin{aligned} AV_{RFMU} &= 108 + 4.955821 \% \text{ Flow} \\ AV_{RFMU} &= 112.955821 \% \text{ Flow} \end{aligned}$$

9. Revise section 13.6 as follows:

From Section 12.6 the total uncertainty for this function is $\pm 4.877467\%$ Flow. From Reference 3.3 the relationship between NTSP and AL for an upscale trip is:

$$\begin{aligned} AL_{RFMC} &= NTSP_{RFMC} + Ten_{RFMC} \% \text{ Flow} \\ AL_{RFMC} &= 10 + 4.877467 \% \text{ Flow} \\ AL_{RFMC} &= 14.877467 \% \text{ Flow} \end{aligned}$$

Per Section 4.9 the process term has already been removed from the uncertainty terms for the comparator trip. Therefore,

$$AV_{RFMU} = AL_{RFMC} = 14.877467 \% \text{ Flow}$$

- 10.0 Add a new section 13.7 and subsections for as-left / as-found tolerances for the APRM flow biased trips for use in instrument performance trending as follows:

13.7 As-Left / As-Found Tolerances For APRM Flow Biased Trips

As-Left / As-Found Tolerances (ALT's / AFT's) are determined for calibrated components, circuits, and modules associated with the APRM flow biased trips. As-Left / As-Found Tolerances are determined in accordance with the methodology provided in section 2.4 as follows:

Module As-Left Tolerance (ALT):

$$ALT = \pm [RA^2 + MTE^2 + RE_{MTE}^2]^{0.5}$$

Module As-Found Tolerance (AFT):

$$AFT = \pm [RA^2 + RD^2 + MTE^2 + RE_{MTE}^2]^{0.5}$$

where,

$$\begin{aligned} RA &= \text{Module Reference Accuracy} \\ RD &= \text{Module Vendor Specified Instrument Drift} \\ MTE &= \text{Module Measurement and Test Equipment (M\&TE) Error} \\ RE_{MTE} &= \text{Module M\&TE Readability} \end{aligned}$$

If a particular calibrated component or circuit (or module) is not provided with a reference accuracy specification, the setting tolerance applied during module calibration will be used in place of the reference accuracy specification.

The APRM flow biased trips consists of the following calibrated components or circuits, (or modules):

- a) Recirculation Flow Transmitters (Module 1)
- b) ABB RFM Input Isolators (Module 6_{II})

- c) ABB RFM Square Root Converters (Module 6_{SR})
- d) ABB RFM Summer (Module 6_{SUM})
- e) ABB RFM Output Isolator (Module 6_{OI})
- f) APRM Flow Biased Trip Circuit (Module 4D).

As-Left / As-Found Tolerances are determined for each of these modules per the above methodology as follows:

13.7.1 Recirculation Flow Transmitters (Module 1) As-Left / As-Found Tolerances

- a) RA: From section 11.1.1.1,

$$RA1_{FT} = \pm 0.25 \% \text{ CS}$$

- b) RD: From section 11.1.1.2,

$$RD1_{FT} = \pm 0.606306 \% \text{ CS}$$

- c) MTE Uncertainty: From Section 11.1.1.3, the uncertainty of the test equipment used to calibrate module 1 input setting is $\pm 0.868971 \% \text{ CS}$ (1σ) which includes MTE readability uncertainty. This uncertainty value is converted to a 2-sigma value as follows:

$$\begin{aligned} MTE1_{FT \text{ IN}} &= \pm 2 * (0.868971 \% \text{ CS}) \\ &= \pm 1.737942 \% \text{ CS} \end{aligned}$$

Per Section 11.1.1.3, the DMM used to calibrate the transmitter output is a Fluke 45 which has an uncertainty of $\pm 0.012141 \text{ mVdc}$ (1σ). Per References 3.5.y and 3.5.z, the calibrated span is 16 mVdc. This uncertainty is converted to units of $\% \text{ CS}$ and converted to a 2-sigma value as follows:

$$\begin{aligned} MTE1_{FT \text{ OUT}} &= \pm 2 * [(0.012141 \text{ mVdc} / 16 \text{ mVdc}) * 100 \% \text{ CS}] \\ &= \pm 0.151763 \% \text{ CS} \end{aligned}$$

therefore,

$$\begin{aligned} MTE1_{FT} &= \pm [MTE1_{FT \text{ IN}}^2 + MTE1_{FT \text{ OUT}}^2]^{0.5} \\ &= \pm [(1.737942 \% \text{ CS})^2 + (0.151763 \% \text{ CS})^2]^{0.5} \\ &= \pm 1.744556 \% \text{ CS} \end{aligned}$$

- d) RE: As noted above, $MTE1_{FT \text{ IN}}$ includes reading error. Per section 11.1.1.3, the reading error associated with the DMM is included in the uncertainty value. Therefore,

$$RE1_{FT \text{ MTE}} = 0$$

- e) ALT / AFT: By substitution into section 13.7 equations ALT1 and AFT1 are determined and converted into transmitter calibrated output units of mVdc,

$$\begin{aligned} ALT1_{FT} &= \pm [RA1_{FT}^2 + MTE1_{FT}^2 + RE1_{FT \text{ MTE}}^2]^{0.5} \\ &= \pm (16 \text{ mVdc} / 100 \% \text{ CS}) * [(0.25 \% \text{ CS})^2 + (1.744556 \% \text{ CS})^2 + (0)^2]^{0.5} \\ &= \pm 0.281980 \text{ mVdc, (rounded to } \pm 0.282 \text{ mVdc)} \end{aligned}$$

$$\begin{aligned}
 AFT1_{FT} &= \pm[RA1_{FT}^2 + RD1_{FT}^2 + MTE1_{FT}^2 + RE1_{FT MTE}^2]^{0.5} \\
 &= \pm(16 \text{ mVdc}/100 \% \text{ CS}) * [(0.25 \% \text{ CS})^2 + (0.606306 \% \text{ CS})^2 \\
 &\quad + (1.744556 \% \text{ CS})^2 + (0)^2]^{0.5} \\
 &= \pm 0.298201 \text{ mVdc, (rounded to } \pm 0.298 \text{ mVdc)}
 \end{aligned}$$

The calculated As-Left Tolerance ($ALT1_{FT}$) bounds the flow transmitter setting tolerance which is 0.08 mVdc per Reference 3.5.y and 3.5.z.

13.7.2 ABB RFM (Module 6) As-Left / As-Found Tolerances

Per section 8.6, the ABB RFM reference accuracy is provided as an overall accuracy specification. Accuracy specifications are not provided for individually calibrated circuits. Therefore, per methodology provided in section 2.4, setting tolerances for individually calibrated circuits will be substituted.

$$RA = ST$$

Additionally, the ABB RFM drift specification is also provided as an overall accuracy specification ($\pm 0.5 \% \text{ CS}$). Drift specifications are not provided for individually calibrated circuits. As such, the drift associated with each calibrated circuit will be divided between the four calibrated RFM circuits (input isolator, square root converter, summer, and output isolator). Drift is considered to be a random uncertainty. Therefore, drift for each individually calibrated RFM circuit is considered to be,

$$\begin{aligned}
 \text{Drift}_{(CS)} &= \pm[(0.5 \% \text{ CS})^2/4]^{0.5} \\
 &= \pm 0.25 \% \text{ CS}
 \end{aligned}$$

Per References 3.5.y and 3.5.z, the calibrated span is 10 Vdc, and drift uncertainty is converted to units of Vdc as follows:

$$\begin{aligned}
 \text{Drift} &= \pm(0.25 \% \text{ CS} / 100 \% \text{ CS}) * 10 \text{ Vdc} \\
 &= \pm 0.025000 \text{ Vdc}
 \end{aligned}$$

13.7.2.1 ABB RFM Input Isolator Circuit (Module 6_{II}) As-Left / As-Found Tolerances

- a) RA: From References 3.5.y and 3.5.z and section 13.7.2 reference accuracy is,

$$RA6_{II} = ST6_{II} = \pm 0.05 \text{ Vdc}$$

- b) RD: From section 13.7.2 drift is,

$$RD6_{II} = \pm 0.025000 \text{ Vdc}$$

- c) MTE Uncertainty: From Section 11.6.1.1.3.a, the uncertainty of the test equipment used to calibrate module 6_{II} input setting is $\pm 0.868971 \% \text{ CS}$ (1σ) which includes MTE readability uncertainty. This value is converted to a 2-sigma value and converted to units of Vdc as follows:

$$\begin{aligned}
 MTE6_{II IN} &= \pm 2 * (0.868971 \% \text{ CS} / 100 \% \text{ CS}) * 10 \text{ Vdc} \\
 &= \pm 0.173794 \text{ Vdc}
 \end{aligned}$$

From section 11.6.1.1.3.a, the uncertainty of the DMM used to calibrate module 6_{II} output is $\pm 0.002462 \text{ Vdc}$. This uncertainty value is converted to a 2-sigma value as follows:

$$\begin{aligned} \text{MTE6}_{\text{II OUT}} &= \pm 2 * (0.002462 \text{ Vdc}) \\ &= \pm 0.004924 \text{ Vdc} \end{aligned}$$

therefore,

$$\begin{aligned} \text{MTE6}_{\text{II}} &= \pm [\text{MTE6}_{\text{II IN}}^2 + \text{MTE6}_{\text{II OUT}}^2]^{0.5} \\ &= \pm [(0.173794 \text{ Vdc})^2 + (0.004924 \text{ Vdc})^2]^{0.5} \\ &= \pm 0.173864 \text{ Vdc} \end{aligned}$$

- d) RE: As noted above, $\text{MTE6}_{\text{II IN}}$ includes reading error. Per section 11.6.1.1.3, the reading error associated with the DMM is included in the uncertainty value. Therefore,

$$\text{RE6}_{\text{II MTE}} = 0$$

- e) ALT /AFT: By substitution into the section 13.7 equations ALT6_{II} and AFT6_{II} are determined as follows:

$$\begin{aligned} \text{ALT6}_{\text{II}} &= \pm [\text{RA6}_{\text{II}}^2 + \text{MTE6}_{\text{II}}^2 + \text{RE6}_{\text{II MTE}}^2]^{0.5} \\ &= \pm [(0.05 \text{ Vdc})^2 + (0.173864 \text{ Vdc})^2 + (0)^2]^{0.5} \\ &= \pm 0.180911 \text{ Vdc, (rounded to } \pm 0.181 \text{ Vdc)} \\ \\ \text{AFT6}_{\text{II}} &= \pm [\text{RA6}_{\text{II}}^2 + \text{RD6}_{\text{II}}^2 + \text{MTE6}_{\text{II}}^2 + \text{RE6}_{\text{II MTE}}^2]^{0.5} \\ &= \pm [(0.05 \text{ Vdc})^2 + (0.025000 \text{ Vdc})^2 + (0.173864 \text{ Vdc})^2 + (0)^2]^{0.5} \\ &= \pm 0.182630 \text{ Vdc, (rounded to } \pm 0.183 \text{ Vdc)} \end{aligned}$$

The calculated As-Left Tolerance (ALT6_{II}) bounds the input isolator setting tolerance which is 0.05 Vdc per Reference 3.5.y and 3.5.z.

13.7.2.1.2 ABB RFM Square Root Converter Circuit (Module 6_{SR}) As-Left / As-Found Tolerances

- a) RA: From section 13.7.2, $\text{RA} = \text{ST}$. From References 3.5.y and 3.5.z, there is an input setting tolerance ($\pm 0.05 \text{ Vdc}$) and an output setting tolerance ($\pm 0.025 \text{ Vdc}$). Therefore,

$$\begin{aligned} \text{RA6}_{\text{SR IN}} &= \text{ST6}_{\text{SR IN}} = \pm 0.05 \text{ Vdc} \\ \text{RA6}_{\text{SR OUT}} &= \text{ST6}_{\text{SR OUT}} = \pm 0.025 \text{ Vdc} \end{aligned}$$

Convert $\text{RA6}_{\text{SR IN}}$ to an equivalent square root converter output value by utilizing equations and the calibrate flow value (75% flow = 3.6 Vdc) determined Section 4.16:

$$y = (k)(\sigma_{\text{ERROR}})/[2(x)^{0.5}]$$

by substitution, $\text{RA6}_{\text{SR IN}}$ is converted to equivalent square root converter output value ($\text{RA6}_{\text{SR IN EQ}}$)

$$\begin{aligned} \text{RA6}_{\text{SR IN EQ}} &= \pm [(3.162278 \text{ Vdc/Vdc}^{0.5}) * (\text{RA6}_{\text{SR IN}})]/[2(3.6 \text{ Vdc})^{0.5}] \\ &= \pm [(3.162278 \text{ Vdc/Vdc}^{0.5}) * (0.05 \text{ Vdc})]/[2(3.6 \text{ Vdc})^{0.5}] \\ &= \pm 0.041667 \text{ Vdc} \end{aligned}$$

therefore,

$$\begin{aligned}
 RA6_{SR} &= \pm[RA6_{SR\ IN\ EQ}^2 + RA6_{SR\ OUT}^2]^{0.5} \\
 &= \pm[(0.041667\ Vdc)^2 + (0.025\ Vdc)^2]^{0.5} \\
 &= \pm0.048592\ Vdc
 \end{aligned}$$

- b) RD: From section 13.7.2 drift is,

$$RD6_{SR} = \pm0.025000\ Vdc$$

- c) From section 11.6.1.1.3.b, the uncertainty associated with the DMM used for measuring the input setting for module 6_{SR} is $\pm0.002462\ Vdc$ (1σ). This value is converted to an equivalent square root converter output value by utilizing equations and calibrated flow value (75% flow = 3.6 Vdc) determined Section 4.16:

$$y = (k)(\sigma_{ERROR})/[2(x)^{0.5}]$$

By substitution, $MTE6_{SR\ IN}$ is converted to equivalent square root converter output value ($MTE6_{SR\ IN\ EQ}$):

$$\begin{aligned}
 MTE6_{SR\ IN\ EQ\ (1\sigma)} &= \pm[(3.162278\ Vdc/Vdc^{0.5}) * (RA6_{SR\ IN})]/[2(3.6\ Vdc)^{0.5}] \\
 &= \pm[(3.162278\ Vdc/Vdc^{0.5}) * (0.002462\ Vdc)]/[2(3.6\ Vdc)^{0.5}] \\
 &= \pm0.002052\ Vdc
 \end{aligned}$$

This value is converted to a 2-sigma value,

$$\begin{aligned}
 MTE6_{SR\ IN\ EQ} &= \pm(2 * 0.002052\ Vdc) \\
 &= \pm0.004104\ Vdc
 \end{aligned}$$

From section 11.6.1.1.3.b, the uncertainty associated with the DMM used for measuring the output setting for module 6_{SR} is $\pm0.002462\ Vdc$ (1σ). This value is converted to a 2-sigma value,

$$\begin{aligned}
 MTE6_{SR\ OUT} &= \pm(2 * 0.002462\ Vdc) \\
 &= \pm0.004924\ Vdc
 \end{aligned}$$

therefore,

$$\begin{aligned}
 MTE6_{SR} &= \pm[MTE6_{SR\ IN\ EQ}^2 + RA6_{SR\ OUT}^2]^{0.5} \\
 &= \pm[(0.004104\ Vdc)^2 + (0.004924\ Vdc)^2]^{0.5} \\
 &= \pm0.006410\ Vdc
 \end{aligned}$$

- d) RE: Per section 11.6.1.1.3, the reading error associated with the DMM is included in the uncertainty value. Therefore,

$$RE6_{SR\ MTE} = 0$$

- e) By substitution into the section 13.7 equations, $ALT6_{SR}$ and $AFT6_{SR}$ are determined as follows:

$$\begin{aligned}
 ALT6_{SR} &= \pm[RA6_{SR}^2 + MTE6_{SR}^2 + RE6_{SR\ MTE}^2]^{0.5} \\
 &= \pm[(0.048592\ Vdc)^2 + (0.006410\ Vdc)^2 + (0)^2]^{0.5} \\
 &= \pm0.049013\ Vdc, \text{ (rounded to } \pm0.049\ Vdc)
 \end{aligned}$$

$$\begin{aligned}
 AFT6_{SR} &= \pm[RA6_{SR}^2 + RD6_{SR}^2 + MTE6_{SR}^2 + RE6_{SR\ MTE}^2]^{0.5} \\
 &= \pm[(0.048592\ Vdc)^2 + (0.025000\ Vdc)^2 + (0.006410\ Vdc)^2 + (0)^2]^{0.5} \\
 &= \pm0.055021\ Vdc, \text{ (rounded to } \pm0.055\ Vdc)
 \end{aligned}$$

The calculated As-Left Tolerance (ALT_{6SR}) bounds the square root converter setting tolerance which is 0.025 Vdc per Reference 3.5.y and 3.5.z.

13.7.2.1.3 ABB RFM Summer Circuit (Module 6_{SUM}) As-Left / As-Found Tolerances

- a) RA: From section 13.7.2, RA = ST. From References 3.5.y and 3.5.z, the output setting tolerance is ±0.010 Vdc. Therefore,

$$RA_{6SUM} = ST_{6SUM} = \pm 0.010 \text{ Vdc}$$

- b) RD: From section 13.7.2 drift is,

$$RD_{6SUM} = \pm 0.025000 \text{ Vdc}$$

- c) From section 11.6.1.1.3.c, the uncertainty associated with the two DMM's used for measuring the input setting for module 6_{SUM} is ±0.002462 Vdc (1σ). This value is converted to an equivalent summer output value by utilizing equations determined Section 4.17:

$$\sigma_{OUT} = [(k1 * \sigma_{ERROR X})^2 + (k2 * \sigma_{ERROR Y})^2]^{0.5}$$

by substitution,

$$\begin{aligned} MTE_{6SUM \text{ IN EQ}(1\sigma)} &= \pm [(k1 * MTE_{6SUM \text{ IN}})^2 + (k2 * MTE_{6SUM \text{ IN}})^2]^{0.5} \\ &= \pm [(0.5 * 0.002462 \text{ Vdc})^2 + (0.5 * 0.002462 \text{ Vdc})^2]^{0.5} \\ &= \pm 0.001741 \text{ Vdc} \end{aligned}$$

This value is converted to a 2-sigma value,

$$\begin{aligned} MTE_{6SUM \text{ IN EQ}} &= \pm (2 * 0.001741 \text{ Vdc}) \\ &= \pm 0.003482 \text{ Vdc} \end{aligned}$$

From section 11.6.1.1.3.c, the uncertainty associated with the DMM used for measuring the output setting for module 6_{SUM} is ±0.002462 Vdc (1σ). This value is converted to a 2-sigma value,

$$\begin{aligned} MTE_{6SUM \text{ OUT}} &= \pm (2 * 0.002462 \text{ Vdc}) \\ &= \pm 0.004924 \text{ Vdc} \end{aligned}$$

therefore,

$$\begin{aligned} MTE_{6SUM} &= \pm [MTE_{6SUM \text{ IN EQ}}^2 + RA_{6SUM \text{ OUT}}^2]^{0.5} \\ &= \pm [(0.003482 \text{ Vdc})^2 + (0.004924 \text{ Vdc})^2]^{0.5} \\ &= \pm 0.006031 \text{ Vdc} \end{aligned}$$

- d) RE: Per section 11.6.1.1.3, the reading error associated with the DMM is included in the uncertainty value. Therefore,

$$RE_{6SR \text{ MTE}} = 0$$

- e) By substitution into the section 13.7 equations, $ALT6_{SR}$ and $AFT6_{SR}$ are determined as follows:

$$\begin{aligned} ALT6_{SUM} &= \pm[RA6_{SUM}^2 + MTE6_{SUM}^2 + RE6_{SUM\ MTE}^2]^{0.5} \\ &= \pm[(0.010\ Vdc)^2 + (0.006031\ Vdc)^2 + (0)^2]^{0.5} \\ &= \pm0.011678\ Vdc, \text{ (rounded to } \pm0.012\ Vdc) \end{aligned}$$

$$\begin{aligned} AFT6_{SUM} &= \pm[RA6_{SUM}^2 + RD6_{SUM}^2 + MTE6_{SR}^2 + RE6_{SUM\ MTE}^2]^{0.5} \\ &= \pm[(0.010\ Vdc)^2 + (0.025000\ Vdc)^2 + (0.006031\ Vdc)^2 + (0)^2]^{0.5} \\ &= \pm0.027593\ Vdc, \text{ (rounded to } \pm0.028\ Vdc) \end{aligned}$$

The calculated As-Left Tolerance ($ALT6_{SUM}$) bounds the summer setting tolerance which is 0.01 Vdc per Reference 3.5.y and 3.5.z.

13.7.2.4 ABB RFM Output Isolator Circuit (Module 6_{OI}) As-Left / As-Found Tolerances

- a) RA: From References 3.5.y and 3.5.z and section 13.7.2 reference accuracy is,

$$RA6_{OI} = ST6_{OI} = \pm0.010\ Vdc$$

- b) RD: From section 13.7.2 drift is,

$$RD6_{OI} = \pm0.025000\ Vdc$$

- c) MTE Uncertainty: From section 11.6.1.1.3.d, the uncertainty of the DMM used to calibrate module 6_{OI} input is $\pm0.002462\ Vdc$. This uncertainty value is converted to a 2-sigma value as follows:

$$\begin{aligned} MTE6_{OI\ OUT} &= \pm2 * (0.002462\ Vdc) \\ &= \pm0.004924\ Vdc \end{aligned}$$

From section 11.6.1.1.3.d, the uncertainty of the DMM used to calibrate module 6_{OI} output is $\pm0.002462\ Vdc$. This uncertainty value is converted to a 2-sigma value as follows:

$$\begin{aligned} MTE6_{OI\ OUT} &= \pm2 * (0.002462\ Vdc) \\ &= \pm0.004924\ Vdc \end{aligned}$$

therefore,

$$\begin{aligned} MTE6_{OI} &= \pm[MTE6_{OI\ IN}^2 + MTE6_{OI\ OUT}^2]^{0.5} \\ &= \pm[(0.004924\ Vdc)^2 + (0.004924\ Vdc)^2]^{0.5} \\ &= \pm0.006964\ Vdc \end{aligned}$$

- d) RE: Per section 11.6.1.1.3, the reading error associated with the DMM is included in the uncertainty value. Therefore,

$$RE6_{OI\ MTE} = 0$$

- e) ALT /AFT: By substitution into the section 13.7 equations $ALT6_{OI}$ and $AFT6_{OI}$ are determined as follows:

$$ALT6_{OI} = \pm[RA6_{OI}^2 + MTE6_{OI}^2 + RE6_{OI\ MTE}^2]^{0.5}$$

$$\begin{aligned}
 &= \pm[(0.010 \text{ Vdc})^2 + (0.006964 \text{ Vdc})^2 + (0)^2]^{0.5} \\
 &= \pm 0.012186 \text{ Vdc, (rounded to } \pm 0.012 \text{ Vdc)} \\
 \text{AFT6}_{OI} &= \pm[\text{RA6}_{OI}^2 + \text{RD6}_{OI}^2 + \text{MTE6}_{OI}^2 + \text{RE6}_{OI\text{MTE}}^2]^{0.5} \\
 &= \pm[(0.010 \text{ Vdc})^2 + (0.025000 \text{ Vdc})^2 + (0.006964 \text{ Vdc})^2 + (0)^2]^{0.5} \\
 &= \pm 0.027812 \text{ Vdc, (rounded to } \pm 0.028 \text{ Vdc)}
 \end{aligned}$$

The calculated As-Left Tolerance (ALT6_{OI}) bounds the output isolator setting tolerance which is 0.01 Vdc per Reference 3.5.y and 3.5.z.

13.7.3 APRM Flow Biased Trip Circuit (Module 4D) As-Left / As-Found Tolerances

- a) RA: From sections 11.4.4.1.1,

$$\text{RA4D}_{(1\sigma)} = \pm 0.625 \% \text{ Power}$$

This uncertainty value is converted to a 2-sigma value as follows:

$$\begin{aligned}
 \text{RA4D} &= \pm 2 * (0.625 \% \text{ Power}) \\
 &= \pm 1.250000 \% \text{ Power}
 \end{aligned}$$

- b) RD: From section 11.4.4.1.2,

$$\text{RD4D}_{(1\sigma)} = \pm 1.74553 \% \text{ Power}$$

This uncertainty value is converted to a 2-sigma value as follows:

$$\begin{aligned}
 \text{RD4D} &= \pm 2 * (1.74553 \% \text{ Power}) \\
 &= \pm 3.491060 \% \text{ Power}
 \end{aligned}$$

- c) MTE Uncertainty: Module 4D is calibrated by applying a simulated power input signal along with a simulated 75% recirculation flow input signal. The simulated power input signal is adjusted while the simulated 75% flow input signal is kept constant while monitoring the module for trip actuation. Both input signals are measured by a Fluke Model 8500A which per section 11.4.4.1.3, has an uncertainty of $\pm 0.00018 \text{ Vdc}$ (1σ). Therefore uncertainty associated with power and flow signal measurement is,

$$\begin{aligned}
 \text{MTE4D}_{\text{POWER}(1\sigma) \text{ VDC}} &= \pm 0.00018 \text{ Vdc} \\
 \text{MTE4D}_{\text{FLOW}(1\sigma) \text{ VDC}} &= \pm 0.00018 \text{ Vdc}
 \end{aligned}$$

Per 3.5.y and 3.5.z, the calibrated span is 10 Vdc. MTE4D_{POWER(1σ) VDC} is converted to units of % Power and converted into a 2-sigma value as follows:

$$\begin{aligned}
 \text{MTE4D}_{\text{POWER}} &= \pm 2 * (0.00018 \text{ Vdc} / 10 \text{ Vdc}) * 125 \% \text{ Power} \\
 &= \pm 0.004500 \% \text{ Power}
 \end{aligned}$$

Per 3.5.y and 3.5.z, the calibrated span is 10 Vdc. MTE4D_{FLOW(1σ) VDC} is converted to units of % Power and converted into a 2-sigma value as follows:

$$\begin{aligned}
 \text{MTE4D}_{\text{FLOW}} &= \pm 2 * (0.00018 \text{ Vdc} / 10 \text{ Vdc}) * 125 \% \text{ Flow} \\
 &= \pm 0.004500 \% \text{ Flow}
 \end{aligned}$$

MTE4D_{POWER} and MTE4D_{FLOW} are converted to an equivalent output value by applying the methodology established in sections 11.4.4.1.5.1 and 11.4.4.1.5.2.

For Two Loop Operation (TLO):

$$\begin{aligned} \text{MTE4D}_{\text{TLO}} &= \pm [\text{MTE4D}_{\text{POWER}}^2 + (0.623333 * \text{MTE4D}_{\text{FLOW}})^2]^{0.5} \\ &= \pm [(0.004500 \% \text{ Power})^2 + ((0.623333) * (0.004500 \% \text{ Flow}))^2]^{0.5} \\ &= \pm 0.005303 \% \text{ Power} \end{aligned}$$

For single Loop Operation (SLO):

$$\begin{aligned} \text{MTE4D}_{\text{SLO}} &= \pm [\text{MTE4D}_{\text{POWER}}^2 + (0.553333 * \text{MTE4D}_{\text{FLOW}})^2]^{0.5} \\ &= \pm [(0.004500 \% \text{ Power})^2 + ((0.553333) * (0.004500 \% \text{ Flow}))^2]^{0.5} \\ &= \pm 0.005143 \% \text{ Power} \end{aligned}$$

- d) RE: The DMM is a digital output device, and therefore, the reading error is considered to be the least significant increment of the display (or resolution) (see Reference 3.34). Per section 9.1, reading error is included in the uncertainty value.

$$\text{RE4D}_{\text{MTE}} = 0$$

- e) ALT / AFT: By substitution into section 13.7 equations ALT4D and AFT4D are determined and converted into module 4D calibrated output units of Vdc,

For Two Loop Operation (TLO):

$$\begin{aligned} \text{ALT4D}_{\text{TLO}} &= \pm (10 \text{ Vdc} / 125\% \text{ Power}) * [\text{RA4D}^2 + \text{MTE4D}_{\text{TLO}}^2 + \text{RE4D}_{\text{MTE}}^2]^{0.5} \\ &= \pm (10 \text{ Vdc} / 125\% \text{ Power}) * [(1.250000 \% \text{ Power})^2 \\ &\quad + (0.005303 \% \text{ Power})^2 + (0)^2]^{0.5} \\ &= \pm 0.100001 \text{ Vdc, (rounded to } \pm 0.100 \text{ Vdc)} \\ \text{AFT4D}_{\text{TLO}} &= \pm (10 \text{ Vdc} / 125\% \text{ Power}) * [\text{RA4D}^2 + \text{RD4D}^2 + \text{MTE4D}_{\text{TLO}}^2 \\ &\quad + \text{RE4D}_{\text{MTE}}^2]^{0.5} \\ &= \pm (10 \text{ Vdc} / 125\% \text{ Power}) * [(1.250000 \% \text{ Power})^2 \\ &\quad + (3.491060 \% \text{ Power})^2 \\ &\quad + (0.005303 \% \text{ Power})^2 + (0)^2]^{0.5} \\ &= \pm 0.296648 \text{ Vdc, (rounded to } \pm 0.297 \text{ Vdc)} \end{aligned}$$

For Single Loop Operation (SLO):

$$\begin{aligned} \text{ALT4D}_{\text{SLO}} &= \pm (10 \text{ Vdc} / 125\% \text{ Power}) * [\text{RA4D}^2 + \text{MTE4D}_{\text{SLO}}^2 + \text{RE4D}_{\text{MTE}}^2]^{0.5} \\ &= \pm (10 \text{ Vdc} / 125\% \text{ Power}) * [(1.250000 \% \text{ Power})^2 \\ &\quad + (0.005143 \% \text{ Power})^2 + (0)^2]^{0.5} \\ &= \pm 0.100001 \text{ Vdc, (rounded to } \pm 0.100 \text{ Vdc)} \\ \text{AFT4D}_{\text{SLO}} &= \pm (10 \text{ Vdc} / 125\% \text{ Power}) * [\text{RA4D}^2 + \text{RD4D}^2 + \text{MTE4D}_{\text{SLO}}^2 \\ &\quad + \text{RE4D}_{\text{MTE}}^2]^{0.5} \\ &= \pm (10 \text{ Vdc} / 125\% \text{ Power}) * [(1.250000 \% \text{ Power})^2 \end{aligned}$$

$$\begin{aligned} &+ (3.491060 \% \text{ Power})^2 \\ &+ (0.005143 \% \text{ Power})^2 + (0)^2]^{0.5} \\ = &\pm 0.296648 \text{ Vdc, (rounded to } \pm 0.297 \text{ Vdc)} \end{aligned}$$

From the above results, impact on ALT and AFT due to TLO vs. SLO is negligible.

The calculated As-Left Tolerance (ALT4D) bounds the Module 4D setting tolerance which is 0.04 Vdc per section 11.4.4.1.4.

14.0 CONCLUSIONS

1. Revise Section 14.1 as follows:

14.1.1 Simulated Thermal Power Upscale (Scram) - Two Loop Operation

Analytical Limit: $0.61W + 69.76$ % Power
 Tech Spec AV: $0.61W + 68.2$ % Power
 Tech Spec NTSP: $0.61W + 62.6$ % Power

Calibration setpoint: Since the setpoint is calibrated at a specific drive flow, the nominal setpoint should be set at least 0.04 Vdc below the corresponding Tech Spec NTSP with a tolerance of +/- 0.04 Vdc. For example, with an 75% drive flow, the Tech Spec NTSP is 108.35% ($0.61*75 + 62.6$). Since 108.35% on a 125% scale corresponds to 8.668 Vdc on a 10 Vdc scale [$10Vdc*108.35\%/125\%$], a setpoint of 8.628 +/- 0.04 Vdc is recommended for 75% drive flow.

14.1.2 Simulated Thermal Power Upscale (Scram) Single Loop Operation

Analytical Limit: $0.54W + 57.39$ % Power
 Tech Spec AV: $0.54W + 55.9$ % Power
 Tech Spec NTSP: $0.54W + 50.5$ % Power

Calibration setpoint: Since the setpoint is calibrated at a specific drive flow, the nominal setpoint should be set at least 0.04 Vdc below the corresponding Tech Spec NTSP with an tolerance of +/- 0.04 Vdc. For example, with an 75% drive flow, the Tech Spec NTSP is 91.00% ($0.54*75 + 50.5$). Since 91.00% on a 125% scale corresponds to 7.280 Vdc on a 10 Vdc scale [$10Vdc*91.00\%/125\%$], a setpoint of 7.240 +/- 0.04 Vdc is recommended for 75% drive flow.

14.1.3 Simulated Thermal Power Upscale (Rod Block) Two Loop Operation

Analytical Limit: $0.61W + 58.51$ % Power
 Tech Spec AV: $0.61W + 56.9$ % Power
 Tech Spec NTSP: $0.61W + 51.3$ % Power

Calibration setpoint: Since the setpoint is calibrated at a specific drive flow, the nominal setpoint should be set at least 0.04 Vdc below the corresponding Tech Spec NTSP with a tolerance of +/- 0.04 Vdc. For example, with an 75% drive flow, the Tech Spec NTSP is 97.05% ($0.61*75 + 51.3$). Since 97.05% on a 125% scale corresponds to 7.764 Vdc on a 10 Vdc scale [$10Vdc*97.05\%/125\%$], a setpoint of 7.724 +/- 0.04 Vdc is recommended for 75% drive flow.

14.1.4 Simulated Thermal Power Upscale (Rod Block) Single Loop Operation

Analytical Limit: $0.54W + 46.14$ % Power
 Tech Spec AV: $0.54W + 44.7$ % Power
 Tech Spec NTSP: $0.54W + 39.2$ % Power

Calibration setpoint: Since the setpoint is calibrated at a specific drive flow, the nominal setpoint should be set at least 0.04 Vdc below the corresponding Tech Spec NTSP with a tolerance of +/- 0.04 Vdc. For example, with an 75% drive flow, the Tech Spec NTSP is 79.70% ($0.54*75 + 39.2$). Since 79.70% on a 125% scale corresponds to 6.376 Vdc on a 10 Vdc scale [$10Vdc*79.70\%/125\%$], a setpoint of 6.336 +/- 0.04 Vdc is recommended for 75% drive flow.

2. Revise Section 14.5 as follows:

14.5 Recirculation Flow Monitor - Upscale

Tech Spec NTSP: 108 % Flow
Tech Spec AV: 111 % Flow
Calculated AV: 112.95 % Flow
Calculated AL: 114.66 % Flow

Reference 3.27 requested that these values be evaluated against an AL of 116 % Flow. As the calculation shows there is a positive margin of about 1.34 % Flow between the calculated AL and that of Reference 3.27.

3. Revise Section 14.6 as follows:

14.6 Recirculation Flow Monitor - Comparator

Tech Spec NTSP: 10 % Flow
Tech Spec AV: 11 % Flow
Calculated AV: 14.87 % Flow
Calculated AL: 14.87 % Flow

Reference 3.27 requested that these values be evaluated against an AL of 19 % Flow. This calculation indicates that there is positive margin between the calculated AL and the value from Reference 3.27.

4. Revise Section 14.7 as follows:

14.7 From References 3.5.s, 3.5.t, and 3.5.y, 3.5.z, the required accuracy for the pneumatic calibrator is specified as ± 2.0 " W.C. For the normal temperatures involved in the Reactor Building, i.e., up to 118 °F, the calculated accuracy of the Wallace and Tiernan pneumatic calibrator exceeds this value (Section 9.2). Therefore, the calibration procedures should be revised to indicate the increased uncertainty or to limit the ambient temperature allowed during calibration.

5. Add the following new conclusion section 14.9:

14.9 As-Left / As-Found Tolerances for APRM Flow Biased Trips are:

Recirculation Flow Transmitters (Module 1):

ALT1_{FT} = ± 0.282 mVdc
AFT1_{FT} = ± 0.298 mVdc

ABB RFM Input Isolator Circuit (Module 6_{II}):

ALT6_{II} = ± 0.181 Vdc
AFT6_{II} = ± 0.183 Vdc

ABB RFM Square Root Converter Circuit (Module 6_{SR}):

ALT6_{SR} = ± 0.049 Vdc

$$\text{AFT6}_{\text{SR}} = \pm 0.055 \text{ Vdc}$$

ABB RFM Summer Circuit (Module 6_{SUM}):

$$\text{ALT6}_{\text{SUM}} = \pm 0.012 \text{ Vdc}$$

$$\text{AFT6}_{\text{SUM}} = \pm 0.028 \text{ Vdc}$$

ABB RFM Output Isolator Circuit (Module 6_{OI}):

$$\text{ALT6}_{\text{OI}} = \pm 0.012 \text{ Vdc}$$

$$\text{AFT6}_{\text{OI}} = \pm 0.028 \text{ Vdc}$$

APRM Flow Biased Trip Circuit (Module 4D);

$$\text{ALT4D} = \pm 0.100 \text{ Vdc}$$

$$\text{AFT4D} = \pm 0.297 \text{ Vdc}$$

The calculated As-Left Tolerances for the above modules bounds the module setting tolerances as noted in sections 13.7.1, 13.7.2, and 13.7.3.

15.0 CALCULATION SPREADSHEET

1. Delete section 15.0 in its entirety. This spreadsheet was included for reference only, and it was utilized for verifying computations. It is no longer required and is therefore being deleted.

FINAL PAGE