

DCS No.: 0500027106232010
0500031506232010
0500031606232010
Date: June 23, 2010

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE - PNO-I-10-003

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the Region I staff on this date.

Facility

Entergy Nuclear Operations, Inc.
Vermont Yankee Nuclear Power Station
Unit 1
Brattleboro, VT
Docket No.: 50-271
License No.: DPR-28

Licensee Emergency Classification

- Notification of Unusual Event
- Alert
- Site Area Emergency
- General Emergency
- Not Applicable

American Electric Power
D.C. Cook Nuclear Power Plant
Unit 1 & 2
Bridgman, MI
Docket No.: 50-315; 50-316
License No.: DPR - 58; DPR - 74

SUBJECT: UNUSUAL EVENT DECLARATIONS DUE TO SEISMIC ACTIVITY

On June 23, 2010, the Vermont Yankee Nuclear Power Station (Vermont Yankee) located in Vernon, VT, declared an Unusual Event (UE) at 2:25 p.m. The declaration was made by Entergy in accordance with the plant specific emergency action guidelines after ground motion was felt by personnel on-site and the occurrence of an earthquake was confirmed by the National Earthquake Information Center. According to U.S. Geological Survey, an earthquake of magnitude 5.0 occurred with a seismic epicenter located 33 miles north of Gatineau, Quebec, Canada, near Ottawa and approximately 300 miles from the Vermont Yankee site.

Additionally, the D.C. Cook Nuclear Power Plant (D.C. Cook) located in Bridgman, MI, declared an UE at 2:28 p.m. The declaration was made by the licensee in accordance with the plant specific emergency action guidelines after ground motion was felt and reported by on-site staff to control room operators.

Vermont Yankee continues to operate normally at 100-percent power and there has been no evidence of damage based upon plant inspection of station equipment and structures. The NRC Resident Inspectors are on-site and independently verifying, by conducting inspection activities, that there is no evidence of damage to plant equipment. The NRC confirmed that VY operators notified the states of NH, VT, and MA regarding the UE emergency declaration.

D.C. Cook continues to operate normally at 100-percent power and there has been no damage based upon inspection of station equipment. The NRC Resident Inspectors are on-site providing independent review of the licensee's response and inspection of plant equipment. The NRC confirmed that D. C. Cook operators notified the State of MI regarding the UE emergency declaration.

The NRC is monitoring the impact of the seismic activity on other U.S. plants. Currently, no other plants have made an emergency declaration in accordance with their emergency action guidelines.

An Unusual Event is the lowest of four emergency classifications of events that apply to nuclear power plants as defined by the NRC. The NRC has not changed response posture due to this event.

The information presented herein has been discussed with Entergy and AEP and is current as of June 23, at 4:30 p.m. This preliminary notification is issued for information only.

NRC Public Affairs is prepared to respond to media inquiries.

ADAMS Accession Number: ML101740638

Contact: Richard Barkley, 610-337-5065, Region I

Frances Ramirez, 630-829-9616, Region III

DISTRIBUTIONS: (by email: RI-DL-PN; PN_Distribution)
BY E-MAIL:

Chairman Jaczko
 Comm. Svinicki
 Comm. Apostolakis
 Comm. Magwood
 Comm. Ostendorff
 OIP OCA OGC EDO
 OE NRR NMSS OIG
 RES ACRS FSME NRO
 NSIR OPA SECY
 Regional Offices

BY FAX:

DOT:Trans
 INPO
 NSAC

Licensee: Entergy Nuclear Operations, Inc.
Vermont Yankee

American Electric Power
DC Cook

SUNSI Review Complete: MXG **(Reviewer's Initials)**

DOCUMENT NAME: G:\DRP\PNs\PNO-I-10-003 Vermont Yankee Sesmic Event.doc

After declaring this document "An Official Agency Record" it **will be** released to the Public.
 To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

ML101740638

OFFICE	RI/DRP		RI/ORAS	RI/SLO		RI/DRP		RI/ORAS	
NAME	MGray		RBarkley	DTifft*		JClifford		MDapas	
DATE	06/ 23 /10		06/ 23 /10	06/ 23 /10		06/ 23 /10		06/ 23 /10	
OFFICE	RIII/DRP								
NAME	GShear*								
DATE	06/ 23 /10								

OFFICIAL RECORD COPY

* Concurrence via telecom