

From: Farnholtz, Thomas AEG II
To: Howell, Linda; Clark, Jeff; Kennedy, Kniss; Vogel, Anton
Subject: FW: Daily event status at Fort Calhoun
Date: Friday, July 01, 2011 8:35:35 AM

Hi -

Today's plant status from Fort Calhoun. Water level has dropped about an inch from yesterday. Plant conditions are relatively stable at this point. Water in-leakage is being handled using pumps.

Thank you and have a great day.

Tom.

From: BERCK, ALLEN [mailto:aberck@oppd.com]
Sent: Friday, July 01, 2011 8:22 AM
To: Bill Pook; Dan; Eric Plautz; Farnholtz, Thomas; Jeff Theulen; Jon Schwarz; Kirkland, John; Larry Oliver; Laurel Ryan; Paul Johnson; Whitney Shipley; 'Stodola, Kathy [HSEMD]'
Cc: GEBERS, STEVEN W; DEANGELIS, PETER A; RELLER, MARK H; MOELLER, CHRISTOPHER J; HANKINS, RHONDA R; SILKE, DEENA L
Subject: Daily event status at Fort Calhoun

Fort Calhoun Flooding Status (changes from yesterday's report are in **bold**)

1. Reactor Status: Shutdown
2. Reactor is covered with > 23-ft of cooling water
3. Offsite power and Emergency Diesel Generators are available. Both vital buses are energized at this time.
4. Spent Fuel Pooling cooling is in service and protected.
5. Shutdown cooling is in service and protected
6. **Current river level is 1006' 5" at Fort Calhoun Station** – the river level has remained steady over the last 24 hours.
7. **Current Blair gauge level is 32.2 ft., which is a decrease in the last 24 hours. Current NWS/USACE predictions are for a slight decrease in river level over the next 4 days.**
8. Yesterday afternoon (June 30, 2011), a small fire occurred during refueling of one of the flooding mitigation pumps. The fire was inside the protected area, but outside of any buildings. The fire was extinguished very quickly, and no additional EALs were applicable. During the fire, one worker was injured and was taken offsite by LifeFlight. This was communicated last night to states and counties, and no new status of this injured worker is known at this time.
9. Early Sunday morning (June 26, 2011), one of the AquaDams that was protecting the plant ruptured. The AquaDam was a backup (secondary) flood protection barrier. All primary barriers are intact and are providing adequate protection to the site. The station is on 345 kv power. Water has not entered any vital equipment, and no personnel were injured. Water has equalized onsite, repair efforts are underway. This section of the AquaDam is expected

Information in this record was deleted
in accordance with the Freedom of Information
Act, exemptions
FOIA. 2011-03-29

to be replaced in the next two weeks.

10. The site has implemented procedures to protect power supplies and vital equipment. Water is onsite, and flood barriers are protecting vital equipment.
11. No release of radioactivity has occurred.
12. Fort Calhoun has declared a Notification of Unusual Event at 08:00 6/6/11.
13. Backup evacuation route onsite is inundated however the primary route onsite is passable and not expected to be affected.
14. Power was removed from siren 257 and 260 in Pottawattamie Co. IA, which is just on the edge of the 10-mile EPZ south east of the plant. Siren 75, 76 in Desoto National Wildlife Refuge have no power. Currently the refuge is closed due to flooding. Siren 1 east of Fort Calhoun on county road 34 between Fort Calhoun and Boyer Chute Recreational Area is without power. This area is closed due to flooding. Power was removed to one additional siren in Washington County – sirens 69 was removed from service due to flooding and may require route alerting for any non-evacuated residents. Power was removed from Siren 259. This siren is located in Pottawattamie County on DeSoto Trail, west of 110th street. County to verify evacuation route alerting capability if needed. Power has been removed from sirens 143 and 144 in Pottawattamie Co. IA due to flooding. This area has been evacuated and is not populated.
15. The Reception and Care Center in Fremont is now official, replacing Bellevue. This has been planned for quite some time, but also provides us with greater protection for the public, as no evacuation routes to that location are affected at this time.
16. At this time no known major evacuation routes are affected without contingency actions planned. Interstate 29 in both directions: from Exit 54A (G Avenue) to Exit 71 (I-680 exit): I-680 road closed to traffic because of flooding. I-680 is closed in both directions: from before Exit 1 130th Street to Exit 62: I-29; Old Mormon Bridge Road --- road closed because of flooding. Flooding enhancements along US-30 in Iowa do not affect evacuation, since the path can be re-opened if needed.

Requested Information from states and counties:

1. When offsite evacuation routes are affected please contact emergency planning.
2. When the Blair Water plant is affected please contact emergency planning.
3. Authorized power outages that affect or could affect siren operability, please contact emergency planning.

The river flow rate and level have been relatively constant at Blair NE. The Corp of Engineers is releasing Gavin's Point dam at 160,000 cubic feet per second (cfs).

Emergency Planning Contacts at FCS:

Steve Gebers:

Pager: (b)(6)

Work Phone: 402-533-7308

[Cell Phone: (b)(6)]

Allen Berck:

[Pager: (b)(6)]

[Cell phone: (b)(6)]

Allen D. Berck

Supervisor - Emergency Planning

Fort Calhoun Station

Omaha Public Power District

phone: 402-533-6064

[pager: (b)(6)]

email: aberck@oppd.com

This e-mail contains Omaha Public Power District's confidential and proprietary information and is for use only by the intended recipient. Unless explicitly stated otherwise, this e-mail is not a contract offer, amendment, nor acceptance. If you are not the intended recipient you are notified that disclosing, copying, distributing or taking any action in reliance on the contents of this information is strictly prohibited.