



MEDIA FILTERS EACH 50% CAPACITY
(ONE SHOWN IN BACKWASH)
NOTE 1

NOTES:

1. FILTER BACKWASH IS INITIATED FROM A TIMER AND THE VALVES WILL FAIL IN THE POSITION THAT MAINTAINS THE DISCHARGE FLOW ON A AIR OR ELECTRICAL FAILURE.

Progress Energy Carolina
Shearon Harris Nuclear Plant
Units 2 and 3
Part 2, Final Safety Analysis Report

Raw Water Distribution System
FIGURE 10.4-202