




Legend

 Potentiometric Surface Contour

Notes:


Drawdowns are in feet below static conditions and represent change in surface water table.

Increase in soil vertical pressure equals drawdown times unit weight of water.

Simulation depicts groundwater drawdown contours after one year of dewatering.

Contours estimated using MODFlow

Black areas show areas of no groundwater flow (i.e. deep structures).



PSEG Power, LLC

PSEG Site ESPA
Part 2, Site Safety Analysis Report

Drawdowns in Fill After
One Year of Dewatering

FIGURE 2.5.4.6-3

Rev 0