

Official Transcript of Proceedings

NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards

Docket Number: (n/a)

Location: Rockville, Maryland

Date: Wednesday, June 5, 2013

Work Order No.: NRC-4286

Pages 1-140

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

+ + + + +

605TH MEETING

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

+ + + + +

WEDNESDAY

JUNE 5, 2013

+ + + + +

ROCKVILLE, MARYLAND

+ + + + +

The Advisory Committee met at the Nuclear
Regulatory Commission, Two White Flint North, Room
T2B1, 11545 Rockville Pike, at 8:30 a.m., J. Sam
Armijo, Chairman, presiding.

COMMITTEE MEMBERS:

J. SAM ARMIJO, Chairman

JOHN W. STETKAR, Vice Chairman

HAROLD B. RAY, Member-at-Large

DENNIS C. BLEY, Member

CHARLES H. BROWN, JR. Member

MICHAEL L. CORRADINI, Member

DANA A. POWERS, Member

JOY REMPE, Member

1 MICHAEL T. RYAN, Member
2 STEPHEN P. SCHULTZ, Member
3 WILLIAM J. SHACK, Member
4 GORDON R. SKILLMAN, Member
5

6 NRC STAFF PRESENT:

7 MARK BANKS, Designated Federal Official
8 EDWIN M. HACKETT, Executive Director
9 CHRISTINA ANTONESCU
10 STEVEN ARNDT
11 ERIC BOWMAN
12 MICHAEL CASE
13 MICHAEL CHEOK
14 SHANA HELTON
15 EILEEN MCKENNA
16 TIM REED
17 KARL STURZEBECKER
18 JOHN THORP
19

20 ALSO PRESENT:

21 RONALD BALLINGER

22 *Present via telephone
23
24

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

A G E N D A

Opening Remarks by ACRS Chairman.....	4
Station Blackout Mitigation Strategies	
Rulemaking.....	6
Revisions to Six Regulatory Guides on	
Use of Digital Software.....	89

P R O C E E D I N G S

8:29 a.m.

Opening Remarks

CHAIRMAN ARMIJO: The meeting will now come to order. This is the first day of the 605th meeting of the Advisory Committee on Reactor Safeguards. During today's meeting, the Committee will consider the following:

First, Station Blackout Mitigation Strategies Rulemaking. Second, Revisions to Six Regulatory Guides on the Use of Digital Computer Software in the Safety Systems in Nuclear Power Plants. Third, Assessment of the Quality of Selected NRC Research Projects, and fourth, Preparation of ACRS reports.

This meeting is being conducted in accordance with the provisions of the Federal Advisory Committee Act. Mr. Mark Banks is the Designated Federal Official for the initial portion of the meeting. We have received no written comments or requests to make oral statements from members of the public regarding today's sessions.

There will be a phone bridge line. To preclude interruption of the meeting, the phone will be placed in a listening mode during the presentations

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

1 and Committee discussion. A transcript of portions of
2 the meeting is being kept, and it is requested that
3 the speakers use one of the microphones, identify
4 themselves and speak with sufficient clarity and
5 volume so that they can be readily heard.

6 I would like to open with an item of
7 interest. Drs. Peter Riccardella and Ronald Ballinger
8 have been selected as new members of the ACRS. Dr.
9 Ballinger, who is joining us here today as an invited
10 expert, has over 40 years of experience with
11 metallurgy and materials in nuclear power
12 applications, and is currently a Professor of Nuclear
13 Science and Engineering at the Massachusetts Institute
14 of Technology.

15 Dr. Ballinger has worked on cooperative
16 research programs at EPRI, has served or is serving on
17 several Department of Energy committees regarding
18 disposition of waste streams at DOE sites, and
19 evaluation of advanced reactor options. He has
20 authored or co-authored over 100 scientific papers,
21 and is a member of several professional societies,
22 including the American Nuclear Society and ASTM.

23 Dr. Ballinger has worked previously with
24 ACRS as a consultant on issues related to steam
25 generator, tube degradation and leakage. Welcome

1 aboard, Ron.

2 (Applause.)

3 CHAIRMAN ARMIJO: Dr. Pete Riccardella has
4 over 45 years of experience in the nuclear industry.
5 In particular, he is an authority in the application
6 of fracture mechanics to nuclear pressure vessels and
7 fissures. Dr. Riccardella has had significant
8 involvement with the American Society of Mechanical
9 Engineers during his career.

10 In 2001, he became an honorary member of
11 ASME Section 11 Subcommittee on Nuclear Power Plant
12 In-Service Inspection, and in 2005, was named an ASME
13 Fellow. Dr. Riccardella was a founding member of
14 Structural Integrity Associates, which has been an
15 industry leader in failure prevention and failure
16 analysis.

17 We hope to have them both on board as
18 official ACRS members by this fall. Again, welcome
19 aboard. With that, I'd like to turn the meeting over
20 to Dr. Bill Shack, who will lead us through the
21 presentation on Station Blackout Mitigation
22 Strategies. Bill.

23 Station Blackout Mitigation Strategies

24 MEMBER SHACK: Okay. Again, one of the
25 recommendations of the near-term task force was to

1 essentially develop a new station blackout rule that
2 would cover extended station blackouts. In the
3 meantime, we've issued an order, EA.12-049, which
4 again mitigating strategies, again which addresses
5 extended blackouts.

6 What the staff is here to present to us
7 today is a regulatory basis to go forward with a new
8 station blackout rule, that in a way addresses the
9 concern of the Near Term Task Force, and essentially
10 perhaps codifies the order and makes it generically
11 applicable.

12 Again, they'll be talking about the
13 regulatory basis to do that and some rule concepts.
14 Mike Cheek wants to make the presentation.

15 MR. CHEOK: Thank you, Dr. Shack. Again,
16 good morning. My name is Mike Cheok. I'm the Deputy
17 Director in the Division of Engineering in NRR. It's
18 a pleasure for us to be here to talk today at ACRS on
19 our efforts, on our rulemaking efforts for station
20 blackout mitigating strategies, and to provide you
21 with a status of our leading strategies for those.

22 At this point, the staff has issued and
23 completed a draft regulatory basis, and have issued
24 this for a 45-day comment period. This comment period
25 ended last week on May the 28th. Our objective today

1 is to discuss this reg basis with you, and to get your
2 comments.

3 Over the next month, the staff will be
4 working on a Commission Assistance Note or MR. CASE:
5 Note to inform the Commissioners of our progress. We
6 will incorporate your comments and your feedback into
7 our Commission Assistance Note.

8 Over the longer term, the staff will be
9 working on the draft rulemaking, the draft package,
10 and it will use your comments today to start our
11 initial writing of the draft rule.

12 So from, going from the reg basis to the
13 draft rulemaking to the final rule, we will continue
14 to update the ACRS as requested, and we will come back
15 and talk to you about the status of what we're going
16 to be doing.

17 So today, we will have Tim Reed, who will
18 talk about the reg basis. We will Eric Bowman, who
19 will talk about the status of the mitigating
20 strategies order, and Eileen McKenna from NRO will
21 entertain any questions that deal with reactors. So
22 Tim.

23 MR. REED: Okay, thanks Mike. It's a
24 pleasure to be back in front of the ACRS again today.
25 Mike just covered the purpose slide, so I don't think

1 we need to do that again. So I'll move to Slide 3.
2 A lot of this going to be familiar to you folks,
3 because you've heard a lot of it more than about a
4 month ago, I guess it was.

5 So I'll shorten this, real condensed on
6 the background, so we can have an opportunity to try
7 to get through all of this material in an hour and a
8 half. So I'll breeze through this background kind of
9 quickly, and get to I think what is much more
10 important, and that's the actual concepts, which is
11 the balance of this presentation.

12 But as we've pointed out, we've briefed
13 the Subcommittee on Regulatory Policies and Practices
14 twice. We briefed you at committee in December 2012,
15 and then also here recently on April 23rd. So most of
16 you are familiar with a lot of this information.

17 The scope and schedule for this regulatory
18 action station blackout mitigation strategies
19 rulemaking was substantially changed by COMSECY-13-
20 0002. That was issued in January of this year and
21 then we've got an SRM, agreeing with the scope and
22 schedule from the Commission in March.

23 What that basically did was the third
24 bullet there, revised the scope to basically address
25 all of the actions stemming from NTTF Recommendations

1 4 and 7 into this rulemaking, and to place, put in
2 place a much more normal rulemaking schedule.

3 In other words, now we -- in fact, as Mike
4 just mentioned, we actually had an opportunity to
5 develop the reg basis federally, put that out for
6 comment for 45 days. Now we'll have a proposed rule
7 stage and a final rule stage, and under the former
8 schedule that wasn't possible.

9 Of course, this was justified because of
10 the scope of the mitigation strategies order, EA.12-
11 049, that was issued on March 12th of 2012.
12 Basically, it's addressing, in large measure, a
13 recommendation for and addressing those issues, any
14 safety issues, in basically about the fastest schedule
15 possible with licensees.

16 So that was -- the very good answer, we're
17 addressing safety as fast as possible with the order,
18 and allows us to do rulemaking on something a lot
19 closer to a normal rulemaking process. You see --

20 MEMBER SHACK: A question there.

21 MR. REED: Yes sir.

22 MEMBER SHACK: When I looked on the
23 rulemaking website, there were very few comments on
24 this rule. Is that just because they were late in
25 posting?

1 MR. REED: There's some coming in kind of
2 late. We have now ten sets, and I expect an
3 additional set coming from NEI, with the real detailed
4 comments from NEI on June 20th. So --

5 (Simultaneous speaking.)

6 MEMBER SHACK: You still have some coming
7 in well past the deadline?

8 MR. REED: Yeah, yeah. Sometimes it takes
9 a while for some of that to get processed, depending
10 on which forum it comes through, whether it comes
11 regulation.gov or through the mail or whatever. So it
12 can take a while. Shana?

13 MS. HELTON: Hi. This is Shana Helton,
14 NRRN. I'd just like to note that, you know, we
15 always, as a matter of practice, try to consider late-
16 filed comments to the extent practical, unless there's
17 some extenuating circumstances. In this case, it's
18 just the regulatory basis stage.

19 If we can consider the comments as we
20 finalize the regulatory basis, that's fine. Even if
21 we can't, if they come in too late for our due date,
22 then we can consider any late-filed comments as part
23 of the development of the proposed rule package.

24 MR. REED: Absolutely. That's -- a lot of
25 the most -- we took the opportunity, when we put the

1 reg basis out, really the draft rule concepts in the
2 appendix is the most important part for me anyway, and
3 most of the substantive comments are coming in on
4 that.

5 A lot of that work is going to be
6 realistically done in the proposed rule stage, and I
7 think NEI's comments will be addressed largely in that
8 stage. Yes. So right now, I'm aware of 10 sets.
9 Very good comments, in fact, from mostly the new
10 reactor designers.

11 So and I'll try to address those as I go
12 through. I've gone through that one time very
13 quickly, so if I see something on a slide, I'll try to
14 mention where I got feedback there, as we go through
15 this.

16 So we mentioned that the -- I got the, by
17 the way I got the schedule on there as June 30th,
18 2014. That's next, end of next June, next year for
19 the proposed rule, and any supporting draft guidance
20 to the Commission. So that's the current rulemaking
21 schedule.

22 Then we've lined up the final rule to line
23 up with the ultimately implementation of EA.12-049,
24 with December 2016, because the drop dead date right
25 now for the mitigation strategies order is December

1 31st of 2006. So we're trying to line these two
2 things up here, so they work in lock step like that.

3 So and then 45 day comment period, ten
4 sets of comments. It was actually at 48, I think,
5 days that ended on May 28th, because we had a holiday.
6 So that's the background.

7 Slide 4, the basis for this rulemaking is
8 actually kind of straightforward, as opposed to what
9 it can be sometimes on rulemakings truthfully as well.
10 Because we have a mitigation strategies order that was
11 issued to all current licensees, all licensed power
12 reactors in fact, including Vogtle and Summer, two
13 COLs.

14 Obviously, those requirements are in any
15 form aren't in any form of the Code of Federal
16 Regulations, that what we typically do in NRC in
17 rulemaking, we make those what I, the language I'm
18 using, is make those generically applicable.

19 So that we have a stable, known set of
20 requirements for everybody to comply with. It's not
21 something that's going to be shifting with each order
22 or license condition in the future. It's the best way
23 to do things, because it's an open format. It allows
24 us to learn lessons from the implementation of the
25 order, allows us perhaps to have some flexibility.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 We have a lot more time and generic
2 flexibility, and it's done when we did the orders,
3 which were done in extraordinarily expedited fashion.
4 So that's all part of this rulemaking. But in fact,
5 I think the rulemaking is an absolute certainty, of
6 course, because of this situation.

7 So we don't really have a situation where
8 we have to go through and justify our rulemaking like
9 we might typically have some of the other Fukushima
10 actions, okay.

11 And of course, the orders, especially
12 because the current station blackout requirements,
13 which for the United States reside in 10 C.F.R. 50.63,
14 did not really do what we wanted to be done. This is
15 -- obviously, this is stemming from a very severe
16 event, which could damage onsite and offsite AC power
17 sources, don't damage the entire site.

18 It can go for quite a long time, and it
19 certainly can devastate offsite AC power sources, and
20 that creates completely different situation than what
21 50.63 was looking at. And since it's a low duration
22 event, you get into other issues like spent fuel pool
23 cooling, which 50.63 was not concerned with.

24 The order is applying these requirements
25 to all modes of operation, and so I suspect that the

1 rulemaking would do so also, and of course 50.63 did
2 not do that. So 50.63 was as, I think everybody's
3 aware, was a cost-justified substantial safety
4 enhancement, which turned to be cost-justified. So as
5 that was demonstrated to be cost-justified by NUREG-
6 1776.

7 So it was a very successful regulation for
8 what it did, but it's got kind of a different focus
9 than the mitigating strategies. But having said that,
10 and ELAP is a severe blackout that goes on essentially
11 for -- I will get to the next slide here.

12 But so they kind of went together nicely,
13 as we'll see here in a minute. So that's the reason
14 why we're doing this rulemaking. I think that
15 wouldn't be a surprise to anyone.

16 Now I'm going to get to, I think, the rest
17 of this really is trying to get to these draft rule
18 concepts that were in the appendix, and these slides
19 are largely look like the slides that I presented last
20 month. We didn't have an opportunity really to go
21 through all the comments that we've got right now and
22 try to change some of this.

23 But if we did, if I could pull the
24 rulemaking group together, I think you'd see a lot of
25 this changing already, because I think we're probably

1 too restrictive on the new reactor designers, have a
2 little bit too much of a current licensee mind set.
3 But nonetheless, as I go through, I'll try to reflect
4 some of the comments that we've had, and I'll try to
5 mention that as we go through.

6 One of the things we did to try to provoke
7 external stakeholder feedback in the draft rule
8 concepts is we put out an ELAP definition, and the
9 very first thing you'll notice about that is I don't
10 have a loss of normal access to the ultimate heat sink
11 there.

12 That was in the order, okay, and we
13 intentionally did not put that in here. The idea was
14 to provoke comments, see what people thought about the
15 fact that why should you assume the loss of normal
16 access to ultimate heat sink unless it's -- if it's a
17 direct consequence of ELAP, of course it's assumed,
18 and if you would expect it to occur from the external
19 event. In other words, that equipment is not
20 reasonably protected; of course you would assume it to
21 occur. But why would you assume it any other way?

22 So that was put out there to provoke
23 comment. We got some pretty interesting comments so
24 far. We're looking at that. There seems to be some
25 agreement that if you have a divers, robust type of

1 heat sink powered source, then maybe it should be
2 allowed. It provides, consistent with the
3 supplemental AC power, which you'll see later, some
4 opportunities for engineers, I think, to design in
5 physical protection here. It might be advantage over
6 human reliance.

7 So that was kind of the intent there.
8 Clearly though, if -- one of the interesting things I
9 got is people didn't like the way I separated the
10 little pieces of the ELAP definition. It's kind of
11 confusing. It's all those things added together down
12 there at the bottom of the slide.

13 MEMBER CORRADINI: So can I ask a
14 question, since I wasn't at the Subcommittee meeting.
15 What does "extend indefinitely" mean?

16 MR. REED: That's another --

17 (Simultaneous speaking.)

18 MEMBER CORRADINI: I mean so are you
19 saying that there's no probability, there's no cutoff
20 frequency? I know you don't really mean that. So
21 what are you thinking?

22 MR. REED: I think actually we got
23 feedback to that extent right now, and that's
24 something I think we'll need to think about, I think
25 the order needs to think about. We have a multiple

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 phased approach right now for current licensees, with
2 the last phase being a reliance on offsite resources,
3 okay. But then at what point do you say you're okay?

4 MEMBER CORRADINI: Right. But so I mean
5 let's just take the current, let's just take the
6 current situation. As you said, this was for a
7 different purpose. It had some sort of cost-benefit
8 analysis that's attached to it. But with the current
9 rule, you have to show that you can essentially
10 recover within some time period.

11 So what's that probability versus -- I
12 mean there must be estimates of all this. So has
13 staff at least gotten some feeling as to what you want
14 to extend it to, or are you letting the rulemaking
15 proceed such that you'll just see what input you get?

16 I'm still struggling with are you going to
17 give a suggestion, a straw man? Are you going to let
18 it just sit out there, because indefinite definitely
19 makes to me no sense, personally. It just seems way
20 too big.

21 MR. REED: Yeah, it's impossible. I know
22 what you're saying, but I think this is a case where
23 I think we need to see what is implemented. I mean
24 for example, you could have a success criteria that
25 says once you've established offsite assistance, and

1 basically that line of assistance is established, you
2 can say okay, you're successful.

3 In other words, you're doing what you can
4 do. That would be one way. I don't know how we're
5 going to call success. I mean obviously, you can't
6 for some of these scenarios say you're going to be
7 successful.

8 I can't say, for example, I'm going to get
9 the cold shutdown or something, given a situation like
10 you've destroyed the facility. There may not be a
11 successful mitigating event.

12 But what you do have is all this
13 equipment, the strategies, the guidance in place. You
14 have it planned out. You have it worked through. You
15 have a good chance of mitigating that you didn't have
16 before. That's definitely better than what existed in
17 50.63, which was typically the scoping periods were
18 designed to have about a 90 percent chance of recovery
19 within those, yeah.

20 So this is an indefinite thing now. I
21 mean indefinite being I want you to be able to go well
22 beyond that, to some point where we can say okay,
23 realistically we're going to start getting power back
24 on site. You're going to realistically now
25 reestablish some of the normal --

1 MEMBER BLEY: So Tim said outside
2 assistance, and we have the flex program that's going
3 on at the same time.

4 MR. REED: Exactly.

5 MEMBER BLEY: So I think what he's saying
6 is, and you can correct me, they've got to be able to
7 look long enough that whatever comes in from offsite
8 to support them comes up there.

9 MEMBER CORRADINI: Well I mean I was
10 expecting you to say back to me that you don't want to
11 define what indefinite is, because you'll allow for
12 multiple definitions of success. So if that's the
13 case, that's fine. I'm just curious if you have some
14 examples of success.

15 So one is essentially you extend by flex.
16 You extend, you essentially are able to reestablish.
17 That's a definition, not the only one. Is that your
18 point?

19 MR. REED: That would be one.

20 MR. CHEOK: And I think another point
21 could be indefinitely might not be time base. It
22 could be a situation base. So you would say define a
23 success statement. If you can get to, achieve to that
24 success state, and that's how we will define when the
25 SBO ends. So it may not be time-based; it could be

1 performance-based.

2 MR. BOWMAN: If I could, this is Eric
3 Bowman. I'm the staff lead for the mitigating
4 strategies order.

5 The inclusion of the phrase "extends
6 indefinitely" as it occurred under the mitigating
7 strategy order and as is being carried forward into
8 the station blackout mitigating strategies rulemaking
9 is based in large part on addressing shortfalls that
10 we had the (b) (5) (B) mitigating strategies, where we
11 set the mission times for the strategies at 12 hours,
12 and didn't look to the use of offsite resources to
13 extend the mission times.

14 So under that set of strategies, because
15 it was not envisioned as being a large regional
16 catastrophe, that would prevent calling a local
17 supplier of diesel fuel from coming in and refilling
18 the fuel tanks for the portable pumps they use there,
19 we felt that it was acceptable to merely require
20 sufficient fuel and water resources for a 12-hour
21 mission time.

22 Here, looking at what occurred at
23 Fukushima, we felt it was more appropriate to include
24 the requirement extending indefinitely, meaning that
25 there has to be some kind of provisions made for the

1 delivery of fuel from offsite or the use of the large
2 fuel tanks that are onsite to refuel the pumps, to the
3 extent that it's possible, and you could think of a
4 success path that maintaining or restoring core
5 cooling, for example, is one of the requirements.

6 If they manage to restore power, AC power
7 to the electrical buses and get back to a normal
8 circumstances where they're using the normal systems
9 for the maintenance of core cooling, they're going to
10 be able to do that indefinitely, until something else
11 happens perhaps. But the idea is we don't have an end
12 point for the need to maintain the safety functions.

13 MEMBER CORRADINI: But I think this could
14 end up -- we don't know yet obviously. But I think
15 you could end up not saying the word "indefinite" in
16 a rulemaking, but a phased thing with offsite
17 assistance or something like that, to get away from
18 something which is impossible to comply with.

19 MR. REED: Right. But I think I see where
20 you guys are going with this. But I'm, at least the
21 way it's phrased here, and I was looking through some
22 of the backup reading material, I was confused. I
23 think I understand a little bit more.

24 MEMBER REMPE: When you start relying on
25 offsite sources, what happens if there's a bridge out

1 for repair for a month or something like that? Is
2 that going to be part of it; they'll have to report
3 that this will occur?

4 MR. REED: Yes. Transportation issues are
5 going to be in here too. We have some language -- I
6 think do we have it on here, the slides, or we didn't
7 have that? I think we didn't. But transportation to
8 the site is an issue in a severe event like that.

9 MEMBER REMPE: Restoring normal
10 operations. Suddenly, you know, that --

11 MR. REED: Yeah. That would be like an
12 earthquake takes out the bridge.

13 MEMBER REMPE: But I mean just for
14 maintenance.

15 MR. REED: Oh.

16 MEMBER CORRADINI: Her point is you're
17 operating perfectly fine operationally, but your plan
18 to satisfy this rule has this key bridge having to be
19 there.

20 MEMBER REMPE: Right.

21 MEMBER CORRADINI: So that if something
22 happens, this is going to be transported by that.
23 That bridge is out for a month. So all of the sudden,
24 your station blackout success path is compromised. I
25 think that's it.

1 MEMBER REMPE: Right, exactly. So is
2 there going to be reporting, you know, they've got to
3 start telling you when the bridge is going to go out
4 for a month, and then you'd have alternate plans? I
5 mean I was reading the material too. I was just
6 thinking of what ifs that could occur.

7 MR. BOWMAN: Well, the requirement as
8 it's listed in the EA.12-049 mitigating strategies
9 order is for the licenses to develop, implement and
10 maintain the guidance and strategies. So the
11 licensees have an obligation, if the bridge goes out,
12 to figure out an alternate method of delivery of the
13 offsite resources.

14 Whether or not it's reportable is not
15 addressed in the order, but would be addressed
16 elsewhere.

17 MEMBER CORRADINI: Okay, but just I'm --
18 I mean I was trying to turn around the first -- I'm
19 still stuck on the first sentence, and then I'll stop.
20 What you're really saying is you want it basically to
21 show long-term decay heat removal under, excuse the
22 rephrasing, under all circumstances.

23 That's really what you're saying. Under
24 all circumstances, you want to show that you can
25 successfully remove decay heat, remove decay heat from

1 the core and the fuel and the spent fuel pool, and
2 maintain the containment function.

3 MR. REED: I'm a little -- I would say you
4 have to have strategies, guidance and equipment in
5 place that has reasonable capability of doing that.
6 You may not be in fact successful. Okay. So I'm a
7 little -- on the success criteria with a situation
8 like this.

9 MEMBER CORRADINI: That's fine, okay.
10 That's fine. I'll stop. Thank you very much.

11 MR. REED: But I see what you're saying.

12 MEMBER REMPE: Thinking about the
13 reportability thing and implementation on a reasonable
14 chance of success, I'm just wondering again if you
15 start having to report when a bridge is out for a
16 month, well is it a week or a month.

17 The implementation of this is what was
18 really I was struggling with when I was reading this,
19 and how fine in detail are we going to go to.

20 VICE CHAIRMAN STETKAR: I mean emergency
21 plans face the same issues in terms of evacuation
22 routes and things like that. People deal with that.

23 MEMBER REMPE: And how do they deal with
24 it? I mean --

25 VICE CHAIRMAN STETKAR: I don't know.

1 They don't report it.

2 MEMBER REMPE: So they don't report. They
3 just ignore it. So if the bridge was out --

4 VICE CHAIRMAN STETKAR: No, no. They
5 don't ignore the bridge is out. They have to have
6 alternates in place, I believe. But they don't have
7 to -- I think John's point is they don't have to, it's
8 not a reportable event, from the licensee's
9 perspective.

10 MEMBER SCHULTZ: Tim, are you going to
11 talk further about Mike's point, that the focus ought
12 to be for the rule to be performance-based, to get
13 away from words like "indefinitely" or just the
14 general description --

15 MR. REED: Right. I'll probably be saying
16 that several times, and not only from the comments
17 here, but from the comments from the new reactor
18 designers I've gotten reg basis. I think we will
19 probably, are too restrictive. Well, we're trying to
20 get past a very high level performance requirement go
21 down, I think it would be a little bit restrictive on
22 what a new designer could do to solve this problem.

23 So absolutely. I think we're probably
24 going to have to be a little more performance-based on
25 what these concepts have. So I think we'll be leaning

1 that way. I don't know. I mean it's just me looking
2 at it. But absolutely I agree with that, so -- that's
3 just me, though.

4 MEMBER SCHULTZ: Because that helps to tie
5 it in with the current rule.

6 MR. REED: Yes.

7 MEMBER SCHULTZ: That's part of the
8 objective, is at some point in the rulemaking, it is
9 going to integrate, I hope very well with the current
10 rule. That's one of the goals, and that would help to
11 get a focus in a different way than just saying well,
12 we're going to handle beyond design basis events,
13 without identifying what they are and what the bounds
14 are.

15 MR. REED: Right.

16 MEMBER SCHULTZ: And understanding that
17 like the current implementation of station blackout,
18 it is site-dependent, both in terms of location, as
19 well as number of reactors --

20 MR. REED: Absolutely.

21 MEMBER SCHULTZ: --capabilities and so
22 forth.

23 MR. REED: And hazards, yeah absolutely.
24 I agree.

25 MEMBER RYAN: Tim, it strikes me that all

1 the sub-bullets on specifically the current concept
2 that includes on short-term intervals, some of those
3 things probably aren't as big of a deal as if it's a
4 very long period of time, and then an intermediate
5 period of time.

6 So all those, in terms of the intensity of
7 what you're going to deal with is time-dependent. Are
8 you going to deal with that at all? For example,
9 complete loss of AC power to the essential and non-
10 essential switch gear. That lasts longer and the
11 backup system, you know, might not be working. Have
12 you thought about the time-dependence of all this?

13 MR. REED: Yeah. In fact Eric, I'll chime
14 in. I think the way I think about this is it's an
15 event that occurs say at T equals zero, okay, and
16 depending on the initial conditions are the mitigating
17 actions you have to take. These are a simple set of
18 assumptions that we're going to assume at the
19 beginning. It may be worse than this.

20 But the actions you have to take at each
21 point of time after T equals zero are dependent on
22 what happened. So the very first action might be,
23 okay, you're in the control room trying to figure out
24 what happened obviously. But then you might think
25 okay, I need to start stripping batteries, or I may

1 need to go and do, for the power send for a central
2 charger, or I may need to go to a turbine-driven aux
3 feedwater pump room.

4 Depending on what you have to -- or go
5 look at water sources. Okay, as you go through the
6 sequence for that event, you need to figure out how
7 long it is until you have to take action. So the time
8 constraints are absolutely the great key, and that's
9 part of the implementation of the order. Folks are
10 trying to work that problem right now.

11 MEMBER RYAN: Okay. So that's covered.

12 MR. REED: So all these things really, you
13 know, they really sit in a time domain, if you will.

14 MEMBER RYAN: That's kind of what I'm
15 thinking if you give them a list. They all have to
16 have --

17 MR. REED: Yeah, absolutely.

18 MEMBER RYAN: Without understanding the
19 time sequencing of all these things, either singularly
20 or interacting in some way, you really don't know
21 where you are on the intensity scale.

22 MR. REED: That's right.

23 MR. BOWMAN: Yeah. This is Eric Bowman.
24 The other thing that needs to be borne in mind is that
25 there's a relationship of this set of requirements

1 with the station blackout requirements.

2 They've got the loss of all AC emergency
3 operating procedures that they'll be going through,
4 and in large part the initial actions will all be the
5 same, as though they're going down the standard
6 station blackout procedure they already have.

7 But at some point there will be a decision
8 point where they'll get a response. Got to obtain --
9 with an alternate AC power source reliant licensee,
10 the current procedure says go start the alternate AC
11 source and place it on the buses.

12 If the response that the AC, the alternate
13 AC power source doesn't start, if the response is not
14 obtained, then it branches off into doing these
15 mitigating strategies.

16 MEMBER RYAN: Got you. So it's got to be
17 kind of a very complicated web of decision-making
18 where, you know, in one set of circumstances that
19 decision could make lots of sense, and if something
20 else precludes you making that decision, that whole
21 pathway is kind of shut off.

22 MR. REED: Absolutely, exactly.

23 MEMBER RYAN: It's a very complicated
24 network of decisions, not just --

25 MEMBER BLEY: Something I think would help

1 the Committee, because some of us have never
2 participated in a rulemaking, some of us have, would
3 be something like a critical path chart. I know you
4 do those out of this rulemaking process, and how it
5 will interact with other rulemakings, like the one
6 about integrating procedures.

7 I think what you were just talking about
8 somehow tends to overlap what's to be going on over
9 there. I think maybe next time we get together, that
10 would be very helpful.

11 MR. REED: Yeah. We have a whole slide of
12 different circumstances kind of right in the center of
13 it. So it's a challenge.

14 MEMBER RYAN: I know you do, yeah.

15 MR. REED: I'm certainly aware of that.
16 But anyway, this is -- these sub-bullets were meant to
17 try to define the specific elements of this entire
18 ELAP condition, and I'm not sure, I think it created
19 some confusion.

20 First of all, I don't think, for example,
21 we got comments that hey, why are you saying safety-
22 related batteries, and I think that's a good comment.
23 If those are reasonably protected batteries, I think
24 we will allow power from reasonably protected
25 batteries.

1 They may have to be strapped for size.
2 They may have to be changed from what they are now, to
3 make sure they are reasonably robust structures. But
4 for example, that's one comment that I've got.

5 Also, going back to an initial comment
6 earlier, if in fact the supplemental AC power sources
7 survive and are in the proposed rule, and by the way,
8 they're strongly supported by designers, that would be
9 one way. That would be one success criteria of
10 restoring power using a supplemental AC power or
11 robust source.

12 So this was meant to give the individual
13 concepts of what this condition was, and to get
14 comments on it. It was, we got a lot of comments on
15 this, and we'll see what we go, where we go from here
16 on that, if there's anything else in there that comes
17 to mind to bring out on this slide.

18 VICE CHAIRMAN STETKAR: During the
19 Subcommittee meeting, we had some discussion about all
20 of these little bits and pieces and words and sub-
21 bullets, and how people might creatively interpret
22 what they might mean at a particular plant and how
23 they might justify the fact that they don't need to
24 meet the intent of this rule, because they don't
25 satisfy any of those specific conditions there.

1 Have you received a lot of feedback? You
2 already mentioned, I think, comments on each of these
3 individual line items. Well, do you have say safety-
4 related batteries and kind of use a Joe battery rather
5 than a safety-related battery?

6 The question I have is are we trying to be
7 so specific that we're walking ourselves into little
8 finely-defined corners that don't really address the
9 concern? The concern being, I'll use the word
10 "indefinitely," an indefinite loss of all AC power
11 sources to any system, SSCs, that are needed for decay
12 heat removal from the core and the spent fuel, period.
13 I mean that's it.

14 How that is achieved at a particular
15 plant. Whether it's loss of power to the essential
16 and non-essential, or whether it's an or, or whether
17 it's some two out of three of this and six out of
18 seven of those other things is a site-specific issue.
19 The fundamental concept needs to be elaborated.

20 MR. REED: I agree. Actually, the
21 comments in this Committee we had those kind of
22 comments, and the comments we got back on the reg
23 basis on this were kind of leaning us towards going
24 more to performance-based, allowing more flexibility.
25 Having, licensees will have all these tools in the

1 tool kit, if you will, and they'll use them as they
2 see fit, depending on what happens. And so if we get
3 too much definition here --

4 VICE CHAIRMAN STETKAR: That's what I was
5 saying.

6 (Simultaneous speaking.)

7 VICE CHAIRMAN STETKAR: You now have some
8 feedback, and if a lot of the feedback is coming about
9 in terms of discussions of specific and and/or logic,
10 or what you call an essential or what you call a
11 safety-related, that might be a clue that we're
12 heading down a path towards over-specificity.

13 MR. REED: Absolutely, too prescriptive at
14 the reg requirements level, and this is one of the
15 good things about putting those draft concepts out
16 there and getting feedback.

17 Before you even get to the proposed rule
18 stage, that can avoid some of that. Now I'm not going
19 to solve all the problems in the world, but I'm sure
20 I'll get good comments on the proposed rule, okay.

21 VICE CHAIRMAN STETKAR: But I mean at the
22 rulemaking level, it's one thing. In terms of
23 implementing regulatory guidance, there could be
24 better definition of --

25 MR. REED: I think if the regulatory

1 guidance --

2 (Simultaneous speaking.)

3 VICE CHAIRMAN STETKAR: --of specific
4 conditions as that comes up.

5 MR. REED: Absolutely. So I think I agree
6 in spirit with what you're saying. It's been, I
7 think, three times now today. So that's, I think,
8 kind of the feedback I've gotten on the ELAP
9 definitions so far. I think you're going to get some
10 more comments from NEI on June 20th, and it's probably
11 going to some of this loss of heat sink stuff.

12 So I'll wait to see and when that comes
13 in, I'll reserve, depends where we end up on this.
14 But I think we definitely need to be at a more
15 performance-based level with this definition.

16 MEMBER BLEY: Just going back to that
17 Subcommittee, Eric said it this way, but I don't
18 think he quite said it. The big thing that we're
19 worried about is when you have a discrete list like
20 this, it'll turn out either you've forgotten something
21 that you could put in that list, or somebody will --

22 MR. REED: Use it.

23 MEMBER BLEY: Break things apart and other
24 pieces and say it only applies to this, and you'll
25 have much difficulty.

1 MR. REED: Some lawyer, I mean. I know
2 exactly what you're saying.

3 (Simultaneous speaking.)

4 MR. REED: So yeah. I definitely agree
5 with that. So but that was, it was good to get that
6 feedback from the committee and from stakeholders on
7 that. So any more comments on this slide?

8 (No response.)

9 MR. REED: I'll go to Slide 6 then. This
10 kind of the harder thing, the mitigating strategies
11 themselves. In fact, on this slide, this looks -- I
12 think it's almost exactly the same as what I presented
13 to the Subcommittee. One thing I wouldn't have on
14 this slide was as the third sub-bullet there,
15 "equipment would be required to sufficient design
16 capacity."

17 It actually should go on the next slide.
18 So ignore that for a second. But the rest of it is
19 really kind of the guidance and strategies and those
20 kinds of requirements, the first one being of course
21 develop, implement and maintain guidance and
22 strategies to maintain or restore core cooling
23 containment, and spent fuel pool cooling capabilities.

24 So that's identical to the order. That is
25 the heart and soul of this requirement, and it's

1 actually a pretty strong argument, that the minute you
2 start dropping down below that, you start getting
3 yourself in trouble. If we stay at that level a
4 little bit more, almost the attachment to the order,
5 you're okay.

6 But we've tried to get a little bit more
7 detail, where we've gotten, I think, we're getting
8 ourselves into some areas where maybe we're not doing
9 the very best thing for the rulemaking or for safety,
10 for that matter. But --

11 MEMBER BLEY: I have a question about the
12 word "strategies." I like the word "strategies," and
13 to me that implies laying out the functional
14 description of how you're going to survive this event.
15 It could mean to somebody else laying out very
16 detailed, specific procedures akin to the EOPs that we
17 have.

18 My concern with that is when the real
19 event doesn't quite match it, it may not be helpful.
20 So I'm wondering if you've defined "strategies" and
21 what you think we're looking for in that area.

22 MR. REED: We haven't, and I'm sure Eric's
23 going to jump in here too, we haven't defined
24 strategies, but we're thinking exactly what you're
25 thinking. You really can't have a step-by-step thing

1 for a situation where you don't even know what the
2 damage state's going to be obviously.

3 MEMBER BLEY: So if that event occurs,
4 that will be better than if that event doesn't occur.

5 MR. REED: These really are strategies,
6 but they're not just amorphous things. They are,
7 they're a set of guidance and strategies, with staging
8 and deployment routes and work through; there's an
9 engineering basis work. There are time constraints
10 built into these things.

11 So when you look at what's being done, if
12 you look at the integrated plans of what's being done,
13 there's a lot of work that is being done. Even though
14 they're strategies, they give you a very good chance
15 that they would be in fact successful in being
16 deployed.

17 And certainly for probably a lot of
18 scenarios, we're not even thinking about it. You
19 know, so they're looking at flexible, but they are
20 engineered, and yeah, it may not work, you know,
21 exactly the way you thought. You might have to take
22 a different pathway, and this in fact has
23 contingencies, that there's more than one connection
24 and there's these other aspects of these strategies
25 that reflect the fact that this is a pretty undefined

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 situation you're going to be addressing.

2 But yeah, you're absolutely right.
3 That's the thing I think really gets done in an EOP,
4 you know, and then once you step into these
5 strategies, you're in a world that's a lot less
6 defined, and you have to be more flexible there, to
7 allow the folks at the site to probably do the best
8 thing they can at that time, you know.

9 MR. BOWMAN: This is Eric. The way I
10 would think of it, the guidance, per the phrase
11 "guidance and strategies" is what is getting to the
12 procedures. The strategies can be a more inclusive
13 term that covers things such as one of the things
14 industry is doing in response to the order is a set of
15 contractual relationships between the licensees and
16 the offsite resource provider that's running regional
17 response centers.

18 The implementation and maintenance of that
19 contract is part of the strategies they're doing, to
20 allow them to maintain and restore the functions. So
21 it's -- we haven't gone and defined what guidance and
22 strategies means. It's gotten a certain cachet to it
23 as a term of art that's been used since 2002, when the
24 Order EA-02-026 was issued with Section (b) (5) (B) for
25 that set of mitigating strategies.

1 MR. REED: But we'd be supporting detailed
2 procedures on the use of this, and that proceduralized
3 and it should be. But yeah, the strategies are
4 obviously more.

5 MR. BOWMAN: And so in large part, we
6 can't really define exactly what the strategies are
7 going to be, because the initial conditions for the
8 entrance into the use of the guidance and strategies
9 aren't entirely well defined. Something has happened,
10 and some of your other structures, systems and
11 components will either survive whatever happened or
12 they won't.

13 So these guidance and strategies give the
14 licensees tools, if you will, and a tool box to choose
15 from, similar to what goes on with the severe accident
16 management guidelines.

17 MR. REED: Let's see. So similar to the
18 rare -- be required to be adapted in all modes, and
19 maybe we'll say something. We got an interesting
20 comment on those, and simply suggested that maybe we
21 should say when irradiated fuels in the reactor vessel
22 are in the spent fuel pool.

23 I kind of like that. It gets to -- I
24 would like tech specs in this thing, and that's an
25 interesting concept I think we might have to give some

1 consideration to. I like that comment, but that's
2 just me.

3 MR. BOWMAN: I do too.

4 MR. REED: Oh, well that's two. I'm sure
5 we add it up and we need more votes for that. We got
6 some comments, "mitigating strategies must be required
7 to consider contingencies." We got an interesting
8 comment here, and it's a concern here about the backup
9 to the backup to the backup. When you guys going say
10 the end of this thing?

11 So yeah, I don't think we're -- we're not
12 expecting licensees to do something they're not
13 actually doing right now in the order. So I think we
14 need to clarify the word "contingencies."

15 You know, at some point, you know, you've
16 got to stop this. We're talking about extremely
17 remote events. I don't even expect anything like
18 Fukushima to happen in the United States ever. I
19 think this equipment could be used in other less
20 severe events and probably will be used in less severe
21 events.

22 But you know, when you're talking about
23 something this remote, you know, how far do you go and
24 what's needed? So contingencies --

25 MEMBER SKILLMAN: Tim, what is your

1 current vision of contingencies? How far are you
2 thinking it should go?

3 MR. BOWMAN: Yeah, let me address that.
4 Where it is addressed, the contingencies that are
5 existent in the program that's responsive to the Order
6 EA.12-049. All the licensees are required to have a
7 capability to use a portable pump as a means of
8 providing water, either make that for the reactor
9 pressure vessel or reactor coolant system, or the
10 steam generators, depending on the plant design.

11 That is a contingency. For example, if
12 there is some reason why there is no alternate power
13 available because of actual damage to the DC buses and
14 the AC buses, as a result of the initiating event.

15 MR. REED: Actually, I see -- to be honest
16 with you, I see -- you may want to get to this area in
17 a second, but I see us being within the regulatory
18 scope of the order for this rulemaking, because one of
19 the things, as I read through basically the
20 information that supported the blackout rule, the
21 post-blackout rule and the reevaluation of risk in
22 2005, you look at all that information about low
23 station blackout risk.

24 Obviously not external, put the external
25 events to the side for a second. That risk is

1 absolutely very low and going lower because of
2 mitigating strategies. It certainly wouldn't support
3 additional regulatory action, or even expending reg
4 resources.

5 I mean the last step turned it down below
6 to the minus 5 on main core damage frequency basis.
7 So that risk is, we're separating that and I'm saying
8 that's 2.1, and physical protection is NTTF 2.1.
9 That's out there, and that needs to be done, you know.
10 That's the real, in my opinion, the real lesson
11 learned.

12 But in terms of the scope, I would
13 probably be very closely inside the umbrella of the
14 order, with lessons learned and feedback and fixing
15 what doesn't work or what's impractical and what needs
16 to be changed from the order, and perhaps with
17 additional flexibility.

18 So that's kind of a -- right now, that's
19 kind of my overriding current thought on where we
20 would be going, in terms of trying to meet our backfit
21 reg analysis processes, you know. I don't think we
22 can go beyond the order right now and see there's any
23 justification for it.

24 So that's kind of a general answer you're
25 going to get on a lot of these things. But in terms

1 of what is imposed, it's already in places. Those
2 were in the side that said a backfit on current
3 licensees if I stay within that. Once I go beyond it,
4 it gets very tough. I don't see that I can satisfy
5 these processes and go beyond that.

6 MEMBER SKILLMAN: Well, you know, I can
7 understand coolant, core, protecting containment and
8 protecting the fuel in the spent fuel pool. But there
9 are a couple of other things that come quickly to
10 mind. You don't want to dump your waste gas decay
11 tanks inadvertently.

12 You need at least 1/100th of a light bulb
13 in your control room. You've got to be able to see,
14 and you probably need to ventilate it. So there are
15 a couple of other functions that are essential in
16 order to accommodate that first box. There's not
17 particularly complicated. Designers know very well
18 they have to do it.

19 But I think as we look at this, we ought
20 to be careful that we're not short-sighted, and to the
21 discussion we had on this issue of "extends
22 indefinitely," of a proponent of maintaining that
23 phrase, because kind of sets of lifeboat standard.
24 That says "hey, you're in trouble. You've got to be
25 able to do something here."

1 There are a lot of clever ways to respond
2 to that, but at least it sets the concept that kind of
3 gets everybody's attention. So and there's room in
4 that for a performance-type response, but stating that
5 the way you've stated it, at least in my mind, in a
6 minimum of words, communicates the problem.

7 MR. REED: We could do that in a real
8 language level, maybe -- and we could do it in
9 supporting considerations that provides the meaning
10 and intent of the rule language. There's others.
11 There are ways of doing that, try to make everybody
12 happy. I don't know how that would work, but --

13 MEMBER SKILLMAN: I was going to draw on
14 this idea of contingencies and I agree with you. How
15 far do you go? Well, not too much further. But let's
16 make sure that as far as we go, it encompasses the
17 things that the operators of the plant really have to
18 attend to. That's cooling the core, cooling the fuel
19 in the spent fuel pool, probably protecting some
20 portion of the radionuclide inventory, where it might
21 be.

22 Whether it's in waste and gas containment
23 tanks or it's your sluicing devices that you do not
24 want to inadvertently dump to the floor or those types
25 of things. There's a minimum lighting and some

1 minimum ventilation are essential, in order to safety
2 operate the unit.

3 MR. BOWMAN: Oh yeah, and this is Eric
4 Bowman again. We do have, I believe, all of those
5 items are covered at the guidance level as being
6 supportive systems that are necessary to continue with
7 the maintenance and restoration of the overarching
8 safety functions, core cooling, spent fuel pool
9 cooling and containment.

10 To make it more performance-based, we were
11 looking to the amount of lumens as opposed to the
12 wattage of the lighting, because we have seen a lot of
13 licensees that are shifting to LED lighting in order
14 to preserve their batteries.

15 MR. REED: The lighting's key, HVAC can be
16 key. There's lot of support equipment that actually
17 is key.

18 MEMBER SKILLMAN: Thank you.

19 MR. REED: Working down through this
20 slide, of course, as mentioned earlier, the mitigating
21 strategies will be, in fact are being integrated into
22 the existing emergency operating procedures station
23 blackout, for a station blackout. That is, that's
24 occurring.

25 As we mentioned earlier about, you know,

1 the response not obtained stage; you know, you can't
2 recover offsite power, AC power. You can't recover
3 onsite AC power. You're going to the beginning
4 strategies where you don't, can't recover your
5 alternate AC power source, then you go into these
6 strategies.

7 So they work, they do link in there, and
8 there's difficult decisions that have to be made by
9 people in the control room about when you have to go
10 the mitigating strategies, and you've probably got to
11 do some of that when it makes sense to do it. They're
12 not all different, as Eric mentioned. Some of these
13 are exactly the same. So that's good, there's an
14 overlap.

15 But for these kinds of severe events, I'm
16 not sure it's completely impossible to make some of
17 these decisions earlier, because if it's a true severe
18 event, and it gets us into what we're talking about
19 here. I think you'll see the grid destroyed pretty
20 substantially.

21 If the grid's not destroyed substantially,
22 that's the best source of AC power you want to
23 generally get back. So there should be hopefully
24 early on, in one of these situations, we've got a
25 pretty good feel of when you're going to get that

1 power back, and that could, I think, hopefully perform
2 all the actions that you take now.

3 But that innovation is a challenge, and
4 trying to make that as smooth is possible is part of
5 the implementation of the strategies into the EOPs.

6 MEMBER-AT-LARGE RAY: I don't think you
7 mean the grid destroyed. You mean the connection to
8 the grid.

9 MR. REED: Yeah. Yeah, probably. Yeah,
10 hopefully the grid's not destroyed, but yes. Yes sir.
11 If the grid's destroyed, we're really in trouble. So
12 let's see, of course the strategies would have to
13 culminate and be able to use offsite assistance from
14 the regional support centers.

15 There's two of those going in place, and
16 that make affect, you know, the success. We'll have
17 to see what we're getting in this thing, and also
18 there's a lot of feedback from the order and how we
19 actually terminate or end is going to cause success to
20 the end of the strategy.

21 Then this framework, this new set of
22 strategies themselves, making any strategies fit
23 inside this other rulemaking that we talked about
24 earlier, that's the NTTF Recommendation 8 rulemaking,
25 which is trying to integrate all this stuff. It's

1 trying to integrate the emergency operating
2 procedures, the severe accident management guidelines,
3 the extensive damage mitigation guidelines, and now
4 this new set of mitigation strategies into one --

5 Well, I shouldn't say one, but a set of
6 guidance, strategies and procedures, such that there's
7 clean transitions, there's command and control, that
8 maybe when you exercise and train, you're doing the
9 entire set. You're working through that. That's that
10 recommendation I know they bridge to at least once or
11 maybe more. So I was there for one of them.

12 We would try to use that rulemaking to the
13 extent possible, and not have redundant or
14 overlapping, you know, requirements if possible. Now
15 if that one doesn't survive, then if that doesn't
16 link, for example, back to the reg analysis, then I
17 would probably, I would have those requirements in my
18 mitigation strategies rulemaking. So and work with
19 those folks and what that should be for the mitigating
20 strategies.

21 So that's all I had to say on that slide.
22 Any questions or comments?

23 (No response.)

24 MR. REED: On the design requirements
25 slide, this is another interesting area where I got

1 some feedback from some of the designers. We have, at
2 least I did, I have kind of a mindset that they
3 install the equipment that's relied on first, in
4 current licensees, is safety-related stuff. So it
5 goes without saying that stuff needs the special
6 requirements of design for safety-related, typically
7 Class 1, 2 and 3 safety-related equipment. It's going
8 to be very robust.

9 So I don't see that I have to do a lot for
10 that. But a new reactor designer should have a little
11 more freedom. So that's, we should be talking about
12 any equipment-installed work order should be
13 reasonably protected, should be able to perform the
14 functions as needed in these situations. It doesn't
15 have to be safety-related, as long as it's reasonably
16 protected and performing functions needed for these
17 situations.

18 So we've got some of that, some of the
19 feedback on that so far on the design requirements.
20 So I think again, you know, this kind of goes back to
21 this idea in the definition, where we're possibly
22 getting a little bit too detailed in some of these
23 areas. We've got to be careful and set up at a high
24 enough performance from this base level, and perhaps
25 even on the design, it might make sense that this

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 stuff really resides in guidance, and not be up at the
2 rule level.

3 We stay at a very performance-based level
4 of the rule, and keep the design requirements down out
5 of the rule, to avoid problems. Or a new reactor
6 would have to come in and then come up with an
7 exemption, and that would create unnecessary burdens.

8 So this was a set of ideas that we put out
9 there, draft concepts that were -- and we got some
10 feedback. They're pretty straightforward. Of course,
11 it's got to perform the functions you need. It's got
12 to be protected. It hopefully can be independent from
13 the installed stuff to some level.

14 The equipment itself, the N plus 1 sets of
15 this equipment needs to be designed, stored and
16 protected. You're trying to minimize that equipment
17 being knocked out by the same event that knocks
18 everything else. So you're trying to avoid common
19 mode and common cause failures, that has the
20 protection from the effects of these events.

21 Then when you design in-state and deploy,
22 you want to of course do that in such a manner that it
23 doesn't destroy the equipment that it's being hooked
24 into. You're going to have to rely to some level on
25 I'll call it a process path and an electrical path.

1 So that's, you know, distribution systems you want,
2 and you want to make sure that that works too. So
3 that's just basic engineering.

4 CHAIRMAN ARMIJO: I have a question. If
5 a licensee complies with the orders that were issued
6 as a result of Fukushima, what other things are on
7 this list that he isn't already going to do?

8 MR. REED: Does he cover it is what you're
9 asking?

10 CHAIRMAN ARMIJO: Yeah. I'm just saying,
11 isn't this what we're already doing?

12 MR. REED: I believe, I am not --

13 CHAIRMAN ARMIJO: We already want them to
14 do it.

15 MR. REED: Yeah. I believe almost
16 everything. I'm a little bit, I'm a little hesitant
17 on the testing and inspection assurance level. But I
18 believe they would be, but I'm not -- what I'm trying
19 to do is write language mostly for a new reactor.

20 CHAIRMAN ARMIJO: Yeah, I understand, I
21 understand.

22 MR. REED: And that's why I keep saying
23 I'm probably too restrictive. But I would -- probably
24 this goes back to a comment I made earlier. If you're
25 in compliance with this order, I don't think I'm going

1 to be imposing right now, based on everything I know,
2 anything additional. So you should be in compliance
3 with the rule, hopefully. Now on the --

4 (Simultaneous speaking.)

5 MR. REED: We do have a change control
6 requirement that's not in the order; it's in the
7 guidance. So there's some differences here, but I
8 don't think they end up being too substantial at all.
9 At the present time, I see that that's where we'd go,
10 at 50,000 feet. That can change. I mean --

11 MEMBER SHACK: Well, the flexibility you
12 allow for the supplemental source is different from
13 the order.

14 MR. REED: That's the thing. That's one
15 thing. Flexibility, that's a voluntary flexibility,
16 and that hopefully gets people away from relying on
17 humans as much, and that's a good thing, I think. I
18 think it's better way.

19 MEMBER SHACK: So we had some discussion
20 at the Subcommittee that, you know, you've built one
21 more Maginot Line, you know. The Guderian comes with
22 the Panzers through the Ardennes somewhere --

23 CHAIRMAN ARMIJO: Flexibility is good.

24 MR. REED: Flexibility is good.

25 CHAIRMAN ARMIJO: When you don't know

1 what's going to happen.

2 MR. REED: Yeah, it is. I think relying
3 on humans in these kinds of events is not a good thing
4 too. So there's two edges to that sword.

5 CHAIRMAN ARMIJO: That's all we've got.
6 That's what we are.

7 MR. REED: That's a very interesting,
8 because you really haven't considered the feasibility
9 and reliability of the manual actions associated with
10 the mitigating order very much.

11 MEMBER SHACK: That's right.

12 MR. REED: You know, there's certainly
13 something to be said for installed equipment that
14 doesn't require any manual actions, or certainly less
15 reliance, less reliance on them.

16 MEMBER SHACK: Yeah, yeah.

17 MR. REED: Absolutely. That's the main
18 thing. To me, that's one thing I sort of see, you
19 know, in the rule, is there really ought to be more
20 emphasis on the feasibility and reliability of the
21 actions that are -- the guidance has very little at
22 the moment, either the ISG or the 1206, and that seems
23 to me somehow that slipped through and we didn't
24 comment on it at the time.

25 VICE CHAIRMAN STETKAR: Tim, we tend to

1 all be engineers and like to think about designing
2 things, pumps and pipes and valves and electrical
3 buses and all that kind of stuff. One of the problems
4 with the existing station blackout rule and everything
5 that we've discussed is that implicitly, all of those
6 things had presumptions about what would go wrong, how
7 it would go wrong, how long that condition would last,
8 and how you could get out of it, and we're discovering
9 that some of those presumptions perhaps should have
10 been challenged.

11 When we start to talk about design
12 requirements and options and strategies and things
13 like that, is there an inherent presumption that the
14 things that you plug into inside the nuclear power
15 plant, called switch gear for example, are by
16 definition not affected by this event?

17 Because if I had to develop a strategy for
18 that contingency, I might think of a couple of
19 different options. The reason I bring it up is that
20 emergency diesel generators and piping, for example,
21 tend to be, from a seismic perspective anyway, rather
22 robust pieces of equipment.

23 In fact, if you look at seismic risk
24 studies that have been done, typically the fragilities
25 of electrical switch gear, control signal cabinets,

1 depending on their mountings and locations in the
2 building, tend to -- they tend to have lower
3 capacities. Still well above the safe shutdown
4 earthquake, but lower capacities than the generators
5 themselves.

6 And therefore, if the presumption is that
7 we're just going to bring in another power supply and
8 plug it into something that by definition is there,
9 that might not exist. So I guess my question is when
10 we're starting to talk about, you know, design details
11 and options, at least at the rulemaking level, is
12 there some inherent presumption that it's there?

13 Because just because the electrical buses
14 are down, my point is that the ways of getting water
15 to the core through piping systems are, might very
16 well be intact. So I don't know. When I start to
17 read some of these, a little bit more details here on
18 some of your slides.

19 MR. REED: On one side of me, you know, I
20 don't like saying beyond design basis, okay. I don't
21 like as a regulator, because I can't -- I don't know
22 what that means in terms of what I'm putting out
23 there. If I was a licensee, I wouldn't know how to
24 comply with that. If I was an engineer, I don't know
25 how to design for that.

1 So but you need to have some definition
2 starting with what are we talking about. What are the
3 requirements, what I need to comply with, what I need
4 to design to. Now as a practical reality, we do that.
5 But then clearly, that's not necessarily going to be,
6 win the day.

7 So that's the other side of this thing,
8 and that's where you're going. You go in place and
9 you do, some of the safety-related set of equipment is
10 going to be robust and available. In fact, it may not
11 be. So that comes back to while there should be some
12 contingencies --

13 MR. BOWMAN: That's a contingency we
14 discuss with the -- and it's not just bring the
15 portable pump over. But it's also the manual start
16 for the emergency core cooling systems like reactor
17 core, isolation cooling or turbine-driven AFW. So
18 it's addressed to a certain extent there. We don't --
19 we aren't looking as far as your turbine-driven AFW
20 pump will not work.

21 MR. REED: I think that's a melt, it
22 doesn't work, for example.

23 MR. BOWMAN: That might be a residual
24 risk.

25 MR. REED: Yeah. There's some I don't

1 think you're going to be successful. That's why I've
2 been saying, you know.

3 VICE CHAIRMAN STETKAR: No. I'm just
4 saying -- the only reason I brought it up is that
5 because this is called extended loss of AC power, we
6 tend to start thinking about electrical things and
7 strategies that tend to get electricity back to places
8 where we can then distribute it to the rest of the
9 plant.

10 As long as you keep focused at fundamental
11 functions of core decay heat removal, however you can
12 accomplish that, and make sure you have strategies in
13 place to do that, whether it's, you know, hose
14 connections to a piping system and making sure you
15 have a diesel-driven pump that has enough pressure and
16 flow capacity, for example, as one of your possible
17 strategies.

18 MR. REED: You can hang in there with a
19 turbine-driven pump on the primary side --

20 (Simultaneous speaking.)

21 VICE CHAIRMAN STETKAR: The only reason I
22 bring it up is, you know, we're going to get to the
23 next slide and talk about the super diesel generators,
24 that's supposed to be really excellently good diesel
25 generators. That doesn't necessarily solve, you know,

1 solve all of the problems.

2 MR. REED: I was going to say, if there
3 aren't any more questions, then we can go to the --

4 (Simultaneous speaking.)

5 MEMBER SKILLMAN: To what extent, in your
6 development of the requirements, have you considered
7 lessons learned from blackouts? I know of two. I was
8 involved in one in 1965. I watched New York City go
9 black, and all of Long Island, and then ultimately the
10 East Coast. But I was looking at downtown Manhattan
11 when the lights went out. There was one in what,
12 2007-2008, that started up in the First Energy system
13 and proceeded east and west.

14 In the first one, there were no nukes.
15 Indian Point wasn't there, Oyster Creek wasn't there.
16 There were some early builds up in New England, but
17 nothing really going on. So we've never tested
18 anything like this in real time.

19 Unless there was a test from the one in
20 2006-2007-2008, and a test where the stations were
21 actually built, and a total loss of offsite power. To
22 what extent have lessons from those experiences been
23 factored into this?

24 MR. REED: I haven't considered those
25 lessons at all, to be honest with you. Actually, I

1 was at Turkey Point in 1985 when they had, I think
2 they lost the power to Miami. I was there at that
3 site at that time. I was the aux feedwater system
4 engineer. So all three aux feedwater pumps were
5 electronic, and they went in and reset those.

6 VICE CHAIRMAN STETKAR: Big surprise.

7 (Laughter.)

8 MEMBER SKILLMAN: So we had SOR, we had
9 SOR-99-01, which kind of laid out a number of the
10 lessons learned. But I'm just wondering if there are
11 some lessons that would be valuable here, because you
12 know, if you thought you had offsite support you
13 didn't, at least in the 1965 event.

14 There was no one to call, because they
15 were just as black as you were. There were no lights,
16 there was nothing. I mean the bridges were out,
17 everything was out. Toll gates were up. The whole
18 city just literally came to a halt.

19 I can just imagine that event in 2013 at
20 Indian Point. What do you do? So I have a hunch that
21 there may be some lessons that are useful. I think
22 you probably circled the wagons in terms of providing
23 AC power. But as John was pointing to, there are some
24 other issues out there that have to do with the
25 infrastructure that you might be depending upon.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 If there's no one to call, because the
2 phones aren't working. Well, maybe the cell phone
3 towers would be down because they're not powered, you
4 know, who do you talk to?

5 MEMBER-AT-LARGE RAY: Well but a loss of
6 -- I mean a grid blackout and a station blackout are
7 two very different things. Loss of offsite power is
8 an operational occurrence that --

9 MEMBER SKILLMAN: That happens routinely.

10 MEMBER-AT-LARGE RAY: The plant is
11 designed and tested for. We're talking about
12 something here which causes a station blackout.

13 MEMBER SKILLMAN: I got that.

14 MEMBER-AT-LARGE RAY: A whole different
15 ball game.

16 MEMBER SKILLMAN: And I'm saying that
17 there have been several.

18 MEMBER-AT-LARGE RAY: Station blackouts,
19 extended station blackouts I mean?

20 MEMBER SKILLMAN: No, not extended station
21 blackouts.

22 MEMBER-AT-LARGE RAY: No. That's the
23 issue on the table.

24 VICE CHAIRMAN STETKAR: There's been a few
25 short-term station blackouts.

1 (Simultaneous speaking.)

2 MR. REED: I think Vogtle's the only
3 station blackout, I believe.

4 VICE CHAIRMAN STETKAR: Huh?

5 MR. REED: I believe Vogtle's the only
6 station blackout --

7 VICE CHAIRMAN STETKAR: Susquehanna, I
8 think, had one, you know. That had some common cause.
9 This was years ago. But they've all been short-term.

10 MEMBER SKILLMAN: There's some lessons
11 there that might be valuable at this early stage of
12 rulemaking. That's my only point.

13 MR. REED: Okay. Is there anything else
14 on Slide 7?

15 (No response.)

16 MR. REED: I want to go to the
17 supplemental AC power source. I was, this was
18 actually strongly supported, and in fact South Texas
19 3 and 4 absolutely loves it, and they have, I guess,
20 two gas turbine generators I believe that are above
21 the 50-foot level, I believe. So they have, and
22 either one can supply Units 3 and 4. So they like
23 this a lot, and they think they're very robust and
24 they would be there.

25 So and other designers like this too. I

1 think there's some flexibility to use something like
2 this. I think the current, you're making a very good
3 point, and this is something that I personally --

4 VICE CHAIRMAN STETKAR: I was going to
5 say. Those gas turbines still plug into the same
6 place.

7 MR. REED: Yeah, I know, and the diesel
8 generators themselves are really robust, you know.

9 VICE CHAIRMAN STETKAR: They are.

10 MR. REED: And I just don't know how much
11 better you can do as far as equipment and diesel
12 generators. They're trains essentially. So it's
13 almost, you know, but you could take --

14 VICE CHAIRMAN STETKAR: Now they don't do
15 so good in flooding, for example, if you have a
16 flooding --

17 MR. REED: Yeah. Clearly that's a --

18 VICE CHAIRMAN STETKAR: --and things like
19 that, speaking not particularly for seismic.

20 MR. REED: This doesn't rule taking
21 something that you already have on site and making it
22 a little bit better, first of all. This is flexible
23 enough to use an existing thing, not adding another
24 Maginot Line, you know, for example. But the idea --

25 VICE CHAIRMAN STETKAR: --was the current

1 one.

2 MR. REED: Yeah. Using the current
3 Maginot Line and just moving it, I guess. But that
4 was, this was the idea to allow this. You know, there
5 was obviously not a lot in the order, and it changed
6 the entire complexion of the mitigation strategy. So
7 like I said, we got strong support from designers, and
8 that to me is interesting.

9 So they see it as an opportunity maybe to
10 do more engineered installed type approaches. I
11 personally think that's the best place. I think
12 that's the best place to be in terms of safety.

13 MEMBER CORRADINI: This would be in
14 addition to diesel generators?

15 MR. REED: You could use -- you could.
16 I'm not ruling out your current diesel generators and
17 doing something more. Presumably, your current diesel
18 generators probably are aligned to one safety bus.
19 You may not have as much cross-connection, maybe not
20 diverse ways of connecting.

21 MEMBER BLEY: Plus they're isolated.
22 (Simultaneous speaking.)

23 MR. REED: Sometimes they're not too
24 separated, you know.

25 MEMBER BLEY: The older plants weren't.

1 In the newer are really separated.

2 MR. REED: I think you could so some
3 things, and it may be as a practical matter, for a
4 current licensee. But this may be mostly for new
5 reactor, new design. You're not talking about huge
6 amounts of cost to try to do something like this.

7 I'm trying to allow for, you know, an
8 approach that would be less reliant on a lot of people
9 running around with supplemental portable equipment.

10 MEMBER CORRADINI: But this is, just a
11 clarification again, since I wasn't in the
12 Subcommittee. This is not, to get back to Sam's
13 point, I'm trying to draw an umbrella around this.
14 This is not part of the current order. This is
15 something over and above.

16 MR. REED: This is an idea that definitely
17 is not in the order. It's a flexibility that the
18 rulemaking group, working group thought let's throw it
19 out there and get feedback on it. I've said to
20 people, I've said in a Category 3 public meeting, we
21 may not, you may not see this in a proposed rule
22 because obviously management at a higher level,
23 including the Commission hasn't, certainly to date,
24 hasn't agreed with this. So we had different views on
25 --

1 MEMBER CORRADINI: This again is the rule
2 might be too much detail at, you know, what specific
3 implementation -- but I guess where my question was
4 coming from was it sounds good, but what's the
5 probability of failure of this compared to everything
6 else I'm worried about?

7 If I have such an extreme event that's
8 going to knock out everything else, it strikes me that
9 this thing's going to be toast, just like everything
10 else would be toast.

11 MS. McKENNA: Well, I think that one of
12 the key points of this really was in the flooding
13 scenario, but that's where if you protected some
14 source for a different flood level, it might have a
15 better chance of survival than so much for seismic
16 conditions. I think that really was the driver for
17 this.

18 CHAIRMAN ARMIJO: Right. I mean so is
19 this a different machine? Is it gas turbine as
20 opposed to diesel, or is it a location issue?

21 MS. McKENNA: I think that it's more
22 probably a location. The second bullet does talk
23 about diverse, but it doesn't have to be diesel versus
24 a gas turbine to be diverse or, you know.

25 CHAIRMAN ARMIJO: Yeah, sure.

1 MR. REED: But if you have a particular
2 hazard, such that for that location, having a diverse
3 machine, it's pretty likely that this one will make it
4 for this event, this one will make it for this other
5 one. That's a good thing, but it may not be for every
6 site and situation.

7 CHAIRMAN ARMIJO: But we found from
8 Fukushima that the air-cooled diesel that didn't get
9 flooded saved Units 5 and 6. Is that what we're
10 talking about here, something like that, in a
11 favorable location, protected against flooding?

12 MR. REED: Air coolant is another great
13 thing is to have the supporting system of cooling,
14 yeah. So yeah, probably with its own supply of fuel
15 bunkered.

16 CHAIRMAN ARMIJO: Of course, the Japanese
17 are now putting everything under the sun on their
18 plants, gas turbines, every piece of equipment they
19 can buy, they're using it. I'm not sure they all work.

20 MR. REED: It's interesting, because we
21 come back to -- if the event takes off the diesel
22 generators --

23 MEMBER CORRADINI: I mean all sorts of
24 questions pop in my head, which is how close it is to
25 the plant, how big is it, right? What is the danger

1 from having all this natural gas piping nearby for
2 another accident that I can imagine? I mean there's
3 a plethora of things that pop in my head that make
4 this not necessarily as good as it sounds at first
5 blush.

6 MR. REED: No, that's exactly -- that's
7 why I want to hear it, that kind of feedback.

8 MEMBER CORRADINI: Yeah.

9 MR. REED: I'm not sure either.

10 MEMBER CORRADINI: That's fine. I just
11 want to understand. So it's not, I just want to put
12 it in context with what Sam was asking. That's fine.

13 MR. REED: But we offer the flexibility I
14 think you allow a designer, they may in fact build,
15 come away with a way to skin the cat that's a lot
16 better than the mitigated strategies. So I'm not
17 convinced that I know the right answer.

18 But if somebody, a new reactor designer
19 comes in and says here's what I got, we can look and
20 go whoa, that is really good. And so until I see it,
21 I don't know. So that's the ideas put out there with
22 that idea. And you see the concepts that we put out
23 there in -- it tends to be kind of the strongest link
24 in the chain, if you will, but not unnecessarily
25 strong if the entire facility's destroyed.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 This also comes back to another thing
2 that, you know, I think I said in the Subcommittee,
3 and people ought to keep in mind. If your plant's not
4 physically protected properly, 25 extra feet of water
5 comes across the facility, it doesn't matter. It
6 really doesn't matter.

7 You know, you've got to physically protect
8 the plant to some level properly, and frankly
9 Fukushima was not, you know. So I think if you do
10 that, then this stuff probably will be pretty useful
11 for a lot of events, and you won't get a lot of stuff
12 destroyed.

13 But then it might a whole lot of extra
14 equipment. So but yeah. So they work together, and
15 in fact that's kind of the way we're going, you know.
16 We're adding 2.1 to the physical protection, and we're
17 doing many strategies, and you don't see me
18 suggesting, for example, additional physical margin
19 and mitigation strategies, because I'm saying that
20 should be over in 2.1.

21 That's where you should do that. That's
22 really GDC-2, you know, so -- and that's what that
23 effort's all about.

24 MEMBER SCHULTZ: Tim?

25 MR. REED: Yes sir.

1 MEMBER SCHULTZ: I just heard you say that
2 this is an alternative to mitigating strategies, and
3 it's a bit confusing, because I thought this was a way
4 in which to meet the elements of mitigating
5 strategies, except when you get down to the point
6 where you mitigating strategies says then you need to
7 rely upon offsite resources as well.

8 I can see a licensee for a new reactor
9 saying "I don't need anybody else. I can install
10 something like this. So I don't think I need that."
11 That would be way out in terms of the likelihood.

12 MR. REED: I think a new reactor designer
13 would in fact try to go that, all the way to that
14 point. In other words, I'm going to put in an
15 engineering approach, and I don't need anything at
16 all. But I would say really? You don't anything?

17 MEMBER SCHULTZ: And discussion would
18 ensue, you're right.

19 MR. REED: Yeah. I can't personally not
20 see of a design that wouldn't need at least a final
21 phase.

22 VICE CHAIRMAN STETKAR: Yeah. I was going
23 to say, we talked about this a little bit, and I think
24 in my notes from the Subcommittee meeting is you
25 characterized this as an alternative to what you call

1 the Phase 2 response.

2 MEMBER SCHULTZ: Yeah. That's why I
3 wanted to clarify it here.

4 VICE CHAIRMAN STETKAR: But it wouldn't
5 necessarily obviate the need for a longer term Phase
6 3, you know, supply fuel or whatever.

7 MR. REED: Yeah, I figure you would
8 probably be in Phase 3. But you might be able to get
9 a lot of the others, you might be able to get most of
10 the rest of it out and basically you're into Phase 3,
11 potentially. I'm not going to say you can't.

12 MEMBER SCHULTZ: I believe that's what you
13 need to do, in order to integrate this option as part
14 of the overall rulemaking strategy.

15 MR. REED: Yes. We have to -- I agree
16 with you, and if we don't do that, I don't think it
17 will be a success.

18 MEMBER SCHULTZ: I agree. Thank you.

19 MR. REED: And like I said, we really, we
20 threw all our concepts out there for this reason. We
21 don't, the stuff may not survive it. But that's the
22 whole idea, is we go out with regulatory basis, that's
23 an opportunity to get a lot of good thoughts from
24 folks, and you can get a lot better rule language that
25 way. So that was the whole spirit here.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So are there other comments on the
2 supplemental AC power source slide?

3 (No response.)

4 MR. REED: Okay. I've got until ten
5 o'clock, don't I? So I'm trying to adjust myself to
6 make it. I'm watching my -- we've done a couple of
7 slides in ten minutes.

8 So at the Subcommittee, we had change
9 control and linkage slides, I combined them together.
10 Change control is something when you're in this realm
11 when you're not in the safety or design basis world,
12 50.59 doesn't work. I'm sure you've talked about
13 Recommendation 1, especially treatments of change
14 control.

15 If you're going to do something in this
16 realm, you've got to pretty much put it in there, put
17 it in this regulation so that whatever treatments you
18 want, whatever control you want on configuration, it's
19 got to be in there.

20 So that's the idea in change control.
21 Certainly, this is important stuff. It was mitigating
22 strategies order. We need to maintain the
23 configuration over time. That's the idea.

24 So we have to have some sort of control.
25 This is a very high level control, change control

1 thing. It's not, nothing real sophisticated. I don't
2 have any criteria like 50.59. I'm not sure we could
3 even do that. We had one suggestion, not too
4 surprising at all, that they suggested that hey, why
5 don't you follow along the 50.54(p), 50.54(q)
6 reduction of effectiveness kind of change control,
7 which is something I also thought about.

8 So that's the one feedback we had in this
9 area. Most of the people here are pretty familiar
10 with 50.59. I'm an old 50.59 person. But so that's
11 really the idea here, that there should be at least
12 some nominal change control requirement, and clearly
13 you want to maintain compliance with your regulations
14 obviously, and your guidance and your commitments and
15 everything else.

16 So certainly that would be as part of it,
17 but I think at some point if you wanted to make
18 changes to what the staff has already looked at and
19 reviewed, then I think we need to see that. If it
20 gets outside the envelope of, you know, what's being
21 done for the current licensees under the mitigating
22 strategies order, we have obviously inspections
23 involved.

24 So that will provide a licensing
25 framework, if you will. If you're outside that, maybe

1 that's where we look at change control. But that's
2 speaking at real time right now. So that's change
3 control.

4 Linkage to 50.63. Got some interesting
5 comments here, also with the overall integrated type
6 of rulemaking. The comments here were not too
7 surprising. While I think the industry supports
8 having a link, a nominal link obviously, these are
9 being implemented at a symptom-based EOP level.

10 But having a link; anything more than that
11 can probably create unintended impacts. Licensees
12 know what it means to comply with 50.63 and supporting
13 guidance. So from a licensee standpoint, they know
14 what that means. And when you start to link
15 regulations, link to the new set between, to a
16 separate set, you've got to be careful that we're not
17 causing impacts.

18 So the first thing we were thinking of is
19 well we probably would want to keep 50.63 as a
20 separate entity, so I don't have thousands of
21 procedures, programs, topical, reports, NUREGs,
22 everything over the last 20 plus years that all refer
23 to 50.63 becoming something, or not labeled correctly
24 and need pointers and everything else.

25 You don't want to do that obviously, but

1 this idea here was pretty simple. It was recognizing
2 these do link together, and this is a concept that
3 perhaps a lot of people that are involved with the
4 nuts and bolts just don't realize, that they think
5 mitigating strategies is one thing; station blackouts
6 is another.

7 What's mitigating strategies for a ELAP
8 condition was really a bad SBO, and so guess what?
9 They link together, right into the same procedure, the
10 EOP. So a lot of them was simply to recognize that in
11 the regulations, almost for a clarity standpoint. But
12 so --

13 MEMBER BLEY: So if you think more in the
14 long term, rather than in the first year or so, does
15 it really make sense to keep them separate?

16 MR. REED: This is an interesting idea.
17 Like if you're a new reactor designer, okay, long-
18 term, you could come in with one set, make any
19 strategies, address everything. One shot. Beyond
20 design external events, if you want to call it that,
21 exposure to fires, normal blackouts. One set of
22 equipment, one set of strategies, one rule.

23 I think I can see that happening, so for
24 you could have a new, a new like I'm not sure where
25 we'd put this thing, Part 52 or somewhere. But a new

1 reactor, they could do it in fell swoop, and that
2 would probably be great for a new reactor type of
3 situation. That would be horrible for a current
4 licensee. We'd have to go through and figure out what
5 did I just, what happened? How do I need all this?
6 What do I have to change?

7 So if we do it, I think we'd have to
8 totally separate and have a new integrated set of
9 requirements for new reactors looking forward. I
10 think you could that. In fact that -- if I was to
11 start all over and we didn't have anything in place,
12 that would be exactly what we would have.

13 We'd have one set of mitigating strategies
14 that would do basically everything. Whether it's an
15 explosion or fire, whether it's external event,
16 whether it's a normal blackout, it would handle them
17 all. In fact, they probably will.

18 VICE CHAIRMAN STETKAR: So I guess what I
19 was thinking is I don't know how much chaos is here
20 for existing plants, but we'll be needing 50.63.
21 We'll have some new requirements that are probably
22 much more heavily overlapped than even you said. I
23 mean you're dealing with the same thing, just longer
24 term. You're extending your ability to deal with it.

25 Having a completely separate set, five-ten

1 years from now, the administrative burden of tracking
2 those notable things might more than overwhelm, you
3 know, than biting the bullet and addressing it all at
4 one time. I don't know if anybody's thought hard
5 about that. I'm sure the industry reaction at first
6 is don't touch this, because we know what we're doing.

7 But I don't know if people, and we'll hear
8 from them some time in the future probably.

9 MR. REED: It could happen.

10 VICE CHAIRMAN STETKAR: I don't know if
11 they think, you know, what about five years from now?
12 Are we really buying a lot of overhead by having two
13 separate -- that was one of the questions that went
14 out to the public comments, wasn't it? What kind of
15 feedback did we get?

16 MR. REED: And you know, a current
17 licensee I think could come in and say you know what?
18 I can meet 50.63, 50.54(hh)(2) and 50.XXX with one set
19 of stuff.

20 (Simultaneous speaking.)

21 MR. REED: He's a numerologist. But with
22 one set of stuff. We'd be fine with that, and they
23 could still have three separate requirements, and one
24 set that's accepted as a Mod 3. But it would be nice
25 to have it in one spot, but if I do that, I think I do

1 create a lot of paper impact, if nothing else.

2 MEMBER CORRADINI: I didn't hear that
3 conclusion. So you agree with the fact that one could
4 satisfy all three with one set of --

5 MR. REED: No doubt, yeah.

6 MEMBER CORRADINI: Okay. But then your
7 thinking is that still you would maintain three
8 separate recording logs?

9 MR. REED: Three separate requirements, so
10 that those who don't want to do that are not adversely
11 impacted or intentionally through changing all the
12 programs, procedures and everything else.

13 MEMBER CORRADINI: Good God. I'm sorry
14 that is not --

15 (Simultaneous speaking.)

16 MEMBER CORRADINI: That's my immediate
17 reaction.

18 MR. REED: That's a rulemaker trying to
19 minimize impact to -- Shana, go ahead.

20 MS. HELTON: Hey Tim, this is Shana
21 Helton, and correct me, Tim, if I've got it wrong, but
22 as we move into the proposed rule stage and we do a
23 full-fledged regulatory analysis, these are the kind
24 of considerations that we take into effect, or take
25 into account.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 As Tim alluded, you know, there's
2 Paperwork Reduction Act, burden requirements. So
3 we'll look at the public feedback that we get, you
4 know. I think it's a very good question, a very good
5 comment, and I appreciate the feedback from the
6 Committee. But I think, you know, we haven't yet done
7 the regulatory analysis, and that will really shed the
8 light on kind of what the radiance is from a cost-
9 benefit standpoint.

10 MEMBER BLEY: I have a related question.
11 If you defined ELAP in the more general simpler terms,
12 like Mr. Stetkar suggested, one could envision a
13 fairly simple rule, but with guidance and detail of
14 how you meet that rule, that would kind of replace all
15 of it.

16 MR. REED: I actually can see this thing
17 going that way eventually. When we go through all the
18 gnashing of the teeth and everything, when all is said
19 and done --

20 MEMBER BLEY: Here's the guidance. You do
21 what you were doing and you're good on what was 50.63.

22 MR. REED: Yeah.

23 MEMBER SHACK: But I'm not sure what the
24 advantage is.

25 MEMBER BLEY: I'm not either.

1 (Simultaneous speaking.)

2 MEMBER SHACK: You know, that kind of
3 guidance and stuff, it's a matter of comfort and fear.

4 MEMBER BLEY: I look at it as a three-
5 tiered rule. The 50.63 takes care of sort of the most
6 common kinds of station blackout situations.

7 MR. REED: The short term.

8 MEMBER BLEY: And people are sort of used
9 to that. High up, this is on maintaining reliability
10 of the AC systems, because you really don't want to
11 have to go to a mitigating system. I look at the
12 mitigating systems order is the next level of things.
13 Lots of stuff has gone wrong. I've got to recover.

14 Then, you know, it's 50.54(hh), you know,
15 everything shot to pieces, you know, the one last shot
16 at it. So I to me see there's three regimes here that
17 are covered, and I think it's worthwhile keeping them
18 separate, and linking them as they go from one to the
19 other.

20 Trying to put them all in one rule, where
21 you really have different expectations. I mean my
22 expectations when I've got lots of damage are
23 different than I do when I'm in my sort of normal
24 operating condition, and I've lost power.

25 MR. REED: Yeah. Sometimes if I roll them

1 up to one high level thing, I can inadvertently impose
2 impact for what you're saying, where somebody says
3 "Wait a second. I don't need to do that for this,"
4 you know. I'm like I can't figure out what are the
5 permutations here.

6 MEMBER BLEY: So I'm not at all sure of
7 that. I have to think a lot more about it, to make
8 sure it doesn't --

9 (Simultaneous speaking.)

10 MEMBER SHACK: It isn't clear one way
11 perhaps to the other. I personally like the three-
12 tier approach, because sort of that's the way I think
13 of it. But I kind of agree.

14 MEMBER POWERS: I can see that it is an
15 implementation, if I was doing it.

16 MEMBER SHACK: You could do that.

17 MEMBER POWERS: But it seems to me that a
18 rule that says "thou shalt code," until you can get to
19 a state where you don't need the code as a very
20 straightforward rule, and strictly a performance-based
21 rule. Very little in it. Perhaps a lot of guidance,
22 but a very simple rule, and maybe the guy that has to
23 comply has three tiers and all kinds of complexity.
24 But the rule, it seems to me, it's very --

25 (Simultaneous speaking.)

1 MR. REED: Since you're acceptable meeting
2 it that way, a new reactor can meet it a different
3 way, but it's one rule.

4 MEMBER BLEY: And maybe once you really
5 go through it, there will be three regimes of
6 response.

7 MEMBER POWERS: How many regimes there are
8 is how you break things down and think about things.
9 But the simpler the rule, the more you make available
10 engineering expertise that relies on the licensee, and
11 the less you have to rely on the engineering expertise
12 of you on your team. I always like to put the burden
13 on somebody else.

14 MR. REED: That's one side of it. If
15 you're a licensee and you just opened this up, and I'm
16 not sure that you, Mr. NRC, are going to play nicely
17 in the sandbox --

18 MEMBER POWERS: Well, that's for, that's
19 the function of the regulatory guide, to say here's
20 one way to cope with this, and what gets you out
21 future trouble is when a guy comes in with his
22 graphite-moderated sodium-cooled fusion reactor, you
23 don't have to change the rule.

24 MR. REED: Yeah. That's what's great
25 about the performance-based rule, absolutely.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER POWERS: Yeah, that they're
2 technology-neutral.

3 MEMBER CORRADINI: Yeah. Are you in favor
4 of that? I just want to get that on the record.

5 (Laughter.)

6 MEMBER CORRADINI: I just thought, I
7 thought I heard something, but maybe I heard something
8 else. So I just want to get it on the record.

9 MEMBER POWERS: No. I mean my favorite
10 rule of all the rules is the 10 C.F.R. 100.33, that
11 says don't care how you do it; just go ahead when the
12 radionuclides exceed 25 rem site boundary. Don't
13 care. Don't tell me anything about how you did it.
14 Just don't do that, and it's totally technology-
15 neutral, totally --

16 (Simultaneous speaking.)

17 MEMBER SHACK: --condenser on the Mark 1.

18 (Simultaneous speaking.)

19 MEMBER POWERS: I would laugh, except I
20 didn't hear you.

21 MR. REED: Last slide. I think I'm
22 violating the agenda. This is --

23 MEMBER POWERS: The penalties for doing
24 that are relatively minor.

25 CHAIRMAN ARMIJO: They're pretty harsh.

1 MR. REED: This delineates the next steps.
2 Right now, we're considering ten sets, and we'll get
3 another set here in a week or so of comments and
4 revising the reg basis and finalizing that. We have,
5 as Mike mentioned in the very beginning, a requirement
6 to provide a Commission Assistance Note. That's due
7 on July 8th and July 1 to the EDO.

8 So that's my early metric, if you will.
9 So as I say here in that sub-bullet, if the
10 Committee's going to decide to write a letter and put
11 it out, I'd appreciate that sooner than later. That
12 would help inform that MR. CASE: Note. If possible,
13 I'd like to reflect any views if I can.

14 And we will, of course, be proceeding into
15 proposed rulemaking after that. So we'll finalize the
16 reg basis. We'll put it out in an FRN, to show the
17 stakeholders that we've done that, and then we'll move
18 forward into rulemaking, and then go to the proposed
19 rule, which is the next stage is January 2014. Mike?

20 MR. CHEOK: I was just going to add real
21 quickly, if we do not get a formal letter from the
22 Committee, we will obviously also take into account
23 the comments we go today and factor them into our CA
24 Note.

25 MR. REED: Yeah, whatever way. I mean

1 today or any other way, creative way, I definitely
2 want all the comments we can get, because there's a
3 lot of good interaction here today, similar to what
4 some of the external stakeholders, and similar to what
5 the working group has already had. So but a lot of
6 these you can see from more than one side.

7 So we're trying to figure out what the
8 best way is. Anyway, that's the next step. That's
9 all I've got.

10 MEMBER BLEY: I have a question. Once we
11 have this rule, and once people propose their
12 strategies, or lay out their strategies, I'm assuming
13 my strategies include using some of the flex ideas and
14 maybe shipping a generator onto site if I need it,
15 either by truck or heloing the thing in, and Ron
16 Ballinger was pointing out to me earlier that how the
17 military has helicopters with fairly large generators
18 on board with hookups.

19 I don't know if those would be available
20 or if the industry is looking at those. But
21 industry's putting together, as I understand it, and
22 INPO is participating in catalogues of where things
23 are, how they can move them and that sort of thing.

24 But once those strategies are defined in
25 meeting the rule, you guys explore to somebody who's

1 exploring how in fact NRC will somehow follow that
2 planning, to be able to get equipment in and adjudge
3 how reliable that might be for different events on the
4 site.

5 MR. BOWMAN: At the guidance level, what
6 we have set up in NEI 12-06, the document we endorsed
7 for the guidance for the order, which would very
8 likely be carried forward into the rulemaking, one of
9 the requirements for the offsite resources is that it
10 be amenable to inspection by the NRC.

11 Our intent is to treat it similar to how
12 we treat Appendix B suppliers. I've been in
13 discussions with the Vendor Inspection branches in NRO
14 on the way forward for that. So that's the type of
15 oversight we'll be having.

16 MEMBER BLEY: Okay.

17 MR. REED: Any more comments?

18 (No response.)

19 MEMBER SHACK: Thank you very much. Ten
20 slides, right on time. Back to you, Mr. Chairman.

21 CHAIRMAN ARMIJO: Okay. Thank you, Bill.
22 Thank you, Tim. We're going to take a break and we'll
23 reconvene at 10:20.

24 (Whereupon, the above-entitled matter went
25 off the record at 10:05 a.m. and resumed at 10:22

1 a.m.)

2 CHAIRMAN ARMIJO: Okay, we're going to
3 start. Okay, we're back in session, and our next
4 topic is on the revisions of Six Regulatory Guides
5 that Charlie Brown will lead us through.

6 Mr. Brown.

7 Revision of Six Regulatory Guides

8 MEMBER BROWN: Okay, yes. The staff is in
9 the process of doing the Reg Guide updates. These six
10 Reg Guides are on software development processes.
11 They are all interconnected, and as anybody who
12 attended our exciting meeting could testify to, which
13 there were only three of us there, but that's okay.

14 So I'm going to introduce Mike Case real
15 fast here, so he can make an introductory comment, and
16 then they will proceed on with getting you through.
17 We need to make one observation first. These were
18 first issued in 1997. There have been no changes to
19 any of them with one exception in that interim.

20 So that's, it's important to get these
21 particular Reg Guides out, and so that's just to set
22 a little bit of a tone for your thought processes and
23 your discussions. Mr. Case, you can then make your
24 comments.

25 MR. CASE: Thanks. I'm Mike Case, the

1 Director of Engineering and Research. Karl used to
2 work for me. He's now over in NRR. So he's finishing
3 up this assignment for the Office of Research. So we
4 appreciate his ability to stick with us and get these
5 things through.

6 Just a couple of thoughts. This is the sort
7 of an agenda item that is a change of pace from the
8 last one. In last one, we were doing something that
9 was important and urgent, as far as rulemakings can be
10 urgent. This one -- Reg Guide update program, and I
11 just wanted to give you a quick status. There's about
12 554 Reg Guides in NRC's Reg Guide program, and you all
13 have been participating in getting them up to date.
14 We are about two-thirds of the way done. So these are
15 being driven by the Reg Guide Update program.

16 So they're not remarkable changes, but it's
17 getting us in the same -- it doesn't quite get us to
18 the same century, but it gets us in the same general
19 area.

20 MEMBER BROWN: The comments on the Reg
21 Guides are you guys still haven't caught up.

22 MR. CASE: But it gets us a large part of
23 the way there. So I just want to -- it has had the
24 benefit of something that you reviewed. Karl's going
25 to report on how we dealt with some of the comments,

1 and I think it's an important thing, and we're looking
2 forward to a letter that probably summarizes those
3 comments, and hopefully releases us to make them
4 final and get them out. Thank you.

5 MEMBER BROWN: Karl, you're on.

6 MR. STURZEBECKER: This will be my
7 presentation. Is it on here, Christine, or do I put
8 my own --

9 MEMBER BROWN: Christina, how does he find
10 his presentation? A momentary glitch in computer
11 operations.

12 MR. STURZEBECKER: Good morning. My name is
13 Karl Sturzebecher. I'm with NRR right now. As Mike
14 explained, I was with the Office of Research, and I'm
15 going to go through six software reg guides that we've
16 been working on.

17 The purpose of the meeting, I'm going to go
18 through a background of what was the goals, how did we
19 go about this effort, what was the overall results.
20 We've gone through a quick iteration of what, how the
21 Reg Guides and associated standards fit with the
22 software life cycle.

23 I have a layout, a matrix layout that shows
24 the IEEE guides, how many different revs have gone
25 since 1997, when we made the first set of six, and

1 then I'll get into, review six Reg Guides, and I'll
2 step through the Subcommittee's findings, and what
3 we're doing to work on those particular points.

4 I have a slide that's going to demonstrate
5 the color code key and how I'm going to present these
6 six guides, so I can do it in a rather structured and
7 fast way, in showing the topics and how they've
8 changed. I have a conclusion. I'll go through the
9 six Reg Guides using that template, and then I have a
10 conclusion.

11 So the goal for these six Reg Guides that
12 were released in 1997 is basically just to update to
13 the latest IEEE standards. In general, there's no
14 change to the approach used, and we'll look further
15 into that. I show you how there's some refinements
16 that have happened.

17 How did we go about this effort? Well, the
18 guides we first started with, the draft from Oakridge
19 National Labs, and then the NRC picked that up from
20 there with a ten-person team, that consisted of NSIR,
21 NRR, NRO and Research, and they had subteams for each
22 guide, and then we used a stakeholder document process
23 to keep track of the changes as we went through them.

24 As for outside influence, we've been talking
25 to JPL, NASA, EDF, a railroad software test engineer.

1 So we've been getting a flavor of what other
2 industries do, and where we sit in that situation.

3 What was the overall results? Well, the
4 lead -- you're going to see that the lead documents
5 have changed quite a lot. While there's some basic
6 documents in here, there are standards that haven't
7 varied at all. The concept still hold for after 20
8 years. They're still in the same way you do; certain
9 things stays the same, like unit test.

10 And like I've mentioned before, the approach
11 has been refined, and I'll give you an example. Like
12 the first Reg Guide we're going to go through, the
13 1.173, it takes certain topics like software quality
14 management and deletes it, and downplays V&V, because
15 the V&V really sits in the other Reg Guide in 1012.

16 So the idea is that it's becoming more
17 refined and you're going to see that. Reg Guide 1.170
18 through 829, IEEE 829, expands significantly in the
19 number of documents. So there's some differences
20 going on, and then yet some of the guides stayed the
21 same.

22 There are cross-cutting topics. Integrity
23 is a big one that steps between the different
24 standards and also the guides. Security, that's the
25 latest topic that's been going on, and we've addressed

1 that. We'll go through that. Tools and release
2 management delivery, which a lot of the standards have
3 brought that topic in, and I'm going to talk about
4 that.

5 So I will give you a quick run-through, that
6 if you start with the software life cycle, the first
7 Reg Guide, 1.173, is the umbrella. It's what the
8 project architect picks up and starts with, and it's
9 associated with 1074.

10 Now the architect's type or the architect,
11 he's going to start working with planning the
12 activities, and he's going to need to set up
13 requirements, and is going to refer to Reg Guide
14 1.172, which is based IEEE Standard 830.

15 Then when you get into the design
16 activities, and you're setting up this particular life
17 cycle process, you're going to start looking at unit
18 tests and you'll reference this particular guide. The
19 implementation activities is when you take the concept
20 and go into code, and integration is when you take
21 unit testing of certain parts of the code, and you
22 begin to link them and you do branch testing.

23 Eventually, that creates a component, and
24 then you step up the next part, where you go to a
25 system test. Now throughout this entire life cycle,

1 you have your software test documentation, and that's
2 our Reg Guide 1.170, based on 829.

3 This document follows each of the steps
4 going through, while using configuration management,
5 and we get into validation activities or testing and
6 I put that one up, and then here's the two-base Reg
7 Guides like I mentioned, configuration management and
8 the verification/validation processes, Reg. Guide
9 1.168, which is used all the way through the life
10 cycle. Then you have your installation activities and
11 finally operating maintenance activities. That ends
12 it.

13 MEMBER REMPE: So before you leave, you get
14 -- I looked through some of the comments from the
15 public, and there were some concerns expressed about
16 some of these standards that are being referenced by
17 these Reg Guides being out of date.

18 So let's pick on 1.168, and actually there's
19 1012 actually has a 2012 IEEE standard, and the
20 response given back to the member of the public was
21 well, the revised standard actually incorporates other
22 aspects that are not covered by this Reg Guide.

23 What I was wondering is again, we're
24 referring to standards that are, have been superseded.
25 Could a person or could the NRC's process be a little

1 more up to date, by at least say while we looked at
2 this IEEE standard, we're only going to consider that
3 aspect of the 1012-2012 standard, instead of tying
4 ourselves back to the older versions of the standards,
5 and being a little more up to date in the process?

6 MR. STURZEBECKER: That is true. 1012-2012
7 came out this past summer. I was in the process of
8 going public for the public comments at that
9 particular point.

10 Just from a standpoint of how we look at our
11 stakeholders and go through the review process, it's
12 hard to step back and pick up a guide, and then retro
13 everything to follow through, especially in trying to
14 carry off six.

15 We already did that once with 829, the 2008.
16 We were referencing, I'm going to go to the next slide
17 here. For 829, the part that came from Oakridge was
18 using the 1998 version. So my question is when I got
19 the project was well, why aren't we using the 2008?

20 So I stepped that up, because and that's a
21 huge change, because from 1983 to 1998, it was only a
22 format change. From there, the documentation -- 829
23 is almost twice the size. So that was enough labor
24 there, just to get the team to re-orientate and start
25 again on that.

1 So when 1012 comes out, and we had many
2 discussions about this, some heated, about going to
3 that, there is the other aspect is that now you're
4 introducing hardware and systems. So we already
5 systems sufficiently, I believe, with the SIPs the way
6 they're laid out.

7 As for hardware, that's a whole another
8 subject, and you know. But the scope of the project
9 was really just to come up to speed on the standards
10 we have. There's been some talk of starting a new set
11 of hardware Reg Guides, and maybe that should be
12 something in the future that we should look at.

13 But frankly, I think where we caught the
14 particular set of standards, they've worked well
15 together as it stands. I don't think you can really
16 say the gang of six, based on software, you can start
17 including hardware. But you're right. We could have
18 said well, just take the software aspect of it, and
19 that is --

20 MEMBER REMPE: There were some new changes
21 in the 2012 versus the 2008 software, I guess, the
22 question is.

23 MR. STURZEBECKER: Right. It just expanded
24 three times its size and said okay, when you want to
25 -- you use the same set of tables and everything, but

1 use it for hardware and use it for systems. It's
2 possible. I mean I went through it and we could have
3 done it, but I just don't know.

4 There was other aspects that I see, like if
5 you look at 830, you know. That vision in the IEC, it
6 just takes the 1998 and drops it into that document.
7 That's okay, fine. The 828, it hasn't really changed
8 either. But when you hooking on IEC and you start
9 going that direction, like 12-207, they have a whole
10 different philosophy of how they do their software
11 life cycle.

12 They integrate integration management, and
13 they integrate the V&V into the process, and they
14 start to lose the whole idea of unit test. The unit
15 test is really the base block of these guides. It is
16 the building block for setting up your testing.

17 So there's certain directions that I've
18 heard and talked to on this particular direction.
19 When we talked to NASA, they followed the same
20 pattern, and I think I'm pretty pleased with what we
21 have. So at this point, I think further on, that
22 should be a consideration.

23 MR. CASE: Karl, let me add from a process
24 perspective, I'm also the Scanners executive. So I
25 get that comment all the time. So from a process

1 perspective, what we did in the Reg Guide Update
2 program, what we invented is a five-year periodic
3 review.

4 So what I expect will happen is although we
5 didn't come up to the latest standard, the Reg Guides
6 will come up for view once again.

7 So hopefully, we'll develop a much better
8 pattern of picking the Reg Guides up five years from
9 now and incorporating some of the latest standards.
10 From a process point of view, that's how I get pass
11 this how come you haven't endorsed my latest standard.

12 MR. STURZEBECKER: I got the signal, yes.
13 All right. So here's the matrix --

14 VICE CHAIRMAN STETKAR: Karl, I hate to do
15 this to you. Go back to the previous slide. I just
16 want to make sure I understand something, because I
17 kind of liked -- no, the other slide. Go backwards.

18 (Off record discussion.)

19 VICE CHAIRMAN STETKAR: Configuration
20 management down in the lower left-hand corner there at
21 least on this cartoon seems to apply only to the
22 design, specification and design activities. Doesn't
23 it actually extend all the way through the whole life
24 cycle, through operations and maintenance?

25 MR. STURZEBECKER: Sure. Yeah, it does.

1 VICE CHAIRMAN STETKAR: Okay.

2 (Simultaneous speaking.)

3 VICE CHAIRMAN STETKAR: I just wanted to
4 make sure that I wasn't missing something here,
5 because I went back to the Reg Guide.

6 MR. STURZEBECKER: You're right.

7 VICE CHAIRMAN STETKAR: Okay, fine.

8 MR. STURZEBECKER: Yeah. It's --

9 VICE CHAIRMAN STETKAR: Keep going. You've
10 satisfied me. I'm happy.

11 CHAIRMAN ARMIJO: Karl, I've got a top level
12 question. When you're doing this upgrades, and maybe
13 this is in general on Reg Guide updates, I mean do you
14 ever consider combining them, just to say "Hey look,
15 like I see unit testing and then test documentation."
16 It seems to me like that would be a nice, complete
17 package that says this is how we test software and
18 this is how you document it.

19 I just wondered if that ever is a
20 possibility, and is it actually a problem?

21 MR. STURZEBECKER: We did consider that. We
22 thought about just putting them all in one set.

23 CHAIRMAN ARMIJO: Yeah.

24 MR. STURZEBECKER: But then again, you lose
25 that ability to change one versus the other. There

1 really isn't a lot of changes going on with unit
2 tests, but it is the basic building block, as I said.
3 It is a little bit separate from the software test
4 documentation. When you get further in it, you'll see
5 why that guide expanded, and what it's --

6 CHAIRMAN ARMIJO: Well, it looks like it's
7 very complicated.

8 MR. STURZEBECKER: It relates to unit test.
9 When we get there, I'll show you.

10 CHAIRMAN ARMIJO: Okay.

11 MEMBER BROWN: That's reflected on this. If
12 you notice the complexity in terms of changes, 170 and
13 173 are the highest, and 170 was the test
14 documentation. Yeah and --

15 CHAIRMAN ARMIJO: It would seem to me it
16 would be more complex to do it --

17 (Simultaneous speaking.)

18 CHAIRMAN ARMIJO: --the document, but you
19 did.

20 MEMBER BROWN: Sam, when I looked that them,
21 that made sense to -- it's a set of standards and an
22 order that everybody's familiar with, and if you go
23 start mixing these things up, people are going to lose
24 the picture on how, you know, what's expected from
25 them.

1 So integrating is good in some cases, and in
2 other cases, it just mashes things. It just adds
3 confusion. So I understand your point. It's just
4 that --

5 MR. STURZEBECKER: The point is that the
6 audience who uses these things understands it this
7 way.

8 MEMBER BROWN: Exactly, and all the
9 standards, you know, the standards kind of mesh that
10 way.

11 CHAIRMAN ARMIJO: Yeah. Like the Standards
12 Committee could have combined them. So I just
13 wondered if there was any reason, and you're saying
14 hey, there's good reasons, but let's move on.

15 MEMBER BROWN: Yeah. Okay Karl, keep
16 moving.

17 MR. STURZEBECKER: Okay. Now I'm moving
18 into the review of the six Reg Guides. When we went
19 through this whole set of changes with the Digital I&C
20 Subcommittee, they came up with six different
21 suggestions for us to improve what we've done.

22 The first one is basically the coverage of
23 Reg Guide should include more than just safety grade
24 systems. We agree to that, except that the way it's
25 situated in the Part A, we're specific on just safety

1 systems for now.

2 MEMBER BLEY: Part A of --

3 MR. STURZEBECKER: Of the guide --

4 MEMBER BLEY: It does state that, yeah.

5 MR. STURZEBECKER: Yeah. So I really didn't
6 change that.

7 MEMBER BROWN: I'm going to help Karl out a
8 little bit on this. There's a footnote in every one
9 of the Reg Guides, and we'll talk about this when
10 we're going through the letter. Footnote 1 says "This
11 only applies to safety-related," these documents,
12 safety-related stuff, but not systems important to
13 safety.

14 So there's a separation. That's the same
15 words in the 1997 versions, as are in the new
16 versions. John raised the issue in the meeting about
17 why is this systems important safety not at the same
18 level of or some level, nor defined, relative to
19 software standards and qualification, that the safety
20 system are, and we're going to talk about that in our
21 letter, and they don't have an answer for that. We're
22 going to have to --

23 VICE CHAIRMAN STETKAR: For the purposes of
24 this meeting, you've decided to retain that scope?

25 MEMBER BROWN: Yes.

1 MEMBER BLEY: And what Karl had said, Part
2 of the Reg Guides?

3 MEMBER BROWN: That's right.

4 MEMBER BLEY: Yeah. So yeah, on the reg we
5 agree. The Reg Guides do say that. We were hoping
6 that it wouldn't.

7 MEMBER BROWN: We're not -- so that's still
8 an open issue that we've got to talk about. The other
9 five are the ones that they were going to do something
10 with. So if you can move on through those.

11 MR. STURZEBECKER: Okay. For each one of
12 these, I'm going to show in the diagrams where they
13 drop in, and I'll be able to explain a little bit
14 more detail. But the first one is on Reg Guide 1.173,
15 which we'll get into shortly, and that was a comment
16 that our cybersecurity language needed to be
17 consistent in Part B, and one of the regulatory
18 positions, 3, with Reg Guide 1.152.

19 We're working on that. We've already
20 repaired Part B with the proper, the same language as
21 in 1.152, and the Reg Guide or Position No. 3, where
22 it's going to take those particular line items out,
23 because they do not match. They're more for building
24 security and that's not what my presentation is about
25 in the first place, when you talk about building

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 security versus just having 1.152.

2 MEMBER BROWN: You do reference 1.152 in the
3 document?

4 MR. STURZEBECKER: Yes, we do. We just need
5 to keep consistency with the language, like you said.

6 VICE CHAIRMAN STETKAR: Our reason, for
7 those who weren't there, 1.173 was in some sense an
8 outlier from the other Reg Guides. The other ones
9 sort of took the same reference language to 1.152.

10 MR. STURZEBECKER: And the only guide,
11 because it's the overarching one that we put in Part
12 C, we actually state go look at Reg Guide 5.71. And
13 the staff felt that that was enough at that point.
14 There's other places in other guides you wouldn't put
15 security in at all.

16 Number 3, Reg Guide 1.170. That's the
17 documentation one. There is a sentence in there when
18 we take an exception to a particular table in Appendix
19 B, that was trying to mix Integrity Level 3 and 4
20 together, and basically took an exception to mixing 3
21 in there and just saying hold at 4.

22 We had a sentence in there that was trying
23 to explain why, and we're going to remove that
24 sentence. It's already been done.

25 Reg Guide 1.170, No. 4 there, "Add failure

1 recovery software testing to the Reg Guide or the
2 Position 4." That is called system testing, and we're
3 working on a paragraph that will do what was asked for
4 on that. And that's an important point, because if
5 you're going through coding and you have a failure or
6 a bug.

7 You need, if you had to come back to a
8 particular starting point. So what's recovery testing
9 software? So it was a very good item to bring up.

10 No. 5, Reg. Guide 1.169, add test cases and
11 test documentation to the RP-6, and I think test
12 documentation's there, I have to double-check. But
13 we're going to put test case is a line item to
14 highlight and emphasize that part for, when you're
15 dealing with configuration management, whether it's an
16 item that you check. I'll show you later on that.

17 The last one is Reg Guide 1.168, which we
18 want to realign the paragraphs in there. We had a
19 discussion about a statement on independence, and a
20 disagreement with the way the boxes were shown on
21 Figure 1 of 1012. There were three little boxes we
22 want to remove.

23 We have a paragraph that's in there that it
24 doesn't sit well, doesn't read right. So we're
25 working on that. We're kind of getting a little -- it

1 doesn't flow well, and the second paragraph kind of
2 sets the tone for releasing the reason for why you
3 just did it.

4 MEMBER BROWN: That's the triangle diagram
5 that had some lower level stuff that you all said we
6 don't agree with those, and it wasn't consistent in
7 the words?

8 MR. STURZEBECKER: Yeah.

9 MEMBER BROWN: And it was confusing, okay.
10 There was a little bit of contradiction. So that
11 point that was brought up. I've forgotten who brought
12 that one up, but --

13 MR. STURZEBECKER: Okay.

14 MEMBER BROWN: So keep going.

15 MR. STURZEBECKER: So let's stop for a
16 second. This is going to be how I'm going to step you
17 through each guide. We're going to start with the IEEE
18 standard on your left, and work across to the new, and
19 then you're going to see whether it's endorsed without
20 exception, it passes right onto the life cycle, the
21 software project life cycle process.

22 Other ones that have been added that are
23 new, and you see the callout little bubbles there, the
24 callout with the new, we took an exception where we
25 used the color red, and yellow is the delete. Green

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 is for existing, circles a particular item in the
2 standard that's been there. We may have an emphasis
3 we wanted to put.

4 We put red in, and I have using purple in a
5 purple callout box for public comments, to show where
6 the public comments came into this process we did for
7 upgrading these docs.

8 CHAIRMAN ARMIJO: Does that mean they're
9 incorporated, or they're --

10 MR. STURZEBECKER: Yes, yes.

11 CHAIRMAN ARMIJO: Okay. Not just somebody
12 send in a suggestion.

13 MR. STURZEBECKER: I'll start with Reg Guide
14 1.172. All right. This guide follows exactly 1074,
15 endorses it, and what it does is by using the
16 standard, it sets the direction up for the project
17 architect for building the software project.

18 Once he builds this particular life software
19 project, life cycle process, you're going to have a
20 product at the end which would hope to be that
21 software product with some high, I don't want to say
22 adaptations, but it's going to have to be the
23 requirements that you put forward, that it is fairly
24 well designed.

25 So the first step, let me run through this

1 quick, is he's going to need to start the life cycle
2 process. You need to establish the requirements.
3 That means you're going to refer to Reg Guide 1.172.
4 You're going to have to select a software project life
5 cycle model.

6 Now when I'm reading through these five
7 steps, this is basically the first Clause 3 and 4 of
8 IEEE 1074. So this is the first steps that this, that
9 the project architect's going to do. So in building
10 the model, a model is defined as it's a framework of
11 processes of activities within a life cycle, and
12 usually it starts with an idealized working of the
13 problem. It becomes an architecture orientated around
14 a supporting set of activities.

15 I'll show you later that 1074 moved this
16 exercise into the Annex. They kind of de-emphasized
17 that and it's set forth, just saying well, it's really
18 up to the project architect, depending on the
19 industry, to pick their model and go forward from
20 there.

21 The next step is to develop the software
22 project life cycle, and that's where you're going to
23 start pulling the activities from the Annex A, and
24 we'll go through that, where there are certain
25 activities required and certain activities that you

1 can add if needed, that fill in this center piece.

2 Then you're going to establish this software
3 project life cycle process using all these different
4 activities, following this particular life cycle that
5 you see in the middle, and then you need to validate
6 the process with the stakeholders, to make sure that
7 you've met. I mean you can even do a V&V at that
8 point if you wanted to, just to see that the process
9 is set up right, correctly.

10 So now I'm going to make a transition to
11 the Annex that I was talking about for the third
12 bullet down, and when they're pulling from it, the
13 Annex A, the activities. So have the Reg Guide on the
14 right-hand side. The left is the 1995 version. The
15 center is the 2006.

16 So the first stage in this animation, and
17 I'll go slow through it, is to show what change in
18 1074. Just to give you some background, it's still
19 using the same life cycle process.

20 The 1995 version had a set of processes.
21 This new one has activities. So it's broken down by
22 activities, because obviously if you're trying to make
23 a life cycle process, why would you have a set of
24 processes? It just kind of gets confusing with the
25 language on that.

1 This particular standard reshuffled a lot of
2 the activities. There were a couple of big moves, but
3 they go through that, and it's more refined. So they
4 moved the software model, like I was telling you, from
5 Clause 2 into the Annex. The software quality process
6 was deleted. Title change on this integral process,
7 which later becomes support, selection of activity
8 groups.

9 And then we have the V&V process, which was
10 deleted. It's still there in the form that you're
11 going to do an evaluation, an audit and so on, but
12 it's more at a peer to peer level for Reg Guide 1.168,
13 for the years when you really want to do a true V&V on
14 things.

15 So this shows the shift of how the guide
16 changed, and it's pretty complicated. You can see the
17 overview dropped over. The project management
18 processes went to Annex A.1. The pre-development set
19 of processes are now in Annex 2, and I shouldn't be
20 using the word "processes," because they're now really
21 called Annex activities in 1074. But there you see
22 the whole line.

23 Now it's in red. I'm going to go through
24 each set of items that changed. Now when we built the
25 software project life cycle process, that was a key

1 concept in implementing the Standard 3 and 4. So
2 we've already stepped through that.

3 Project management section, added a
4 security, set of security objectives in Annex A.1, and
5 that related to our Reg Guide Position 1(d), where we
6 added what's called "secure analysis," and that's
7 appointed to Reg Guide 1.152 and 571.

8 Now this is where the Subcommittee came in
9 and said we need to adjust this, and make it exactly
10 like Reg Guide 1.152. So that will be done, and so
11 there's the animation to show that, and I talked to
12 that earlier.

13 The project planning. In this change to the
14 2006 version, all of the planning processes are now
15 activities. They're all moved into Annex A.1. So you
16 have this brand new set of planning activities. So
17 they de-emphasized more of the project management and
18 started emphasizing up front that you need to do more
19 planning, which will only make sense if you're a
20 project manager, and they added release management.

21 Also in Annex A.3, for the development,
22 during the development process, you're going to have
23 that managed software release where that's when you
24 take a particular software product that you finished.
25 You've got to be able to know what Rev it is and keep

1 the configuration management straight for issuing them
2 out.

3 Okay. So here is planned system transition,
4 and this is an existing clause and now it's in Annex
5 A.1, A.2-3. We created a regulatory position. The
6 team felt that we needed to emphasize this, and this
7 was just a reminder to the licensee that safety
8 software needs to be evaluated by the 50.59 process.

9 MEMBER BROWN: I want to make one comment
10 relative -- so you understand that one. That's a
11 little confusing. If you read the IEEE standard, it
12 effectively said that transition planning should -- is
13 only required for when you're completely replacing all
14 the software or revising the system. There are
15 exceptions that says hold it guys.

16 You've got to do this in accordance with
17 50.59. All safety changes to the software need to be
18 managed under the 50.59 process. Now so that's an
19 exception they took, and I think that's what you're
20 referring to; is that correct?

21 MR. STURZEBECKER: Yes.

22 MEMBER BROWN: So that's what that means.
23 So there's nothing wrong with what they've got, but
24 you've got to say no, hold it. You've got to do it to
25 everything, not just when you take the whole thing out

1 and put a whole new one in, which was an allowance in
2 the IEEE standard.

3 MR. STURZEBECKER: Software importation
4 activities group, and this is the set up for
5 activities in the standard that's new, and it's for
6 evaluating the software importation required. We
7 already have that in our regulatory Position 1, which
8 is basically refers to the EPRI for pre-existing or
9 commercially off the shelf software.

10 We reference a topical report that we have
11 endorsed. That was one of the public comments that
12 came in, and said you need to put the citation in
13 there and the date. So we took care of that, and that
14 has been updated to the Guide.

15 Okay, the next step is down in post
16 development, and this is where you need to identify
17 software improvement needs. This is a new section.
18 Remember how we deleted the SQM? Well, this is kind
19 of where it fits in place in the process now.

20 They put it into this area, and these three
21 new activities, identifying the improvement,
22 implementing the problem reporting and then reapplying
23 it back to the software project life cycle process.
24 So there's your quality link right there.

25 85. It has a new name, "Support Section of

1 Activity Groups." There was some difficulty in really
2 seeing what's shuffled into this from the original
3 guide. A lot of it is new. It's about evaluations,
4 conducting reviews, a traceability matrix for
5 conducting the audits, and reporting the evaluations.

6 Other subsections still holds configuration
7 management in there, document development and
8 training. Those were existing.

9 The last was the Annex D through F, which
10 includes mapping information, model examples, glossary
11 and a bibliography. We have a new Regulatory Position
12 6 that outlines each one of those particular annexes.

13 So that guide helped the project architect
14 set up a particular process, and they would turn to
15 this particular Reg Guide to develop the software
16 requirements specifications. So Reg Guide 1.172 again
17 follows directly a 30, I believe 30, let's see here.
18 One of the issues, or if you want to put it one
19 sentence, it's basically what do you do for the Reg
20 Guide?

21 You're creating a software requirements
22 specification that delineates the function accurately,
23 without adding constraints. So it comes down to this
24 point that even words that you use to try and explain
25 a particular requirement in software have to be exact.

1 All parties have to understand what the word means and
2 where you're going with it.

3 There's traceability from the original
4 baseline. When you make your first revision of that
5 particular requirement in your future developments,
6 and the guide and the standard is written that it
7 supports the life cycle process.

8 I didn't do any animation with this one,
9 because it's pretty simple. You can see that there's
10 only one change between the 1993 version and the 1998.
11 That was the addition of Annex B, which is five lines
12 for compliance to the EAI 12207 1997 version.

13 The unambiguous subsection or subclause in
14 4, we did create a Regulatory Position 2, and this is
15 a new subsection called "Unambiguity." There was a
16 public comment about how we've written it.

17 We were basically conveying that if you're
18 going to set up your software requirements, that
19 sometimes are generally derived from an associated
20 software product, and to do this for a safety system
21 requirement, you need to make sure the interpretation
22 in the SRS should be unambiguous.

23 So it's just re-emphasizing that. The
24 public comment was we didn't write it very well. So
25 we rewrote it and that's been completed.

1 MEMBER BROWN: The point here was just we
2 wanted a clear specification, not an ambiguous one.

3 MR. STURZEBECKER: Not ambiguous.

4 MEMBER BROWN: That's the English version of
5 this particular additional stuff. Other than that,
6 this was pretty benign.

7 MR. STURZEBECKER: In Clause 5 of the 830-
8 1998 version, there is a subclause about security. We
9 took exception to this and we got in again with the
10 regulatory position 6(b), and we talk about security
11 analysis, and we state in there that we need to refer
12 to the SDOE from Reg Guide 1.152, which is Secure
13 Development Operating Environment.

14 MEMBER BROWN: When you wrote that, I went
15 back and looked. You say you took an exception. You
16 didn't really say you took an exception to that in the
17 Reg Guide. So any --

18 MR. STURZEBECKER: You want to --

19 MEMBER BROWN: I want to be -- all of the
20 rest of the places where you took an exception, you
21 said "We take exception to this, and here's what we
22 want." In this case, you just stated what you wanted.

23 MR. STURZEBECKER: Yeah, we just stated what
24 we wanted. What items that are in that particular --

25 MEMBER BROWN: I'm going to get beat up by

1 the members here, because I said there were no
2 exceptions to this.

3 MEMBER REMPE: Now that you've told us to
4 beat you up.

5 MEMBER BROWN: If you want to rewrite it --

6 MEMBER BLEY: Maybe this is an addition
7 rather than exception.

8 MEMBER BROWN: That's the way I read it,
9 that they added that to it. They weren't taking
10 exception to anything there. They just added --

11 MEMBER BLEY: Added more requirements.

12 MEMBER BROWN: That's the way I read it,
13 after I read the way you stated it before.

14 MR. STURZEBECKER: Yeah, because when you
15 look at the --

16 MEMBER BROWN: Well, you don't have to
17 mouse-milk this. You can go ahead and go on. I just
18 wanted to make that point --

19 MEMBER POWERS: Do you have any idea what
20 mouse-milking is? It's a baby term, I think.

21 (Laughter.)

22 (Simultaneous speaking.)

23 MEMBER POWERS: Why do you have those?
24 You're always telling people not to do that.

25 MEMBER BROWN: Okay, Karl. We can go onto

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 this now, and go to the next item, okay?

2 PARTICIPANT: Actually 6(b) says "is not
3 endorsed." So that sounds like an exception.

4 MEMBER BLEY: No. They have a lot of the
5 annexes that they don't endorse in here, in these
6 various Reg Guides, in the --

7 MEMBER BROWN: So that's not -- I made that
8 point in the letter also, that they, you know, where
9 they don't endorse an annex, they don't. It's very
10 clear when they do, and it's very clear when they
11 don't. So that was, in terms of clear writing, that
12 was good.

13 MR. STURZEBECKER: Yeah, and maybe we
14 should. I missed one earlier.

15 MEMBER BROWN: It's not an exception.

16 MR. STURZEBECKER: It's not an exception,
17 but you know, the items are listed --

18 MEMBER BROWN: Let's go on, Karl.

19 MR. STURZEBECKER: Yeah. Okay. Unit
20 testing. Here's another. This is based on IEEE 1008.
21 There's literally no changes to the standard, and it
22 provides emphasis on unit testing, just like I
23 explained before. This is the smallest piece of
24 software that can be independently tested.

25 Right now, the only thing we've done to the

1 Reg Guide is we've modified Regulatory Position 5, and
2 we've also laced through the Guide references to 829,
3 because like the Chairman said before, the unit
4 testing and software documentation are pretty close,
5 and they are, and this one is pointing to 829, saying
6 here is where you need to look for where unit testing
7 will be used in Reg Guide 1.170, and then the
8 Regulatory Position 6, which outlines the Annexes A
9 through D.

10 MEMBER SCHULTZ: And it needs to go back to
11 the 1983 version, because the 2008 version doesn't
12 comply, or doesn't provide those sections.

13 MR. STURZEBECKER: Yeah. It used to
14 reference 1983, and now we're telling -- maybe I
15 should have put 2008 there instead. Make that clear,
16 yeah. In the Reg Guide, it says go to the --
17 originally, it said 1983, yeah. My mistake on the
18 slide, so you might want to change that.

19 MEMBER SCHULTZ: Okay, thank you.

20 MR. STURZEBECKER: Okay. This is going to
21 be a busy one, Test Documentation. Okay. This Reg
22 Guide follows 829-2008 directly. Again, the objective
23 is to create a software test plan and you can read the
24 rest there, methodically documenting some of the
25 requirements with reportability demonstration of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 unit component system and testing.

2 It follows the common framework of the life
3 cycle process, and it applies to developing software
4 with the life cycle, the pre-existing or pre-developed
5 software. This is where we begin to introduce
6 Integrity Level 4, the traceability and anomalies.

7 This Reg Guide had the largest set of
8 changes. Literally this standard doubled in size.
9 It's impressive, I think, the work that was done on
10 this particular standard, how the details they went
11 through to create another set of documents that
12 overarch it.

13 Literally, it goes from being one-
14 dimensional, the first version, to being three-
15 dimensional in this sense, because they have, they've
16 addressed these other issues of anomalies that may
17 happen, how do you handle that, how do you record
18 that, what kind of logs you use and it's traceable,
19 and they had that integrity, four levels, four steps
20 of integrity and we just stick to Level 4.

21 So in 1983 is on the left, we've got 2008,
22 the new version in the middle, and our Reg Guide
23 1.170. Right off the bat, the scope's deleted. It's
24 not part of the new one. The test item transmittal
25 report is gone. The test incident report is gone, and

1 the appendices are gone. 1983 is too far out, a long
2 time ago.

3 Where the particular parts did meet, you can
4 see how the test plan number three moved into Level
5 Test Plan Clause 9. Four, the test design
6 specifications, became Level Test Design, Clause 10,
7 and Test Case Specifications became Level Test Case
8 11, Clause 11, and the test procedures became a Level
9 Test Procedure.

10 And you keep saying "Level" in front of
11 everything. But when you're actually doing the work,
12 you're working on a Unit Test A. You take the word
13 "level" out and you drop it in front of there, and you
14 call it "unit test, Unit A Test Plan," and you can
15 begin to create your configuration management of
16 parent, daughters and work breakdown structure using
17 that particular nomenclature here.

18 So you can see how the 1983 version was
19 really a core part of this new standard. So it looks
20 like it's going through 2008. Okay. So the first
21 part, Clause 1 and 2, basically how you use the
22 standard. It's kind of a structured set of, you know,
23 instructions. So you really need just to read through
24 the entire document to understand it.

25 I'm going to start here with software system

1 integrity levels. Now in Integrity Level 4, we made
2 a change to our Regulatory Position 1, which is Test
3 Programs. We've added in there that you need to
4 maintain Level 4. That's just a small change in
5 there.

6 MEMBER BROWN: Well, that's not -- let me,
7 I want to emphasize that a little bit, because in
8 fact, the IEEE standard allowed the acceptance of a
9 lesser level of software integrity, based on a risk
10 analysis from one of the annexes, and I think the
11 staff appropriately looked at that and said look, for
12 safety systems software, we want Integrity Level 4,
13 and that's very much in tune, as you probably well
14 imagine, with my general thought processes.

15 I really like that, because they told people
16 what they wanted, and I thought that was an important
17 thing, a point to get across, in terms of their
18 insistence. It's very specific and said they can only
19 apply Level 4, should be assigned to all nuclear
20 plants safety systems, and they developed that.

21 CHAIRMAN ARMIJO: Well that's a built-in
22 requirement.

23 MEMBER BROWN: Yeah, that's very specific.
24 Well, it's a Reg Guide.

25 CHAIRMAN ARMIJO: It's a back door

1 requirement.

2 MEMBER BROWN: But it's very specific as to
3 what they want. So if they come in with something
4 other than that, they're going to --

5 CHAIRMAN ARMIJO: It's going to be painful.

6 MEMBER BROWN: It should be painful, let's
7 put it that way. The fact is they should say no about
8 4,000 times before they look at it. That's an offhand
9 comment. Anyway, I just wanted to make sure you
10 understood that.

11 MR. STURZEBECKER: So that goes right up
12 front in that regulatory position. In Regulatory
13 Position 6, we do have integrity levels, a new section
14 there, and it takes exception to the Annex B and Table
15 B-3, because in that particular annex, we'll get to
16 that later, but it basically says that they tried to
17 mix in with a risk assessment scheme of Level 3 with
18 Level 4. So we take, we put that exception there.

19 The public comment we had for Regulatory
20 Position 1 was they didn't like the language, because
21 when you look at Regulatory Position 1, there's a list
22 of items we add, ask the licensee to look at, along
23 with the master test plan, and it wasn't clear whether
24 we were saying the Master Test Plan and A through G,
25 or one or the other. So we cleaned that up.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Now this is one of the little Subcommittee's
2 comments were when we took exception to that Annex B,
3 we had that one sentence in there, and it's going to
4 be deleted. So I'm showing --

5 MEMBER BROWN: That's the likely cause.

6 MR. STURZEBECKER: The likely cause, yeah.
7 Likely to cause, yes. Okay. So Clause 5 is Test
8 Processes. It follows the life cycle. It really
9 outlines exactly how the stages when you route through
10 it, that you're supposed to set your documentation up
11 with the life cycle.

12 It also had a statement about testing tasks
13 that in Clause 5, that we wanted to point in our
14 Regulatory Position 7 here, that if you read through
15 Annex C, Table C.1, that it emphasizes it better than
16 what's in Clause 5. So we just made that addition
17 with that Regulatory Position 7.

18 Regulatory Position 9, which is associated
19 with Clause 5, because Clause 5 has a Table 3 in
20 there, which identifies security issues in the life
21 cycle that should be addressed, but it doesn't include
22 the very beginning at Acquisition Supply, Planning and
23 Concept, which is picks up from concept and goes on.
24 So we made the revision that in the plan, you need to
25 consider security all the way from the start.

1 Test Documentation. This points to two
2 aspects that we brought up in Regulatory Position 3.
3 There's a Clause 6.4 that says, you know, if you want
4 to minimize your documentation, just lower your
5 integrity level, and we're saying no, we don't accept
6 that.

7 At the same time, we also brought up that
8 it's okay to use test logs and to reduce documentation
9 at the open entry, and that can be a tool in which you
10 repeat the same particular procedure, and just have an
11 open entry where you drop in the next item that you're
12 calibrating or working on.

13 MEMBER BROWN: You really covered that in
14 Position 8, if I remember correctly?

15 MR. STURZEBECKER: Yeah. Yeah, I did.

16 MEMBER BROWN: And you took exception to
17 that.

18 MR. STURZEBECKER: And that's the next one.
19 Yes Charlie. Okay, yeah. On Position 8, we're saying
20 if you're going to use that tool, it's got to be
21 usually accessible for electronic validation for a
22 safety concern. So those three particular items were
23 all hinged upon Clause 6.

24 We'll go to Clause 7, Test Documentation,
25 Address and Mapping. This is, it's kind of -- as a

1 clause, it's not really, I would say exciting. But it
2 has some really strong relevance that maybe they
3 should strengthen in the future, because it points to
4 -- it starts laying out where you're supposed to go
5 and take all these particular documents that you want
6 to address, and how do you lay them out and have the
7 work breakdown structure in testing. So it's a very
8 important clause.

9 We finally get to the Master Test Plan, and
10 if you're running through a set of tests and you have
11 your tests, your level test logs, your anomaly reports
12 and then say you document this with a level and then
13 a test status report. This all ends up in the master
14 test report.

15 There's a clause there that -- I think we
16 went down too far -- there's a clause there, in Master
17 Test Clause 8, at 8.2.3.3, where we wanted to
18 emphasize that they had a deviation policy, and that
19 we need to establish this and record using the proper
20 documents.

21 So that's all Regulatory Position 2 was, is
22 it emphasizes that, that change that we put in there.

23 Then we have -- I've already clicked, good,
24 the AR 14, 15 and 16. It was three clauses, and this
25 is a new set of clauses that, excuse me, really is a

1 complete improvement over the ones that were deleted
2 on the left there, the test item transmittal report
3 and the test incident report. I really couldn't find
4 anything directly related between the two.

5 They were rewritten. So that's the tail
6 end, after you've gone through this process and you've
7 done your testing, and how to report your anomalies,
8 your bugs in the software. We make note of that in
9 Regulatory Position 1(g), and say highlight the use of
10 this level test log and the anomaly report
11 documentation.

12 Last is the annexes, and A through H, we put
13 that in Regulatory Position 10.

14 MEMBER BROWN: I don't remember. Did you
15 all endorse all of those annexes in this particular
16 Reg Guide?

17 MR. STURZEBECKER: No.

18 MEMBER BROWN: I didn't think you did.
19 Okay. Just that I remember one of them, you said you
20 did pretty much all the exceptions.

21 MR. STURZEBECKER: Yeah, Table C.

22 MEMBER BROWN: Yeah. I'd have to go back
23 and look. I just, because I couldn't remember which
24 Reg Guide we did. But you stated that. You can go
25 ahead. That's a confusing question on my part.

1 MR. STURZEBECKER: Yes. Here's where we're
2 going to add the failure recovery software testing,
3 right, in Regulatory Position 4. That's when you're
4 testing your code and it fails. Where does it go?
5 You need to have it fall back and have the
6 documentation that shows that your recovery software
7 testing is working.

8 Reg Guide 1.169, Configuration Management.
9 This follows 8/28/2005 directly. The Guide follows it
10 directly, and the objective here is to use the
11 configuration management plan, the activities
12 reporting, the software, the system history and the
13 baseline to final use.

14 There weren't really that many changes, and
15 this is a medium level set of changes. It's not like
16 some of the other standards which didn't change it
17 all. But there are a few things.

18 MEMBER BROWN: Is that through IEEE 828?

19 MR. STURZEBECKER: Yeah. Here's some
20 tweaking to say that the standard matches the other
21 standards, and that's -- we'll go through that next
22 year, changes in words that they did.

23 The appendix becomes an annex, so you see
24 1990 going to 2005. The introduction is split up into
25 overview, definitions and acronyms. In Clause 3, we

1 added a couple of tasks for doing the software
2 configuration management process, and those were
3 costs, surveillance of activities and types of risks.
4 They were very minor updates.

5 This is where the release management and
6 delivery comes in. They've added that in, and we did
7 the same with Regulatory Position 12. So they just
8 re-emphasized that need. We also made a note of it in
9 several other areas, line items like in Regulatory
10 Position 4, in the line item there, because it's
11 basically saying make sure you include this.

12 We also had a paragraph that we said control
13 the development of your commercial contracts, as part
14 of the whole configuration management scheme.
15 Regulatory Position 7, that refers to the EPRI topical
16 report, and that's how you dedicate a particular
17 commercially off the shelf software, and again, the
18 public comments stating about our citation and when we
19 accepted that report needed to be put in there. So
20 that was changed.

21 Basic word changes throughout the two
22 standards, from the 1990, 2005. "Tailoring" was
23 changed to "adapting." Nothing exciting, and then the
24 annex becomes Regulatory Position 14. A is the
25 Bibliography and B is Relationship to Other Standards.

1 Then on the Regulatory Guide, we had this
2 outdated reference to Standard 1012-1987, which is no
3 longer in use, so that was deleted. There was a
4 public comment that removing a line item that said
5 "Commercial software items that are safety software,
6 or safety system software."

7 Those items, when you look at the Reg Guide,
8 is about safety system software. So it is redundant
9 that we had line item, so we took that out. This is
10 where we put the test case, added that into Regulatory
11 Position 6. It's called "Documentation." So that's
12 where they added that, so that's covered.

13 Reg Guide 1.168. This one was interesting,
14 because it has two standards it refers to. Again, it
15 follows 1012-2004 version, 1028-2008 directly. This
16 is one guide that was updated from the original 1997
17 group. It was updated in 2004 and now we're updating
18 it today, 1013. The Reg Guide --

19 MEMBER BROWN: Is this the interim one that
20 went to 2004?

21 MR. STURZEBECKER: Yes.

22 MEMBER BROWN: But it was just, it was
23 editorial. There was very little, if anything, in the
24 difference between the two standards.

25 MR. STURZEBECKER: Right.

1 MEMBER BROWN: Because that's a comment you
2 made during the Subcommittee meeting.

3 MR. STURZEBECKER: There's a few additions,
4 minor additions to 1028, and I'll show you the next on
5 1012. There are a lot more minor things put in there,
6 but no big changes at all. In fact, we look at 1028,
7 we go through it. This is one where it deleted the
8 anomaly classes, the Annex A.

9 The anomaly classes were some sort of
10 taxonomy. It wasn't really useful. Anomaly ranking
11 was shifted over into 2008. It has the same wording
12 and structure, starting with catastrophic, critical
13 and working your way down, as 1012, but it just
14 doesn't have any numbers. Level 4, 3, 2, 1.

15 These were minor changes. In Clause 4, it
16 added life cycle and a planning line item. The next
17 level we're going to call out shows in Clause 5, with
18 the add spec descriptions. In Section 6, 6.1, gave
19 software topics for the inspector to look at. 6.3,
20 added some inspection items, documentation, quality,
21 procurement and software history. So really general
22 small things. I might not even have wanted to put
23 them on, but they had no effect on the standard.

24 So this is the last one. This is your 1012-
25 1998, the 1012-2004. These two figures were moved

1 into the back end of Clause 7. 7.6 was moved into 6.1
2 of 2004. It's again the reporting requirements, which
3 makes sense to fix under Clause 6, which is about V&V
4 reporting. So that was taken care of. Then the annex
5 was moved over, A through H.

6 As to Scope and Field Application, some
7 minor details of how you go. Like now you can include
8 commercially off the shelf items for this. This is
9 where Clause 4, where they added integrity levels 1
10 through 4, the description. Also in 5, where it has
11 integrity levels the highest, the V&V intensity should
12 be just as high.

13 We included this in our title. It was just
14 a title change in our Regulatory Position 1, was
15 "Critical Software." We just changed it to software
16 integrity. There wasn't anything different than that,
17 because this guide is pretty up to date, Charles was
18 saying.

19 The public comment on this one is there is
20 a contradiction between what we said in Reg Guide 1.70
21 and Reg Guide 1.68. In 1.70, it was about Annex B,
22 but we took an exception to being B.1 and B.3.

23 We didn't have it in here, so we added that
24 paragraph. This is the same paragraph that has that
25 "likely" sentence that we want to delete. So it's

1 just we're repairing it, but we're also following up
2 with what the Subcommittee said to do.

3 The process management has four process
4 improvement tasks. The process development adds life
5 cycle security, and that's laid out through the life
6 cycle that they now acknowledge look at security.

7 There was a clause in 7.74 about security,
8 and we reference it just again, or we note that you
9 should look at and use SDOE activities, that that
10 should be part of your V&V activity, to check the
11 SDOE.

12 This was another adder, small adder with 7.
13 It adds 6 under reports. That's all it was. Nothing
14 major. Now the annex, I have it separated here, two
15 different colors. One was existing and one was partly
16 the new, some of the new changes they made. That was
17 Annex B, B.1. That's the one we took exception to.
18 The original Annex B.3, we took exception to that too,
19 and that's how it ties up with Regulatory Position 1.

20 In Regulatory Position 3, we added this
21 paragraph. That's what we talked about before. We
22 disagreed with the Figure 1, the three bottom boxes on
23 the triangle, and the Subcommittee says we need to
24 work on that paragraph. So we're going to straighten
25 that out, because it doesn't flow right.

1 The last callout here is Table C.1 adds
2 additional independence, which is not acceptable, and
3 we took exception to that, because they try to mix in
4 an idea of conditional independence. So it will just
5 be purely "independent."

6 Public comment to include a topical report
7 citation, and that was taken care of in Regulatory
8 Position 4. That's the end.

9 MEMBER BROWN: Okay. Before you leave that
10 slide, go back. The two interesting ones in there
11 were the Regulatory Position 3, where it talks about
12 the little block about independence of software, V&V
13 exceptions. If you look at IEEE 1012, there's a
14 figure called a "Relationship of Verification and
15 Validation to Other Project Responsibilities."

16 That's a little triangle showing, you know,
17 the major step and then it drops down to subgroups,
18 and they pigeon-holed them, those little subgroups.
19 They said, hey, look, we're not going to agree with
20 how you pigeonhole. That's got to be, you've got to
21 tell us what you're going to do in the big picture
22 when you go through and lay it out, as opposed to
23 allowing that, the pre-defining what was acceptable
24 or not, relative to an organizational standpoint.
25 That was in Annex C, excuse me, Annex F, Figure F.1.

1 So Position 3 actually takes exception to
2 those subordinate relationships. That's what it does.
3 I mean it's fairly easily stated.

4 The other one is the conditional
5 independence. When you do V&V but you've technical
6 independence, managerial independence and financial
7 independence from the development organization. If
8 it's rigorous, those are completely independent from
9 the development organization.

10 The IEEE standard allowed a less than
11 rigorous independence, based on, you know, some
12 evaluation and an analysis that you did, and the staff
13 or NRC staff took exception to that and said, to that
14 form of independence and said that that's not
15 acceptable. You need rigorous independence.

16 Again, this is a Reg Guide, and if somebody
17 wants to do something slightly off normal, doesn't
18 mean they can't come in and talk about it. It's just
19 they set the metric in a particular place, which at
20 least the Subcommittee members didn't disagree with
21 that. Is that correct Dennis and John, on materials?

22 So those are the two major items in my mind,
23 relative to this particular one. So other than that,
24 didn't want to steal your thunder, but I think you're
25 now complete; correct?

1 MR. STURZEBECHER: Yes, I am.

2 MEMBER BROWN: So I guess I would open the
3 floor to questions, if anybody has any additional
4 question.

5 MR. STURZEBECHER: I've just got one more
6 slide.

7 MEMBER BROWN: Oh, you've got one more
8 slide. I'm sorry. I apologize for that.

9 (Simultaneous speaking.)

10 MR. STURZEBECHER: Yeah. It just shows that
11 we've worked on this. We've looked at it and all the
12 common topics were contemplated. We matrixed through
13 the guides, and key public comments were addressed,
14 and they are ready for publication of the changes we
15 need to make.

16 VICE CHAIRMAN STETKAR: Now you mentioned
17 that Karl has evolved past these. If we recommend
18 that they're not issued, does that mean he gets pulled
19 back in? Just a piece of information.

20 (Simultaneous speaking.)

21 (Laughter.)

22 MEMBER BROWN: If there are any other
23 questions from the members?

24 MEMBER REMPE: Throughout the presentation,
25 I heard you say we're fixing a paragraph here or

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 there. Are you still doing that or are they done?

2 MR. STURZEBECKER: Part of them were done.

3 MEMBER BROWN: Is this relative to the
4 questions that you -- thank you.

5 VICE CHAIR STETKAR: Are you going to -- are
6 you going to show us what you did? I mean yes,
7 Christina.

8 MS. ANTONESCU: Yeah. Yes, they're
9 planning to give us the copies of all the regulations.

10 VICE CHAIR STETKAR: I don't think we need
11 another Subcommittee meeting. We just would like to
12 see what you did.

13 DR. ARNDT: Sorry, Steven Arndt, ACRS.

14 (Laughter.)

15 DR. ARNDT: Sorry, NRR. For those members
16 who don't know, I had Christina's job about 25 years
17 ago.

18 MEMBER REMPE: And we worked together.

19 DR. ARNDT: Yeah. We will get that
20 revisions based on comments from the Subcommittee
21 cleaned up, finished and concurred on by the various
22 players, and then we'll forward a courtesy copy over
23 to you, so that you understand, along with our
24 comment resolution letter, what we've done to address
25 your comments.

1 MS. ANTONESCU: Before they're issued,
2 right?

3 DR. ARNDT: Yes.

4 CHAIRMAN ARMIJO: Okay.

5 MEMBER SKILLMAN: Hey Charlie, I do have a
6 question. I'm thinking about how often we update
7 computers. It seems that once every 36 months there's
8 a need to update. What's the required update
9 frequency for these Reg Guides?

10 MEMBER BROWN: I think they didn't use to
11 have one, and now they're trying to do it on a five
12 year review cycle, is what, that's what -- if I'm
13 correct, that's what you said at the earlier part of
14 the presentation.

15 MEMBER POWERS: What we found was when we
16 didn't have a regular review of it, that when it
17 became inevitable we had to, it was a horrific
18 process.

19 MEMBER BROWN: Yeah, that's what it appears
20 to be.

21 MEMBER POWERS: And so now a more regular
22 process, at least the magnitude of the changes is
23 trackable.

24 PARTICIPANT: So once each five years or
25 once 60 months?

1 MEMBER BROWN: Yeah. That's what their, I
2 think the NRC plan now is, right? That's part of the
3 overarching --

4 MEMBER BLEY: But they've still got a third
5 of them to revise.

6 (Simultaneous speaking.)

7 MEMBER BROWN: It's a big job.

8 MEMBER POWERS: Right. But at least we're
9 not letting it accumulate for a decade or so.

10 MEMBER BROWN: For 25 years. Twenty-five
11 years in some circumstances.

12 (Simultaneous speaking.)

13 MEMBER POWERS: I think that's the -- I mean
14 the single biggest thing is the commitment to do a
15 fairly regular update, without having to have somebody
16 sitting there changing it day by day, you know like an
17 odometer changing.

18 MEMBER BROWN: I want to make one other
19 comment. Just trying to coordinate six Reg Guides
20 with all the changes in the IEEE standards was just a
21 huge job, and the staff, Karl and the folks that he
22 dealt with, and I know he had assistance from others
23 in wrapping some stuff up.

24 My personal opinion is they did an
25 outstanding job of putting this together, and then

1 mapping it, such that we had some idea of where pieces
2 from the old ones went and what was added in new.
3 Without that, the review of these and the
4 identification of the changes would have been just --

5 MEMBER POWERS: The problem is that you look
6 at any one, mostly you look at the IEEE standard.
7 Just look at one of them and you get totally confused.
8 You have to have a very much more integrated view on
9 things.

10 MEMBER BROWN: And these are all
11 intertwined, and that's the problem. These six Reg
12 Guides are very much intertwined.

13 MEMBER BLEY: But there's charts you put
14 together, Karl, for us to show that mapping were very
15 helpful.

16 MEMBER BROWN: Anyway, I wanted to thank you
17 very much. I thought you did an outstanding job on
18 that, your staff and your supervisors and whole thing.
19 Unfortunately, they let you loose to do your thing,
20 and job done very well.

21 (Laughter.)

22 CHAIRMAN ARMIJO: We're going to get a copy
23 of the transcript and preserve that. It will get
24 written down.

25 (Laughter.)

1 MEMBER BROWN: Sam, I turn the meeting back
2 over to you. Thank you, with some time on your hands.

3 CHAIRMAN ARMIJO: Yes.

4 MEMBER BROWN: Definitely ahead of schedule.
5 That was very well done. Thank you. That's
6 management. That's time management, Sam.

7 CHAIRMAN ARMIJO: That's outstanding. I
8 think you'll definitely get a bonus this year.

9 (Simultaneous speaking.)

10 (Laughter.)

11 CHAIRMAN ARMIJO: Well, I also want to thank
12 Karl. It was a lot of work, and you made it easy for
13 us to follow. It took a while to figure out the code
14 in your color-coded stuff, but actually even I could
15 figure it out, so that's good.

16 What I'd like to do now is recess for lunch,
17 but since we're going to take advantage of the time
18 that you've saved us and we're going to reconvene at
19 one o'clock. Okay.

20 (Whereupon, at 11:45 a.m., the meeting in
21 the above-entitled matter was adjourned.)

22

23

24

25




Software Regulatory Guidance

US Nuclear Regulatory Commission
Advisory Committee on Reactor Safeguards
June 5, 2013

Karl Sturzebecher
Office of Nuclear Reactor Regulation
Division of Engineering

Purpose of Meeting

- Background
- Review 6 Regulatory Guides (RGs)
 - RG 1.173 Project Management
 - RG 1.172 Software Requirements Specs
 - RG 1.171 Unit Testing
 - RG 1.170 Test Documentation
 - RG 1.169 Configuration Management
 - RG 1.168 V&V Review Audits
- Conclusion



Background

- What was goal for these RGs?
- How did we go about this effort?
- What was overall result?
 - Change in emphasis
 - Approach refinement
 - Common cross cutting topics: security, integrity, tools, and release management & delivery

Background

Regulatory Guides & Associated IEEE Standards



SOFTWARE PROJECT LIFE CYCLE PROCESS – RG 1.173
IEEE Std. 1074-2006

**SOFTWARE REQUIREMENTS
SPECIFICATIONS – RG 1.172**
IEEE Std. 830-1998

**UNIT TESTING
– RG 1.172**
IEEE Std. 830-1987 (R2002)

SOFTWARE TEST DOCUMENTATION – RG 1.170
IEEE Std. 829-2008

**CONFIGURATION
MANAGEMENT
PLAN – RG 1.169**
IEEE Std. 828-2005

**VERIFICATION AND VALIDATION
PROCESSES – RG 1.168**
IEEE Std. 1012-2004
IEEE Std. 1028-2008

Background

Regulatory Guide change matrix

- Demonstrates the IEEE updates (Left to Right) per RG
- Level of complexity of the RG and IEEE changes
- Natural flow of the RGs on developing software

Regulatory Guides	<u>IEEE Standards</u>				Change Complexity
	Previous	Interim	Update	Future	
<u>RG 1.173</u>	1074-1995	1074-1997	1074-2006		2 nd Highest
<u>RG 1.172</u>	830-1993	————→	830-1998	IEC 29148	Low
<u>RG 1.171</u>	1008-1987	————→	1008-1987(2002)		Reaffirmed
<u>RG 1.170</u>	829-1983	829-1998	829-2008		Highest
<u>RG 1.169</u>	828-1990	828-1998	828-2005	828-2012	Medium
<u>RG 1.168</u>	1012-1998	————→	1012-2004	1012-2012	Medium
	1028-1997	————→	1028-2008		Medium

Suggested revisions by the ACRS Subcommittee:

1. Coverage of RGs to include more than safety grade systems
2. RG 1.173 make cyber security language consistent in Part B and regulatory position (RP) 3, as compared to RG 1.152
3. RG 1.170 remove “likely to cause” sentence in RP 6 (also found in RG 1.168)
4. RG 1.170 add failure recovery software testing in RP 4
5. RG 1.169 add “test cases” and “test documentation” to RP 6
6. RG 1.168 realign paragraph contradiction on independence in RP 3

Review 6 RGs

Color Key:

Software Project Life Cycle Process

(Old) IEEE Standard

(New) IEEE Standard

Regulatory Guide


Overview 1
Software LC Model Process 2
Deleted PM Processes 3
Pre-development Processes 4
Development Processes 5
Post-development Processes 6
Integral Processes 7
Bibliography

Overview 1
Software LC Model Process 2
New PM Processes 3
Pre-development Processes 4
Development Processes 5
Post-development Processes 6
Integral Processes 7
Bibliography

Part A
Part B
New
Part C
Part D
Ref.

Endorsed without exception

Variation (exception and/or addition)



Deleted

New

ACRS Comment

Existing

Public Comment

RG 1.173

Developing Software Life-Cycle Processes for Digital Computer Software used in Safety Systems of Nuclear Power Plants


- Background
- Review 6 Regulatory Guides (RGs):
 - **RG 1.173 Project Management**
 - RG 1.172 Software Requirements Specs
 - RG 1.171 Unit Testing
 - RG 1.170 Test Documentation
 - RG 1.169 Configuration Management
 - RG 1.168 V&V Review Audits
- Conclusion

RG 1.173

Developing Software Life-Cycle Processes for Digital Computer Software used in Safety Systems of Nuclear Power Plants

What does this RG do?

- Follows IEEE 1074-2006 directly
- Overview regulatory guidance
- Objective: Create a Software Project Life Cycle Process (SPLCP)
 - Establish requirements
 - Select a Software Project Life Cycle Model (SPLCM)
 - Develop Software Project Life Cycle (SPLC)
 - Establish SPLCP
 - Validate the process



Software Project Life Cycle Process



IEEE Std. 1074-1995

IEEE Std. 1074-2006

RG 1.173

Moved to Annex D

SQM Process

Title

V&V Process

How to map a SPLCP

Project Management adds Security Objectives

Project Planning adds Release Management

Plan System Transition

Software Importation Activity Groups

Manage Software Release

Identify Software Improvements Needed

Support Section of Activity Groups

Mapping, information, model examples with glossary and bibliography

Public Comment
Provide NRC citation for EPRI Topical Report

ACRS Comment
Add security

ACRS Comment be consistent with RG 1.152

Overview 1
Software LC Model Process 2
PM Processes 3
Pre-development Processes 4
Development Processes 5
Post-development Processes 6
Integral Processes 7
Bibliography 8

Overview 1
Definitions and acronyms 2
Key Concepts 3
Implementing the standard 4
Annex A.1
Annex A.2
Annex A.3
Annex A.4
Annex A.5
Annex B to F

Part A
Part B
RP 1(c)
RP 1(d)
RP 3(a&b)
RP 4(d)
Part C
RP 6 Annex
Part D
Ref.

RG 1.172

Software Requirement Specifications for Digital Computer Software and Complex Electronics used in Safety Systems of Nuclear Power Plants


- Background
- Review 6 Regulatory Guides (RGs):
 - RG 1.173 Project Management
 - **RG 1.172 Software Requirements Specifications**
 - RG 1.171 Unit Testing
 - RG 1.170 Test Documentation
 - RG 1.169 Configuration Management
 - RG 1.168 V&V Review Audits
- Conclusion

RG 1.172

Software Requirement Specifications for Digital Computer Software and Complex Electronics used in Safety Systems of Nuclear Power Plants

What does this RG do?

- Follows IEEE 830-1998 directly
- Objective: Create a Software Requirements Specification that delineates the function accurately without added constraints
- Traceability for both original baseline and future development
- Supports the SPLCP



RG 1.172

IEEE Std. 830-1993

Overview 1
References 2
Definitions 3
Considering for producing a good SRS 4
The parts of an SRS 5
Annex A

IEEE Std. 830-1998

Overview 1
References 2
Definitions 3
Considering for producing a good SRS 4
The parts of an SRS 5
Annex A & B



Unambiguous

Security

Annex B

Public Comment
Improve written
description

RG 1.172

Part A
Part B
RP 2(h)
RP 6(b)
Part C
RP 7 Annex
Part D
Ref.

RG 1.171

Software Unit Testing for Digital Computer Software used in Safety Systems of Nuclear Power Plants


- Background
- Review 6 Regulatory Guides (RGs):
 - RG 1.173 Project Management
 - RG 1.172 Software Requirements Specs
 - **RG 1.171 Unit Testing**
 - RG 1.170 Test Documentation
 - RG 1.169 Configuration Management
 - RG 1.168 V&V Review Audits
- Conclusion

RG 1.171

Software Unit Testing for Digital Computer Software used in Safety Systems of Nuclear Power Plants

What does this RG do?

- Follows IEEE 1008-1987 directly
- Objective: Provides emphasis on unit testing for software safety systems
- Smallest piece of software that can be independently tested



RG 1.171

IEEE Std. 1008-1987

Scope and References 1
Definitions 2
Unit Testing Activities 3
Annex A to D



RG 1.171

Part A
Part B
RP 5
Part C
RP 6 Annex
Part D
Ref.

References to
ANSI/IEEE Std. 829-1983

RG 1.170

Test Documentation for Digital Computer Software and Complex Electronics used in Safety Systems of Nuclear Power Plants


- Background
- Review 6 Regulatory Guides (RGs):
 - RG 1.173 Project Management
 - RG 1.172 Software Requirements Specs
 - RG 1.171 Unit Testing
 - **RG 1.170 Test Documentation**
 - RG 1.169 Configuration Management
 - RG 1.168 V&V Review Audits
- Conclusion

RG 1.170

Test Documentation for Digital Computer Software and Complex Electronics used in Safety Systems of Nuclear Power Plants

What does this RG do?

- Follows IEEE 829-2008 directly
- Objective: Create a software test plan that methodically documents the software requirements with a reportable demonstration of the unit, component, system and acceptance testing
- Follows a common framework with life cycle processes
- Applies to developing software in the life cycle and/or preexisting or pre-developed software
- Uses Software Integrity Level 4 with traceability, when reporting anomalies



RG 1.170

IEEE Std. 829-1983

Scope 1
Definitions 2
Test Plan 3
Test-Design Specification 4
Test-Case Specification 5
Test- Procedure Specification 6
Test-Item Transmittal Report 7
Test Log 8
Test-Incident Report 9
Test- Summary Report 10
Appendix A to D

IEEE Std. 829-2008

Overview 1
Normative 2
Definitions 3
Software & system integrity levels 4
Test Processes 5
Test Doc. content process 6
Test Doc. content addressed 7
MTP 8
LTP 9
LTD 10
LTC 11
LTPr 12
LTL 13
AR 14
LITSR 15
LTR 16
MTR 17
Annex A to H

RG 1.170

Part A
Part B
RP 1
RP 1(g)
RP 2
RP 3
RP 4
Part C
RP 6
RP 7
RP 8
RP 9
RP 10 Annex
Part D
Ref.

How to use
this Standard

Integrity Levels
Level 4 Safety
Systems

Test process
follows the
SPLCP

Selection process
Allow open entry /
no low integrity

Test
Documentation
Address and map

Master Test Plan
Establish deviation policy &
resolve variations

ACRS
Comment
delete "likely"
sentence

Improved issue
recording &
resolution

Annexes

Public
Comment
Improve phrase
to include items
a thru g

Highlights use of
LTL & AR
documentation

ACRS Comment
Adds failure recovery
software testing

Exception
Lowering Catastrophic
consequence

Adds emphasis to
Annex C; Table C.1

Recorded tool
documentation
easily accessible

Consider security
in beginning life
cycle areas

RG 1.169

Configuration Management Plans for Digital Computer Software and Complex Electronics used in Safety Systems of Nuclear Power Plants


- Background
- Review 6 Regulatory Guides (RGs):
 - RG 1.173 Project Management
 - RG 1.172 Software Requirements Specs
 - RG 1.171 Unit Testing
 - RG 1.170 Test Documentation
 - **RG 1.169 Configuration Management**
 - RG 1.168 V&V Review Audits
- Conclusion

RG 1.169

Configuration Management Plans for Digital Computer Software and Complex Electronics used in Safety Systems of Nuclear Power Plants

What does this RG do?

- Follows IEEE 828-2005 directly
- Objective: Addresses an integral SPLCP need for Software Configuration Management (SCM) plan with activities for tracking and reporting software safety system history from baseline to final use
- Enables sustainability of software development with release management and delivery
- Monitors and records version iterations and extends this discipline to preexisting software



RG 1.169

IEEE Std. 828-1990

Introduction to the standard 1
The Software Configuration Management Plan 2
Tailoring of the Plan 3
Conformance to the standard 4
Appendix

IEEE Std. 828-2005

Overview 1
Definitions and acronyms 2
The Software Configuration Management Plan 3
Adapting the Plan 4
Conformance to the standard 5
Annex A & B

RG 1.169

Part A
Part B
RP 4
RP 6
Part C
RP 7
RP 12
RP 14 Annex
Part D
Ref.



Outdated IEEE std. 1042-1987

Adds to management of the SCM process

Release management and delivery

Global term change from "tailoring" to "adapting"

Adds Annex A Bibliography

SCM Plan adds release management item

Control developed or commercial contracts

ACRS Comment Adds test cases line item

Public Comment Remove duplicate line item

Adds reference to EPRI dedication (TR)-106439

Public Comment Provide NRC citation for EPRI Topical Report



RG 1.168

Verification, Validation, Reviews, and Audits for Digital Computer Software and Complex Electronics used in Safety Systems of Nuclear Power Plants


- Background
- Review 6 Regulatory Guides (RGs):
 - RG 1.173 Project Management
 - RG 1.172 Software Requirements Specs
 - RG 1.171 Unit Testing
 - RG 1.170 Test Documentation
 - RG 1.169 Configuration Management
 - **RG 1.168 V&V Review Audits**
- Conclusion

RG 1.168

Verification, Validation, Reviews, and Audits for Digital Computer Software and Complex Electronics used in Safety Systems of Nuclear Power Plants

What does this RG do?

- Follows IEEE 1012-2004 and 1028-2008 directly
- Objectives:
 - Engage in verification and validation plans that follows the SPLCP to ensure objective assessments of software safety systems
 - Provide expectations for inspectors performing walk-throughs, reviews and audits
- Follows a common framework with life cycle processes and integrity level
- Applies to developing software in the life cycle and/or preexisting or pre-developed software



RG 1.168

IEEE Std. 1028-1997

Overview 1
References 2
Definitions 3
Management reviews 4
Technical reviews 5
Inspections 6
Walk-throughs 7
Audits 8
Annex A to C

Anomaly Classes

Anomaly Ranking

Annex A

IEEE Std. 1028-2008

Overview 1
Normative references 2
Definitions 3
Management reviews 4
Technical reviews 5
Inspections 6
Walk-throughs 7
Audits 8
Annex A to B

Management reviews adds plans & LC

Technical reviews adds specs & descriptions

Per inspectors adds software topics for review

Adds source docs, quality, & software history

Procedures adds inspection rate & author present at test

Anomaly ranking same as IEEE Std. 1012-2004 (no #s)

RG 1.168

Part A
Part B
Part C
Part D
Ref.

RG 1.168

IEEE Std. 1012-1998

Overview 1
Normative References 2
Definitions, abbreviations, and conventions 3
V&V software integrity levels 4
V&V process 5
Software V&V reporting, administrative and documentn requirements 6
SVVP outline 7
Annex A to H

Figure 1
SV&V
overview
moved after
Table 3

Figure 2
Time phasing
example
follows
Figure 1

7.6 moved
to 6.1

IEEE Std. 1012-2004

Overview 1
References 2
Definitions, abbreviations, and conventions 3
Software integrity levels 4
Software V&V process 5
Software V&V reporting, administrative and documentn requirements 6
Software V&V plan outline 7
Annex A to H

Adds Scope &
Field of application

Software
Integrity level
updated level description
with direction to select
integrity level

V&V intensity
with integrity level

Process
Management
adds 4 process
Improvement
tasks

Process
Development
adds LC Security
analysis tasks

Software
V&V Plan outline
adds task, activity,
anomaly, final and
special reports

Clause
7.7.4 security

Annex F, Fig.1 &
Annex B, Table B.3

Annex B, Table B.1 &
Annex C, Table C.1

RG 1.168

Part A
Part B
RP 1
RP 3
Part C
RP 4
RP 7(c)
RP 8 Annex
RP 8 Annex C
Part D
Ref.

New title
"Software Integrity"
vs. old "Critical
Software"

Public
Comment resolved
Contradiction on
Annex B & exception
to Table B.1 & B.3
adding "critical"

ACRS
Comment
deletes "likely"
sentence

Independence
of software V&V
exception to Annex
F blocks

ACRS
Comment
contradicting
paragraphs

Public Comment
Provide NRC
citation for EPRI
Topical Report

Adds Secure
Analysis with SDOE
for V&V activities

Tables C.1 adds
"condition independence"
which is not acceptable

Conclusion

- RGs updated
- RGs and IEEE Standards provide cohesive approach
- Common topics contemplated
- Key public comments addressed
- RGs ready for publication

Backup

Change Comparison between Standards

1074-2006

Overview 1
Definitions and acronyms 2
Key Concepts 3
Implementing the standard 4
Annex A.1
Annex A.2
Annex A.3
Annex A.4
Annex A.5
Annex B to F

830-1998

Overview 1
References 2
Definitions 3
Considering for producing a good SRS 4
The parts of an SRS 5
Annex A & B

1008-1987

Scope and References 1
Definitions 2
Unit Testing Activities 3
Annex A to D

829-2008

Overview 1
Normative 2
Definitions 3
Software & system integrity levels 4
Test Processes 5
Test Doc. content process 6
Test Doc. content addressed 7
MTP 8
LTP 9
LTD 10
LTC 11
LTPr 12
LTL 13
AR 14
LITSR 15
LTR 16
MTR 17
Annex A to H

828-2005

Overview 1
Definitions and acronyms 2
The Software Configuration Management Plan 3
Adapting the Plan 4
Conformance to the standard 5
Annex A & B

1028-2008

Overview 1
Normative references 2
Definitions 3
Management reviews 4
Technical reviews 5
Inspections 6
Walk- throughs 7
Audits 8
Annex A to B

1012-2004

Overview 1
References 2
Definitions, abbreviations, and conventions 3
Software integrity levels 4
Software V&V process 5
Software V&V reporting, administrative and documentn requirements 6
Software V&V plan outline 7
Annex A to H

Backup

Change Comparison between Regulatory Guides

RG 1.173

Part A
Part B
a.
b.
c.
Part C
d.
Part D
Ref.

RG 1.172

Part A
Part B
a.
b.
c.
Part C
d.
Part D
Ref.

RG 1.171

Part A
Part B
a.
b.
Part C
c.
Part D
Ref.

RG 1.170

Part A
Part B
a.
b.
c.
d.
e.
Part C
f.
g.
h.
i.
j.
Part D
Ref.

RG 1.169

Part A
Part B
a.
b.
c.
d.
e.
f.
Part C
g.
Part D
Ref.

RG 1.168

Part A
Part B
a.
b.
c.
d.
Part C
e.
f.
g.
Part D
Ref.

- **ACRS – Advisory Committee on Reactor Safeguards**
- **ADAMS – Agencywide Documents Access and Management System**
- **ANSI – American National Standards Institute**
- **AR – Anomaly Report**
- **CFR – Code of Federal Regulations**
- **DI&C – Digital Instrumentation and Control**
- **eDF – Électricité de France**
- **EPRI – Electric Power Research Institute**
- **IEC – International Electrotechnical Commission**
- **IEEE – Institute of Electrical and Electronics Engineers**
- **RG – Regulatory Guidance**
- **ISG – Interim Staff Guidance**
- **JPL – Jet Propulsion Lab**
- **LC – Life Cycle**
- **LER – Licensee Event Report**
- **LITSR – Level Interim Test Status Report**
- **LTC – Level Test Case**
- **LTD – Level Test Design**
- **LTL – Level Test Log**
- **LTP – Level Test Plan**
- **LTPr – Level Test Procedure**
- **LTR – Level Test Report**
- **MTP – Mast Test Plan**
- **MOU – Memorandum Of Understanding**

- **NASA – National Aeronautics and Space Administration**
- **NEA – Nuclear Energy Agency**
- **NRC – U.S. Nuclear Regulatory Commission**
- **NRR – Office of Nuclear Reactor Regulation**
- **NRO – Office of New Reactors**
- **NSIR – Nuclear Security and Incident Response**
- **NPP – Nuclear Power Plant**
- **OpE – Operational Experience**
- **QA – Quality Assurance**
- **RES – Office of Nuclear Regulatory Research**
- **RP – Regulatory Position**
- **SCM – Software Configuration Management**
- **SDOE – Secure Development and Operational Environment**
- **SPLC – Software Project Life Cycle**
- **SPLCP – Software Project Life Cycle Process**
- **SPLCM – Software Project Life Cycle Model**
- **SRM – Staff Requirement Memoranda**
- **SRS – Software Requirements Specification**
- **SwA – Software Assurance**
- **TR – Topical Report**
- **SVVP – Software Verification and Validation Plan**
- **V&V – Verification and Validation**

Beizer, B., Software Testing Techniques, Van Nostrand Reinhold, New York, NY, 1990.

Code of Federal Regulations (CFR), *Title 10, Energy*, Part 50,
“Domestic Licensing of Production and Utilization Facilities.”

Electric Power Research Institute (EPRI) Topical Report TR-106439,
“Guideline on Evaluation and Acceptance of Commercial Grade Digital Equipment for Nuclear Safety Applications,” EPRI, Palo Alto, CA, October 1996. (ADAMS Accession No. ML092190664)

IEEE Std. 1074-2006, “IEEE Standard for Developing a Software Project Life Cycle Process,”
IEEE, Piscataway, NJ, 2006.

IEEE Std. 830-1998, “IEEE Recommended Practice for Software Requirements Specifications,”
IEEE, Piscataway, NJ, 1998.

IEEE Std. 1008-1987, “IEEE Standard for Software Unit of Testing,” IEEE, Piscataway, NJ, 1987.

IEEE, Std. 829-2008, “IEEE Standard for Software and System Test Documentation,”
IEEE, Piscataway, NJ, 2008.


IEEE Std. 828-2005, “IEEE Standard for Software Configuration Management Plans,”
IEEE, Piscataway, NJ, 2005.

IEEE, Std. 1012-2004, “IEEE Standard for Software Verification and Validation,”
IEEE, Piscataway, NJ, 2004.

IEEE, Std. 1028-2008, “IEEE Standard for Software Reviews and Audits,” IEEE, Piscataway, NJ, 2008.

Backup – RG 1.173

Example from ACRS Subcommittee May 21, 2013



Station Blackout Mitigation Strategies Rulemaking

Advisory Committee on Reactor Safeguards
Full Committee
June 5, 2013

Purpose

- Discuss with the ACRS full committee the draft regulatory basis for the Station Blackout Mitigation Strategies rulemaking in conjunction with the status of the implementation of EA-12-049 (mitigating strategies order):
 - Basis for moving forward with rulemaking
 - Current thoughts on draft rule concepts (appendix)
- Obtain ACRS feedback to inform our regulatory efforts going forward

Background

- Previously briefed the Regulatory Policy and Practices Subcommittee on December 5, 2012 and on April 23, 2013
- COMSECY-13-0002 (dated 1/25/2013) revised the scope and schedule for the rulemaking recognizing the scope of EA-12-049 and the fact that it is addressing safety issues
- Revised scope and major schedule milestones:
 - Scope includes regulatory actions stemming from NTTF Recommendation 4 and 7
 - SBOMS Regulatory Basis: CA Note to the Commission - 7/8/2013
 - SBOMS Proposed Rule (with guidance): June 30, 2014 to the Commission
 - SBOMS Final Rule (with guidance): December 2016 to the Commission
- Issued SBOMS draft regulatory basis for 45 day comment period
 - Held a public meeting on May 13, 2013
 - Comment period ended May 28, 2013 and currently reviewing comments

Basis for SBOMS Rulemaking

- Mitigating strategies requirements issued in EA-12-049 were issued to all licensed power reactors
- The Order requirements need to be made generically-applicable
- Current station blackout requirements (sec. 50.63) do not provide for:
 - Station blackouts involving damage to both the onsite and offsite ac power sources from beyond design basis external events (including unavailability of alternate ac power)
 - Site-wide events (i.e., multiple power reactors in a station blackout)
 - Station blackouts that extend indefinitely
 - Spent fuel pool cooling
 - Not applicable in all modes of operation

ELAP Definition

- Conceptually an ELAP definition is an “SBO” that extends indefinitely
- Since this can involve severe external events the ELAP definition would assume that ac power sources (both the 1E sources and the SBO alternate ac source) are not available and can not be readily recovered in the near term
- Specifically the current concept would include:
 - Complete loss of ac power to the essential and nonessential switchgear busses
 - Loss of offsite power that results in a reactor trip and concurrent turbine trip
 - Unavailability and non-recoverability of onsite emergency ac power sources and offsite ac power sources continuing beyond the duration determined by the licensee per sec. 50.63
 - Unavailability and non-recoverability of a sec. 50.63 alternate ac power source (if relied upon to meet sec. 50.63 requirements)
 - ac power is available from inverters fed by safety-related batteries
 - If requirements are put in place by this rulemaking to allow for a “supplemental ac power source” – then this source would be available to restore power
 - Portable mitigating strategies equipment can be used to maintain/restore functions

Mitigating Strategies

- Mitigating strategies requirements would follow an approach similar to EA-12-049:
 - Develop, implement, and maintain guidance and strategies to maintain/restore core cooling, containment, and SFP cooling capabilities
 - Guidance and strategies would be required to be adapted for all modes
 - Equipment would be required to be of sufficient design and capacity considering the nominal conditions expected
 - Mitigating strategies must be required to consider contingencies
 - The strategies would be required to be integrated into existing station blackout procedures
 - The strategies would be required to accommodate the use of offsite assistance and resources including consideration of damage to transportation infrastructure
 - The regulatory framework would integrate with NNTF Recommendation 8 rulemaking requirements

Design Requirements

- Design requirements for equipment:
 - Equipment must be design to perform functions relied upon for ELAP mitigation
 - Portable equipment would be independent of installed SSCs
 - Portable equipment must be designed, stored, and protected to minimize common mode and common cause failure
 - Portable equipment would need to be protected from the effects of beyond design basis external events
 - Portable equipment would be designed, staged, and deployed to minimize potential damage or impairment to installed safety-related equipment
 - There needs to be sufficient sets of portable equipment to enable maintenance and testing
 - Design should enable periodic testing and inspection
 - A test program needs to be established to provide assurance of continued functionality

Supplemental AC Power Source

- Supplemental ac power source is a potential new design flexibility – in concept it would be:
 - Electrically independence from emergency ac power sources
 - Potentially diverse in design from current emergency ac power sources
 - Physically located to minimize common cause failure from external events
 - Capacity and capability to operate equipment necessary to maintain or restore core cooling, containment, and spent fuel pool cooling following a beyond design basis external event, for all units on a site
 - Supply power through physically and electrically separate pathways to multiple distribution systems or motor control centers
 - Designed to for external events to a margin \geq supplied equipment (at least one train of equipment)
 - Designed to interact with connected SSCs

Additional Concepts

- **Change Control**
 - Change control appears needed to control the configuration of the strategies, guidance and equipment relied upon over time
 - Current sec. 50.59 would typically not be effective for changes to the strategies, guidance, and equipment
 - The concept: ensure that changes continue to meet the new requirements or otherwise follow the sec. 50.90 amendment process to obtain prior NRC review and approval

- **Link with 10 CFR 50.63**
 - Mitigation of ELAP is linked into the current plant procedures in the emergency operating procedures (i.e., the station blackout EOP)
 - This links mitigating strategies with current station blackout procedures
 - Linking these requirements (sec. 50.63 and the new sec. 50.xxx) aligns the regulatory framework with implementation
 - Current concept is to amend sec. 50.63 to indicate that if a station blackout exceeds the specified duration (including the failure of an alternate ac power source) then the mitigating strategies are to be implemented

Next Steps

- Staff is currently considering the feedback and revising the regulatory basis accordingly
- We are required to provide a Commissioner Assistants (CA) Note on the regulatory basis in early July
 - We would appreciate ACRS feedback (if practical) to support the CA note
- We plan to proceed forward to proposed rule stage
- We plan to interact with ACRS on the proposed rule (2014) and final rule (2016)