

**Official Transcript of Proceedings**  
**NUCLEAR REGULATORY COMMISSION**

Title: Advisory Committee on Reactor Safeguards  
APR 1400 Subcommittee: Open Session

Docket Number: (n/a)

Location: Rockville, Maryland

Date: Wednesday, February 21, 2018

Work Order No.: NRC-3544

Pages 1-131

**NEAL R. GROSS AND CO., INC.**  
**Court Reporters and Transcribers**  
**1323 Rhode Island Avenue, N.W.**  
**Washington, D.C. 20005**  
**(202) 234-4433**

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S  
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION

+ + + + +

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS  
(ACRS)

+ + + + +

APR1400 SUBCOMMITTEE

+ + + + +

OPEN SESSION

+ + + + +

WEDNESDAY

FEBRUARY 21, 2018

+ + + + +

ROCKVILLE, MARYLAND

+ + + + +

The Subcommittee met at the Nuclear  
Regulatory Commission, Two White Flint North, Room T2B1,  
11545 Rockville Pike, at 8:30 a.m., Ronald G. Ballinger,  
Chairman, presiding.

COMMITTEE MEMBERS:

RONALD G. BALLINGER, Chairman

CHARLES H. BROWN, JR., Member

MICHAEL L. CORRADINI, Member

VESNA B. DIMITRIJEVIC, Member

1           WALTER L. KIRCHNER, Member  
2           JOSE A. MARCH-LEUBA, Member  
3           DANA A. POWERS, Member  
4           JOY L. REMPE, Member  
5           GORDON R. SKILLMAN, Member  
6           JOHN W. STETKAR, Member  
7           MATTHEW W. SUNSERI, Member

8  
9           DESIGNATED FEDERAL OFFICIAL:

10           CHRISTOPHER BROWN

11  
12           ALSO PRESENT:

13           TONY AHN, KHNP  
14           CLINTON ASHLEY, NRO  
15           ALEX BURJA, NRO\*  
16           NAN CHIEN, NRO  
17           CHUNG RAE CHO, Doosan  
18           GREG CRANSTON, NRO  
19           ANTONIO DIAS, NRO  
20           ADAKOU FOIL, NRR  
21           CHEWUNG HA, KHNP  
22           GARY HAYNER, Jensen Hughes  
23           RAUL HERNANDEZ, NRO  
24           ATA ISTAR, NRO

1 BHAGWAT JAIN, NRO  
2 RANDY JAMES, KHNP  
3 DAWNMATHEWS KALATHIVEETTIL, NRO  
4 JOO WAN KANG, KHNP  
5 SUNG HOON KANG, Doosan  
6 REBECCA KARAS, NRO  
7 JUNG-HO KIM, KHNP  
8 YOUNG MAN KWON, KEPCO E&C  
9 OLIVIA LAREYNIE, NRO  
10 HIEN LE, NRO  
11 HAKRO LEE, KHNP  
12 MARVIN LEWIS, Public Participant\*  
13 CHANG LI, NRO  
14 DAE HEON LIM, KEPCO E&C  
15 MARK LINTZ, NRO  
16 SHANLAI LU, NRO  
17 GREG MAKAR, NRO  
18 JIHONG MIN, KHNP  
19 MATTHEW MITCHELL, NRO  
20 RICHARD MORANTE, BNL\*  
21 ALISSA NEUHAUSEN, NRO  
22 RYAN NOLAN, NRO  
23 JIYONG OH, KHNP  
24 NGOLA OTTO, NRO

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MARIE POHIDA, NRO  
2 SHEILA RAY, NRR  
3 CAYETANO SANTOS, NRO  
4 THOMAS SCARBROUGH, NRO  
5 ROB SISK, Westinghouse  
6 JAMES STECKEL, NRO  
7 ANGELO STUBBS, NRO  
8 JEONG-KWAN SUH, KHNP  
9 MATT THOMAS, NRO  
10 VAUGHN THOMAS, NRO  
11 ANDREA D. VEIL, Executive Director, ACRS  
12 ROBERT VETTORI, NRO  
13 DAVE WAGNER, AECOM  
14 WILLIAM WARD, NRO  
15 GEORGE WUNDER, NRO  
16 ANDREW YESHNIK, NRO  
17 JINKYOO YOON, KHNP

18  
19 \*Present via telephone  
20  
21  
22  
23  
24

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24

T-A-B-L-E O-F C-O-N-T-E-N-T-S

PAGE

Opening Remarks & Objectives

By Ronald Ballinger, ACRS.....7

Staff Opening Remarks

By William Ward, NRO.....10

Chapter 9 Auxiliary Systems (Open) KHNP

By Hakro Lee, Joowan Kang.....11

Chapter 9 Auxiliary Systems (Open)

By NRC: George Wunder, Alex Burja,

Andrew Yeshnik, Bhagwat Jain,

Dawnmathews Kalathiveettil

BNL: Rich Morante.....28

Adjourn.....76

## P R O C E E D I N G S

8:30 a.m.

CHAIRMAN BALLINGER: The meeting will now come to order. This is a meeting of the APR1400 Subcommittee of the Advisory Committee on Reactor Safeguards. I'm Ron Ballinger, Chairman of the APR1400 Subcommittee.

ACRS members in attendance are Mike Corradini, Dick Skillman, Dana Powers, Matt Sunseri, John Stetkar, Jose March-Leuba, Walt Kirchner, Joy Rempe, and Vesna Dimitrijevic. I think I pronounced that right, a second time. Pretty good. I think Charlie Brown will arrive a little bit late.

First, today's meeting is for the Subcommittee to receive briefings from Korea Electric Power Corporation and Korea Hydro and Nuclear Power Company regarding their design certification, excuse me, application, and the NRC staff regarding their safety evaluation report with no open items specific to Chapter 9, Auxiliary Systems, 19.3, the undesigned base external vents, 19.4, loss of large area, and 19.5, aircraft impact assessment.

The ACRS was established by statute and is governed by the Federal Advisory Committee Act, FACA.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433



1       That means that the committee can only speak through  
2       its published letter reports. We hold meetings to gather  
3       information to support our deliberations. Interested  
4       parties who wish to provide comments can contact our  
5       offices requesting time after the meeting announcement  
6       is published in the Federal Register.

7               That said, we also set aside ten minutes  
8       for comments from members of the public attending or  
9       listening to our meetings. Written comments are also  
10      welcome.

11              The ACRS section of the USNRC public website  
12      provides our charter, bylaws, and letter reports, and  
13      full transcripts of all full and subcommittee meetings,  
14      including slides presented at the meeting. The rules  
15      for -- for participation -- participation in today's  
16      meeting were announced in the Federal Register on Friday,  
17      February 21st, 2018 -- not.

18              The meeting was announced as an open and  
19      closed to public meeting. This means that the chairman  
20      can close the meeting as needed to protect information  
21      proprietary to KHNP or its vendors.

22              That means this afternoon's, after the  
23      break meeting, according to our schedule, they're marked  
24      closed. They're closed for the purposes of the staff

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

1       wanting to avoid having to open and close things if  
2       they make -- if there are discussions related to  
3       proprietary information.

4               No requests for making a statement to the  
5       Subcommittee has been received from the public. A  
6       transcript of the meeting is being kept and will be  
7       made available as stated in the Federal Register notice.

8       Therefore, I request that participants in this meeting  
9       use the microphones located throughout the meeting room  
10      when addressing the Subcommittee. Participants should  
11      first identify themselves and speak with sufficient  
12      clarity and volume so they can be regularly heard.

13             Not to presenters, there's a small black  
14      microphone in front of you. When you speak, please  
15      be sure that the green light on the top of the microphone  
16      is glowing green. To make this happen, you must press  
17      the pad at the base of the microphone.

18             We have a bridge line established for  
19      interested members of the public to listen in. The  
20      bridge number and password were published in the agenda  
21      posted on the NRC public website.

22             To minimize disturbance, the public line  
23      will be kept in the listen only mode. And I understand  
24      we have two lines open for staff members to participate.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       The public will have an opportunity to make a statement  
2       or provide comments at the designated time towards the  
3       end of the meeting, actually, towards the end of the  
4       Chapter 9, or at the end of the Chapter 9 session  
5       presentations.

6               NRO staff and contractors are on a separate  
7       bridge line for Chapter 9. We ask that the staff place  
8       their phone on mute until you are called upon. And  
9       we'll do some signaling to make that happen.

10              Now Bill is here, yes. I now invite Bill  
11       Ward, NRO project manager, to introduce the presenters  
12       and start the briefing. Bill?

13              MR. WARD: Thank you. This meeting is third  
14       to the last of the subcommittees. We're really happy  
15       that we are making good progress on this, and we hope  
16       we can meet the dates of the other two. As they're  
17       scheduled, I don't see any problem with that. And we're  
18       glad to be here again and hope we answer all your questions.

19       Thank you.

20              This is Rob Sisk, Westinghouse, consulting  
21       to KHNP. Just again, appreciate the opportunity to  
22       present the APR1400 as we continue through the review  
23       process. And without further ado, I'd like to introduce  
24       Mr. Hakro Lee to lead us through Chapter 9.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. H. LEE: Good morning, ladies and  
2 gentlemen. This is Hakro Lee from KHNP. This  
3 presentation is for the Chapter 9 which covers auxiliary  
4 system for APR1400 design.

5 The contents are provided in this slide.  
6 Main contents are overview of Chapter 9, 9.1.2, new  
7 and spent fuel storage, summary of main topic in Section  
8 9.1.2, summary of open items, response to Phase 3  
9 questions, current status, and attachments. Here we  
10 can see an overview of the titles and major contents  
11 each section in DCD.

12 The following documents have been submitted  
13 for addition to Chapter 9. There were five open items  
14 in full Committee in last July. These are three of  
15 the main topics. Description of issue and resolution  
16 for each item will be described in orderly.

17 These items are five open items.  
18 Description of issue and resolution for each open item  
19 will be described in orderly. From now on, 9.1.2 new  
20 and spent fuel storage will be presented by Mr. Kang.

21 MR. KANG: Good morning, ladies and  
22 gentlemen, my name is Joowan Kang from Tucson. I am  
23 going to start with introducing redesign pictures of  
24 fuel racks in DCD Section 9.1.2.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           The new spent fuel racks are constructed  
2 of stainless steel and designed as a seismic Category  
3 1. For NFSR, two modules are located in the New Fuel  
4 Storage Pit. The remaining pieces of NFSR are bolted  
5 to the embedment plate at the bottom of the pit to preclude  
6 tipping during seismic events.

7           For SFSR, 29 modules are located in the  
8 spent fuel pool which consists of over six vents in  
9 Region I and 23 vents in Region II. The main features  
10 of SFSR modules are free-standing with a pedestal.  
11 That's the base plate.

12           Installation of SFSR modules in the spent  
13 fuel pool, they are surmounted in borated water with  
14 the space between the racks and cell walls at all times,  
15 especially to keep the reaction of several material  
16 as called METAMIC is used.

17           Next. This slide shows the safety  
18 evaluation of event. As the background of this slide,  
19 the revision chair or technical report for fuel racks,  
20 mechanical analysis was issued on December 2014 at the  
21 8:38:25, RAI 8272. The latest technical report was  
22 revised as a revision study on August 2017 to reflect  
23 resolutions.

24           As of the recent oral evaluation, the seismic

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 models were proposed 36 cases dynamic simulations to  
2 determine the loads and displacement for the racks.  
3 The structural evaluation results shows that the new  
4 and spent fuel cylinders met the requirement as  
5 specified on SRP 3.8.4, Appendix D, and ASME Section  
6 III, Subsection NF, Class 3.

7 The postulated mechanical accident analysis  
8 are performed based on the impact image and configuration  
9 of each rack scenario as well. An evaluation result  
10 of each rack scenario, the new and spent fuel racks  
11 are just acceptable modules of safety and no effect  
12 on the computation to maintain a civil criticality  
13 over the fuel.

14 Next. This slide is related to the number  
15 time histories and the critical discretion of artificial  
16 time histories based on SRP 3.7.1, Option 2. It stated  
17 that for nonlinear structural analysis the number of  
18 time histories should be greater than four. Therefore,  
19 we provide that for the number of time history sets.

20 Five sets of artificial acceleration time  
21 histories were developed to match the safe shutdown  
22 escape instruction as far as background.

23 MEMBER REMPE: There was a message a few  
24 minutes ago that you needed to plug in your computer.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       You're about out of power.

2               CHAIRMAN BALLINGER: What is it that you  
3       can't see?

4               MEMBER REMPE: Someone, ha, ha, ha.

5               CHAIRMAN BALLINGER: We're on it.

6               (Off the record comments)

7               CHAIRMAN BALLINGER: For those of you who  
8       may be listening on the phone, the presentation computer  
9       died. And we're resurrecting it. So hold on for a few  
10      minutes.

11              MEMBER POWERS: In his testimony before  
12      a Senate committee, former Chairman Dick Meserve, when  
13      asked what he had discovered about nuclear engineers  
14      said, "One of my findings is they cannot talk without  
15      view graphs."

16              (Laughter)

17              CHAIRMAN BALLINGER: There are exceptions.

18              MEMBER POWERS: They cannot talk well  
19      without view graphs.

20              (Laughter)

21              CHAIRMAN BALLINGER: There are exceptions.

22              MEMBER STETKAR: The appropriate  
23      characterization ends with a period after the word well.

24              (Laughter)

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BALLINGER: Theron, how long do  
2 you think it's going to take?

3 (Off the record comments)

4 (Whereupon, the above-entitled matter went  
5 off the record at 8:43 a.m. and resumed at 8:48 a.m.)

6 CHAIRMAN BALLINGER: Okay, we're back in  
7 session. Thank you for being considerate, or  
8 inconsiderate.

9 MR. KANG: This slide is related to the  
10 number of time histories and technical justification  
11 of artificial time history sets based on SRP 3.7.1,  
12 Option 2. It states that for manual rises to the number  
13 of time histories should be greater than four.  
14 Therefore, we provided that for the number of time history  
15 sets.

16 Five sets of artificial acceleration time  
17 histories were developed to match the safe shutdown  
18 earthquake instruction response criteria. Also we  
19 provided technical participation for artificial time  
20 history sets to review and provided on Section 3 of  
21 technical report. The results showed that the  
22 suitability of the time histories was verified, according  
23 to SRP 3.7.1.

24 Next. This slide relate to the study of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 a seismic analysis of racks. Due to free-standing fuel  
2 storage rack modules in the pool, the seismic response  
3 are nonlinear and involve a complex combination of  
4 emulsions, so just to provide additional information  
5 about the structure around the modeling.

6 First, sufficient information of the rack  
7 and fuel assembly model and it's parameters. Second,  
8 sensitivity analysis results of the impact force and  
9 rack response to variation in spring constants. Third,  
10 sensitivity analysis results of integration time step  
11 used in performing the seismic analyses for SSE.

12 The next slide show what be provided. Next?  
13 What we provided for information is a detailed  
14 description of the rack and fuel assembly model for  
15 seismic analysis. And model element properties are  
16 derived from the dynamic characteristics of the detailed  
17 3-D shell model of the racks.

18 What we performed is sensitivity analysis  
19 for spring constants in the model, such as rack-to-rack,  
20 rack-to-floor, and fuel-to-rack. And comparison of  
21 a run at one half the fixed time step used for all other  
22 runs.

23 What is provided for analysis result is  
24 the effect of sensitivities was a change in the predicted

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 loads within the variation found for different time  
2 histories and less than the variation for different  
3 function depletion, such as CHERIFON 2, CHERIFON 5,  
4 and CHERIFON 8.

5 Next? This slide relates to mechanical  
6 accident analysis. First, we had to consider detailed  
7 evaluation for drop accident analysis. First, consider  
8 finite element model on evaluation of a nonlinear dynamic  
9 analysis for the impact effect of drop accidents.  
10 Second, consider deep drop locations to maximize the  
11 deformation of the rack base plate. Third, consider  
12 all other fuel assemblies in place when a fuel assembly  
13 drops through an empty cell.

14 Next? This slide is a resolution we gave.  
15 All drop accidents analyzed by developing a finite  
16 element model of a rack, base plate, a fuel assembly,  
17 and the pedestal using ANSYS LSDYNA program to evaluate  
18 maximum plate, drops are considered at the two locations  
19 that maximize the distance of the point of support.  
20 And drop analysis model was considered fully loaded.

21 As a different analysis result, loss of  
22 breastplate such as a puncture has not occurred. The  
23 breastplate of the new and spent fuel storage racks  
24 are calculated per 2.99 inch and 2.72 inch respectively.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1           These value are less than that the minimum  
2           disturbance between the breastplate and the drying  
3           surface. Therefore, throughout the simulation, the  
4           NFSR base plate to contain the pit flow or the SFSR  
5           base plate to protect the fuel liner.

6           Next? From now on, we will present five  
7           open items in Phase 3 and a list of them. The staff  
8           checked RAI 8191 (Q 09.01.01-13) as an open item. The  
9           staff gets to confirm that mechanical accidents do not  
10          cause the rack deformation that would affect criticality.

11          The resolution related that -- and the damage  
12          of -- any damages to the rack is limited to the portion  
13          above the neutron absorber and does not affect their  
14          configuration relative to the criticality analysis.  
15          The staff's review for the technical report was completed.

16          Next? This slide relates to neutron  
17          absorber material. The staff has the RAI 8578 (Q  
18          09.01.01-39) as an open item. The purification process  
19          of the standard fuel rack may expose the Metamic neutron  
20          absorber to evaluate the temperature really in close  
21          proximity.

22          So staff concerns regarding the adequacy  
23          of utilizing as-fabricated Metamic coupons in the neutron  
24          absorber monitoring program The resolution we did is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 that purification test exposure to Metamic material  
2 to 1900 giga Fahrenheit for 48 hours and demonstrates  
3 no change in the run obstruction. This item is closed.

4 The next presenter is Mr. Lee again.

5 MR. H. LEE: So from now on I'm going to  
6 present again. The staff stressed RAI 8582 (Q  
7 09.01.03-4) is an open item. Related to this open item,  
8 the staff requested to identify the minimum safety water  
9 level and update the DCD accordingly, also requested  
10 to revise the thermal-hydraulic calculations using the  
11 minimum safety water level.

12 The minimum safety water level was provided  
13 in the response to RAI 8582 (Q 09.01.03-4) In addition,  
14 thermal-hydraulic analysis report was also revised.

15 Additionally, the staff identified that  
16 the normal water level has been identified as elevation  
17 154 feet, while in other places it shows as elevation  
18 153 feet. These two levels represent different  
19 conditions through the response to RAI 8582 (Q  
20 09.01.03-5).

21 The staff stressed RAI 8613 (Q 09.05.02-4)  
22 as an open item. Related to the requirements of 10  
23 CFR Part 50, Appendix A, GDC 1 through GDC 4, the staff  
24 requested to justify why the communication systems are

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 not considered as risk significant SSCs.

2 The staff issued a follow-up RAI 548-8822, (Q 09.05.02-6)  
3 related to this open item.

4 KHNP responded that the communication  
5 systems of the APR1400 are designed to meet GDC 1 through  
6 GDC 4 and do not interface with any safety-related or  
7 risk-significant SSC. The four communication  
8 subsystems are designed to assure that any single event  
9 does not result in a complete loss of plant communication.

10 The staff stressed RAI 8613 (Q 09.05.02-5)  
11 as an open item. The staff requested to provide the  
12 detailed description of all ITAAC items along with their  
13 acceptance criteria and ITP for the communication systems  
14 in Section 14.2.

15 In addition, the staff requested to clarify  
16 what the applicant means by functional arrangement of  
17 communication systems. Related to this open item, the  
18 staff issued a follow-up RAI 8822, (Q 09.05.02-7).

19 KHNP provided the new ITP for plant  
20 communication system and the detailed description of  
21 all ITAAC items for communication system through the  
22 response to the follow-up RAI.

23 And KHNP revised DCD Tier 1, Subsection  
24 2.6.9 providing the detailed description of plant

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 communication systems instead of the term of functional  
2 arrangement.

3 So from now on, I will answer the question  
4 in ACRS Subcommittee on May 18th, 2017. During KHNP  
5 presentation on Section 927 Chilled Water System, ACRS  
6 asked about the basis for the non-safety-related plant  
7 chilled water system to provide cooling water for the  
8 safety-related TDAFW pump room.

9 I will explain the reason why the  
10 non-safety-related cubicle cooler is installed in the  
11 TDAFW pump room. It is basic principle to use the  
12 safety-related HVAC system to cool the area where a  
13 safety-related accumulation is located.

14 In case of TDAFW pump room, the non-safety  
15 cubicle cooler is installed, and it does not serve any  
16 cooling function at accident condition. The reason  
17 why non-safety related cubicle cooler is applied for  
18 the room is that the room is high energy line break,  
19 HELB, area which means the essential chilled water just  
20 have temp would be damaging and have accident if the  
21 cubicle cooler is safety-related.

22 Because of loss of cooling during accident,  
23 the TDAFW pump shall be qualified to be operable at  
24 maximum temperature for the operation period.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   Now I will explain the summary for heat-up  
2 calculation of TDAFW pump room. The purpose of the  
3 room heat-up calculation is as follows. First,  
4 determine the maximum temperature in the TDAFW pump  
5 room. Second, demonstrate that the maximum temperature  
6 of the room does not exceed the maximum allowable  
7 temperature during 72 hours under loss of HVAC system.

8                   The GOTHIC program is used to perform heat-up  
9 calculation. Maximum allowable temperature, 150  
10 Fahrenheit degrees of the room, is decided based on  
11 the steady-state temperature of Condition 2 mentioned  
12 in NUMARC 87-00. The maximum temperature of TDAFW pump  
13 room is about 155 -- 145 Fahrenheit degrees. The TDAFA  
14 pump rooms are maintained below 150 Fahrenheit degrees  
15 during 72 hours and under loss of cooling.

16                  MEMBER STETKAR: Does that maximum  
17 temperature occur at 72 hours? In other words, is the  
18 temperature still increasing at 72 hours?

19                  MR. H. LEE: Sorry, would you say again?

20                  MEMBER STETKAR: Does the maximum  
21 temperature of whatever you cited, 145 degrees, occur  
22 at 72 hours? Or, what I'm asking is, is the temperature  
23 still increasing at 72 hours?

24                  MR. H. LEE: The equivalent temperature

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 condition is 145 during 72 hours.

2 MEMBER STETKAR: What I'm asking is, what  
3 we asked you for was to show us the temperature profile.

4 I have not yet seen that temperature profile.

5 (Off the record comments)

6 MR. SISK: This is Rob Sisk. Just to  
7 clarify, the temperature profile, it increases up to  
8 145. It is more asymptotic. It does not continue up  
9 at a continual rate. But it asymptotically reaches  
10 145 and stays.

11 MEMBER STETKAR: Could you tell me when  
12 it reaches 120 degrees?

13 (Off the record comments)

14 CHAIRMAN BALLINGER: So to be clear, we  
15 do not have the exact profile here. But the approximate  
16 value, it hits 120 in about 16 hours.

17 MEMBER STETKAR: Sixteen hours, okay,  
18 that's interesting. Do the turbine-driven auxiliary  
19 feedwater pumps have electronic speed control? And  
20 is there any instrumentation located in the  
21 turbine-driven auxiliary feedwater pump room that  
22 controls either turbine operation, or auxiliary  
23 feedwater flow, or steam generator level, or information  
24 in the main control room?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 MR. SISK: We do not have that information  
2 available.

3 MEMBER STETKAR: The reason I ask these  
4 questions ---

5 (Off the record comments)

6 MR. YOON: I am Mr. Yoon from KHNP,  
7 Administrative Office. The equipment related to  
8 turbine-driven aux feedwater pump, and something like  
9 that, that equipment is located in another room, not  
10 installed in that room, of course, to prevent damages  
11 in the event of high energy line break.

12 MEMBER STETKAR: To me, that doesn't make  
13 much sense. Because if the steam line breaks, I don't  
14 have the turbine-driven pump. So I don't understand  
15 why I have to install the equipment in another room.

16 But if you say that on the record, you are now on the  
17 record that any electronic equipment for the  
18 turbine-driven pump and instrumentation is not located  
19 in the turbine-driven pump room. Is that correct?

20 MR. YOON: Yes.

21 MEMBER STETKAR: Hum? You are now on the  
22 public record in a meeting saying that is part of your  
23 design? I was not aware of that. That's an important  
24 piece of information.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. YOON: As I'm -- to my knowledge, the  
2 pressure transmitter is located in the containment.  
3 So turbine-driven fuel pump is located in the aux  
4 building.

5 MEMBER STETKAR: I understand that. But  
6 I'm asking -- I didn't ask about a pressure transmitter.

7 I asked whether there was any -- the reason I -- let  
8 me cut to the chase. The reason I'm asking this is  
9 that I have read documents that indicate that the maximum  
10 allowable temperature in several locations in the plant  
11 that contain, I'll just call it electrical and INC  
12 equipment, is 120 degrees Fahrenheit, the maximum  
13 allowable temperature. And that's a fairly typical  
14 temperature for qualification of that type of equipment.

15 However, you state that the maximum  
16 allowable temperature, in the turbine-driven auxiliary  
17 feedwater pump rooms in particular, is 150 degrees  
18 Fahrenheit, 30 degrees higher.

19 That to me says, well, you either have to  
20 have electronic equipment that is qualified to be better  
21 than all of the other electronic equipment in your plant,  
22 or you don't have any electronic equipment in that room,  
23 or it's qualified to 120 degrees. And that's why I  
24 was interested in when you had reached 120 degrees in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 your room heat-up calculation.

2 So if there's no electronic equipment in  
3 that room, which we just heard on the public record,  
4 the official record of our meeting, then I don't have  
5 a problem. But that is now our understanding of your  
6 design.

7 MEMBER REMPE: Further, can we ask if that's  
8 the way Shin Kori is designed and built?

9 MEMBER STETKAR: I'll just note they can  
10 design this one differently than Shin Kori.

11 MEMBER REMPE: They can, but I just am  
12 curious if they've changed it from Shin Kori.

13 MR. H. LEE: From my colleague, I received  
14 some kind of related information about your question.  
15 I mentioned that when we decided the maximum temperature  
16 in each room, it incorporated to our purchased  
17 specification later. So I'm not sure that electrical  
18 panel or some kind of equipment shall be located in  
19 some rooms. We're not --

20 MEMBER STETKAR: We have it on the record.  
21 The staff has our question.

22 MR. SISK: We don't have the information  
23 at this point for Shin Kori. Andy?

24 MR. OH: At this point in Shin Kori, this

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 is Andy Oh, KHNP Washington Office, at this point we  
2 don't have the information for Shin Kori.

3 MR. H. LEE: I will continue on my  
4 presentation. Chapter 9 is complete. KHNP continues  
5 to monitor Chapter 9 to assure any confirming changes  
6 that are addressed. Five open items that were identified  
7 in Phase 2 and 3 have been resolved with adequate and  
8 sufficient discussion with the staff.

9 Changes in Chapter 9 as reviewed and marked  
10 up in response to the RAIs will be incorporated into  
11 the next revision of the DCD. Thank you for listening.

12 MR. SISK: And that concludes the Chapter  
13 9 presentation. We want to leave time for questions  
14 if there were any.

15 CHAIRMAN BALLINGER: Any additional  
16 questions from the members? Thank you. And we get ---  
17 no? Ready for the staff's presentation?

18 MALE PARTICIPANT: Is it closed?

19 CHAIRMAN BALLINGER: No, Chapter 9 is not  
20 closed.

21 There are two staff members who are on the  
22 phone, we think. Can you identify yourselves just so  
23 that we're sure that you're there please?

24 MR. MORANTE: This is Rich Morante from

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Brookhaven National Laboratory on the phone.

2 CHAIRMAN BALLINGER: Thank you.

3 MS. BURJA: And this is Alex Burja from  
4 the Reactor Systems Branch.

5 CHAIRMAN BALLINGER: Thank you. I'm not  
6 sure what the order is, who's doing what when.

7 (Off the record comments)

8 MR. WUNDER: Okay, good morning, Mr.  
9 Chairman, ladies, and gentlemen of the Committee. I'm  
10 George Wunder, and I'm the project manager for Chapter  
11 9 of the APR 1400 design certification review.

12 Last month we presented Chapter 4 to you.  
13 And at that time I told you that the team had put that  
14 together, that chapter together. It was like the 1927  
15 Yankees of review teams. Well, the team that I'm going  
16 to introduce to you today, they're more like the 1969  
17 Mets. And I say that because --

18 (Laughter)

19 MR. WUNDER: -- I say that because --

20 MALE PARTICIPANT: Nobody is sure about  
21 the Mets.

22 MR. WUNDER: I say that because I think  
23 it's -- sometimes I think it's a miracle that we got  
24 this thing done. Thank you. As you can see at a glance,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       there are multiple contributors. I think there are  
2       19 of them plus our consultant makes 20.

3               And when you have that many contributors,  
4       it makes for some unique problems for the project manager  
5       to coordinate and integrate it all into a unified chapter.

6       And it would have been nigh impossible had not everyone  
7       on the technical staff done such a wonderful and  
8       professional job.

9               So it's a real pleasure to introduce the  
10       team. From the Plant Systems Branch, we have Raul  
11       Hernandez, Hien Le, Chang Li, Angelo Stubbs. And this  
12       is my favorite part, whereas the 1969 Mets had Nolan  
13       Ryan, we've got Ryan Nolan -- can't make this stuff  
14       up -- also Bob Vettori, Dennis Andrukat, and Thinh Dinh  
15       from the Materials and Chemical Engineering Branch.

16              Sir?

17              MEMBER KIRCHNER: Where are Sever and  
18       Darling?

19              MR. WUNDER: Sever's right there.

20              (Laughter)

21              MR. WUNDER: From the Material and Chemical  
22       Engineering Branch we have Andrew Yeshnik, John  
23       Honcharik, Greg Makar, from the Containment and  
24       Ventilation Branch, Danny Chien. From Structural

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 Engineering we have Vaughn Thomas, Pravin Patel, and  
2 B.P. Jain. We have Dawnmathews Kalathiveettil from  
3 the Instrumentation and Control Branch, Alexandra Burja  
4 who is joining us on the phone from Reactor Systems,  
5 and Adakou Foil, and Sheila Ray from way over in NRR  
6 in the Electrical Engineering Group.

7 We also have our outstanding consultant  
8 from Brookhaven National Lab, Rich Morante, who's also  
9 joining us on the phone. And I would be remiss if I  
10 did not mention the incredibly valuable contribution  
11 of two of our project managers, Carolyn Lauron and Brian  
12 Hughes, who stepped in when I was called out of town  
13 on an emergency. And they put in many, many very long  
14 hours to make sure that we got this thing done by our  
15 deadline. And finally, in the roll of Gil Hodges, we  
16 have our extremely able lead project manager, Bill Ward.

17 We have not presented Section 9.1.2 to the  
18 Subcommittee prior to this. So I thought we'd start  
19 off with that section, and then we can move on and go  
20 over the open items in the remaining sections.

21 So I am joined by B.P. Jain, and Rich Morante  
22 is on the phone. And I'm going to turn you over to  
23 B.P. for Section 9.1.2. Thank you. B.P., take it away  
24 when you're ready.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. JAIN: Goodmorning. This is B.P. Jain.

2 I'd like to acknowledge my team who have contributed  
3 to the review of this complex section, Vaughn Thomas,  
4 Pravin Patel, and Rich Morante at BNL.

5 So here I am basically going over the work  
6 this team did and reviewing the fuel racks, spent fuel  
7 pool racks. So the primary objective under this review  
8 is to view the structural design and mechanical design  
9 of the fuel storage racks to make sure that they can  
10 withstand effects of outbreaks and mechanical accident  
11 loads resulting from the fuel assembly drops.

12 The other complements with this fuel pool  
13 and the liner have been presented before, so I will  
14 not address those. And they were covered under Section  
15 38346. And the same thing goes with criticality  
16 evaluation, I would not address that. It's been  
17 addressed by the staff in the SER Section, 911.

18 So overall, we will be addressing more --  
19 just to give you an overview of what I'm going to be  
20 talking about and what the staff did to review this  
21 new fuel and the spent fuel pool structure --

22 MEMBER REMPE: B.P., just be very careful.  
23 Your papers were hitting the microphone. And that makes  
24 the poor little guy that's the reporter --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 MR. JAIN: I'll be careful.

2 MEMBER REMPE: -- literally going deaf.

3 MR. JAIN: I'll be careful. So overall,  
4 the high level overview, to give you the presentation,  
5 the staff reviewed the KHNP's technical report and the  
6 mechanical analysis for new and spent fuel pool racks.  
7 It was around three in August 17. And the review basis  
8 for the staff is guidance in Appendix B of the SRP 3.8.4  
9 with the appropriate title, Guidance in Spent Fuel Pool  
10 Racks.

11 The staff reviewed the seismic input  
12 analysis to the mathematical model of the racks and  
13 the non-linear analysis which the KHNP performed. The  
14 staff also reviewed the mechanical accident scenarios,  
15 especially resulting stresses and what scenarios they  
16 have considered.

17 Staff looked at the computer codes they  
18 used and see if they are reasonable for the kind of  
19 problem they are trying to solve.

20 Staff reviewed the analysis methodology  
21 including the design parameters which went into making  
22 the model, such as the hydrodynamic loads, the gap springs  
23 for rattling, and so on and so forth.

24 Overall, we sat back and looked at the ---

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 it's a very complex problem, a lot of input goes into  
2 it. It's a non-linear problem. So staff looked at the  
3 reasonableness of the results. Do the results make  
4 sense, and not really going micro, analyzing each and  
5 every parameter.

6 Staff also looked at the COL item that the  
7 KHNP identified. During this process, staff had 39  
8 RAIs. And KHNP did an excellent job in responding to  
9 all of them. And there are no open RAIs remaining.

10 So the staff basically concludes at a high  
11 level that these racks and these complements meet the  
12 applicable ASME code allowable stresses. And the  
13 seismic displacements of these racks, because spent  
14 fuel pool rack is free-standing, are small compared  
15 to the physical dimensions of the design. And they  
16 would not invalidate the criticality analysis which  
17 has been performed under a different section, 9.11.

18 And the other concern with these  
19 free-standing racks is would they impact the pool wall.

20 And the staff assured itself that they would not.  
21 Displacements are small. So that's overall the real  
22 strategy, what the staff looked at.

23 MEMBER SKILLMAN: Let me ask this question,  
24 please. From your overall strategy, to what extent

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 are the results that you are communicating dependent  
2 upon a precision of installation of the racks?

3 MR. JAIN: They are not related to the  
4 precision of installation of the rack, I can say after  
5 the fact. Because the displacements are, even if they  
6 were uncertain -- there are uncertainties, obviously,  
7 in any of these analyses -- the fact of safety or additional  
8 margins, what we find will, in our judgement, more than  
9 compensate for some of those things.

10 MEMBER SKILLMAN: Can you cite an  
11 approximate dimension that is allowable between the  
12 installed racks? Is it a centimeter, half a centimeter,  
13 half an inch, three-quarters of an inch?

14 MR. JAIN: The way these -- they are  
15 installed, the base plates are pretty close to each  
16 other. And I believe the, if I recall the dimensions,  
17 like, one inch between the base plate and one class  
18 of racks. Another class of racks, it's a couple of  
19 inches. And the displacement, just to give you an order  
20 of magnitude, is like quarter inch due to seismic.  
21 So even if it was, you know, you double the displacements,  
22 it still would not close the gap.

23 MEMBER SKILLMAN: Thank you.

24 MR. JAIN: So just to focus, what the focus

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 area -- what the staff looked at, and again this was  
2 guided more by the staff guidance in SRP 3.8.4., so  
3 we looked at the physical description of the racks and  
4 the arrangements, then striations. Staff also looked  
5 at what are the applicable design codes, standards,  
6 and specifications for manufacturing these racks.

7 Obviously, seismic and impact loads are  
8 the big part of it, because they are free standing racks.

9 Again, we wanted to make sure that we considered all  
10 the loads, the load combinations for various scenarios  
11 of allowable stresses.

12 We looked at them with analogy first, just  
13 to analyze the design, and what the acceptance criteria,  
14 when you say they have met the allowables, and things  
15 like materials, appropriate quality control programs,  
16 things of that nature, we also looked at.

17 The physical descriptions, and I would not  
18 go over that. I think KHNP has covered, but at a high  
19 level, there were a few figures which have been pulled  
20 out with production, where a pictorial view of the plant,  
21 how these racks are sitting in the pool.

22 But basically, the new fuel racks, they  
23 are sitting in a pit. And the highlight of that is  
24 it's bolted to the floor. So it's not free-standing.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1        So it's less critical during seismic movement. They  
2        are constructed with the same stainless steel material  
3        as the spent fuel pool racks. And they are spaced at  
4        14 inches fuel assemblies for criticality, of  
5        sub-criticality maintainment.

6                Next? The spent fuel pool racks are  
7        different in the sense that they are free-standing,  
8        and there is a gap between the racks and between the  
9        racks and the pool wall. By the way, just a gap between  
10       the racks and the pool wall is about 33 inches. So  
11       it's quite substantial. It's not sitting right next  
12       to it.

13               Again, the pool is divided, for talking  
14       purposes, two type of racks, Region I, Region II. They  
15       have a different configuration. Pitch is different,  
16       but nothing else. And from a structural point of view,  
17       it does not make much difference whether call it Region  
18       I rack or Region II racks.

19               So the staff looked at their physical  
20       descriptions and the level of detail they provided in  
21       their DCD and the tech report and determined that the  
22       guidance in SRP is fully complied with. So it's  
23       consistent with the guidance, the physical description,  
24       and the staff finds it acceptable. This shows just

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the isometric view of the typical rack.

2 The staff reviewed KHNP's design core  
3 standards and specifications, what they indicated in  
4 their tech report. And for material, they used some  
5 ASME code Section 2 and ASME Section 3 for designing  
6 core section and Appendix F. And they used -- Reg Guide  
7 1.61 they cited and Reg Guide 1.29. These are the key  
8 documents there.

9 There are other materials they have  
10 referenced, but that's all, again, consistent with what  
11 the SRP guidance 384 calls out for in terms of the codes,  
12 and specifications, and the reg guides. So staff finds  
13 that they are all consistent, and therefore the codes  
14 and standard they have used are acceptable to the staff.

15 So the seismic analysis makes a big chunk  
16 of staff's review of these racks and primarily because  
17 of the complex, free-standing structure. It's  
18 non-linear in nature. So staff had a lot of questions  
19 and understood, at the end of the day, staff ensured  
20 that they meet all the applicable requirements of the  
21 SRP guidance and analysis methodology.

22 Just to go in a little more detail, staff  
23 looked at the information, what they had computed.  
24 And basically, the envelope, the spectra at the base

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 of the rack, and the pool wall. And that was their  
2 target spectra, this one spectrum of that place.

3 They completed synthetic time histories  
4 consistent with that spectra and followed the  
5 requirements of Reg Guide 3.71 which basically tells  
6 you what certain parameters you need to meet in order  
7 to qualify to be able to use those time histories.  
8 And it requires more than four-time history to be used.  
9 KHNP used five. So staff finds it acceptable.

10 And I'll pick a model, so KHNP used the  
11 3-D model of the racks and extracted the equivalent  
12 B properties to simulate the rack structure dynamically.

13 Same thing they did with the fuel. They had PWR fuel,  
14 P7, and based on the test results, they computed a  
15 frequency and the stiffnesses. And they simulated as  
16 a beam element out of that. So staff is pretty comfortable  
17 with the way they've approached to compute the properties  
18 of equivalent beam model.

19 With regard to the rattling and the impact  
20 between the fuel and the rack, or the rack to rack,  
21 or the rack to floor, the Applicant used the gap element.

22 Basically they're active and they're under compression.  
23 And they used the appropriate properties of the springs'  
24 stiffnesses to simulate the gap.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   Staff asked again where ability is there,  
2                   I mean, how sure are you about those stiffness values?

3                   So staff asked them to do the uncertainty analysis  
4                   to vary those stiffnesses by 20 percent, pluses and  
5                   minuses, and make sure that what you are doing is bounded.

6                   So that was the regarding of the gap stiffnesses.

7                   Hydrodynamic effects, there's a  
8                   hydrodynamic mass between the fuel and the rack, then  
9                   the plate and the floor, and then the pool wall and  
10                  the rack. And they are pretty much, I would say, standard  
11                  approaches, formulas to compute the hydrodynamic mass.

12                  Some people do it 3-D, hydrodynamic elements  
13                  and so on. But KHNP chose to use sort of hand calculations  
14                  which are pretty accurate, have been tested out. So  
15                  that was their approach. And staff points those tested  
16                  out approaches were acceptable and then that's it.

17                  To simulate or to check or to confirm the  
18                  fuel integrity, the two components of the colliding  
19                  and rate of the fuel is balanced or held together.  
20                  And then the spacer grid would be in the fuel bundles.

21                  So they, I mean KHNP, based on their test  
22                  results of the buckling capacity of the spacer grid,  
23                  the model that's spring in the model, to get the responses  
24                  during the citation so they assure the fuel integrity

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 will be maintained. So they have simulated the impact,  
2 fuel impact with the rack in that manner.

3 And staff looked at their results, the fuel  
4 test results, and they are consistent with what they  
5 have used in their bigger analysis. So the fuel is  
6 represented pretty accurately.

7 As I said before, they have also used the  
8 radiation in the fuel properties, the new fuel versus  
9 end of life fuel. Because your stiffnesses change,  
10 the fuel stiffnesses. So what effect that has, we wanted  
11 to study that to make sure that you do analysis only  
12 once, but there's bounding analysis in terms of the  
13 rack stresses.

14 Seismic analysis methodology, overall we  
15 find it's consistent with what's being done in other  
16 applications and what the reg guide requires that.  
17 So they applied the three dimensional to a three  
18 dimensional model with three dimensional time histories  
19 in two horizontal and one vertical direction. They  
20 found, in nonlinear time it's the analysis for five  
21 sacrificed time histories. So there are five analyses  
22 for one condition or one variation.

23 As these are free-standing racks, the focus  
24 and the selection plays an important role, so they have

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 used the lower bound, upper bound, and the mean values,  
2 the lower bound being 0.2 coefficient reflection, upper  
3 bound is 0.8, the mean is 0.5. So for each of the time  
4 histories, they used three separate coefficient  
5 reflections to get the results of the responses during  
6 earthquake.

7 Their design basis analyses consists of  
8 the fully loaded racks. But the staff was not sure  
9 if that really balanced the response during seismic,  
10 because being a non-lineal response. So they also  
11 studied the various patterns of the fuel loading, like,  
12 50 percent loaded, 25 percent loaded, or the checkered  
13 load, some empty racks, and enveloped the results of  
14 all those analyses. So that uncertainty regarding the  
15 fuel loading was very well covered.

16 Numerical solutions is all highly nonlinear  
17 analyses. So staff wanted to make sure that your direct  
18 integration time stamp is fine enough so that the results  
19 are converging. And they demonstrated that the time  
20 integration was small. By changing it 20 percent, they  
21 found the results are changed.

22 So overall, they performed 20 such analyses.  
23 Like, you have a five-time histories, and you have  
24 three different sets of coefficient reflection. So

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       it gives you 15. That's for spent fuel. And then new  
2       fuel racks, you don't need friction or radiation, because  
3       it's bolted. So five cases there. So altogether, it's  
4       20 cases they analyzed.

5               And then there are about 16 cases where  
6       they studied the barometric variation group I talked  
7       about, like varying the different masses, the  
8       stiffnesses. So that total is about 36 simulations.  
9       And the results, the stress analysis they performed  
10      there's the bounding of all of this work. So staff  
11      considered that they have covered or attempted to cover  
12      the uncertainties to the extent reasonable.

13             They have also, related to the computer  
14      program ANSYS where they used for this analysis, staff  
15      wanted to make sure that for this class of problem,  
16      meaning free-standing, highly nonlinear analysis, this  
17      model computed the record they're using, is converging,  
18      or is reasonable.

19             So they demonstrated that by, well, a  
20      combination of a few things. ANSYS has been used, its  
21      staff has used and approved ESBWR, so staff feels pretty  
22      comfortable.

23             But in addition to that, we asked them  
24      to sort of analyze the same problem or simplified problem,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 so everything remaining same. You change the codes.  
2 And the results, and again, mostly we are looking for  
3 displacement. And we found them pretty reasonable.  
4 They will not match, will not be a match. Because the  
5 approach to solve the problem is different but fully  
6 reasonable.

7 So based on this seismic analysis review,  
8 we find that their input, the model, and the parameters,  
9 the methodology they have used, and validated computer  
10 code they've used, they all meet the guidance in SRP  
11 3.8.4, 3.7.1, 3.8.1, and Reg Guide 161. And therefore  
12 we find it acceptable.

13 The second part of the assessment is the  
14 mechanical analysis due to accident. The full scenarios  
15 are postulated in the SRP 3.8.4, Appendix D. Basically,  
16 one of them is a straight, shallow drop. The fuel assembly  
17 drops at, well, it can drop, what is it, a straight  
18 drop away from the pedestal. And one is on the pedestal.

19 Away from the pedestal, you're trying to  
20 maximize the deflection of the base plate where the  
21 fuel is supported to make sure that it does not -- it's  
22 not that excessive that it touches the floor below,  
23 impacts the floor below.

24 Then the other scenario is you drop it on

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 the pedestal. And by that, you're trying to maximize  
2 whether it's going to penetrate the concrete and go  
3 downward. So that's purpose of doing that scenario.

4 Third one is you just accidentally drop,  
5 and you want to make sure that you're not hurting the  
6 rack cell to the point that you come close to the neutron  
7 absorber. Because then the sub-criticality becomes  
8 an issue. So that's, like, just a drop on the corner  
9 of the fuel bay.

10 And the last one is the stuck fuel assembly.  
11 You're trying to pull the assembly, it gets stuck,  
12 you know, against the wall of the shell. And again,  
13 you want to see that stresses in the racks are within  
14 the code allowables.

15 So all these four scenarios, KHNP analyzed  
16 it, used the detail, two dimensional, finite element  
17 model and used ANSYS LSDYNA code which is validated  
18 code. And the rack, when it drops, the fuel assembly  
19 is dropped back. It's considered fully loaded. So it's  
20 not empty, so maximize. Because the plate deflection  
21 will be more when the pool is loaded, and then you drop  
22 more. So that's one of the rationales.

23 So with all these analyses, what they  
24 performed, they showed two things. One, the minimum

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 factor of safety, meaning the margin, if you want to  
2 call it, really it's not a factor of safety. That isn't  
3 the right term. It is 1.4. And that occurs for the  
4 drop. It's right on the pedestal.

5 So there's the concrete compressive  
6 strength, the impact load on the concrete and allowable  
7 compressive strength. That's where the margin of 1.4.  
8 The margin at other places, for other three scenarios,  
9 is much greater than 1.4. It's, like, of the other  
10 two or three. We just mention only the lowest one.

11 CHAIRMAN BALLINGER: Excuse me.

12 MR. JAIN: Yes?

13 CHAIRMAN BALLINGER: When you say a margin  
14 of 1.4, 1.4 against what?

15 MR. JAIN: Against allowables --- computed  
16 allowables.

17 CHAIRMAN BALLINGER: Okay. And what's the  
18 -- you're talking about destruction of the concrete,  
19 penetration of the concrete?

20 MR. JAIN: No. No, no. These are, like,  
21 not within code allowables. You don't go into those  
22 penetration or spalling, or any of that, no. When a  
23 load acts on the concrete, it causes compression, regular  
24 compression. And code gives you allowables to what

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       that compression stress should be.

2                   CHAIRMAN BALLINGER:   Okay.

3                   MR. JAIN:   So it's, again, design basis,  
4       code allowables.   So it's not like we covered an aircraft  
5       impact when things are penetrating and --- no.   They  
6       are not there.

7                   And, in fact, the SRP guidance does not  
8       allow that either.   So we --- although it's called  
9       accident, but is it a scenario?   Really, it's a mechanical  
10      accident, unplanned, unanticipated accident.

11                  MEMBER SKILLMAN:   Let me ask this question  
12      on the next to the last carrot under analysis, the slide  
13      reads as follows, "Demonstrated that the impact of the  
14      straight, deep drop of the fuel assembly on a specific  
15      location does not cause any significant deformation  
16      to the base plate."

17                  MR. JAIN:   Right.

18                  MEMBER SKILLMAN:   Does that mean that there  
19      are other locations that are not specified that can  
20      be?

21                  MR. JAIN:   Okay, let me just ---

22                  MEMBER SKILLMAN:   Areas where the base plate  
23      is deformed?

24                  MR. JAIN:   I understand your question.   Let

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 me clarify what is meant here. So they --- when the  
2 plate is fully loaded with the fuel, the base plate,  
3 you would expect, right, kinetics. The maximum  
4 deflection will be at the center, simply supported here.

5 And if you drop the fuel assembly at the center of  
6 the plate, in the cell, you will increase that deflection.

7 And that's what we are watching, that the  
8 floor is still cleared when it deflects. So that is  
9 a critical location for dropping the fuel for that  
10 particular scenario.

11 MEMBER SKILLMAN: Well, how about the  
12 scenario, as you mentioned a few minutes ago, the edge  
13 of the rack is about 33 inches away from the wall of  
14 the pool.

15 MR. JAIN: Uh-huh.

16 MEMBER SKILLMAN: It's 780 millimeters or  
17 800 millimeters. If a fuel assembly is dropped between  
18 the rack and the wall, does that impact load exceed  
19 what you have just described?

20 MR. JAIN: Well, first of all, it's not  
21 postulated, so I cannot really straight away address  
22 it to you, number one. Number two, so this is really  
23 non-required scenario, Scenario Number 5, if you will.  
24 Because all the fuel that's supposed to drop, we are

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1 testing the rack. Our focus is the rear of the racks,  
2 whether the racks meet all the stress requirements during  
3 postulated scenarios. So if the fuel drops between  
4 the pool wall and the rack, probably it will fall on  
5 the floor.

6 MEMBER SKILLMAN: I would expect it to.

7 MR. JAIN: Right. And if it falls on the  
8 floor, that should not be a problem at all, because  
9 we have covered --- that is covered under when it drops  
10 right on the pedestal.

11 MEMBER SKILLMAN: Except that you have an  
12 impact load that is the, if you will, the full face  
13 of the lower end fitting that could have a higher local  
14 penetration impact load than if it were spread more  
15 widely as would be the base of the fuel rack.

16 MR. JAIN: Yes.

17 MEMBER SKILLMAN: Like a bullet.

18 MR. JAIN: Right. I could not answer the  
19 question simply because that case would have been covered  
20 under the design of the spent fuel pool.

21 MEMBER SKILLMAN: So your focus today is  
22 simply only the racks.

23 MR. JAIN: Yes. My focus is just the racks.  
24 And the design of the spent fuel pool is covered under

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 384-something, which I mentioned at the beginning,  
2 383.4.6.

3 MEMBER SKILLMAN: Thank you.

4 MR. JAIN: That's in the SEO.

5 MR. JAIN: The next, this slide shows a  
6 couple of cartoons for various accidents we talked about.

7 Now we talk about the load to load  
8 combination. So we spent time and looked, talking about  
9 the seismic and the mechanical accident. Those are  
10 the two primary loads which really control the design  
11 of the racks. Nevertheless, there are other loads for  
12 completeness, that load, five loads, safe shutdown,  
13 thermal loads, mechanical accident loads.

14 And then there are combination of these  
15 loads can occur. And what are the corresponding service  
16 levels for those combinations. And that's all specified  
17 in our regulatory SRP. And the KHNP's design is  
18 consistent with the requirement, what's in Appendix  
19 D.

20 As you can see, they are all -- seismic  
21 and mechanical accident loads never get combined. So  
22 each one is treated separately. And there is no live  
23 load for these racks. It's just a dead load.

24 Okay, and thermal loads, I'm going to talk

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1       about. They're secondary loads, according to ASME code,  
2       so they are looked at, they're evaluated. But then  
3       they are evaluated by themselves and shown to be within  
4       the code allowables.

5               This is the general procedure that KHNP  
6       has followed. And this is really a no-brainer. This  
7       is what you would do to design anything, any structure.

8       So some other design considerations would go into the  
9       analyzing and designing these various elements. There  
10      are wells between the cell to base plate, base plate  
11      to pedestal, and cell to cell.

12             Then obviously, these local stresses caused  
13      by the impact loads, the rattling loads, the cell wall  
14      may buckle, because of the heavy fuel load on the base  
15      plate. Secondary stresses as I said, they are also  
16      looked at.

17             And then the compute, you need to compute  
18      the stress in the fuel assembly to make sure the integrity  
19      of the fuel assembly is maintained. And that is done  
20      by checking the stress in the cladding which holds the  
21      fuel palate together, and the structural integrity of  
22      the fuel stressor grates.

23             So how you go about doing your analysis  
24      and design, you calculate the forces, what you get from

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 knowing your seismic analysis of these racks, and  
2 mechanical accident load. Then you combine those  
3 responses of the forces and the given element, for  
4 example, well design or rack wall design, and combine  
5 them according to a load combination which was shown  
6 before. And then you calculate the maximum stress.

7 You compare that maximum stress with the  
8 acceptance limits that I specified in Section 3 of the  
9 ASME code, subsection NF. That provides the limits  
10 for various service levels, A, B, and D. And you compute  
11 the safety factor or margin, if you will, the ratio  
12 of the allowable to the calculated stresses. Now, in  
13 all cases, the staff finds that the ratio is always  
14 greater than one. And that's a requirement.

15 MEMBER STETKAR: B.P.? In your response  
16 to Dick, you mentioned some section that would analyze  
17 the load on the spent fuel pool liner, if I were to  
18 drop the fuel assembly into the spent fuel pool. I  
19 can't seem to find that in the DCD, at least the section  
20 that you mentioned.

21 MALE PARTICIPANT: And neither can I.

22 MEMBER STETKAR: Could you confirm that  
23 indeed the design certification evaluates that load  
24 and where it is?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. JAIN: Well, like I said, we were going  
2 to make it an action item. I'm not familiar. I did  
3 not --

4 MEMBER STETKAR: I'm trying to do it real  
5 time here, and I'm not coming up quickly with anything.

6 MR. JAIN: Well, I was thinking more like  
7 the staff's SER would address that.

8 MEMBER STETKAR: Okay. Well, it ---

9 MR. JAIN: And again ---

10 MEMBER STETKAR: -- should be addressed  
11 in the DCD someplace.

12 MR. JAIN: I can only ---

13 MEMBER STETKAR: Anyway, just take it away  
14 and if you can get ---

15 MR. JAIN: Yes, yes. Sure. I'm just going  
16 by my experience with other designs. So am not familiar  
17 with this particular design spent fuel pool. So I could  
18 not be certain.

19 So these are the acceptance limits, what  
20 the stresses, computer stresses are checked against,  
21 some other things we talked about already. These  
22 stresses are from subsection NF, ASME code Section 3.  
23 Material properties, we'll use that 200 degrees to  
24 maximize the thermal load and get the lower allowables.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   And the -- I guess Service Level 8, they  
2                   are all consistent but specify the code, NF, Section  
3                   3320. And then for service level D, that was used mostly  
4                   for seismic and mechanical accident loading. They used  
5                   that too in Appendix F of that section, 1334. And it's  
6                   all consistent.

7                   Since we've got free-standing racks, the  
8                   sliding and overturning is a concern. And the  
9                   requirement is that the fact of safety against sliding  
10                  or overturning should be at least 1.5.

11                  We find these acceptance criteria, what  
12                  KHNP used, they're consistent with Appendix D in SRP  
13                  Section 3.8.4 and 3.8.5. And 3.8.5 talks about the  
14                  fact of safety against sliding and overturning. And  
15                  therefore, we find the acceptance criteria used for  
16                  the design of these racks acceptable.

17                  Material, quality control programs, and  
18                  inspections, the rack material is reviewed by staff  
19                  under Section 9.1.2, so same material, SA type 240.  
20                  That's been used for all racks, not only for this one  
21                  but other designs. So material is consistent.

22                  Fuel assembly data is from PWR PLUS7  
23                  assembly. Design and fabrication inspection is per  
24                  NF requirements, Section 3 code. Quality control, QA

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 program, QC program, they commit to Appendix B for quality  
2 control program. And then 10 CFR 5065 regarding  
3 monitoring to ensure that the racks are capable of  
4 fulfilling their intended functions during operation  
5 and after.

6 So the staff finds these codes and their  
7 commitment to the QA programs and inspections consistent  
8 with the SRP requirements. And they find it acceptable.

9 KHNP identified a few small items, four  
10 to be more specific. First one is periodic condition  
11 monitoring, the need to continue to remain valid. It's  
12 one of the things that you mentioned about the way they  
13 fabricate and put it in place. Is that important? Well,  
14 that's how they maintain the check, by periodic condition  
15 monitoring, that they are not drifting apart or they  
16 continue to maintain the geometry which was analyzed  
17 for it.

18 They need to perform the confirmatory  
19 dynamic analysis to make sure that, at a given site,  
20 their design stresses still remain valid. They also  
21 need to develop plant procedure and admin control for  
22 handling the fuel over the pool, the specific admin  
23 controls.

24 And for seismic, they need to do inspection

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 to see if the racks have drifted apart. And if they  
2 have, then they need to bring them back in analyzed  
3 condition or demonstrate why they're still adequate,  
4 if they don't take any corrective action. So that's  
5 one of the core items. So staff finds those acceptable  
6 and reasonable.

7 For the conclusion, the staff has reached  
8 that, based on its review, that the structural design  
9 of the fuel racks meets the ASME code, Section 3,  
10 Subsection NF, design requirements. Minimum factor  
11 of safety for the fuel racks seismic event, including  
12 a mechanical accident scenario, is 1.19.

13 The spent fuel rack displacement to the  
14 design basis seismic events is small and do not close  
15 the large gap of 33 inches between the wall and the  
16 spent fuel pool racks. The relative displacements of  
17 the spent fuel pool racks is about quarter inch, 0.28  
18 inches, due to design basis size. And the rack to rack  
19 separation is 1.18 inch. So that gives you a margin  
20 against impact of four.

21 For the other variety of racks, which is  
22 in Region I, the margin is a little greater. It's better  
23 than six, simply because they're separated to begin  
24 with, so the gap between them is larger. So it gives

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701



1       you a larger factor of safety.

2               Free standing racks, they do not overturn  
3       during seismic events. And factor of safety is much,  
4       much better than 1.5 against sliding and overturning.

5       It's on the order of, I believe, it's 15, if I'm not  
6       mistaken. Because the displacement is so small, and  
7       the rack is very heavy, it doesn't go --- it cannot  
8       tip. It's not able to tip.

9               So due to small seismic movements,  
10      criticality analysis, which has been performed for normal  
11      conditions, still remains valid. And they continue  
12      to provide the function, what they're designed for.  
13      That's what the staff's conclusion is.

14              CHAIRMAN BALLINGER: I had a question --  
15      I got it. I was trying to go back and look at my notes,  
16      but I couldn't find it. The SA-564, grade 630, steel  
17      for the bolts, that's a precipitation hardened stainless  
18      steel. And it's offered in multiple heat treatments  
19      to vary the strength.

20              Can you tell me which heat treatment is  
21      going to be used? There are at least three aging  
22      treatments. The very high strength one is the lowest  
23      temperature age, but it is susceptible to hydrogen  
24      embrittlement.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. JAIN: I would pass that question to  
2 KHNP. I'm not knowledgeable in that area. I could not  
3 answer the question. We can take it back to KHNP and  
4 get you a specific answer.

5 CHAIRMAN BALLINGER: Yes. This material  
6 is otherwise known as, I think, 17-4 PH which is a more  
7 common name for it. But the very high strength version  
8 is ---

9 MR. YESHNIK: I'm not exactly --

10 CHAIRMAN BALLINGER: -- be careful.

11 MR. YESHNIK: I'm not exactly sure if I  
12 have that off the top of my head. I want to say it's  
13 the 1100 degrees Fahrenheit heat treatment.

14 CHAIRMAN BALLINGER: Okay. The 1100 one  
15 is the better one.

16 MR. YESHNIK: Okay. And also this material  
17 is in compression, so hydrogen embrittlement really  
18 isn't going to affect --

19 CHAIRMAN BALLINGER: Well, except for  
20 during seismic loading and things like that.

21 MR. YESHNIK: I mean, maybe.

22 (Simultaneous speaking)

23 CHAIRMAN BALLINGER: We're all into maybe.

24 MR. YESHNIK: Yes.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. JAIN: The staff will get back to you  
2 more specifically.

3 CHAIRMAN BALLINGER: It's the 900 F aging  
4 treatment that's usually the most problematic. And  
5 they use this material for bolts at the bottom of the  
6 Macondo Oil Platform which failed.

7 MR. JAIN: Well, this concludes my  
8 presentation with the new spent fuel and spent fuel  
9 pools storage racks. They will maintain a coolable  
10 geometry preventing criticality and protect the fuel  
11 assembly from seismic and mechanical loading factors.  
12 That's what the staff's review indicates.

13 MEMBER KIRCHNER: B.P., just out of  
14 curiosity, when in another section, wherever it is,  
15 when you look at the actual pool design, do they use  
16 the same -- do you use a consistent set of assumptions,  
17 in terms of seismic loading, and history, and such,  
18 that's compatible with how the racks are loaded?

19 MR. JAIN: They need to be, yes.

20 MEMBER KIRCHNER: Yes, okay.

21 MR. JAIN: They need to be.

22 MEMBER KIRCHNER: Where would we find that  
23 other analysis. I'm trying to think, that's ---

24 MR. JAIN: Again, it should all be addressed

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 or should be addressed in that SER for spent fuel pools  
2 and the liner.

3 MEMBER KIRCHNER: And they will look at  
4 things like hydrodynamic loading on these racks there.

5 MR. JAIN: Well, there would need to get  
6 the factor --

7 (Simultaneous speaking)

8 MR. JAIN: -- yes, the factor of the racks  
9 in the pool.

10 MEMBER KIRCHNER: Yes. Thank you.

11 CHAIRMAN BALLINGER: And I have one more.  
12 I think you may have addressed this in an earlier  
13 presentation. But you said that when you do the drop  
14 analysis, you assume that the fuel racks are fully loaded.

15

16 MR. JAIN: Correct.

17 CHAIRMAN BALLINGER: So have you looked  
18 at the situation where you have an open cell, and you  
19 get a drop on an adjacent fuel assembly? Does that  
20 do anything to change the configuration, crush the open  
21 cell area?

22 MR. JAIN: No. I don't believe that  
23 scenario has been considered, simply because we do not  
24 believe that that's -- the parameter we are trying

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 to view, in looking at, will really affect that parameter,  
2 meaning would it increase the deflection of the base  
3 plate of the fully loaded racks. It will not.

4 Number two, would it increase the load on  
5 the pedestal? It's not going to do that either. So  
6 from the postulated mechanical accident, what you're  
7 viewing here and what the possible effect of the parameter  
8 we are trying to maximize, we believe that, if that  
9 were the case, that would need to be covered.

10 CHAIRMAN BALLINGER: Thank you.

11 MR. JAIN: Just to add that, there's  
12 sufficient margin on top of it. So if there were  
13 uncertainties, the minimum margin is 1.4. That's  
14 against the concrete. But if you talk about the racks  
15 and the base plate, that structure, the margin there  
16 is even much larger, like two to three. So, you know  
17 ---

18 CHAIRMAN BALLINGER: Is that it for your  
19 presentation?

20 MR. JAIN: Yes, I'm done.

21 CHAIRMAN BALLINGER: Okay. We're going to  
22 have a transition between the open session and the closed  
23 --

24 MEMBER POWERS: No, you're ---

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BALLINGER: Pardon?

2 MEMBER POWERS: No, you're not. You're  
3 going to ask for public comment.

4 CHAIRMAN BALLINGER: I was about to get  
5 there. That's why I was making the comment.

6 MEMBER POWERS: You're slow. You're very  
7 slow.

8 CHAIRMAN BALLINGER: Yes, I am slow, okay.  
9 So that means we'll need public comments now for this  
10 presentation. So while we're getting the --

11 MR. BROWN: Professor Ballinger, they're  
12 not done their presentation.

13 CHAIRMAN BALLINGER: They're not?  
14 (Off microphone comments.)

15 CHAIRMAN BALLINGER: That's part of my  
16 slowness. Okay. Continue.

17 MR. WUNDER: Andrew?

18 MR. YESHNIK: Okay. Well, good morning,  
19 everyone. My name is Andrew Yeshnik and I am the reviewer  
20 for the materials and chemical engineering issues with  
21 the spent and new fuel rack. My slide is going to be  
22 pretty brief because you've already seen this information  
23 today.

24 So, the spent and new fuel racks are designed

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 with normal materials that we would expect to see in  
2 these applications. We have type 304Ls, authentic  
3 stainless steel, and type 630, the PH grade which we  
4 already talked about. And I did take a look at the  
5 DCD, and it is the 1100 degrees Fahrenheit heat treatment  
6 on those.

7 The spent fuel racks also have the metamic  
8 neutron absorber which is not credited for any structural  
9 capacity. The spent fuel liner is type 304 stainless  
10 steel. The spent fuel racks are designed, fabricated,  
11 and inspected to the requirements of Section 3NF and  
12 the liner is ASTM grade, but the quality assurance is  
13 upgraded with ASME NQA1 in Appendix B QA program.

14 The new fuel is stored in dry storage, so  
15 there's no expectation of any degradation mechanisms  
16 for that. The spent fuel is stored in the spent fuel  
17 pool. The water chemistry is in conformance with the  
18 EPRY primary water chemistry guidelines which is  
19 described in SR Section 9.1.3 and evaluated in Staff's  
20 SVRN Section 9.1.3.

21 And the coupon monitoring program for the  
22 metamic material is described in Section 9.1.1 and in  
23 Staff's SVRN, and we found that to be acceptable. So  
24 for the racks themselves, the authentic stainless steel

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433

1 has sensitive controls and delta ferrite content controls  
2 that are consistent with Staff guidance. And the  
3 cleanness of the new spent fuel racks are consistent  
4 with NQA1 subpart 2.1.

5 So in general, Staff finds that the approach  
6 that the Applicant had is consistent with the SRP, and  
7 we found it to be acceptable. I think that concludes  
8 all of my comments for this. So if there's any questions,  
9 if not we'll pass it on to Raul.

10 MR. HERNANDEZ: Well, good morning. My  
11 name is Raul Hernandez. I'm the reviewer for our plant  
12 systems branch. And I looked at the fuel storage as  
13 a system.

14 The new fuel storage feed and the spent  
15 fuel pool were looked into making sure that they maintain  
16 their safety function which is that the assemblies are  
17 maintaining a safe and sub-critical array during all  
18 credible storage conditions and to provide a safe means  
19 to load the spent fuel into shipping casks, like, making  
20 sure that as a system overall, all the different  
21 components that have been presented, that the fuel is  
22 going to remain safe.

23 The Staff reviewed the design of storage  
24 systems and the new fuel storage PID and the spent fuel

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433



1 in accordance with the guidance in SRP 912. Particular,  
2 we looked into the configuration and the design of,  
3 seismic design of the different components that are  
4 credited to maintain the pool level and the safe location,  
5 making sure that all of them be properly identified  
6 as required.

7 When a system is required to be seismic  
8 one, it's included in Chapter 3, and that's already  
9 been presented to the Commission here. The Staff issued  
10 several RAIs, and the Applicant has addressed all the  
11 RAIs satisfactorily. There's no open items in this  
12 section.

13 The Staff determined that the fuel source  
14 system is designed in accordance with the SRP guidelines  
15 and meets all the applicable regulations including GDCs  
16 2, 4, 5, 61, 63, the ALARA concerns, and 20.1406.

17 This is going to be brief. There's no major  
18 issue here. Is there any question in the overall design  
19 of the pool?

20 (No audible response.)

21 MR. HERNANDEZ: That's the last of my items.  
22 Then we go to the --

23 MR. WUNDER: Okay, now we're -- that  
24 concludes the Staff presentation of Section 9.1.2.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 So now all we have to do is go through the few open  
2 items we have. And if I could change out BP Jane for  
3 DK. Thank you.

4 And the first item I believe belongs to  
5 Alex Burja who is on the phone. So if we can get her  
6 unmuted.

7 MEMBER STETKAR: Alex, if you're out there,  
8 just say something. You should be unmuted.

9 MS. BURJA: Can you hear me now?

10 MEMBER STETKAR: Yes.

11 MS. BURJA: Okay. I'm not sure what  
12 happened, but I'm here now. So, is my slide up?

13 MR. WUNDER: It is.

14 MS. BURJA: Okay, great. So at the time  
15 of our last presentation, the two items that remained  
16 open associated with DCD Section 9.1.1, criticality  
17 safety of new and spent fuel storage, were mainly  
18 associated with ongoing work or resolution of disuse  
19 and other review areas that might have potential impact  
20 on Section 9.1.1.

21 The first issue involved the effect of  
22 thermal conductivity degradation. In particular, the  
23 Staff had asked in an RAI un Section 9.1.1 how the maximum  
24 fuel temperature assumed for the depletion calculation

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 in the burn up credit criticality analysis accounted  
2 for GPD.

3 This issue was resolved because in the  
4 response to RAI 7954 which was related to the plus seven  
5 fuel design topical report, the Applicant showed that  
6 the assumed maximum fuel temperature and the criticality  
7 analysis found the accepted maximum fuel temperature  
8 for this design plus the Staff approved CPD penalty.  
9 So therefore, it is acceptable to the Staff.

10 The second open item which related to the  
11 mechanical analysis review. So as a Phase II and Phase  
12 III Staff's review of the storage rack mechanical analysis  
13 technical report was incomplete, and there were several  
14 technical issues that remain to be resolved.

15 So due to these issues, the Staff was unable  
16 to determine whether any mechanical accidents could  
17 have impact on criticality. But as you just heard,  
18 this issue was resolved because the Staff an Applicant  
19 worked to resolve the technical issues related to the  
20 storage rack mechanical analysis technical report, and  
21 the Staff has completed its review of the report.

22 The Staff concludes that the criticality  
23 analyses found any criticality related effects of the  
24 analyzed mechanical accident. Are there any questions?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN BALLINGER: Fifteen second rule  
2 is applied. No questions.

3 MS. BURJA: Thank you.

4 MR. WUNDER: Eighty-five seventy-eight is  
5 yours, isn't it?

6 MR. YESHNIK: Yes.

7 MR. WUNDER: Okay.

8 MR. YESHNIK: I thought that there was  
9 another party --

10 MR. WUNDER: No, that's it.

11 MR. YESHNIK: Okay. So, my open item is  
12 Question 9.1.1-37, and it involved a question on the  
13 exposure of the metamorphic material to elevated temperatures  
14 during fabrication, and whether the neutron absorber  
15 coupons needed to be heat treated to reflect that  
16 condition.

17 And the Applicant stated that the  
18 qualification testing has already demonstrated that  
19 there is no effect on neutron absorbing properties.  
20 The Staff re-looked at the qualification testing that's  
21 at the bottom of the slide and agreed that the 900 degree  
22 tests for 48 hours demonstrating that there is no change  
23 is sufficient.

24 And the Staff also reviewed generic

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 literature and concluded that the welding temperatures  
2 are bounded by normal manufacturing temperatures so  
3 that there is no predicted issue. And that's it.

4 MR. HERNANDEZ: Section 9.1.3 contained,  
5 at the time of the presentation of Section 9.1.3 to  
6 the Subcommittee, Section 9.1.3 contained an open item.

7 And this open item was related to the assumptions used  
8 on the spent fuel pool, thermal hydraulic analysis.

9 The Staff had identified some apparent  
10 inconsistencies between the information on the DCD and  
11 the assumptions used on the thermal analysis, the  
12 Applicant responded to the Staff's RAI by revising the  
13 thermal hydraulic calculation and making this  
14 calculation available for the Staff to audit.

15 They provided clarification of the  
16 assumptions used under thermal analysis and proposed  
17 DCD markups that have already been incorporated into  
18 the DCD. The Staff reviewed the information that was  
19 provided in the RAI, the DCD, and the technical report  
20 that summarized the thermal hydraulic analysis and  
21 confirmed that the revised thermal hydraulic analysis  
22 used conservative assumptions that are consistent with  
23 the SRP guidance, and therefore meets the applicable  
24 GDC in this case, GDC 61.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1                   MEMBER STETKAR: Raul, I'm just going to  
2 bring this up when we discuss Section 19.3. But since  
3 you're here and I'm not sure that you'll be here for  
4 that section, let me just ask you about it.

5                   If I look at the differences in those times  
6 that you mentioned, I understood I would say in my opinion  
7 a rather substantial difference that the time to heat  
8 up and boil off water for example to within ten feet  
9 of the top of the fuel assemblies went from about 25  
10 hours down to about a little over 15 hours.

11                  That to me, these are numbers that are in  
12 section 19.3, but they're related to heat up and boil  
13 off of spent fuel pool inventory, which is not directly  
14 related to the design of the spent fuel pool cooling  
15 system.

16                  But I'm curious about what did they do in  
17 the revised analyses that would result in such differences  
18 in heating up and boiling water?

19                  MR. HERNANDEZ: You are looking at two  
20 different thermal analysis.

21                  MEMBER STETKAR: Well, I'm looking at one  
22 pool that heats up.

23                  MR. HERNANDEZ: Yes. But the difference  
24 is this. In Section 9.1.3, we're looking at the thermal

1 analysis of the performance of the safety related cooling  
2 system.

3 And the initial conditions are different.

4 This is a design basis event. So you have less water  
5 and a different set of initial conditions. When you're  
6 looking at Chapter 19, accident scenarios, the guidance  
7 for Chapter 19 is from -- your initial set of conditions  
8 are different.

9 You're not on the design basis event.  
10 You're already, you start from normal conditions and  
11 then you have this beyond design event. So those two  
12 are not exactly comparable events. You have different  
13 water levels, different heat loads, different  
14 conditions.

15 MEMBER STETKAR: All right. I'll wait  
16 until this afternoon, then. Thank you.

17 MR. KALATHIVEETIL: Good morning,  
18 everyone. My name is Don Matthews Kalathiveettil, and  
19 I will be presenting the closure of two open items with  
20 respect to Section 9.5.2, communication systems.

21 First open item was RAI 548 Question 9.5.2-6.  
22 The issue was that the Applicant had classified all  
23 the communication systems as non-safety related. And  
24 the DCD stated that the communication systems did not

1 require compliance with 10 CFR Part 50 Appendix GDC's  
2 1, 2, 3, and 4.

3 Since compliance with these GDCs is part  
4 of the acceptance criteria of SRP Section 952 and the  
5 availability of these communication systems is important  
6 for programs that has emergency planning, the Staff  
7 did not agree with the Applicant's stance and requested  
8 through the RAI to demonstrate how the communication  
9 systems would meet the applicable GDCs.

10 The Applicant's response to the RAI included  
11 a commitment that the design of the communication systems  
12 will comply with GDCs 1, 2, 3, and 4. It also included  
13 detailed markups of the DCD that explained how the  
14 communication systems would meet all the applicable  
15 GDCs.

16 Subsequently, the Staff reviewed the  
17 information we just provided by the Applicant and  
18 determined that the design information and commitment  
19 given by the Applicant was sufficient to meet the intent  
20 of DCDs 1, 2, 3, and 4.

21 The second open item was RAI 548 Question  
22 9.5.2-7. The issue was that the DCD lacked sufficient  
23 information in APRIL 1400 FSR Tier 1 Table 2.6.9-1.  
24 This table contains the various ITAAC related to the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

(202) 234-4433

(202) 234-4433



1 communication systems. 10 CFR 52.47(b)(1) requires that  
2 it is answered in certification application contains  
3 the necessary and sufficient ITAAC.

4 Hence, the Staff requested additional  
5 information through the RAI. The Applicant's response  
6 to the RAI included detailed markups in which it was  
7 explained which procedures are needed to ensure that  
8 each communication subsystem would be able to perform  
9 its required function.

10 It also included the necessary and  
11 sufficient information about each subsystem in the ITAAC  
12 and acceptance criteria sections of Table 2.6.9-1.  
13 Subsequently, the Staff reviewed the information  
14 provided by the Applicant and determined that sufficient  
15 detail was now provided in Tier 1 to meet the intent  
16 of 10 CFR 52.47(b)(1).

17 This basically concludes my presentation  
18 for this section. Any questions?

19 CHAIRMAN BALLINGER: Once again, we now  
20 can -- well, we're transitioning.

21 MEMBER STETKAR: Will there be a closed  
22 session?

23 CHAIRMAN BALLINGER: There will be a closed  
24 session. So we would like public comments now for what

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 has been presented so far. Is there anybody in the  
2 room that would like to make a comment?

3 MR. OH: This is Andy Oh, KHNP Washington  
4 Office. Before finishing this session, the KHNP would  
5 like to correct something regarding tub and tubing aux  
6 feedwater room heater calculations. First thing is  
7 that for members that is the temperature profile.

8 So our temperature profile indicated that  
9 about the 52 hours in room, the temperature is at 140  
10 Fahrenheit and 72 hours it increased to 145.

11 MEMBER STETKAR: Andy, let me make sure  
12 I have that. At what time is 140?

13 MR. OH: Fifty-two hours, 140.

14 MEMBER STETKAR: Okay.

15 MR. OH: Seventy-two hours, 145.

16 MEMBER STETKAR: So, okay.

17 MR. OH: It is in an increasing slope. It  
18 is approximately 2.25 Fahrenheit per hour. That's the  
19 first question, your first answer from the member.  
20 Second is one of our, the technical staff had mentioned  
21 that there's no electrical the INC equipment inside  
22 the tub and tubing aux feedwater room.

23 But when we checked our design document,  
24 we identified the control panel is located inside tub

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 driven aux feedwater room.

2 MEMBER STETKAR: All right, thank you.

3 MR.OH: We corrected that fact. And second  
4 thing is -- third thing is that staff member indicated  
5 there is two different criteria is used in the room  
6 heater calculation. One is 120 Fahrenheit, the other  
7 is 150 Fahrenheit.

8 KHMP is using the criteria from the NUMARC  
9 87-00. That says condition one is equipment located  
10 in the condition one room are considered to be a low  
11 constant with respective elevated temperature effect,  
12 and will likely require no special action to assure  
13 operability for our station blackout.

14 That is category one. NUMARC 87-00  
15 recommend to use that 120 Fahrenheit, and specifically  
16 there's some example for that is for -- example is they  
17 specified that exempt means electrical equipment  
18 instrumentation how they did category one.

19 And also, it indicated that there is category  
20 two room is equipment located in condition two rooms  
21 generally requires not force the cooling in order to  
22 ensure operability for a four hour station blackout.

23 And also they make some specific example for that room  
24 is for either is RCIC and feedwater room is steam driven

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 aux feedwater pump room.

2 That is our basis to using what that criteria  
3 for the room feeder calculation. In conclusion that  
4 we used the 150 Fahrenheit as a criteria, and we also  
5 notify with that that we have some control panel inside  
6 it that aux feedwater, the temperature in the aux  
7 feedwater room.

8 So in order to protect that equipment, the  
9 KHMP 1400 design and the equipment spec is that some  
10 that equipment have to survive over 160 Fahrenheit.  
11 That is also very consistent with the single core design.

12 MEMBER STETKAR: Thank you. That  
13 clarifies at least my understanding of what is in that  
14 room. And it does clarify the fact that the electrical  
15 and INC equipment inside that room must be qualified  
16 to a substantially higher temperature than other  
17 electrical and INC equipment throughout the plant.  
18 So we have that on record now. Thank you.

19 CHAIRMAN BALLINGER: Okay, back to the,  
20 are there any comments from the public in the room?

21 (No audible response.)

22 CHAIRMAN BALLINGER: Hearing none, are  
23 there any members of the public on the bridge line that  
24 would like to make a comment?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1 MR. LEWIS: Marvin Lewis, member of the  
2 public.

3 CHAIRMAN BALLINGER: Yes, Marvin?

4 MR. LEWIS: Wonderful, thank you.  
5 Appreciate it greatly. Look, I listened to this, and  
6 as you well know, I listen to other ACRS meetings and  
7 what have you. And one of the things that has been  
8 bothering me for a long time, but I think especially  
9 here, is when you start talking about things that are  
10 not easily traced, this often falls under category of  
11 warehouse.

12 In other words, suppose you need a bolt  
13 or a nut to finish a shipment, what do you do? You  
14 grab a bolt and a nut that looks like it and throw it  
15 into the bin and ship it. That's called warehouse.

16 And I just was wondering, it may not be  
17 here, but how do you assure that the right materials  
18 come through and are just not picked up to finish a  
19 shipment? Thank you.

20 CHAIRMAN BALLINGER: Thank you. Are there  
21 any other members of the public that would like to make  
22 a comment?

23 (No audible response.)

24 CHAIRMAN BALLINGER: Hearing none, we'll

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701


1 close the bridge line. And we're now going to make  
2 a transition, so it's time to make a break. We'll break  
3 until about 20 minutes 'til. And at that time, we'll  
4 have a closed session.

5 (Whereupon, the above-entitled matter went  
6 off the record at 10:25 a.m.)

7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18

# APR1400 DCA

## Chapter 9: Auxiliary Systems



**KEPCO/KHNP**  
**February 21, 2018**

# Contents

---

- **Overview of Chapter 9**
  - Section Overview
  - List of Submitted Documents and Summary of RAIs
  - List of Main Topic in Section 9.1.2
  - List of Open Items
- **9.1.2 New and Spent Fuel Storage**
- **Summary of Main Topic in Section 9.1.2**
- **Summary of Open Items**
- **Response to Phase 3 Questions**
- **Current Status**
- **Attachments:**
  - Acronyms
  - List of COL Items related to Open Items



# Overview of Chapter 9

## ❖ Section Overview

| Section | Title                     | Major Contents   |
|---------|---------------------------|--|
| 9.1     | Fuel Storage and Handling | <ul style="list-style-type: none"> <li>• Criticality Safety of New and Spent Fuel Storage</li> <li>• New and Spent Fuel Storage</li> <li>• Spent Fuel Pool Cooling and Cleanup System</li> <li>• Light Load Handling System (Related to Refueling)</li> <li>• Overhead Heavy Load Handling System</li> </ul>   |
| 9.2     | Water Systems             | <ul style="list-style-type: none"> <li>• Essential Service Water System</li> <li>• Component Cooling Water System</li> <li>• Domestic Water and Sanitary Systems</li> <li>• Ultimate Heat Sink</li> <li>• Condensate Storage Facilities</li> <li>• Chilled Water System</li> <li>• Turbine Generator Building Closed Cooling Water System</li> <li>• Turbine Generator Building Open Cooling Water System</li> </ul> |
| 9.3     | Process Auxiliaries       | <ul style="list-style-type: none"> <li>• Compressed Air and Gas Systems</li> <li>• Process and Post-Accident Sampling System</li> <li>• Equipment and Floor Drainage Systems</li> <li>• Chemical and Volume Control System</li> </ul>  |

# Overview of Chapter 9

| Section | Title                     | Major Contents   |
|---------|---------------------------|--|
| 9.4     | Fuel Storage and Handling | <ul style="list-style-type: none"> <li>• Control Room HVAC System</li> <li>• Fuel Handling Area HVAC System</li> <li>• Auxiliary Building Clean Area HVAC System</li> <li>• Turbine Generator Building HVAC System</li> <li>• Engineered Safety Features Ventilation System</li> <li>• Reactor Containment Building HVAC System and Purge System</li> <li>• Compound Building HVAC System</li> <li>• Design Features for Minimization of Contamination</li> </ul>                      |
| 9.5     | Other Auxiliary Systems   | <ul style="list-style-type: none"> <li>• Fire Protection Program</li> <li>• Communication Systems</li> <li>• Lighting Systems</li> <li>• Emergency Diesel Engine Fuel Oil System</li> <li>• Emergency Diesel Engine Cooling Water System</li> <li>• Emergency Diesel Engine Starting Air System</li> <li>• Emergency Diesel Engine Lubrication System</li> <li>• Emergency Diesel Engine Combustion Air Intake and Exhaust System</li> <li>• Gas Turbine Generator Facility</li> </ul> |

# Overview of Chapter 9

## ❖ List of Submitted Documents for Chapter 9

| Document No.                    | Title  | Revision | Type | ADAMS Accession No. |
|---------------------------------|--|----------|------|---------------------|
| APR1400-K-X-FS-14002<br>-P & NP | APR1400 Design Control Document<br>Tier 2: Chapter 9 Auxiliary Systems | 0        | DCD  | <u>ML15006A048</u>  |
|                                 |  | 1        | DCD  | -                   |
| APR1400-K-X-IT-14001<br>-P & NP | APR1400 Design Control Document<br>Tier 1                              | 0        | DCD  | <u>ML15006A039</u>  |
|                                 |  | 1        | DCD  | -                   |
| APR1400-Z-A-NR-14011            | Criticality Analysis of New and Spent Fuel<br>Storage Racks            | 1        | TeR  | <u>ML17094A138</u>  |
| APR1400-H-N-NR-<br>14012-P/NP   | Mechanical Analysis for New and Spent<br>Fuel Storage Racks            | 3        | TeR  | <u>ML17242A310</u>  |

## ❖ Summary of RAIs

| No. of Questions | No. of Responses | No. of OI |
|------------------|------------------|-----------|
| 277              | 277              | 5         |

# Overview of Chapter 9

## ❖ List of Main Topic in Section 9.1.2

| No. | Related RAI                      | Topic                        | ADAMS Accession #  |
|-----|----------------------------------|------------------------------|--------------------|
| 1   | 287-8272<br>(Q 09.01.02-15)      | Seismic Load                 | <u>ML17243A348</u> |
| 2   | 287-8272<br>(Q 09.01.02-20)      | Seismic Analysis of Racks    | <u>ML17244A512</u> |
| 3   | 287-8272<br>(Q 09.01.02-23 & 24) | Mechanical Accident Analysis | <u>ML17244A512</u> |

# Overview of Chapter 9

## ❖ List of Open Items

| No. | Related RAI                     | Topic   | ADAMS Accession #  |
|-----|---------------------------------|---|--------------------|
| 1   | RAI 167-8191<br>(Q 09.01.01-13) | Abnormal Conditions   | <u>ML15344A144</u> |
| 2   | RAI 469-8578<br>(Q 09.01.01-39) | Neutron Absorber Material   | <u>ML16169A030</u> |
| 3   | RAI 473-8582<br>(Q 09.01.03-4)  | Minimum safety water level of SFP   | <u>ML16123A040</u> |
| 4   | RAI 491-8613<br>(Q 09.05.02-4)  | 10 CFR Part 50, Appendix A, GDC 1, GDC 2, GDC 3, and GDC 4 in communication system                          | <u>ML16222A952</u> |
| 5   | RAI 491-8613<br>(Q 09.05.02-5)  | 1. ITAAC and ITP for communication system<br>2. Meaning of 'functional arrangement' in communication system | <u>ML16211A158</u> |

## 9.1.2 New and Spent Fuel Storage

### ❖ Key Design Features

- New Fuel Storage Rack (NFSR)
  - Two modules (Total 112 cells) of NFSRs are constructed of stainless steel, and are designed as seismic Category I.
  - NFSRs are located in the NFP, and are bolted to embedment plates at the bottom of the pit to preclude tipping.
- Spent Fuel Storage Rack (SFSR)
  - SFSRs are constructed of stainless steel, and are designed as seismic Category I.
  - SFSRs are located in the SFP, and are freestanding with pedestal resting on embedment plates. SFSRs are made up of Region I (Total 352 cells) and Region II (Total 1,440 cells) and provide total 29 rack modules. (Total 1,792 cells)
  - METAMIC<sup>TM</sup> is used as a neutron absorber.

## 9.1.2 New and Spent Fuel Storage

### ❖ Safety Evaluation

- Dynamic simulations for total of 36 cases runs (including sensitivity runs) are performed to determine the loads and displacements for each rack.
- NFSRs and SFSRs under the postulated mechanical accident possess acceptable margins of safety.
- NFSRs and SFSRs are designed to meet the requirements which are specified on SRP 3.8.4, Appendix D and ASME Section III, Subsection NF, Class 3 component supports.
- In response to NRC feedback on both the TeR and RAI No. 8272 responses, APR1400-H-N-NR-14012-P was completed (as Rev. 3) on August, 2017.

# Summary of Main Topic in Section 9.1.2

## ❖ Seismic Load

- Related RAIs : 287-8272 (Q 09.01.02-15)
- Description of issue :
  - Staff requested to clarify and confirm that it used at least the five sets (greater than required four) of time histories for the nonlinear structural analysis of the NFSR and SFSR.
  - Technical adequacy justification for artificial time history sets.
- Resolution:
  - KHNP developed five sets of artificial acceleration time histories for three orthogonal directions specific to the NFSR and SFSR.
  - The suitability of the time histories was verified in accordance with SRP 3.7.1, Option 2, criteria for multiple sets of time histories.



# Summary of Main Topic in Section 9.1.2

## ❖ Seismic Analysis of Racks

- Related RAIs : 287-8272 (Q 09.01.02-20)
- Description of issue : Staff requested to provide the followings:
  - Sufficient information of the rack and FA model and its parameters (e.g., spring elements, hydrodynamic mass, time history integration time step) considered for the seismic evaluation of NFSR and SFSR
  - Sensitivity analysis results of the impact forces and rack responses to variation in spring constants considered in the nonlinear seismic analyses
  - Sensitivity analysis results of the integration time step used in performing the nonlinear time history analyses for SSE.

## Summary of Main Topic in Section 9.1.2

- Resolution:
  - KHNP provided a detailed description of the Rack and FA model. NFSR and SFSR models are composed of 3-D elastic beam elements and lumped mass elements with properties derived from the dynamic characteristics of the detailed 3-D shell model of the racks.
  - Sensitivity analyses were performed for spring constants (i.e., stiffness) in the model; rack-to-floor, rack-to-rack and fuel-to-rack stiffness's at  $\pm 20\%$  of the nominal value. The effect of the sensitivities was a change in predicted loads within the variation found for different time histories and less than the variation for different COFs.
  - Comparison of a run at one half the fixed time step used for all other runs showed small changes in calculated results comparable to the run to run variation with different time histories.

# Summary of Main Topic in Section 9.1.2

## ❖ Mechanical Accident Analysis

- Related RAIs : 287-8272 (Q 09.01.02-23 & 24)
- Description of issue : Staff requested to provide the followings:
  - A nonlinear dynamic analysis for the impact effects of drop accidents, considering a finite element model
  - Location of the drop on the rack base plate that were considered to maximize the deformation of the rack base plate and whether it also considered a deep drop into a cell along the perimeter and half way between the supports
  - Consider all other fuel assemblies in place when a fuel assembly drops through an empty cell

## Summary of Main Topic in Section 9.1.2

- Resolution:
  - KHNP responded that all drop accidents are analyzed by developing a finite element model of the rack, rack base plate, a fuel assembly and the pedestal support using appropriate shell, beam, and solid body elements of ANSYS LS-DYNA program.
  - Drops as far away from the support provided by a pedestal are considered at two locations (a central cell and a peripheral cell at the midpoint of a side) that maximize the distance to the points of support.
  - The effects of all of the stored fuel assemblies in the rack is considered by modifying the density of the baseplate to simulate the loading effects of the other fuel assemblies.

# Summary of Open Items

## ❖ Open Item: Abnormal Conditions

- Related RAIs
  - RAI 167-8191 (Q 09.01.01-13)
- Description of issue
  - The staff is unable to confirm the applicant's statement that the mechanical accidents do not cause rack deformation that would affect criticality, until the seismic and structural review of the new and spent fuel storage racks (APR1400-H-N-NR-14012-P) is complete.
- Resolution:
  - KHNP provided that any damage to the racks is limited to portions above the neutron absorber and does not affect their configuration relative to the criticality analysis. The staff's review for APR1400-H-N-NR-14012-P, "Mechanical Analysis for New and Spent Fuel Storage Racks" was completed.

# Summary of Open Items

## ❖ Open Item: Neutron Absorber Material

- Related RAIs
  - RAI 469-8578 (Q 09.01.01-39)
- Description of issue
  - The staff concerns regarding the adequacy of utilizing as-fabricated Metamic™ coupons in the neutron absorber monitoring program because the Metamic™ material will be heated during fabrication (due to welding).
- Resolution:
  - KHNP provided that welding near the neutron absorber would not have an effect on corrosion resistance or neutron absorption of the material. The Metamic™ material qualification included exposing Metamic™ to a 900°F environment for 48 hours and examining the cooled material for changes in material properties. The qualification test demonstrated that the 48 hours in a 900°F environment resulted in no change in areal density, product weight, or dimensions.

# Summary of Open Items

## ❖ Open Item: Spent Fuel Pool Cooling and Cleanup System

- Related RAIs : 473-8582 (Q 09.01.03-4)
- Description of issue
  - Staff request to identify the minimum safety water level of SFP and update the DCD accordingly.
  - Staff request to revise the thermal-hydraulic calculations using the revised minimum safety water level and update the DCD accordingly.
  - Additionally, the staff identified that the normal water level has been identified as elevation 154', while in other places it shows as elevation 153'.
- Resolution:
  - The minimum safety water level for SFP was provided through the response to RAI 473-8582, Q 09.01.03-4.
  - Thermal-hydraulic calculation has been revised based on minimum water level (EL. 146').
  - KHNP proposed DCD changes in order to indicate clearly that these two levels (EL. 153' in Technical Specifications and EL. 154' as normal water level) represent different conditions through the response to RAI 473-8582, Q 09.01.03-5.

# Summary of Open Items

## ❖ Open Item: Communication System

- Related RAIs : 491-8613 (Q 09.05.02-4)
- Description of issue
  - Staff requested to justify why the communication systems are not considered as risk significant SSCs, related to the requirements of 10 CFR Part 50, Appendix A, GDC 1, GDC 2, GDC 3, and GDC 4.
  - Staff issued a follow-up RAI 548-8822, Q 09.05.02-6.
- Resolution:
  - KHNP responded that the communication systems of the APR1400 are designed to meet GDC 1, GDC 2, GDC 3, and GDC 4 and do not interface with any safety-related or risk-significant SSC.
  - The four communication subsystems are designed to assure that any single event does not result in a complete loss of plant communication.



# Summary of Open Items

## ❖ Open Item: ITAAC and ITP for communication system

- Related RAIs : 491-8613 (Q 09.05.02-5)
- Description of issue
  - Staff requested to provide the detailed description of all ITAAC items along with their acceptance criteria and ITP for the communication systems in Section 14.2.
  - Staff requested to clarify what the applicant means by functional arrangement of communication systems.
  - Staff issued a follow-up RAI 548-8822, Q 09.05.02-7.
- Resolution:
  - KHNP provided the new ITP for plant communication system and the detailed description of all ITAAC items for communication system through the response to RAI 548-8822, Q 09.05.02-7.
  - KHNP revised DCD Tier 1, Subsection 2.6.9 providing the detailed description of plant communication systems instead of the term of functional arrangement.

# Response to Phase 3 Questions

## ❖ The Question in ACRS APR1400 Subcommittee on May 18, 2017

### ▪ 9.2.7 Chilled Water System

- Question: The basis for the non-safety-related plant chilled water system to provide cooling for the safety related turbine driven auxiliary feedwater (TDAFW) pump room
- Response:
  - In order to avoid damage caused by HELB accident to safety-related system (ECW), non-safety-related cubicle cooler is installed in the TDAFW pump room.
  - The heat-up calculation is performed to determine the maximum temperatures in the TDAFW pump room under the loss of cooling.
  - TDAFW pump shall be qualified to be operable at maximum temperature for the operation period.

# Response to Phase 3 Questions

## ❖ The Question in ACRS APR1400 Subcommittee on May 18, 2017

- Summary for Heat-up calculation of turbine driven auxiliary feedwater pump room
  - Purpose:
    - 1) To determine the maximum temperatures in the TDAFW pump room
    - 2) To demonstrate that the maximum temperature of the room does not exceed the maximum allowable temperature during 72 hours under loss of HVAC system
  - Calculation Program: GOTHIC (Generation of Thermal-Hydraulic Information for Containments) program
  - Maximum Allowable Temperature: Maximum allowable temperature, 150 °F of the room is decided based on the steady-state temperature of Condition 2 mentioned in NUMARC 87-00
  - Result : The TDAFW pump rooms are maintained below 150 °F during 72 hours under loss of cooling.

# Current Status

---

- ❖ **Chapter 9 is complete**
  - KHNP continues to monitor Chapter 9 to assure any conforming changes are addressed.
  - 5 open items, that were identified in Phase 2 and 3, have been resolved with adequate and sufficient discussion with the staff.
  
- ❖ **Changes in Chapter 9 as reviewed and marked-up in response to the RAIs will be incorporated into the next revision (Rev.2) of the DCD**

# Attachment: Acronyms

|               |  |
|---------------|--|
| <b>COF</b>    | Coefficient of Friction                                      |
| <b>COL</b>    | Combined License   |
| <b>DCD</b>    | Design Control Document                                      |
| <b>ECW</b>    | Essential Chilled Water System                               |
| <b>FA</b>     | Fuel Assembly  |
| <b>GOTHIC</b> | Generation of Thermal-Hydraulic Information for Containments |
| <b>HELB</b>   | High Energy Line Break                                       |
| <b>ITAAC</b>  | Inspection, Test and Acceptance Criteria                     |
| <b>KHNP</b>   | Korea Hydro and Nuclear Power Co.                            |
| <b>NFP</b>    | New Fuel Storage Pit   |
| <b>NFSR</b>   | New Fuel Storage Rack  |
| <b>RAI</b>    | Request for Additional Information                           |
| <b>SFP</b>    | Spent Fuel Pool  |
| <b>SFPCS</b>  | Spent Fuel Pool Cooling System                               |
| <b>SFSR</b>   | Spent Fuel Storage Rack                                      |
| <b>SSE</b>    | Safe Shutdown Earthquake                                     |
| <b>TDAFW</b>  | Turbine Driven Auxiliary Feedwater                           |

## Attachment : List of COL Item related to OIs

| COL Identifier | Description   |
|----------------|---|
| COL 14.2(17)   | The COL applicant is to prepare the site-specific preoperational and startup test specification and test procedure and/or guideline for offsite communication system. |



# **Presentation to the ACRS Subcommittee**

**Korea Hydro Nuclear Power Co., Ltd (KHNP) APR1400 Design  
Certification Application Review**

**Safety Evaluation with No Open Items:**

**Chapter 9 AUXILIARY SYSTEMS**

**February 21, 2018**

# Staff Review Team

## **NRO/SPSB**

Raul Hernandez  
Hien Le  
Chang Li  
Angelo Stubbs  
Ryan Nolan  
Bob Vettori  
Dennis Andrukat  
Thinh Dinh

## **NRO/MCB**

Andrew Yeshnik  
John Honcharik  
Greg Makar

## **NRO/SCVB**

Danny Chien

## **NRO/SEB**

Vaughn Thomas  
Pravin Patel  
BP Jain

## **NRO/ICE**

Dawnmatthews Kalaliveettil

## **NRO/SRSB**

Alexandra Burja

## **NRR/EENB**

Adakou Foli  
Sheila Ray

**Special Thanks** Rich Morante, Carolyn Lauron, and Brian Hughes

## **Project Managers**

Bill Ward – Lead Project Manager  
George Wunder – Chapter 9 Project Manager



# Introduction

## New and Spent Fuel Storage Racks

- Function
  - ♦ New and spent fuel storage racks provide safe storage for fuel assemblies and maintain a coolable geometry, preventing criticality, and protect the fuel assemblies from seismic and mechanical load effects
- Safety Review Scope in Section 9.1.2
  - ♦ Structural design of new and spent fuel storage racks to withstand effects of natural phenomena (seismic) and mechanical accident scenarios involving fuel assembly
- Spent fuel pool and pool liner design
  - Staff's safety evaluation of the spent fuel pool and the pool liner provided in SER Section 3.8.3.4.6
- Criticality Evaluation
  - Staff's safety evaluation of the racks criticality in provided in SER Section 9.1.1

# New and Spent Fuel Storage

## Overview

- Review Highlights
  - ♦ Reviewed TR “Mechanical Analysis for New and Spent Fuel Storage Racks,” APR1400-H-N-NR-14012-P, Rev. 3, August 2017
  - ♦ Review basis Appendix D to SRP Section 3.8.4, “Guidance on Spent Fuel Racks”
  - ♦ Seismic input and finite element models used for nonlinear seismic analysis
  - ♦ Mechanical accident scenarios involving dropped and stuck fuel assembly
  - ♦ Computer codes and validation
  - ♦ Analysis methodology including design parameters, and assumptions made in finite element analyses
  - ♦ Review results for reasonableness
  - ♦ Applicable COL information items
- Request for Additional Information (RAIs)
  - Staff issued 39 RAIs and all questions were resolved

**Staff concludes that stresses induced in the racks and its components meet the applicable ASME Code allowable stresses, rack seismic displacement are small and do not impact each other or the pool wall and its sub-critical configuration is unaffected.**

# New and Spent Fuel Storage

- Areas of Review
  - ♦ Physical description
  - ♦ Applicable design codes, standards, and specifications
  - ♦ Seismic and impact loads
  - ♦ Loads and load combinations
  - ♦ Structural design and analysis
  - ♦ Structural acceptance criteria
  - ♦ Materials, quality control programs, and Inspection

# Physical Description

## New Fuel Storage Racks (NFSRs)

- ♦ Located in the new fuel storage pit in Fuel Handling Building
- ♦ Two identical racks, each with a 7 x 8 array of storage cells
- ♦ Total of 112 fuel storage locations
- ♦ NFSRs are bolted to embedment plates at the bottom of the pit and do not slide
- ♦ The NFSRs are constructed of stainless steel
- ♦ The center-to-center spacing between adjacent fuel assemblies is designed to be 14 inches to maintain sub-criticality


# Physical Description

## Spent Fuel Racks (SFRs)

- ♦ 23 SFSRs located in the Spent Fuel Pool (SFP) with gaps between the adjacent racks and the surrounding fuel pool walls
- ♦ SFSRs are freestanding, with pedestals resting on embedment plates in the reinforced concrete floor of the SFP
- ♦ The SPF is divided into two regions, region I and region II.
- ♦ Region I contains four 8 x 8 array racks and two 6 x 8 array racks; The center-to center spacing between adjacent fuel assemblies is designed to be 10.83 inches to maintain sub-criticality
- ♦ Region II contains nineteen 8 x 8 array racks and four 8 x 7 array racks; The center-to center spacing between adjacent fuel assemblies is designed to be 8.86 inches to maintain sub-criticality

# Physical Description

Figure 2-8 Isometric Schematic of the SFSR  
(Region II)



# Design Codes, Standards, and Specification

- Applicant identified the following industry codes and regulatory guides that are applicable to the design, fabrication, construction, materials, testing, and inspections of the new and spent fuel storage racks for the APR1400 plant:
  - ♦ ASME Code, Section III, Division 1, Subsection NF and Appendix F, 2007 Edition through 2008 Addenda
  - ♦ ASME Code, Section II, “Materials,” 2007 Edition through 2008 Addenda
  - ♦ RG 1.29
  - ♦ RG 1.61
- **The staff found the use of these codes, standards, and specifications to be consistent with the guidance given in SRP Section 3.8.4, Appendix D and therefore acceptable**

# Analysis for Seismic and Impact Loads

## Nonlinear Seismic Analysis

### Input Motion

- ♦ Target input response spectra - envelope of rack base and the SFP wall
- ♦ Input Time histories -Five time histories developed enveloping the target spectra with the guidance in SRP 3.7.1 for multiple time histories.

### Analytical Model

- ♦ A 3-D coupled Rack-Fuel beam model for each rack and whole pool multi-rack model
- ♦ Hydrodynamic effects: Rack-to-rack, rack-to-pool wall, rack baseplate-to-pool floor, fuel assembly-to-cell wall
- ♦ Mass and stiffness of fuel assembly and fuel spacer grid for impact
- ♦ New and end of life (EOL) fuel properties
- ♦ Gap and contact spring and sensitivity analysis of spring parameters

### Seismic analysis Methodology

- ♦ Three directional orthogonal time histories applied simultaneously
- ♦ Nonlinear seismic time history analysis performed for 5 sets of acceleration time histories



# Analysis for Seismic and Impact Loads

## Seismic and Impact Loads

- ♦ Nonlinear seismic analyses performed for three values of the coefficient of friction: 0.2, 0.5, and 0.8
- ♦ Considered the configurations of the SFSR at full, 25-percent full, 50-percent full, and empty mixed loadings and the NFSR fully loaded
- ♦ The numerical solution was obtained by direct integration of the nonlinear equations of motion
- ♦ Considered sensitivity analysis for Integration time step
- ♦ Considered 20 Dynamic simulation
- ♦ Considered additional 16 simulations for the sensitivities of various seismic model parameters (e.g., gap springs stiffness)
- ♦ Validated and verified (V&V) ANSYS Computer code for nonlinear fuel rack analysis

**The staff found the applicant's seismic nonlinear analysis including the seismic input, seismic model parameters and the analysis methodology and validation of the computer Code ANSYS to be reasonable and consistent with the regulatory guidance in SRP Section 3.8.4, Appendix D, Section 3.7.1, Section 3.8.1, Section II.4.F (guidance for the use of validated computer programs) and Regulatory Guide 1.61, and therefore are acceptable.**

# Analysis for Seismic and Impact Loads


## Mechanical Accidents Analysis involving Fuel Assembly

- Four mechanical accident scenarios considered
  - ♦ Straight shallow drop on SFSR (NFSR has no neutron absorber to damage)
  - ♦ Straight Deep Drop Away from NFSR and SFSR rack pedestal
  - ♦ Straight Deep Drop Over a SFSR Pedestal
  - ♦ Stuck Fuel assembly
- Analyses
  - ♦ Accident scenarios analyzed by a detailed 3-D finite element model using LS-DYNA computer code
  - ♦ Rack is considered fully loaded in the drop analysis
  - ♦ Drop locations are appropriate to evaluate maximum plate deflection
  - ♦ Demonstrated that the impact of the straight deep drop of a fuel assembly on specific locations on the baseplate does not cause any significant deformation to the baseplate
  - ♦ Minimum safety factor for all four accident scenarios is greater than 1.4

**The staff found that the applicant used a detailed 3-D finite element model to analyze the mechanical accident scenario and deformation acceptance limit are consistent with the guidance in SRP 3.8.4, Appendix D and therefore acceptable.**


# Analysis for Seismic and Impact Loads (Accident Scenario)

Figure 4-1 Straight Shallow Drop




# Analysis for Seismic and Impact Loads (Accident Scenario)

Fig. 4-2 Deep Drop Away from  
a Pedestal



# Analysis for Seismic and Impact Loads (Accident Scenario)

Figure 4-3 Deep Drop Over a Pedestal



# Loads and Load Combinations

- Loads
  - ♦ Dead Load including fuel assembly weight (D)
  - ♦ Live Load (L)
  - ♦ Safe Shutdown Earthquake (E')
  - ♦ Thermal loads (To, Ta)
  - ♦ Mechanical accident loads involving Fuel assembly (Fd, Pf))
- Load Combinations for ASME Code Service level limits A, B, and D
  - ♦  $D + L$  Service Level A
  - ♦  $D + L + T_o$  Service Level A
  - ♦  $D + L + T_o + P_f$  (stuck fuel assembly) Service Level B
  - ♦  $D + L + T_a + E'$  Service Level D
  - ♦  $D + L + F_d$  (Fuel load drop) Rack Functional Capability

**The staff found the loads and load combinations considered for applicable ASME Code Service level limits to be consistent with the information in SRP Section 3.8.4, Appendix D and therefore acceptable.**

# Structural Design and Analysis Procedures

- Design Considerations
  - ♦ Applicant described the structural design of various elements of the rack structure
  - ♦ Stresses in welds between cell-to-baseplate, baseplate-to-pedestal, and cell-to-cell,
  - ♦ Local stresses caused by cell wall impact, cell wall buckling,
  - ♦ Secondary stress due to thermal effects
  - ♦ Stresses in Fuel Assembly
- Design Forces and stresses
  - ♦ Forces from the nonlinear seismic analysis or mechanical accident analysis
  - ♦ Combined with appropriate loads in the load combination
  - ♦ Calculated design stresses
- Stress Acceptance Limit
  - ♦ ASME Code Section III, Subsection NF, Level A, B, and D service limits for Class 3
- Safety Factor
  - ♦ Ratio of Allowable stress to calculated stress

# Structural Acceptance Criteria (Limit)

- Acceptance limits of the rack structures are defined in ASME Code Section III, Subsection NF, as applicable for Class 3 components support.
- Material Properties” at 200 degrees Fahrenheit (F)) used to develop the stress limits for various service level conditions
- Service Level A limits consistent with ASME Code Section III, Subsection NF-3320. The applicant conservatively used service level A stress limits to evaluate service level B loading
- The Increase factor for Service level D stress limits consistent with the criteria in ASME Code Section III, Appendix F, Section F-1334
- Minimum factor of safety against overturning is required to be equal to or greater than 1.5

**The staff found the structural acceptance criteria consistent with the information in SRP Section 3.8.4, Appendix D and SRP Section 3.8.5 and therefore acceptable**



# Material, Quality Control Programs & Inspections

- Material
  - ♦ SA-240 type 304 L for cells and plates
  - ♦ SA-564 Grade 630 for support studs
  - ♦ Neutron absorber material (METAMIC) attached to SFSRs
  - ♦ Fuel assembly material data from PWR Plus7 fuel assembly
- Design, Fabrication, and Inspection
  - ♦ ASME Code Section III Subsection NF requirements
- Quality Control Program
  - ♦ Racks are designated seismic Category I structures and treated as safety-related components
  - ♦ Committed to 10CFR Part 50 Appendix B for Quality control program and 10CFR 50.65 for periodic monitoring

**The staff found the material, design, fabrication and inspection and QA program consistent with Appendix D to SRP 3.8.4 and therefore acceptable.**

# COL Information Items

## Four COL Items

- ♦ Periodic condition monitoring program – confirm material and geometric assumptions remain valid during operating life of the plant
- ♦ Perform confirmatory dynamic and stress analysis considering site specific conditions
- ♦ Develop plant procedures and admin controls for fuel handling activities over the spent fuel pool
- ♦ Develop post-seismic event inspection procedure to measure gaps between fuel storage racks

**The staff found COL items to be acceptable because it adequately describes actions necessary for the COL applicant.**

# Conclusion

- Structural design of the fuel racks meets the ASME Code Section III Subsection NF design requirements
- Minimum safety factor for the fuel racks during seismic event and postulated mechanical accident scenarios is 1.19 ( $>$  minimum required 1.0)
- Spent fuel rack displacements due to design basis seismic event are small and do not close the large gap of 33" between the SFSRs and the SFP wall
- Spent fuel rack maximum relative displacement (0.28", Region II racks) due to design basis seismic event is smaller than the rack-to-rack separation (1.18", Region II racks); margin against impact is  $1.18"/0.28" = 4$ ; Larger margin for Region I racks ( $>6$ )
- Free standing spent fuel rack do not overturn due to the design basis seismic event and the safety factor against overturning is significantly greater than the required minimum safety factor of 1.5
- Due to small seismic movements, criticality analysis for the rack configuration is bounded by the SFP Criticality analysis for normal conditions included in SER subsection 9.1.1

# Summary Conclusion

New and spent fuel storage racks provide safe storage for fuel assemblies and maintain a coolable geometry, preventing criticality, and protect the fuel assemblies from seismic and mechanical load effects

# Materials

- Applicant uses typical materials for fuel storage
  - New fuel racks: Type 304L and Type 630 stainless steel
  - Spent fuel racks: Type 304L and Type 630 stainless steel, Metamic neutron absorber (not credited for structural capacity)
  - Spent fuel pool liner: Type 304 stainless steel
- Fuel racks are designed, fabricated, and inspected to ASME Code Section III-NF requirements
- Spent fuel pool liner ASTM grade material with ASME NQA-1 and Appendix B Quality Assurance.
- New fuel is in dry storage – degradation will not occur.
- Spent fuel is stored in the spent fuel pool. The applicant has selected materials with good resistance to corrosion in spent fuel pool environments. The spent fuel pool water is controlled as described in FSAR Section 9.1.3 and is consistent with the EPRI Primary Water Chemistry guidelines. The neutron absorber coupon monitoring program is evaluated in SER Section 9.1.1 and was found to be acceptable.
- Sensitization controls, delta ferrite content, and cleanness controls are consistent with staff guidance (RG 1.31, RG 1.44, and NQA-1 Subpart 2.1).

**The staff found the approach consistent with SRP Section 9.1.2 and acceptable.**

## Review Objective

New fuel storage pit (NFSP) and spent fuel pool (SFP) safety functions: maintain the fuel assemblies in a safe and subcritical array during all credible storage conditions and to provide a safe means of loading the spent fuel assemblies into shipping or storage casks.

## Items of major interest

Staff reviewed NFSP and the SFP in accordance with the guidance in SRP 9.1.2. The staff evaluated system configuration and seismic design of SSCs to ensure adequate water inventory in the SFP.

All RAI responses found acceptable and proposed changes to DCD have been incorporated, there are no remaining Open Items.

# Technical Topics

## Section 9.1.1 – Criticality Safety of New and Spent Fuel Storage

### Open Item – Effects of Thermal Conductivity Degradation (TCD)

**Issue:** Staff asked in RAI 8191, Question 09.01.01-8, how the maximum fuel temperature assumed for the depletion calculation in the burnup credit criticality analysis accounted for TCD.

**Resolution:** In the response to RAI 7954, Question 11 (related to the PLUS7 Fuel Design Topical Report), the applicant showed that the assumed maximum fuel temperature bounds the expected maximum fuel temperature plus the staff-approved TCD penalty.

### Open Item – Mechanical Analysis Review

**Issue:** The staff's review of APR1400-H-N-NR-14012-P, "Mechanical Analysis of New and Spent Fuel Storage Racks," was incomplete as of Phase 2, so the staff was unable to determine whether any mechanical accidents could have impacts on criticality.

**Resolution:** The staff completed its review of APR1400-H-N-NR-14012-P and concludes that the criticality analyses bound any criticality-related effects of the analyzed mechanical accidents.

# Technical Topics

## Section 9.1.1 - Criticality Safety of Fresh and Spent Fuel Storage and Handling

### Open Item - RAI 469-8578, Question 09.01.01-39

**Issue:** The fabrication process of the spent fuel rack may expose the Metamic neutron absorber to elevated temperatures (welding in close proximity). The staff questioned if the neutron absorber coupons needed an additional heat treatment to reflect the final condition of the Metamic neutron absorber.

**Resolution:** The applicant stated that the as-manufactured coupons were sufficient.

**Open Item Closure:** The staff re-examined the qualification testing of Metamic<sup>[1]</sup> that has been previously submitted and accepted by the NRC. One qualification test exposed Metamic material to 900 °F for 48 hours and demonstrated no change in neutron absorption. The staff also reviewed generic literature on aluminum-boron carbide neutron absorbers and concluded that temperatures above 1000 °F are expected during fabrication (solidus temperature around 1100 °F for aluminum alloys). The staff agrees that the as-fabricated neutron absorber coupons are sufficient and this item is closed.

1. "Use of Metamic in Fuel Pool Applications," HI-2022871 [ML022280353] and "Qualification of Metamic for Spent-Fuel Storage Application [EPRI Report 1003137]



## Section 9.1.3 – SFP Cooling and Cleanup System

### Open Item - RAI 473-8582

**Issue:** the staff evaluated the applicant's SFP thermal-hydraulic analysis and identified inconsistencies between the assumptions used for the analysis and the system description in the DCD.

**Resolution:** A response to RAI 473-8582 was provided and included:

- Revised thermal-hydraulic calculation (available via audit),
- clarification of assumptions used in revised thermal-hydraulic analysis;
- DCD markups to eliminate the inconsistency in assumptions;

**Open Item Closure:** The staff reviewed the information provided by the applicant in the RAI response, the DCD, and the technical report summarizing the thermal-hydraulic analysis and confirmed that the revised thermal-hydraulic analysis uses conservative assumptions that are consistent with the SRP guidance and therefore meet the requirements of GDC 61.

# Technical Topics

## Section 9.5.2 – Communication Systems

### Open Item - RAI 548-8822, Question 09.05.02-6

**Issue:** Applicant had classified all communication systems as non-safety related. Hence DCD stated that the communication systems did not require compliance with 10 CFR Part 50, Appendix A, GDC 1, GDC 2, GDC 3, and GDC 4

**Resolution:** A response to RAI 548-8822 was provided and included:

- Commitment that the design of the communication systems will comply with 10 CFR Part 50, Appendix A, GDC 1, GDC 2, GDC 3, and GDC 4
- Detailed mark-ups of the DCD which explained how the communication systems would meet all of the applicable GDCs

**Open Item Closure:** The staff reviewed the information provided by the applicant and determined that the design information and commitment given by the applicant was sufficient to meet the intent of 10 CFR Part 50, Appendix A, GDC 1, GDC 2, GDC 3, and GDC 4.

# Technical Topics

## Section 9.5.2 – Communication Systems

### Open Item - RAI 548-8822, Question 09.05.02-7

**Issue:** DCD lacked sufficient information in APR1400 FSAR Tier 1, Table 2.6.9-1. Additional detail was needed to ensure that each communication subsystem is capable of performing its intended function.

**Resolution:** A response to RAI 548-8822 was provided and included:

- Detailed mark-ups which explained the procedures needed to ensure that each communication subsystem is capable of performing its intended function.
- Necessary and sufficient information about each communication subsystem in the ITAAC and Acceptance Criteria of Table 2.6.9-1.

**Open Item Closure:** 10 CFR 52.47(b)(1) requires that a design certification application contain the necessary and sufficient ITAAC. The staff reviewed the information provided by the applicant and determined that sufficient detail was provided in APR1400 FSAR Tier 1 to meet the intent of 10 CFR 52.47(b)(1).