

SUBSECTION 2.4.8 TABLE OF CONTENTS

<b><u>Section</u></b>	<b><u>Title</u></b>	<b><u>Page</u></b>
2.4.8	Cooling Water Canals and Reservoirs.....	2.4.8-1

#### **2.4.8 Cooling Water Canals and Reservoirs**

The small modular reactors under consideration at the Clinch River Nuclear (CRN) Site do not rely on the Clinch River arm of the Watts Bar Reservoir for a safety-related water supply, and the site does not include cooling water canals or reservoirs. The CRN Site uses the Clinch River arm of the Watts Bar Reservoir as the source of makeup water for nonsafety-related, normal plant cooling.