

Official Transcript of Proceedings
NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
Open Session

Docket Number: (n/a)

Location: Rockville, Maryland

Date: Thursday, March 5, 2020

Work Order No.: NRC-0839

Pages 1-117

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA

NUCLEAR REGULATORY COMMISSION

+ + + + +

671ST MEETING

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

OPEN SESSION

+ + + + +

THURSDAY

MARCH 5, 2020

+ + + + +

ROCKVILLE, MARYLAND

+ + + + +

The Advisory Committee met at the Nuclear
Regulatory Commission, Two White Flint North, Room
T2D10, 11545 Rockville Pike, at 8:30 a.m., Matthew W.
Sunseri, Chairman, presiding.

COMMITTEE MEMBERS:

MATTHEW W. SUNSERI, Chairman

JOY L. REMPE, Vice Chairman

WALTER L. KIRCHNER, Member-at-Large

RONALD G. BALLINGER, Member

DENNIS BLEY, Member

CHARLES H. BROWN, JR., Member

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

VESNA B. DIMITRIJEVIC, Member

JOSE MARCH-LEUBA, Member

DAVID PETTI, Member

PETER RICCARDELLA, Member

ACRS CONSULTANTS:

STEPHEN SCHULTZ

DESIGNATED FEDERAL OFFICIAL:

MIKE SNODDERLY

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

C-O-N-T-E-N-T-S

Opening Remarks by the ACRS Chairman 4

NuScale Areas of Focus: Steam Generator
Design, Containment Evacuation System and
Hydrogen & Oxygen Monitoring 8

NuScale Topical Reports: Loss of Coolant Accident
(LOCA), Non-LOCA and Rod Ejection Accident
Methodologies 74

P R O C E E D I N G S

(8:30 a.m.)

CHAIRMAN SUNSERI: The meeting will now come to order. This is the first day of the 671st meeting of the Advisory Committee on Reactor Safeguards.

I am Matthew Sunseri, the Chair of the ACRS. Members in attendance today are Pete Riccardella, Ron Ballinger, Dave Petti, Joy Rempe, Walt Kirchner, Jose March-Leuba, Charlie Brown.

Dennis Bley is here. He'll be stepping in a minute and Vesna Dimitrijevic. We also have our consultant, Steve Schultz present as well. And I note that we have a quorum.

The ACRS was established by the Atomic Energy Act and it's governed by the Federal Advisory Committee Act.

The ACRS section of the U.S. NRC public website provides information about the history of the ACRS and provides documents such as our charter, bylaws, Federal Register notices for meetings, letter reports and transcripts of all full and subcommittee meetings, including slides presented at the meetings.

The Committee provides its advice on safety matters to the Commission through its publicly

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 available letter reports. The Federal Register notice
2 announcing this meeting was published on February 21,
3 2020, and provides an agenda and instructions for
4 interested parties to provide written documents or
5 request opportunity to address the Committee.

6 The Designated Federal Official for this
7 meeting is Mr. Mike Snodderly. During today's meeting
8 the Committee will consider the following.

9 NuScale Area of Focus: Steam Generator
10 Design, Containment Evacuation System and Hydrogen and
11 Oxygen monitoring and number two, NuScale Topical
12 Reports: Loss of Coolant Accident (LOCA), Non-LOCA
13 and Rod Ejection Accident Methodology.

14 Following those presentations the ACRS
15 will engage in preparation of reports. As reflected
16 in our agenda, portions of the NuScale session may be
17 closed in order to discuss and protect information
18 designated as sensitive or proprietary. And I will
19 say there will be closed sessions today.

20 A phone bridge line has been opened to
21 allow members of the public to listen in on the
22 presentations and Committee discussion. We have
23 received no written comments or requests to make oral
24 statements from members of the public regarding
25 today's session.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 There will be an opportunity for public
2 comment and we have set aside time in the agenda for
3 comments from members of the public attending or
4 listening to our meetings. Written comments may be
5 forwarded to Mr. Mike Snodderly, the Designated
6 Federal Official.

7 A transcript of the open portion of the
8 meeting is being kept and it is requested that
9 speakers use one of the microphones, identify
10 themselves and speak with sufficient clarity and
11 volume so that they may readily be heard.

12 For the people that will be presenting
13 today, I ask that you consider the following. We've
14 seen a lot of the material. And in most of the
15 subcommittee meetings on these topics we've had full
16 committee membership participation.

17 So, please feel free to progress smartly
18 through, you know, maybe the background material and
19 stuff that we've seen before and focus your detail on
20 the things that you've been briefed on as important to
21 us because we know you know what topics are important
22 to us.

23 If we need to slow you down we will slow
24 you down. So, let us control the pace.

25 Just one thing before we get into the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 presentations. I do have an item of interest that I
2 want to make public. Today in the Federal Register
3 notice a notice was published that we are seeking
4 qualified candidates for membership on the ACRS.

5 The ACRS is seeking two members, one with
6 nuclear power plant experience and a second one
7 regarding, with risk analysis and the consideration of
8 uncertainty in decision making. So, those positions
9 fill out vacant and soon to be vacant with retirement
10 the positions.

11 And any interested candidates should
12 follow the instructions on the Federal Register
13 notice. We will now begin the presentations with
14 NuScale.

15 And I'll turn to staff to see if they have
16 any remarks that you want to make before the NuScale
17 presentation. Who is, Rebecca, are you over there?

18 MS. PATTON: No. We just thank the
19 Committee for their time and hope for a productive
20 dialogue.

21 CHAIRMAN SUNSERI: Okay, thank you. And
22 now, Marty, the floor is yours for the NuScale.

23 MR. BRYAN: Okay, thanks, Matt. I'm Marty
24 Bryan. I'm the licensing project manager for Chapter
25 3. I've got with me Bob Houser, Kevin Spencer,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Matthew Presson and also Brian Wolf will be joining us
2 on the phone for part of the presentation.

3 So, today in open session it's fairly
4 brief. We're going to get into more of the feedback
5 we received in the closed session. But certainly ask
6 questions if something comes up.

7 So, we're going to do just a brief
8 overview of Steam Generator Design and then talk a
9 little bit about the proposed DCA revisions that we
10 intend to include in the errata for Rev 4. So, I'll
11 turn it over to Kevin.

12 MR. SPENCER: So, I'm Kevin Spencer. I'll
13 be doing a brief overview of the Steam Generator
14 Design this morning. This was previously presented so
15 I'll try to -- I'll make it fairly high level.

16 Each NuScale power module has two steam
17 generators. On the shell side we have the primary
18 fluid. On the tube side we have the secondary fluid.

19 We have about 1,380 tubes overall. They
20 range in length from 74 to 86 feet. It is a helical
21 coil design. Each tube is made out of Alloy 690,
22 thermally treated material.

23 I have brought with me this morning a
24 little, a plastic prototype of the steam generator
25 tubes and how they interact with the steam generator

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 supports. I'll pass this around.

2 Feel free, it does come apart. If it
3 falls apart you can put it back together easily. But
4 it will allow you to take a look at how the helical
5 coil tubes interact with the tube supports. So, I'll
6 pass this around.

7 MEMBER MARCH-LEUBA: While you still have
8 it in your hand, what's the length of the straight
9 shot on the tube? When does it start curving because
10 you're going to put the other thing, the metal thing
11 inside it, right?

12 MR. SPENCER: Yes. So, the helical coil
13 this is, the supports have the, work on the helical
14 coil section of it.

15 But at the, where it intersects with the
16 steam and feedwater plenum you can kind of see on the
17 drawing on the left-hand side here there is a straight
18 section, a straight leg section.

19 MEMBER MARCH-LEUBA: You need to look at
20 the microphone or he can't hear you.

21 MR. SPENCER: Okay. There is a straight
22 leg section down at the feedwater plenum and at the
23 steam plenum. That's a transition from the helical
24 coil to a straight tube.

25 That varies in length for each tube. But

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 it's typically on the order of 20 to 30 inches at
2 least on the feedwater side.

3 MEMBER MARCH-LEUBA: So, you have like 20
4 inches of straight?

5 MR. SPENCER: Yes.

6 MEMBER MARCH-LEUBA: Good. That's good
7 information to have.

8 MR. SPENCER: Yes. And I do want to note,
9 we can actually just probably go to the next slide and
10 I'll do the IFR.

11 I did bring a prototype inlet flow
12 restrictor as well. Now this one is a prototype so
13 it's a little bit longer than the one you'll see on
14 the screen which is representative of the actual
15 design.

16 Notably, this has eight sections and the
17 actual design has five sections. This also doesn't
18 have the threaded connection that will thread it onto
19 the plate.

20 But it is kind of -- it's prototypical so
21 you it would allow you to get a feel for it.

22 MEMBER MARCH-LEUBA: That's not
23 proprietary, the design?

24 MR. SPENCER: No. Not in this form
25 without dimensions and such.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER MARCH-LEUBA: The dimensions are
2 proprietary. But the number of stages is not
3 proprietary.

4 MR. SPENCER: Right, right.

5 MEMBER MARCH-LEUBA: Okay.

6 MEMBER RICCARDELLA: I note that from this
7 model that tubes can slide axially. Is that true in
8 the actual model?

9 MR. SPENCER: That won't be necessarily
10 true in the actual model because the helical coil will
11 be constrained on all sides.

12 But what I did want to mention here with
13 the five, with the set of five expansions you'll
14 notice that the IFR is contained within the actual
15 tube sheet.

16 So, it doesn't extend out past the, it
17 doesn't extend past the tube sheet into the heated
18 area.

19 MEMBER MARCH-LEUBA: What is the tube
20 sheet?

21 MR. SPENCER: Yes. So, it's not as long,
22 the --

23 MEMBER MARCH-LEUBA: So, this is outside
24 of the primary? It's not in contact with the primary
25 fluid?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. SPENCER: That's correct. That's
2 correct.

3 CHAIRMAN SUNSERI: So, when you said the
4 tube straight piece is 30 inches or so is that
5 including the length through the tube sheet or after
6 it passes through the tube sheet?

7 MR. SPENCER: The straight section from
8 the feedwater transition plenum is probably on the
9 range from 20 to maybe 35 inches overall. And then
10 that does include the length of tube which is, which
11 passes through the tube sheet and is welded on the
12 secondary face of the tube sheet.

13 I think I can say that it's probably not
14 proprietary to say that. That's on the order of six
15 inches is the thickness of the tube sheet.

16 MEMBER MARCH-LEUBA: So, just so I can
17 visualize it. Where the IFR is inserted that is not
18 a tube but is a stronger piece of material?

19 MR. SPENCER: It is, it's a tube that's
20 passed through a hole. So, there's a six inch thick
21 metal plate.

22 MEMBER MARCH-LEUBA: So, it's a thick
23 metal plate with drills.

24 MR. SPENCER: Yes, with the appropriate --
25 the OD of the tube would be drilled through. The tube

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 is inserted into the tube sheet. It's hydraulically
2 expanded.

3 So, it's pushed out with force up against
4 those walls. And then it's, there's a fillet weld on
5 the end of the tube on the secondary face.

6 MEMBER MARCH-LEUBA: So, it's welded at
7 the bottom?

8 MR. SPENCER: So, in this drawing here it
9 would be welded in between the IFR mounting plate.
10 And you'll see there's clouding on that second side.
11 That's to allow a similar metal weld.

12 MEMBER MARCH-LEUBA: The IFR is held in
13 place from the back on the, with a screw?

14 MR. SPENCER: Yes. So, there's an IFR
15 plate that all these, each IFR is inserted into the
16 plate. It's mounted through a threaded section
17 through the plate.

18 Ideally that's going to be a loose design
19 when it's inserted into the tube so that it will allow
20 each IFR to be seated into the tubes. That plate will
21 be mounted through various mounting studs to the
22 actual tube sheet.

23 That will prevent any sort of bowing or
24 flexure of that plate. And then once all that is in
25 position then those IFR, then the IFR threads

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 themselves will be tightened up and preloaded.

2 MEMBER MARCH-LEUBA: And you do this every
3 refueling, to load it?

4 MR. SPENCER: Yes. This will be --

5 MEMBER MARCH-LEUBA: So, you loosen the
6 screw in the back for every one of them and then put
7 them in?

8 MR. SPENCER: Yes. Not for every
9 refueling but for every inspection.

10 MEMBER MARCH-LEUBA: Yes, right. Every
11 time you take it apart.

12 MR. SPENCER: Yes. And it may be during
13 a steam generator inspection you may be doing 100
14 percent inspection of the tubes. You may also be
15 inspecting some smaller number of the tubes based on
16 the steam generator program that the utility sits on.

17 MEMBER MARCH-LEUBA: But all the IFRs are
18 on the same plate?

19 MR. SPENCER: I'm sorry.

20 MEMBER MARCH-LEUBA: All of the IFRs are
21 on the same plate --

22 MR. SPENCER: Yes.

23 MEMBER MARCH-LEUBA: -- for each entrance?

24 MR. SPENCER: Yes.

25 MEMBER MARCH-LEUBA: You have four of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 them.

2 MEMBER BALLINGER: What is the orientation
3 of the flow restrictor, is the left-hand end the
4 furthest end of the tube sheet?

5 MR. SPENCER: The furthest end of the tube
6 sheet is the tip, yes.

7 MEMBER BALLINGER: Yes. So, is there any
8 concern about vibration there? It's a very short,
9 it's a sharp V on the thing.

10 Is there any concern that you might have
11 a wear problem on that point there because that's on
12 the hydraulically expanded part?

13 MR. SPENCER: Yes.

14 MEMBER BALLINGER: So, is there
15 possibility of this thing doing this?

16 MR. SPENCER: So, we've done a significant
17 amount of testing with respect to forward flows, flows
18 in the nominal direction from the feedwater into the
19 tube at velocities, we've done prototypic testing
20 where we're looking at Reynolds numbers that are much
21 higher than we would expect and the turbulent buffing
22 that we've looked at and any sort of vibration that
23 we've looked at has not been a cause for concern for
24 the IFR.

25 MEMBER MARCH-LEUBA: But that's assuming

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 no oscillations, no flow oscillations, correct?

2 MR. SPENCER: That's, so, yes. That
3 explicitly has been forward flow on the IFR.

4 MEMBER MARCH-LEUBA: For 100, 120 percent
5 nominal flow, not 300 percent nominal flow?

6 MR. SPENCER: I want to say that we've
7 gone up to like maybe 800 percent flow in our testing.

8 MEMBER MARCH-LEUBA: On the --

9 MR. SPENCER: In the forward direction.

10 MEMBER MARCH-LEUBA: Vibration testing?

11 MR. SPENCER: Yes, prototypically. Not at
12 temperature and pressure. But --

13 MEMBER MARCH-LEUBA: And this thing is
14 screwed into a plate on the back, right?

15 MR. SPENCER: Yes.

16 MEMBER MARCH-LEUBA: Yes, a Phillips
17 screwdriver. Hopefully you torque it the right
18 position, you don't do it like I do?

19 MR. SPENCER: Yes. Well, it will be a
20 hardware design that will prevent loose parts. So, we
21 wouldn't want to have loose parts from this. But it
22 will be, so it will be --

23 MEMBER MARCH-LEUBA: You have 1,200 of
24 these. One of them after ten years is not going to
25 get a little loose and go ping, ping?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. SPENCER: Well, so again these would
2 be removed and, these would be considered to be a part
3 of the Steam Generator Program. So, they will be
4 inspected at the same frequency at which the tubes
5 would be inspected as a part of that Steam Generator
6 Program.

7 So, when the IFRs are removed they will,
8 you know, any time that you return a threaded part to
9 service part of your procedure in doing that is to
10 look at the condition of the threads, at the condition
11 of the mounting hardware to ensure that it can be put
12 back into service safely.

13 MEMBER MARCH-LEUBA: And I assume you look
14 inside the tube sheet to look for wear?

15 MR. SPENCER: Yes. So, there's 100
16 percent volumetric inspection of the tubes from the
17 inside. So --

18 MEMBER MARCH-LEUBA: I'm told from the
19 people that know about this that this particular alloy
20 scratches easily. Is that correct?

21 MEMBER BALLINGER: I don't know about
22 scratch easily. But its wear characteristics are much
23 different than Alloy 600.

24 MEMBER MARCH-LEUBA: It creates oxide, you
25 scratch the oxide, it creates oxide, you scratch the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 oxide.

2 MEMBER BALLINGER: Now I have one more
3 question. Is there any thought to having an ejection
4 collar on one of those things?

5 What I'm saying is it would be a pretty
6 bad hair day if the nut on the outside, if it were to
7 fracture there and this thing ended up going into the
8 tube.

9 But if it was designed so that there was
10 a diameter change in the plate if the nut cracked it
11 wouldn't be possible to send that thing into the tube.

12 MR. SPENCER: Yes, yes. So, we've done
13 some preliminary test analysis. I guess, I mean the
14 current design that we're here to present today is the
15 current design for the DCA.

16 You know, we do -- as we change operation,
17 if we change operationally in the future we're going
18 to also be required to change this as a function of
19 that to ensure that we have the same characteristics
20 to prevent DWO that the inlet flow restrictor is
21 designed to do.

22 So, if we change the operation that
23 affects the design and that allows us to reexamine the
24 design. But the current design that we're presenting
25 today doesn't include that feature.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 But we have done some preliminary stress
2 results. We'll present those in the closed session a
3 little bit to show that, you know, we think we have
4 sufficient margin to, any sort of ASME, you know, any
5 sort of ASME analysis on the thread or on the bolt or
6 anything like that.

7 I think I've presented this slide kind of
8 overall. If you have any questions about it otherwise
9 I suggest we move on.

10 CHAIRMAN SUNSERI: You just move on and
11 we'll stop you.

12 MR. BRYAN: One thing that is different
13 from the last time we were here, we got a lot of
14 feedback. We went back and evaluated it.

15 And we are now proposing a COL item to
16 address the evaluation methodology. And so, I'll
17 pause there just a minute and let you read the COL
18 item.

19 But this is what we proposed to address
20 developing a methodology that would evaluate the
21 secondary side instabilities including reverse flow.

22 MEMBER MARCH-LEUBA: If I'm reading
23 correctly you will ensure you have a validated tool
24 that will be able to predict instabilities and what
25 happens during them and how then to calculate the ASME

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 loads if they should happen. Is that what you're
2 saying?

3 MR. BRYAN: Yes, correct.

4 MEMBER MARCH-LEUBA: And that will be a
5 COL item?

6 MR. BRYAN: Correct.

7 MEMBER MARCH-LEUBA: Can we say carveout
8 in the open session?

9 MEMBER KIRCHNER: That has a different
10 meaning.

11 MEMBER MARCH-LEUBA: I know but, okay,
12 maybe we'll wait for the -- yes, but can we talk about
13 that?

14 CHAIRMAN SUNSERI: Why don't you wait
15 until the staff --

16 MEMBER MARCH-LEUBA: All right. I wanted
17 to see what the difference is. But we'll wait for the
18 staff to tell us what the difference is.

19 CHAIRMAN SUNSERI: Would you envision that
20 this is, this methodology be documented on a technical
21 report or a topical report or something? I'm just
22 trying to think of what, how that would get looked at.

23 MR. HOUSER: Yes, it would be. We would
24 develop something that's very. Yes. It would be
25 documented and available.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 It would be much like the methodologies
2 that were developed for the LOCA and non-LOCA topical
3 reports in terms of content. We can get into that in
4 a little bit more detail in the closed session.

5 MEMBER MARCH-LEUBA: You would issue a
6 topical or a technical report?

7 MR. BRYAN: It would be technical, I
8 think.

9 MEMBER MARCH-LEUBA: Yes, that would be
10 more likely.

11 MEMBER BROWN: But you all developed the
12 other reports. Now you're pushing this off to the COL
13 who has no background in this design other than they
14 have chosen you all as the design document, the design
15 whatever you want to call it.

16 It's kind of hard to see this guy walks in
17 cold and has to develop all this analysis technology
18 and methodology for a design that they haven't even
19 seen until they decided to go with you. Maybe I'm
20 speaking out of turn.

21 This just seems to be kind of complicated
22 when you all have spent several years developing your
23 own evaluations and design analyses and topical
24 reports, that's all.

25 MR. HOUSER: We are continuing to move

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 forward with development of that ASME scale, that
2 methodology.

3 MEMBER BROWN: So, why the COL if you're
4 all doing it and you're all not going to provide it
5 yourself?

6 MEMBER RICCARDELLA: The timing.

7 MEMBER BROWN: I understand that. But
8 that's, time is nice. But I'm looking at it from the
9 technical standpoint and the ability to get a, I guess
10 a methodology that it's truly representative of what,
11 you know, the design and what density wave
12 oscillation.

13 I'm not a thermal hydraulic guy, okay.
14 But I know that's not good.

15 MEMBER RICCARDELLA: But it's not
16 realistic to assume that there's going to be a COL guy
17 and NuScale is just going to walk away and this COL
18 applicant is going to build the plant all by himself.
19 Come on, Charlie.

20 MR. HOUSER: That will not happen.

21 MEMBER RICCARDELLA: That's absurd.

22 MEMBER BLEY: There's another thing here.
23 Correct me if I'm wrong. If you issue it as a
24 technical, I assume you'll just move into this and
25 you're working on it.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 If you finish it and it's a technical
2 report it won't come to the staff or to us until
3 there's a COL applicant. If you issued it as a
4 topical it might come right away for approval.

5 Am I correct in that assumption of how
6 things could progress?

7 MR. BRYAN: Yes. In terms of technicals
8 and topicals that's correct.

9 MEMBER MARCH-LEUBA: But it's not
10 necessary. I mean, you could send a technical ahead
11 of time.

12 Given the visibility that it has already
13 had you likely will or you will have a visit in
14 Corvallis to go see it, I think.

15 MR. MELTON: I want to say, it's Mike
16 Melton with NuScale. So, the COL items will be
17 addressed with, you know, people that are technically
18 qualified.

19 You know, all resources will be applied to
20 make sure that methodologies or NuScale's involvement.

21 I don't think we need to be concerned
22 about because the design expertise, analysis, you know
23 consultants we'll have the right workforce to make
24 sure that this gets done properly as with all our COL
25 items.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 I just want to assure the Committee.
2 We'll make sure it gets done properly. And I think
3 Marty is correct. This does sound like a technical
4 report but I don't know if we've made that internal
5 decision.

6 But because of the applicability it's
7 probably that direction. If it does go in the form of
8 a topical report it will follow the process.

9 MR. PRESSON: And in terms of process
10 it's, you know, we have the ITAAC which is tagged to
11 the COL. But this would ensure that methodology is
12 reviewed prior to the ITAAC process. So, it would be
13 captured in the FSAR portion of that.

14 MR. DUDEK: And just to add, this is
15 Michael Dudek, the Branch Chief for Nuclear Reactors.
16 The COL versus the carveout is really, as you said, a
17 timing issue.

18 We have not seen or evaluated fully the
19 proposed COL item. Previous to that we had identified
20 a technical open item and that's where we proposed not
21 giving them finality in the role which is AKA the
22 carveout.

23 So, as we evaluate and go forward we may
24 take that off the table. But as of now it's still an
25 open item and we propose not giving finality through

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the rulemaking.

2 MEMBER MARCH-LEUBA: So, that carveout
3 would be a way to address this technical review, if
4 it's a technical report.

5 MR. DUDEK: What they do could suffice and
6 take that open off the table. But we have yet to
7 reach that conclusion.

8 MR. BRYAN: Okay. So, just to wrap up.
9 There is again, we got a lot of feedback. We heard
10 the feedback. We went back for both the staff and the
11 Committee and we revised both 3.9 to include the COL
12 item.

13 And we also clarified the language in 5.4.
14 There was a lot of discussion about the use of RELAP
15 there. So, we took that discussion out and replaced
16 it.

17 We thought you would have the errata by
18 now. But that got held up, that you would have seen
19 it before this meeting. But that will be forthcoming
20 in the errata letter to clean up some of the 5.4
21 language.

22 So, that's really all we had planned to
23 cover in the open session. We'll get into some more
24 of the details in the closed session.

25 We know the staff is going to speak to the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 carveout from our perspective. As Matthew said, by
2 having successful completion of the ITAAC we have a
3 COL item, we believe this constitutes the basis for
4 NRC determination to allow operation of the facility
5 certified under 10 CFR 52.

6 MEMBER MARCH-LEUBA: You say operation,
7 you mean certification under 52, right?

8 MR. BRYAN: Yes.

9 CHAIRMAN SUNSERI: Okay, thank you.
10 Members, any questions for the presenters?

11 MEMBER MARCH-LEUBA: I just wanted to put
12 on the record that this is good. I'm happy that
13 you're taking it seriously and we are going to follow
14 through instead of trying to avoid it. So, today I'm
15 happier than I was yesterday.

16 CHAIRMAN SUNSERI: Well, that's a
17 milestone. Okay. All right, thank you. Let's bring
18 up the staff now.

19 And as you all are taking the table I
20 would remind you once again this is open. And if we
21 ask any questions that drive us to proprietary
22 information just refrain and we'll address those in
23 the closed session later.

24 MS. JOHNSON: Good morning, everyone. My
25 name is Marieliz Johnson. I'm the project, not yet.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 (Off-microphone comments.)

2 MS. JOHNSON: Do you hear me better now?
3 So, I'm Marieliz, sorry, Marieliz Johnson, project
4 manager for NuScale the certification application.

5 Today we're going to present the NRC
6 review of the NuScale steam generator. For the agenda
7 we have the NRC staff review team. We have a brief
8 summary of the review of the steam generator.

9 And we will go through a summary of the
10 steam generator design issues that are not resolved by
11 the, by certification, by the design certification
12 application. Here's a list of the review team.

13 And then I'm going to turn it over to Greg
14 Makar to continue.

15 MR. MAKAR: I'm Greg Makar from the
16 Corrosion and Steam Generator Branch. And I want to
17 briefly review our -- is that better?

18 I'm Greg Makar of Corrosion and Steam
19 Generator Branch and I want to briefly review our
20 findings on the topics for steam generator materials
21 and Steam Generator Program. And then I'll turn our
22 attention to the incomplete topic of secondary side
23 flow stability.

24 We found in most cases, except for that
25 one, we found the materials area acceptable. That

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 includes material selection and the associated
2 requirements, things like the application of the ASME
3 code and fabrication, cleaning, inspection
4 requirements.

5 The design limits the crevices along the
6 tubes and enables flow along the tubes and we found
7 that important, degradation mechanisms associated with
8 crevices.

9 The materials will be compatible with the
10 planned primary and secondary environments. And the
11 design provides for primary and secondary side access
12 for inspection, cleaning, foreign object search and
13 retrieval.

14 Next slide, please. Steam Generator
15 Program we found to be acceptable. It is consistent
16 with the standard tech specs and the industry
17 guidelines.

18 We say appropriately acceptable because
19 there are some differences in terminology and other
20 aspects of the tech specs that are different for
21 NuScale.

22 And the inspection program, it's a
23 performance based framework that has some prescriptive
24 elements and it defines tube integrity in terms of the
25 structural and or describes the performance criteria

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 in terms of the structural and leakage integrity of
2 the tubes.

3 They have provided a generic tube plug in
4 criterion which is the amount of through wall loss of
5 the tube that you can have before you have to take a
6 tube out of service.

7 And the COL applicant will submit the and
8 prepare the steam generator inspection program and
9 implement that plan and provide any site specific
10 information which includes their own degradation
11 assessment, their own plug in criterion and timing and
12 so forth. Next slide.

13 MEMBER BALLINGER: I just had something
14 pop into my head. The standard tube integrity
15 inspection technique is bobbin coil or something like
16 that.

17 But usually the, it's on the primary side,
18 goes up the primary side. In this case you're going
19 to have to go up the secondary side.

20 And if the criteria is 40 percent through
21 wall volumetric, right, that's one of the criteria for
22 tube plugging, that volumetric will be on the inside
23 not the outside of the tube. So, is there, that going
24 to work out okay?

25 MR. MAKAR: Well, the inspection is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 looking for any kind of degradation that you could
2 expect according to your degradation assessment for
3 that particular plant.

4 Some degradation has come from the inside
5 of the tube, some secondary, some --

6 MEMBER BALLINGER: Cracking is not an
7 issue. But I'm talking about removal of material,
8 volumetric defect on the inside of the tube where the
9 bobbin coil or pancake or whatever you're using goes
10 up.

11 That's a little bit different, I think,
12 then what you would find in a recirculating or once
13 received generator like in a PWR.

14 MR. MAKAR: Well, the inspection will be
15 able to detect volumetric on the inside or the
16 outside.

17 MEMBER BALLINGER: Okay.

18 MR. MAKAR: As it does now.

19 MEMBER BALLINGER: Okay.

20 PARTICIPANT: Are you worried about the
21 coil getting caught up?

22 MEMBER BALLINGER: You know, I'm not a
23 coil expert. But if it's all of a sudden now you have
24 a 40 percent volumetric defect once you have removed
25 material.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. MAKAR: And that, still the most
2 likely place for that is on the outside of the tubes
3 at support structures. But it could be that this flow
4 restrictor if that, you know, we talked about that.

5 MEMBER BALLINGER: Corrosion on the
6 outside of that type doesn't concern me. You're not
7 going to get any kind of thing because it's on the
8 primary side.

9 MR. MAKAR: But the support structures are
10 on the, are also on the outside.

11 MEMBER BALLINGER: Yes, okay.

12 MR. MAKAR: So, we still need to look for
13 anything they expect on both the inside and outside.

14 MEMBER BLEY: I hadn't thought about it
15 and it's not an issue here. But in the current
16 designs where the primary is on the inside when you go
17 in to work you've got a lot of streaming coming out of
18 those tubes, radiation streaming.

19 I wonder if that's going to be different
20 or better this way around. Go ahead, I'm just
21 wondering.

22 MEMBER KIRCHNER: Proximity to the core
23 of the tube sheets is going to make for a much
24 different situation. In the current fleet the
25 inspection of the PWRs is, like you said, it's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 whatever, particulate corrosion, whatever inside the
2 tubes.

3 This one you're much closer, the structure
4 has been sitting much closer to the core. So, I
5 wonder what activation --

6 The core is about what, ten feet lower
7 than the start of the steam generator? But that's the
8 difference I see in terms of personnel exposure. They
9 take this, put it in the dry dock and then inspect it.
10 It may be hotter, the material.

11 MEMBER BLEY: Kind of in general. But in
12 the current ones you have it on the inside of the
13 tubes and you really get a beam kind of coming out of
14 it.

15 MEMBER MARCH-LEUBA: Activation is neutron
16 flux and very few neutrons are going to make it
17 through 20 feet of water. So, there will be a gamma
18 flux.

19 But the gamma doesn't activate. In
20 inspection the core will be in a different place.

21 MEMBER BALLINGER: That's about 20 tenth
22 value layers.

23 MEMBER KIRCHNER: The other thing is that
24 assuming they keep doing water chemistry, but these
25 are low flows. So, if stuff is going to accumulate on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the primary side it's going to be around the tube
2 sheet entrance on the primary side, if there's crud in
3 other things.

4 MEMBER BALLINGER: The first inspection
5 will be interesting.

6 MR. MAKAR: All right, next slide, please.
7 We have determined that this, we have this issue of
8 structural leakage integrity that has not been fully
9 demonstrated.

10 And that's related to the effective
11 density wave oscillations on tube integrity and also
12 for the method of analysis for the secondary side,
13 thermal hydraulic conditions and associated loads.

14 NuScale is working to address that topic.
15 And if there are no, unless there are other questions
16 about our Chapter 5 review I'm going to turn this over
17 to Tom Scarbrough to talk more about the secondary
18 flow instability topic.

19 MR. SCARBROUGH: Thank you, Greg. I'm Tom
20 Scarbrough with the Mechanical Engineer Branch. We
21 had quite a bit of discussions over the past few weeks
22 regarding the steam generator tubes and their
23 integrity.

24 And after quite a bit of significant
25 interactions, you know, among all the technical

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 reviewers. There are a number of technical reviewers.
2 You know, there are several chapters that are involved
3 here of this.

4 And so, after a lot of deliberation we
5 decided that at this point we're going to propose that
6 we specify the structural integrity and leakage, the
7 structural and leakage integrity of the steam
8 generator tubes are not resolved and not receiving
9 finality in the NRC draft proposed rule for design
10 certification.

11 MEMBER BLEY: I would just interject here.
12 We've had concerns about wear which could lead to two
13 failures.

14 The PRA certainly has not reflected
15 anything about this phenomena if it exists.

16 MR. SCARBROUGH: Yes. And you brought
17 that point and that was one of our concerns that we've
18 talked about quite a bit over the last few weeks.

19 And so, we're going to talk about the
20 specific details of the technical reasons why in the
21 next couple slides. But I'm just kind of telling you
22 what the process is right now.

23 MEMBER RICCARDELLA: What you said, does
24 that mean carveout?

25 MR. SCARBROUGH: It's a carveout, yes,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 sir. I didn't use carveout --

2 MEMBER RICCARDELLA: That's different than
3 what the licensee, the licensee was talking about a
4 COL item and an ITAAC and you're talking about a
5 carveout.

6 MEMBER BLEY: This is a carveout. They've
7 been working independently on this.

8 MR. SCARBROUGH: Yes. They've been trying
9 to resolve the issue themselves. And they proposed a
10 COL item. We looked at the COL item.

11 We don't have a technical concern with the
12 COL item. We actually think it's a good thing. But
13 in terms of whether or not we could certify the
14 specific aspects, and this is focused right, it's
15 focused on the steam generator tube integrity.

16 And, you know, it's not the whole steam
17 generators. And so, but in this focused area we do
18 not feel we had confidence that we could decide on
19 finality for this particular aspect.

20 MEMBER MARCH-LEUBA: So, from the way you
21 envision the certificate is to have a carveout and a
22 COL. Is that correct?

23 MR. SCARBROUGH: Yes, yes. In discussions
24 when we had first seen their proposed COL item we
25 said, you know, we have our own process for, you know,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 going on carveout.

2 And the response we received, they felt
3 like the COL item was a good thing, right. It was a
4 benefit to their design in terms of what, how they
5 presented their design certification application.

6 And we agreed. But it doesn't
7 specifically affect what we're trying to do here with
8 the finality.

9 MEMBER MARCH-LEUBA: I was going to make
10 another momentous announcement in the fact that I'm
11 happier with the applicant's proposal than with yours.

12 CHAIRMAN SUNSERI: So, let me ask a
13 question. So, let me so, I guess this doesn't make a
14 big difference.

15 But would you envision that when a COL
16 applicant comes in and does what the applicant is
17 saying in the COL item for this activity, would that
18 information be sufficient to resolve the carveout?

19 They would have, I know they would have to
20 license amendment or something like that to get it
21 approved. But is the work that they plan to do for
22 the COL the work that needs to be done to address your
23 safety concerns?

24 MR. SCARBROUGH: Yes. They're very
25 similar because they, if they plan to demonstrate that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 they are not going to have issues with the potential
2 DWO and the reverse flow the first step from this
3 perspective is to develop a methodology that would
4 predict that reliably.

5 And so, then they would use that. And
6 then, you know, as through and we'll talk a little
7 more about the sections that we have a concern with.
8 But in the design certification they need to have a
9 methodology listed right for all of the various
10 aspects of the design.

11 And this methodology is not ready yet.
12 And so, once they are ready they will use it to, in
13 combination with probably the ANSYS model to show that
14 the stress and the wear on the tubes are not
15 significantly impacted by the DWO and reverse flow.

16 So, again that's the first step that the
17 COL applicant would come in and say here is the
18 methodology and this is how we're going to use it to
19 show that we do not have significant wear on the tubes
20 or damage the IFRs.

21 MEMBER BLEY: I'd like to try something
22 because we haven't dealt with carveouts as such before
23 this time around. It seems to me what we have the
24 applicant has a COL item which will have to be met
25 during the COL.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 What you're saying is they're saying what
2 they're going to do. You're just saying we haven't
3 reviewed this yet. We have to review it at the COL
4 time.

5 MR. SCARBROUGH: Yes, yes. And that's
6 basically what a carveout is. It's, if we did not
7 have a carveout and we didn't mention it at all
8 officially we have finality on all the aspects of a
9 steam generator.

10 We really don't have the authority to
11 question the steam generator tubes anymore. And so,
12 we're not ready there. We're not there yet, you know.

13 We still want to review the COL item and
14 make sure the methodology is proper.

15 MS. PATTON: I think Mike has something to
16 add.

17 MR. DUDEK: And, Mr. Chairman, just to
18 dovetail into Tom's response is that the COL item is
19 only one small piece of the carveout. I think you'll
20 see that in the upcoming slides is that, yes, they can
21 include the COL item.

22 And it may address one small piece of the
23 carveout. But that doesn't resolve the larger picture
24 of all of the open items that are included. And
25 you'll see they are included in the carveout.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN SUNSERI: Yes, I get it. But it
2 does outline the methodology that would take them
3 there, right?

4 MR. DUDEK: You'll see that's only one
5 small piece.

6 CHAIRMAN SUNSERI: Yes, okay. All right.

7 MR. DUDEK: It's like a first step.

8 MS. PATTON: There is also a little
9 difference in the legal definition between like a
10 carveout versus a COL item. And a carveout makes it
11 very clear that has to be done by the COL.

12 You know, you can rely on a carveout in
13 making the findings and it's a little bit more limited
14 how much reliance we can place on a COL item. And so,
15 we're still working through that and some of the
16 questions on COL item versus carveout.

17 So, I don't want to get ahead of that.
18 But some of those differences are what's being
19 considered in this as well.

20 CHAIRMAN SUNSERI: As Dennis said, we're
21 still learning on this. But when it comes to carveout
22 and I don't like using that vernacular.

23 But is there any timing issues regarding
24 when a license then would be issued or when a licensee
25 would be able to start operating the plant regarding

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 a carveout or anything?

2 MR. SCARBROUGH: Well, they would need to
3 come in -- the COL applicant would come in and address
4 this aspect of the design that did not reach finality
5 as part of design certification.

6 MEMBER RICCARDELLA: So, doesn't that, I
7 mean a carveout automatically implies a COL item,
8 right? I mean you have to resolve the carveout
9 because it hasn't been, that aspect of the design
10 hasn't been approved.

11 MR. SCARBROUGH: In words or not, right,
12 of course. And so, the COL item that NuScale is
13 proposing is that first step to resolve this issue
14 that's been carved out, exactly.

15 MEMBER MARCH-LEUBA: So, while you're
16 making the presentation can you address my bias. I
17 see opposite to what you said. I see that their COL
18 proposal is broader than your very limited carveout.

19 MEMBER RICCARDELLA: Maybe we need to see
20 the remaining, the additional slides.

21 MEMBER KIRCHNER: All they have proposed
22 is a methodology. You still have to do all of the
23 analysis and have to do the ASME code case, et cetera,
24 et cetera. It's much more.

25 MEMBER BLEY: We've only seen their first

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 slide. Maybe we could look at some more.

2 MS. PATTON: There are two more slides on
3 the carveout.

4 MEMBER MARCH-LEUBA: I want you to address
5 my biases while you present it because what I hear
6 here is as long as you satisfy the ASME code, the tube
7 doesn't break, we're perfectly okay with it.

8 MR. SCARBROUGH: No. We're only on the
9 first bullet on the first slide.

10 MEMBER MARCH-LEUBA: I have a bias of
11 controllability and moisture in the steam line.

12 MR. SCARBROUGH: Exactly, yes. We're
13 going to get there. So, this is just --

14 VICE CHAIRMAN REMPE: To follow up on
15 Matt's question about how to fix things. I can
16 remember with Vogtle that there was, they let them go
17 ahead and pour concrete for some things but not some
18 nuclear construction.

19 And that was a fuzzy line. When does the
20 carveout have to be addressed? Does it affect what
21 can be done in the construction for a COL applicant?

22 MR. SCARBROUGH: In this case and we are
23 fortunate we had actually two OGC lawyers helping us
24 with this, right, and so, because this is new ground
25 for me too. This is carved out.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And this only affects the steam generator
2 tube aspect of the design. Everything else goes
3 forward the way it is supposed to go forward.

4 VICE CHAIRMAN REMPE: Okay. And that
5 would be true for the other carveout too?

6 MR. SCARBROUGH: Yes.

7 VICE CHAIRMAN REMPE: It's just limited on
8 that thing, thank you.

9 MEMBER BLEY: But at the COL stage an
10 applicant could not get a license until these
11 carveouts were fulfilled, reviewed and approved?

12 MR. SCARBROUGH: Yes. This aspect has to
13 be completed, you know, for the COL applicant to
14 receive the COL.

15 MS. PATTON: Right. It basically just
16 identifies the portion of the design that wasn't
17 granted finality through the rule, right.

18 So, it's basically takes a piece that
19 would normally be in a design certification and says
20 the COL when they apply has to provide this additional
21 piece.

22 MEMBER BLEY: But since this is new to us,
23 one last question. Assuming the Commission issues a
24 design certification that rule would then say the
25 following aspects have not yet been evaluated or

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 something.

2 MR. SCARBROUGH: Exactly. We are working
3 with OGC on the exact words. And we're going to sort
4 of show you the words that we're working with OGC to
5 put into the rule itself that will indicate that this
6 specific aspect of the steam generator tubes does not
7 receive finality yet as to OGC license.

8 MS. PATTON: Right. There's a few lines
9 that actually go directly into the rule and carve it
10 out.

11 MEMBER BLEY: We have one or more other
12 carveouts that are going on.

13 MR. SCARBROUGH: I believe there's two
14 other carveouts on different topics.

15 MS. PATTON: That's why I said, there's a
16 little difference in legal definition between like a
17 carveout and a COL items and a carveout, you know,
18 makes it very clear within the rule that needs to be
19 provided.

20 CHAIRMAN SUNSERI: Thank you, thanks for
21 taking us on this little detour of the regulatory
22 practice here. Let's get back into the technical
23 presentation. Go ahead, Mike.

24 MR. DUDEK: Just one more side note.
25 Something that may help is that the legal definition

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 according to OGC has evolved for a COL item.

2 The COL items is being used now is more
3 interpreted as just an information tracking item. It
4 doesn't have any legal gumption or enforcement in the
5 COL going forward. So, it's more of an information
6 tracker versus an enforcement item.

7 MEMBER BLEY: I could get an operating
8 license without fulfilling the COL item?

9 MS. PATTON: We would have to probably
10 have an attorney answer that.

11 MEMBER BLEY: I think so. That really
12 sounds bizarre.

13 MS. PATTON: My understanding is that, my
14 little bit of understanding and, Mike, you can chime
15 in is that there is, more like there could be a
16 potential fight about that a little bit.

17 And this, a carveout makes it, gives it
18 the force of law.

19 MEMBER BLEY: Is the authority here. It
20 brings the strength.

21 MS. PATTON: It's stronger than a COL
22 item.

23 MEMBER BLEY: We've supported a number of
24 design certs under the assumption all COL items --

25 CHAIRMAN SUNSERI: Maybe we can take up

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that topic at a different meeting. Okay, thanks.
2 Tom, go ahead.

3 MR. SCARBROUGH: Okay. So, Appendix G is
4 going to be the portion of Part 52 which is the
5 NuScale design certification rule.

6 And so, there's a section, Section 6, I'll
7 call it issue resolution which will talk about the
8 steam generator tube integrity issue and indicate that
9 it's not resolved within the meaning of 5263 Alpha 5.

10 And that, I went back and pulled that out.
11 That has to do with all matters all resolved except
12 for 10 CFR 2.335 which has to do with petitions.

13 So, that's what that has -- basically it's
14 saying that this issue has not been resolved yet for
15 finality for the design certification.

16 And then there is another section that
17 will be in Appendix G, which is Section 4 which talks
18 about what is the COL applicant responsible for. And
19 it will talk about the fact that the COL applicant
20 needs to provide the design information to address the
21 steam generator tube integrity.

22 And so, those sort of two sections that we
23 are working with OGC now to get the words just right
24 from the legal perspective to make sure we carve it
25 out to cover the issues but also, you know, it's only

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the steam generator tube area aspect that's being
2 carved out.

3 And so, the rule now, the proposed rule
4 language it's with OGC right now and they're working
5 on it to have it ready for Commission approval. So,
6 that's where we are right now.

7 So, now Becky is going to walk us through
8 -- there is two specific sort of parts to this
9 carveout. And, but we talk about them separately just
10 because it's easier to keep track of.

11 So, Becky is going to talk about the first
12 part.

13 MS. PATTON: Okay. So, currently in the
14 FSAR that NuScale submitted, Section 3912 there's a
15 listing of the computer programs that are used by
16 NuScale for the dynamic and static analyses and for
17 the hydraulic transient load analyses.

18 So, you know, if you look in that
19 currently it will list, you know, NRELAP, for example,
20 as one of those codes. And then, you know, points you
21 over to 1502 for the code description and the V&V.

22 And so, you know, my branch in Reactor
23 Systems assisted, you know, with the review of NRELAP
24 for those, you know, mechanical, those blow down
25 loads.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Currently in the FSAR in Chapter 5 it also
2 lists NRELAP as being used for determining the
3 pressure drop in the IFR design to ensure acceptable
4 mass flow fluctuations for power levels, et cetera, et
5 cetera.

6 Our understanding is that, you know,
7 NuScale has plans to, you know, modify that to clarify
8 that. But basically, that's listing currently of
9 NRELAP in 391 is intended for blow down loads
10 currently.

11 That's what the staff had reviewed. We
12 hadn't reviewed it for, you know, other loading
13 conditions potentially for DWO.

14 So, this would be a portion of the
15 carveout to say that 3912 with DWO loads being a
16 potential loading condition you would need to list a
17 method of analysis into 3912 for those loading
18 conditions.

19 And those presently are not there. So,
20 the carveout would specify that in demonstrating steam
21 generator tube integrity a COL applicant would need to
22 provide information to demonstrate that GDC 4 is met
23 for the method of analysis to predict thermal
24 hydraulic conditions of the steam generator fluid
25 system and the resulting load stresses and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 deformations from DWO.

2 So, our understanding is that NuScale is
3 planning on, you know, adding some, you know, a COL
4 item for one to this section to specify that would be
5 done in the future. We would still, you know, the
6 current plan is that we would still maintain this as
7 part of the carveout.

8 But that's, basically the first portion
9 would be that method, you know, hasn't been specified
10 and it's integral to the finding in that section made
11 by the Mechanical Branch that all those methods are
12 listed.

13 MR. SCARBROUGH: Right, exactly. So,
14 that's the first part. So, that would -- that's the
15 COL item sort of section.

16 Now the other part is the actual steam
17 generator tube integrity issue. And that sort of has
18 been, I've been to the meetings in the past couple
19 months of the ACRS and heard a lot about that.

20 But the bottom line is NuScale has not
21 provided reasonable assurance that the flow
22 oscillations that occur in the steam generator
23 secondary fluid system will not cause damage to the
24 steam generator tubes directly from DWO or reverse
25 flow or indirectly by possible damage from the inlet

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 flow restrictors, IFRs where they might vibrate and
2 such.

3 As you saw, they're kind of a cantilevered
4 process. And NuScale talked about their forward flow
5 testing.

6 But they really haven't done really much
7 in the other direction to see if there was something
8 that might cause these to have some issues in the
9 opposite reverse flow direction. And so, that's what,
10 the concern we have there.

11 So, and it sort of -- this issue sort of
12 grew over time because, you know, if you go back to
13 the original Rev 2 of the DCA it indicated in Section
14 5412 that the flow restriction devices would preclude
15 DWO.

16 And then there was Rev 3 which came out
17 that said well, there will be oscillations but they
18 will be within acceptable limits. And as we've gotten
19 more interaction with NuScale in terms of what that
20 really meant and what the information was we
21 determined that we weren't comfortable with the amount
22 of degradation that might occur from reverse flow from
23 DWO and such.

24 And so, based on that our concern is not
25 like one tube failing. Our concern would be if there

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 was catastrophic failure of a number of tubes could it
2 interfere with the natural circulation process because
3 everything in this reactor relies on natural
4 circulation for cooling.

5 And so, if you had a significant break of
6 a number of tubes you could disrupt natural
7 circulation cooling either from ECCS system which we
8 talked a lot about this week and also the decay
9 removal system.

10 You know, both of those are natural
11 circulation processes. So, that was our concern.
12 Until we are comfortable that there won't be this
13 potential for catastrophic failure because there is
14 GDC 4 which is dynamic effects and vibrations and
15 such.

16 And then there's also GDC 31 which is the
17 fracture prevention of the reactor coolant pressure
18 boundary. And so, and that GDC talks about the fact
19 that you need to have capability to ensure that you do
20 not have a rapid, propagating failure of the reactor
21 coolant pressure boundary.

22 And if you had a number of these IFRs come
23 loose and go through these tubes you might have a
24 number of tubes that fail at the same time. So, we
25 did not feel comfortable that we had enough

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 information to be able to say that, yes, this issue
2 can have finality.

3 And so, as part of this carveout is a
4 specification, and this would be in the rule itself
5 that a COL applicant will need to provide information
6 demonstrating that 10 CFR Part 100, Appendix A, which
7 is the seismic capability aspect and also Part 50
8 Appendix A, GDC 4 and 31 are met with respect to
9 structural and leakage integrity for the steam
10 generator tubes that might be compromised by these
11 adverse effects from DWO and the secondary fluid
12 system.

13 But we're going to be very clear in the
14 carveout that these are the areas that we're carving
15 out. You know, we're not carving out the entire steam
16 generators and that sort of thing because we have to
17 make sure that we focus it on what the concern was and
18 what is not receiving finality.

19 And that's what is happening right now
20 with the rule that OGC is helping us with. So, that
21 is the two sort of technical issues.

22 So, there's no question, now I was going
23 to have Yuken go through and kind of describe the DWO
24 phenomenon and what's going on with that.

25 MR. WONG: My name is Yuken Wong. NuScale

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 had performed the TF-2 tests mainly for thermal
2 hydraulic performance of the steam generators. These
3 tests are also used for flow induced vibration
4 purpose.

5 The TF-2 specimen had five columns of
6 tubes with 250 tubes in total. And one column of tube
7 with 52 tubes was used for the density wave
8 oscillation tests.

9 Density wave oscillation was observed
10 during the TF-2 testing with temperature and flow
11 oscillations in the secondary cooling. The DWO
12 frequency was low and will not excite the steam
13 generator tube structural resonances. Based on the TF-
14 2 strength gauge measurements, the staff estimate that
15 the alternating stress intensities will be below the
16 ASME fatigue endurance limits.

17 However, any differences such as geometry,
18 material and operating conditions between the TF-2 and
19 the actual as built steam generators have not been
20 evaluated.

21 As discussed on the next slides the staff
22 is concerned about the potential impact of the density
23 wave oscillation on the steam generator tubes directly
24 and indirectly by the inlet flow restrictors.

25 MEMBER RICCARDELLA: Excuse me. Could I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 ask, those strain gauges that you show on the previous
2 slide, were they on the inside or the outside of the
3 tube?

4 MR. WONG: They are on the outside of the
5 tubes.

6 MEMBER RICCARDELLA: Okay. So, they would
7 pick up pressure oscillations. But if there were any
8 thermal gradient effects that would only occur on the
9 inside. It might not, you might not see it on the
10 outside, right?

11 MR. WONG: They pick up the strains as
12 well.

13 MEMBER RICCARDELLA: Not if there was a,
14 if there was a thermal gradient and thus a strain
15 gradient through the thickness of the tube it would
16 not, you know, when you do a thermal shock on a
17 component you get higher stresses on the inside than
18 on the outside.

19 That's a fairly thin tube. But you still
20 might have some through wall gradient.

21 MR. WONG: The tubes are very thin. And
22 from the --

23 MEMBER RICCARDELLA: I understand.

24 MR. WONG: -- what the data indicates it
25 does pick up the strain in this subset. They suspect

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 some of the strains at the thermal oscillations.

2 The steam generator in the flow
3 restrictors are designed to provide the necessary
4 pressure drop to limit density wave oscillation in the
5 tubes.

6 As explained earlier, the flow restrictors
7 are mounted on the mounting plate and inserted into
8 the steam generator tubes. NuScale performed in the
9 flow restrictor, excuse me, leakage flow instability
10 tests for the conceptual design of the inlet flow
11 restrictors.

12 The staff did not identify any concerns
13 for the test for the normal flow or forward flow.
14 However, these tests did not include density wave
15 oscillation conditions as the forward flow.

16 NuScale has selected a final inlet flow
17 restrictor design that is similar to one of the tested
18 designs. And NuScale will perform validation testing
19 for the final inlet flow restrictor design after
20 design certification.

21 Next slide, please. Unstable density wave
22 oscillation can cause reverse flow to the inlet flow
23 restrictors including subcooled liquid from modest
24 density wave oscillation or slug and two-phase flow
25 for strong density wave oscillation.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 NuScale has not yet evaluated potential
2 impacts on steam generator tubes and inlet flow
3 restrictors for reverse flow such as fatigue of bolted
4 joints and loose inlet flow restrictors.

5 The concerns due to leakage flow
6 instability cantilever the inlet flow restrictors
7 unless stable under reverse flow conditions. Also,
8 due to cyclic pressure drops and high speed turbulent
9 two-phase flow through the inlet flow restrictors.

10 The concern also includes cavitation
11 erosion of the steam generator tube walls and wear of
12 inlet flow restrictors and the tube walls that can
13 further worsen density wave oscillation.

14 MEMBER BLEY: Excuse me. Two related
15 questions. When you say they're less, the flow
16 restrictors are less stable under reverse flow
17 conditions, what do you mean by that?

18 And my second question is I'm envisioning
19 this thing maybe going back and forth a little bit.
20 And can these screws back out? I've seen screws back
21 out in vibrating situations.

22 And if they do I guess that flow
23 restrictor is free to either flow out or go forward.

24 MR. WONG: Literature indicates when a
25 cantilever structure, when the flow is going from the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 support end to the free end it's more stable.

2 MEMBER BLEY: So, it's this kind of
3 vibration that you're talking about?

4 MR. WONG: Correct.

5 MEMBER BLEY: Yes, that makes sense.

6 MEMBER MARCH-LEUBA: When the flow is
7 going forward you're pulling. When you're pushing.
8 The pushing is much more -- when you're pulling it
9 straightens out.

10 When you're pushing it moves towards the
11 wall, right.

12 MEMBER BLEY: That makes sense if that is
13 what you're talking about.

14 MR. WONG: Yes, yes. And if the screws --

15 MEMBER BLEY: Let me, I've looked at these
16 things and I kind of assume that you've got a lot of
17 turns on that screw that hold it in place. But that
18 screw is long enough to go through that plate.

19 I don't know how many turns you get. So,
20 I'm -- the idea that a screw could back out might not
21 be crazy.

22 MEMBER RICCARDELLA: It's preloaded, you
23 know.

24 MEMBER BLEY: Yes. I know it's preloaded.
25 But now you're jerking it back and forth.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER RICCARDELLA: Yes, but, you know,
2 theoretically if the preload sustain you don't get
3 oscillatory loads on a preloaded bolt. That's why you
4 preload bolts.

5 MEMBER BLEY: But you preload them under
6 assumptions and this assumption wasn't there.

7 MEMBER RICCARDELLA: Yes. You preload and
8 there's also, typically there's something that keeps
9 it from backing out like in LWR internals they use
10 some sort of retainer device or something to keep it
11 from unscrewing.

12 CHAIRMAN SUNSERI: NuScale said that there
13 would be, you know, loose parts prevention measures
14 applied, right. So, if that's what you're talking
15 about.

16 MEMBER RICCARDELLA: Yes. But that
17 doesn't, if you just contain it as a loose part like
18 you would put a cap over it that doesn't keep it, that
19 doesn't ensure that the preload is maintained. It
20 could still lose preload.

21 It, you know, they're going to be doing a
22 lot of work in this area obviously. That's detailed
23 design work that has to be done.

24 MR. SCARBROUGH: Right. And that's,
25 they're going to have to finish, you know, the design,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 pick the final design and then qualify the design.

2 So, there's still quite a bit of work to
3 do to address your issues that you're raising.

4 MEMBER RICCARDELLA: But theoretically, if
5 it's properly preloaded you won't see oscillatory
6 loads.

7 MEMBER BLEY: And one would think after
8 this testing and analysis a consideration of reverse
9 flow would be part of that preloads.

10 MEMBER RICCARDELLA: Yes, for sure.

11 MR. SCARBROUGH: Okay. Next slide,
12 please. So, where do we go from here, okay?

13 Assuming that the design certification
14 rule is issued, the COL applicant will be responsible
15 to address the steam generator tube integrity in its
16 COL application and it has these sort of two parts
17 that we talked about.

18 One is the method of analysis that they
19 have a COL item that's going to make sure the COL
20 applicant knows they have to submit that. And then
21 the second part will be demonstrating that the tubes
22 will not be damaged by DWO directly or by, or
23 indirectly by the IFRs vibrating and things of that
24 nature causing some damage.

25 So, the COL applicants will be responsible

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 for demonstrating that in the process of receiving its
2 COL. So, that's going to be a review that the staff
3 will do.

4 And this will all come back to the ACRS
5 for you all to take a look at as well. And then
6 assuming that COL is issued, the next step will be a
7 COL holder.

8 And there's a number of aspects that the
9 COL holder is responsible for. There are ITAAC
10 related to the ASME Boiler and Pressure Code, Section
11 3 requirements.

12 But there also, in addition to that there
13 is the Comprehensive Vibration Assessment Program, the
14 CVAP which Yuken reviews quite a bit in terms of the
15 review for applicants.

16 And there's specific aspects. There is
17 some additional testing. The TF-3 referred to as TF-3
18 testing that has to be done. There's also vibration
19 testing that's specified in Tier 2 in Table 14.272
20 that had to do.

21 So, they have that to do. And plus
22 they're going to have some instrumentation on, for the
23 initial start of a steam generator.

24 So, the COL holder has quite a bit of work
25 to do as well after that phase of receiving the COL.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So, that's the process after the design certification
2 to make sure this issue is fully reviewed as part of
3 the next step after design certification.

4 And then Becky is going to talk about next
5 steps.

6 MS. PATTON: Sure. NuScale is currently
7 preparing errata to the Revision 4 of the DCA. And
8 you saw part of that with their proposed COL item that
9 they presented earlier.

10 They are also, you know, preparing some
11 other changes potentially to clarify some of the steam
12 generator secondary fluid flow issues that could
13 impact the tubes, the IFRs, some of the various
14 statements, you know, made in the associated chapters.

15 So, we have prepared drafts for the
16 proposed rule. And it discussed the steam generator
17 tube integrity, the issue as a whole. It includes the
18 method of analysis and as Tom mentioned, the portion
19 of the carveout related to integrity of the IFR and
20 the tubes.

21 So, the draft proposed rule would exclude
22 both aspects of that issue from finality and will,
23 basically what will happen is a COL applicant would
24 have to provide those portions when they apply for the
25 COL and then that's when the NRC staff would perform,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 you know, that review.

2 Except, I think as noted they could, you
3 know, put a topical report or something together on
4 the method, you know, that could come in ahead of
5 time. If it's a technical report it would typically
6 come with the COL.

7 But either way the COL would, you know,
8 fulfill that by either referencing like an approved
9 topical report, you know, or providing the technical
10 report.

11 So, other aspects of the steam generator
12 design are considered acceptable to staff. Those
13 would be granted finality but not the ones
14 specifically identified in the carveout.

15 MEMBER MARCH-LEUBA: Okay. And that's
16 where my earlier comment was. Apparently the staff is
17 not concerned about controllability and operability of
18 the steam generator?

19 MR. SCARBROUGH: That issue is, we
20 consider, we separated. The design certification
21 focuses on the reactor aspects. The COL applicant
22 still will need to come in and talk about the
23 secondary side, control and things of that nature.

24 But just from a design certification
25 perspective we focused on is there a potential impact

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 on the reactor safety. And our concern was that if
2 there was catastrophic failure of a number of tubes
3 that could affect reactor safety.

4 And so, that's how we separate it. We
5 haven't, it's not that we're not concerned about it.
6 We just have put that over into the COL application
7 review.

8 MS. PATTON: Right. The carveouts are
9 linked to what the findings are that the staff has to
10 make at the design certification stage specifically.

11 So, you know, you can as a finding right
12 that he has to make on that IFR, for example, you
13 know, show it doesn't fall apart and somehow impact
14 the integrity of the tubes or fail to perform its
15 function and therefore you could, you know, have
16 oscillations impacting that.

17 The controllability of the plant, whether
18 or not there are any issues with that, you know, I
19 think if I remember correctly I believe the control
20 system like gets, you know, that gets designed later.

21 I think there's a COL item on some aspects
22 of the MPS control system. So, those are things that
23 would be looked at, you know, at the COL stage.

24 You don't need a, you don't use a carveout
25 for that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER MARCH-LEUBA: Control and
2 protection system will determine, you're still dumping
3 moisture in the steam line that becomes an issue too.

4 MS. PATTON: Right. But, so some issues
5 have to be, you know, looked at as part of the design,
6 their design, the findings that need to be made, you
7 know, under the regulations.

8 And so, those where you can't make them
9 it's a carveout.

10 MEMBER MARCH-LEUBA: So, you have not made
11 any finding about the controllability and operability
12 of the secondary side?

13 MS. PATTON: No. The control system is
14 part of --

15 MR. SCARBROUGH: That would be a COL item,
16 COL application review not for design certification.

17 MEMBER DIMITRIJEVIC: Okay. Up to now I
18 look at this as operability issue. I did not think it
19 was a safety concern because of your putting, they
20 don't call it steam generator tube rupture but steam
21 generator tube failure. Now when you bring the safety
22 concern isn't that too big to carveout because you
23 cannot even make conclusion that this plant meets
24 safety goal?

25 With this carveout you cannot make

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 conclusion in Chapter 19 that this plant is meeting
2 safety goal.

3 MR. SCARBROUGH: Well, we're carving out
4 just the aspect of the steam generator tube integrity
5 aspect.

6 MEMBER DIMITRIJEVIC: Yes. But this is a
7 risk steam generator to fail. That leads to loss.
8 So, you are carving safety concern which can impact
9 conclusions about safety of this plant. How can you
10 do that?

11 So, by making it a, well by making it a
12 carveout for one you're putting it directly in the
13 rule. So, the COL applicant will have to demonstrate
14 that IFR, you know, does remain intact, doesn't, you
15 know, cause damage to the tubes, right, performs its
16 function.

17 That is ensured to have to be demonstrated
18 by the COL applicant by carving that out specifically.
19 So, that's what we would expect.

20 MEMBER DIMITRIJEVIC: But then your
21 Section 19 cannot make conclusions that this plant
22 meets safety goal until that's proved. Just, I just
23 want to say that.

24 Until this is proved by COL applicant we
25 don't know that this plant meets safety goals.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. SCARBROUGH: The COL applicant will
2 have to demonstrate this to be able to receive
3 permission to load fuel. So, they're going to have to
4 --

5 MEMBER DIMITRIJEVIC: No, no. I
6 understand. But I just say the second sentence in
7 Chapter 19 is this plant meets safety goals with
8 badging, blah, blah, blah.

9 That's not true anymore. It won't be true
10 until they prove that in the COL.

11 MR. SCARBROUGH: We have interacted with
12 OGC on how this process works. And according to their
13 legal opinion you sort of carve that, this very narrow
14 focus out when you make that decision.

15 So, we're going through the process of OGC
16 of what carveouts work. And so far they've indicated
17 that this focused carveout is acceptable from the
18 perspective of you can proceed with design
19 certification with this carveout.

20 So, that's sort of where we are with the
21 process.

22 MEMBER DIMITRIJEVIC: You know, if you
23 think that this is safety concern, you know, it would
24 be tough to agree with that, that you can proceed
25 having such a big safety concern.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. SCARBROUGH: Okay, well thank you.
2 I'll relay that back to OGC and make sure we're on
3 good legal ground. Thank you.

4 CHAIRMAN SUNSERI: Okay. Any other Member
5 comments?

6 VICE CHAIRMAN REMPE: Okay. Real quick,
7 this has changed in the last few weeks. It's been
8 changed again because we might have done a letter this
9 week and how confident are we in the material that
10 we've only seen in slides?

11 MR. SCARBROUGH: Well, in terms of the
12 carveout I think we're pretty comfortable. We have
13 OGC agreement on how the carveout works and how it's
14 very focused on this specific aspect.

15 So, we're comfortable with this aspect.
16 We don't plan to, this has to go to the Commission of
17 course and they have to, you know, sign out the rule.
18 But we do not plan to have any changes at this point
19 in terms of how the carveout.

20 And it's very consistent with the slides
21 you've seen in terms of the wording. The discussion
22 in the rule is very short.

23 It's very similar to what is in the slides
24 because OGC says you just have to focus it and make
25 sure you that you carve out a very narrow, specific

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 concern that you have.

2 So, we don't anticipate any changes. But
3 it does have to go to the Commission for their
4 approval.

5 MS. PATTON: Right. I mean, the
6 Commission, you know, review of the proposed rule
7 always happens afterwards anyway.

8 VICE CHAIRMAN REMPE: So, just trusting
9 and wanted to kick the tires and make sure. Thank
10 you.

11 MS. PATTON: Right. I mean obviously feel
12 free to weigh in one way or another because you're
13 always before the Commission. Bob had --

14 MEMBER BROWN: Yes. You zipped right
15 through something where you said changes in the MPS,
16 Module Protection System. What --

17 MS. PATTON: No, I believe that's, I'm
18 sorry I may have misspoke.

19 MEMBER BROWN: I was hoping you were,
20 okay.

21 MS. PATTON: I believe it's the control
22 system.

23 MEMBER BROWN: Okay. You're talking about
24 the control system for like feedwater control or
25 something like that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MS. PATTON: But my understanding was the
2 control system actually has like a COL item on it.

3 MEMBER MARCH-LEUBA: I said trip but I
4 meant protection of equipment and protection of --

5 MEMBER BROWN: She used the words, the
6 acronym MPS when she zipped right through a comment
7 earlier.

8 MS. PATTON: Yes. I meant to say control,
9 MCS.

10 MEMBER BROWN: Module Protection System
11 is, has nothing to do with this.

12 MS. PATTON: No.

13 MEMBER BROWN: Thank you for the
14 clarification.

15 MR. CALDWELL: This is Bob Caldwell. I'm
16 the deputy director of DNRL. I just want to make
17 sure. But we cannot make a safety finding based on a
18 COL item.

19 We can't say the design is good or bad
20 based on the COL item. It is a tracking item.
21 However, COL items must be addressed during the COL
22 application where we do a review, basically the same
23 SRP type review of what's actually being built with
24 all the final design details in it.

25 So, we actually look at it before a plant

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 will ever be built for that. So, a carveout is very
2 specific. It's very focused. It's on one of the
3 findings.

4 We have multiple findings during our DC
5 review and the certification. So, they are findings
6 by regulation. I'm not familiar that we ever make a
7 finding that the plant is safe.

8 We say that the plant meets the
9 regulations and that all the regulations are satisfied
10 with the exception of an aspect of a regulation. So,
11 we're very comfortable with the COL carveout, excuse
12 me, the carveout process.

13 We're also very comfortable with the COL
14 items. But we can't make a safety finding that the
15 regulations are met based on a COL item.

16 MEMBER BROWN: So, you're confirming
17 Member Dimitrijevic's comment that you can't give a
18 firm basis that it meets the safety goal until, that's
19 why you're saying later? That's what I heard you just
20 say.

21 I'm sorry, I didn't talk to the mic.
22 Vesna noted that how can you give a, say you meet the
23 safety goals, I forgot what the words are, okay, as
24 part of this rulemaking.

25 You have to, part of it's being deferred

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 because of this until the COL applicant completes
2 whatever is necessary on the steam generator design
3 issue. And you all will be reviewing it at that time.

4 You made a comment you can't make a firm
5 commitment that it meets it until you finish this and
6 that's going to be delayed. I'm just trying to
7 confirm what Vesna said that I got it, that first of
8 all they kind of waved their hands.

9 And you're saying well, she's really kind
10 of right. That's the way I --

11 MEMBER RICCARDELLA: I'm not a policy
12 person. But the rulemaking says hey, it meets the
13 safety goals in everything except for these specific
14 areas in which are carved out.

15 MR. CALDWELL: That's correct.

16 MEMBER RICCARDELLA: That's not a big
17 deal.

18 MEMBER BROWN: I didn't say the rule was
19 --

20 MEMBER DIMITRIJEVIC: There is three
21 things core damage large release and conditional
22 containment which this will impact significantly. So,
23 those are three safety goals that come from the PRA
24 perspective.

25 So, I mean that much we don't know. That

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 would be me. And, you know, this is not a carveout
2 for the hydrogen, you know line. You are carving out
3 a big part of the thing.

4 I mean, you know, it's not really small
5 item like we were discussing yesterday the hydrogen
6 and, you know, line. So, I mean, I really, you know,
7 I am really, I am not comfortable with this.

8 MR. SCARBROUGH: Okay, well thank you.
9 We'll go back and talk to OGC and make sure that we're
10 on --

11 MR. CALDWELL: Let me just make it clear.
12 Excuse me, this is Bob Caldwell again. For the items
13 of which we determine finality they meet the safety
14 goals.

15 For the items that we have not reached
16 finality on we do not say one way or the other. But
17 for everything that we have reached finality on we
18 have, we believe we meet the Commission's safety
19 goals.

20 MEMBER BROWN: But you won't have finality
21 on this?

22 MR. CALDWELL: We won't have that on that
23 before we actually get the review on the COL for that
24 one aspect.

25 CHAIRMAN SUNSERI: And the plant won't

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 operate until they do.

2 MEMBER BROWN: So, that part I understand.
3 But you need to know how to say, no.

4 CHAIRMAN SUNSERI: All right, Members, any
5 other, I'm sorry, Tom, anything else?

6 MR. SCARBROUGH: No, we're good. Thank
7 you.

8 CHAIRMAN SUNSERI: Members, any other
9 comments or questions for staff while we're in the
10 open session?

11 MEMBER MARCH-LEUBA: Let me put something
12 on the open session. Certainly I like better the
13 approach of the applicant than your approach in the
14 sense that I believe, and this is a belief of religion
15 if you want, that the output of that process will be
16 ending up more validated so we will know for sure
17 whether we are unstable or not.

18 And we will make the changes that will be
19 necessary to the plant so that we won't be unstable at
20 100 percent flow. That's what I believe the output of
21 the COL process will be.

22 And I love it. As I said before, I'm
23 getting tired of winning. So, thank you very much.

24 CHAIRMAN SUNSERI: Okay. At this time I
25 will ask any Members that are in the room that would

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 like to make a statement please come up to the mic and
2 do so.

3 While we're doing this, Mike, can you get
4 the public line open?

5 MR. DUDEK: I will. But just to clarify
6 for members of the public that are on the line we are
7 going to closed session in order to protect
8 proprietary information to the NuScale design is the
9 reason that we're going as announced earlier in the
10 meeting that we can go to closed session to protect
11 proprietary information.

12 We will reopen the line for public
13 discussion or for the public to participate at 1:00
14 p.m. this afternoon when the open session will begin
15 again. Thanks.

16 CHAIRMAN SUNSERI: Anybody in the room?

17 MR. DUDEK: This is Michael Dudek. I just
18 have one additional comment to add on to what you
19 said, Jose. It's not one or the other.

20 I think you're going to get both. So, I
21 think you're going to get NuScale's proposed design
22 fixes and you're going to get the carveout. So,
23 that's just the extra regulatory assurance.

24 MEMBER MARCH-LEUBA: Well, let me
25 reiterate, I'm happier today than I was yesterday.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN SUNSERI: No comments from the
2 room. So, I'll turn to the phone line. Any member of
3 the public on the phone line that wishes to make a
4 statement please state your name and your comment.

5 All right. We're going to close the phone
6 line. And at this point we have reached the end of
7 the open session. We're going to take a 15 minute
8 break.

9 We're going to reconvene at 10 after ten
10 in a closed session with NuScale presenting first. We
11 are recessed until 10:10.

12 (Whereupon, the above-entitled matter went
13 off the record at 9:53 a.m. and resumed at 1:03 p.m.)

14 CHAIRMAN SUNSERI: All right, we are
15 reconvening the meeting now. We will start with
16 NuScale in open discussion to begin with the -- lost
17 my -- rod ejection accident.

18 MR. PRESSON: Matt Sunseri?

19 CHAIRMAN SUNSERI: Matthew, you all are
20 ready to go?

21 MR. PRESSON: Yeah, thank you, and good
22 afternoon. Appreciate you all taking the time to hear
23 from us on these topical reports today. I'm Matthew
24 Presson, Licensing Project Manager for NuScale Power.
25 And we are going to be discussing the evaluation

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 methodologies for rod ejection accidents, loss of
2 coolant accidents, and non-loss of coolant accidents.

3 The presentations provided today are
4 identical to the presentations we gave to the
5 Subcommittee on February 19, so we'll be moving
6 through them at a pretty quick summary level today.
7 But for interested members of the public, when the
8 transcripts for that February 19 meeting come out,
9 there will be a fair amount more detail there.

10 That being said, while we'll be giving a
11 summary, if you have any questions, feel free to
12 interrupt. And we have our engineers listening in on
13 the phone or one of them here at Rockville, so let us
14 know.

15 CHAIRMAN SUNSERI: All right, thank you.

16 MR. PRESSON: Next slide. All right, so
17 slide 2. For our first presentation on the rod
18 ejection method, it'll be myself up here, and Kenny
19 Anderson is supporting from Corvallis as our Nuclear
20 Fuels Analyst. Next slide.

21 For slide 3, I did want to spend a minute
22 on this just to re-scope, given our week of discussing
23 DCA and FSAR topics here. This slide provides us with
24 a high level map of the technical and topical reports,
25 which develop the methods needed for Chapter 15 and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 other related thermohydraulic sections.

2 Today we will be looking specifically at
3 rod ejection LOCA and non-LOCA. And while these do
4 support the NuScale FSAR, the results of these as
5 applied to the FSAR design are presented in Chapter
6 15. Our discussions today will be focused on the
7 separate licensing submittals for these methods.

8 All right, for our agenda, our
9 presentation will cover a quick summary of the event,
10 our acceptance criteria, our expectations against
11 future reg guides, especially DG-1327, a flow chart of
12 the method, how we initialize and evaluate our events.
13 And then a quick summary of that method again.

14 For slide 5, we discuss why we look at a
15 separate method for rod ejection and for meeting our
16 GDC-28 commitments. And it provides a couple of
17 examples on why it's unique insofar as Chapter 15
18 events, such as its focus on nuclear physics instead
19 of thermohydraulics, where that spatial focus is.
20 Postulated causes, and definitely acceptance criteria,
21 which we will also discuss on slide 6.

22 This slide 6 is another summary table
23 providing information on which acceptance criteria are
24 more unique to the rod ejection event than the rest of
25 Chapter 15 events. For the NuScale method, most of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 those acceptance criteria are covered by our method
2 requirements to preclude fuel failure, there we go,
3 and that's part of that footnote down at the bottom of
4 the table.

5 Our next slide, while not applicable to
6 the current method or FSAR DCA design, discusses why
7 we feel pretty comfortable in meeting future proposed
8 criteria for pellet clad interaction. As it is not
9 current criteria, we do not have a full evaluation
10 showing this. But as no exposure is credited in our
11 rod ejection method and as M5 cladding is less
12 susceptible to those interactions in general, we are
13 confident that we won't be challenged when those
14 criteria are revised.

15 So for slide 8, we are looking at a flow
16 chart that shows an overview of our method, how we
17 moved from SIMULATE5 to SIM-3K. And then eventually
18 split it out to look at our peak RCS pressure, our
19 MCHFR, and our fuel temperature and enthalpy
20 requirements.

21 For slide 9, that's a very summary
22 discussion, but it does provide some of the
23 information for how we initiate and set up our steady
24 state assumptions and evaluations. We use SIMULATE5
25 to set up the core response. SIMULATE5 is covered in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 our nuclear analysis codes and methods qualification.

2 And our design does include the assumption
3 bounding potential for an ejected assembly to damage
4 adjacent assemblies, which has been discussed in terms
5 of our FSAR design. I believe, if my notes are
6 correct, that we and the NRC intend to follow up with
7 that during DCA discussion in the April full committee
8 insofar as the DCA design. For the scope of this
9 method, it is simply an assumption that is built into
10 those initial conditions.

11 Slide 10. Slide 10 shows how we build on
12 from that steady state initialization and move into
13 our dynamic response. SIM-3K is used to model the
14 transient and what's benchmarked to demonstrate a
15 combined neutronic, thermohydraulic and fuel time
16 modeling capabilities. So the slide also lists some
17 of the primary uncertainties that were applied for the
18 simulations.

19 Slide 11 discusses how we move into our
20 CHF evaluation, where we use VIPRE-01. This was
21 originally demonstrated to be appropriate for our
22 design in our subchannel analysis methodology.

23 There are some unique differences in this
24 application versus that original topical report, such
25 as smaller axial nodalization, case-specific radial

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 power distributions, couple of the other bullets seen
2 there. And to that point, we evaluated additional
3 sensitivities to holistically justify those changes.

4 For slide 12, to insure against our fuel
5 heat-up criteria, we include a hand calc, which takes
6 a adiabatic approach, including total energy generated
7 by a SIM-3K, and runs that through either as a
8 temperature or energy increase. Those values are
9 compared against NRC-developed acceptance criteria.
10 And some example values are included in the
11 Subcommittee closed session slides from February 19.

12 Slide 13 looks at the first side of our
13 dynamic system response. So we covered CHF in the
14 previous slide. Our first type of dynamic response
15 that we look at is our CHF evaluation. It takes a
16 transient response and provides those system
17 thermohydraulic conditions over to VIPRE for a
18 subchannel evaluation.

19 Next slide, 14, discusses a quick summary
20 of our second dynamic system response, which is
21 looking for pressurization. For that we, it's a
22 little bit different scenario. We are looking for
23 something that raises the power quickly up to just
24 below those high power and high power rate trip
25 setpoints, and let it go for as long as it takes

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 before it trips the core.

2 So then from there we calculate the peak
3 system pressure and compare that against our
4 acceptance criteria.

5 So a very quick presentation, but in
6 summary, we have a conservative analysis method for
7 our unique rod ejection accident, at least in terms of
8 Chapter 15 events.

9 And the topical report provides details
10 and justification for software tools and acceptance
11 criteria used, the applicability of the method and
12 those tools, the appropriate treatment of
13 uncertainties, and the results of this application of
14 the method by input to our DCA FSAR Chapter 15. So.

15 MEMBER KIRCHNER: I do have one question.
16 I didn't bring the slides from the previous
17 Subcommittee meeting, but I thought on the slide for
18 fuel that shows the figure fuel enthalpy rise versus
19 oxide wall thickness, you drew a box in within the
20 lefthand figure that you were using for your
21 acceptance criteria.

22 You mention the next-to-the-last bullet,
23 the upper limit that you were using, so I think I can
24 say that. I was curious, I don't remember how you
25 chose a point on the abscissa on oxide wall thickness.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Is that a proprietary number?

2 MR. PRESSON: I'll have to ask Kenny if
3 that was a proprietary value.

4 MEMBER KIRCHNER: Yeah, I --

5 MR. PRESSON: But it was based on not
6 needing to basically ever take credit or advantage of
7 any of the space after you pass that point, so.

8 MEMBER KIRCHNER: So that was a box that
9 you drew as your acceptance criteria.

10 MR. PRESSON: Yeah, that's correct.

11 MEMBER KIRCHNER: For the actual NPM,
12 right?

13 MR. PRESSON: Yup.

14 MEMBER KIRCHNER: I'll go back and check
15 on whether that was an open slide or a closed. But
16 again, the basis for that was that that was the
17 estimated maximum oxide oxidation you would see?

18 MR. PRESSON: Correct. And Kenny, if
19 you're available --

20 MEMBER BALLINGER: That's number's a
21 widely used number.

22 MEMBER KIRCHNER: Okay.

23 MEMBER BALLINGER: The one that they use,
24 so.

25 VICE CHAIRMAN REMPE: So I forgot that I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 needed to declare that I might have a conflict of
2 interest in certain aspects of this discussion on this
3 particular methodology and limit my participation in
4 such discussions and deliberations.

5 CHAIRMAN SUNSERI: Noted.

6 MR. PRESSON: Kenny, are you available to
7 chat? Because I do believe that value is open
8 information, it just didn't show up on the slide.

9 MEMBER KIRCHNER: Okay.

10 MR. PRESSON: Yeah, you can talk right
11 now.

12 MR. ANDERSON: Hi, this is Kenny in
13 Corvallis. Yes, that number comes from our assumed
14 or calculated maximum corrosion. And it, I think it
15 is on the slide, but perhaps it's not showing up in
16 the presentation.

17 MEMBER KIRCHNER: Yeah, okay. Thank you.

18 MR. PRESSON: Yeah, I'm 99% sure it's not,
19 so. All right, that is the end of our presentation,
20 so if there are any questions.

21 CHAIRMAN SUNSERI: Any members, comments,
22 questions on rod ejection? All right, then we're
23 done. Did that one.

24 MR. PRESSON: All right. Are we
25 presenting this? Yeah. Good?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIRMAN SUNSERI: Yes, when you're ready.

2 MR. PRESSON: All right, so next
3 presentation will be a similar summary fashion. And
4 again, same slides as before. This is the, our
5 presentation on our NuScale topical report, loss of
6 coolant accident evaluation model.

7 So here we have myself, Matthew Presson,
8 on the line we have Dr. Pravin Sawant, a Supervisor of
9 Code Validation and Methods. We also have Dr. Selim
10 Kuran, who is our Thermohydraulic Analyst. And Ben
11 Bristol, our Supervisor of System Thermohydraulics.

12 Slide 3 provides a quick overview of our
13 agenda. We describe a very summary version of our
14 methodology, provide a reference slide for our NPM
15 safety systems. There were the four elements of our
16 LOCA topical report and the PIRT, our assessment base.
17 The evaluation model for NRELAP5, and our
18 applicability evaluation. And we discuss how we
19 extend the LOCA evaluation to an IORV event and end
20 with conclusions.

21 So slide 4, little bit of background on
22 the NPM and the LOCA. Some of the unique features
23 involve our integrated design, which eliminates a lot
24 of piping and limits potential breaks. Coolant is
25 captured completely in containment, cooled and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 returned to the reactor pressure vessel using a large
2 pool.

3 Our regulatory requirements that we use to
4 build our method are, well, that we used to make sure
5 our method met, was the 10 CFR 50.46 acceptance
6 criteria. And we looked to maintain maximum PCT at
7 steady state with no clad heat-up. To meet those for
8 our evaluation method, we used conservative LOCA
9 acceptance criteria. These are figures of merit that
10 the core remains covered, and therefore it collapsed
11 liquid level over the top of active fuel.

12 Our MCHFR is greater than our CHFR limit
13 of 1.29, and our containment pressure and temperature
14 are below the design limit.

15 For slide 6, this provides kind of a
16 roadmap for how we take those acceptance criteria and
17 develop them out into a method. So we start with our
18 10 CFR 50.46 requirements. We then process that using
19 Reg Guide 1.203. And we develop that into our LOCA
20 PIRT Element 1. Use that to develop our assessment
21 base for separate effects testing and integral effects
22 testing.

23 Move on to Element 3, where we developed
24 the evaluation model. And finally, with Element 4, we
25 use all the prior elements to assess that adequacy.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Slide 7 is just a quick picture for
2 reference in case any information is needed, but it
3 provides a lot of information about our safety
4 systems, kind of how they're oriented. All right.

5 Slides 8 and 9 get us into Element 1 of
6 our PIRT process. So there we assessed our relative
7 importance of phenomena. We would recognize experts
8 and NuScale subject matter experts in our PIRT panel.
9 And we targeted those figures of merit, CHF, collapsed
10 level above top of active fuel, and containment
11 pressure and temperature. That when we used rankings
12 in importance and knowledge to see where we needed to
13 focus our, any evaluations on.

14 It was a result of that for slide 10, we
15 developed this understanding of phases, Phase 1a
16 blowdown, Phase 1b ECCS actuation, and Phase 2 flow
17 reversal at RRVs. For LOCA, we focus on Phase 1a and
18 1b. We move onto long-term cooling for Phase 2.

19 All right, yeah, for slide 12, it goes
20 into how we develop our NRELAP5 code. We use RELAP5
21 3D, version 4.1.3, as the baseline code. We maintain
22 a code configuration control and development
23 consistent with NuScale's NQA-1 2008 and 2009 NQA
24 program.

25 And some of the specific modifications we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 made for NRELAP5 were to consider NuScale specific
2 components such as our helical coil steam generator.
3 Make sure that we met those regulatory requirements
4 from earlier and apply error corrections as they're
5 determined.

6 Slide 13 is a very high level, but we did
7 want to point out that we have a fair number of tests
8 spanning our integral effects testings and separate
9 effects testing. And for slide 14, we present our
10 NIST-1 facility, where a large portion of those tests
11 took place. It's the primary source of our NuScale-
12 specific test data, and it includes a good number of
13 design features that look to scale and provide
14 information for our LOCA and non-LOCA events.

15 All right, so for our NuScale LOCA model
16 overview, we look into the analysis and justifications
17 of why we use NRELAP5, what we need for time-step
18 controls, how we set up those boundary conditions, and
19 how we maintain and treat setpoints and trips. We
20 also take a look at the LOCA break spectrum and dig
21 into the methodology of sensitivity calculations.

22 Those are required by Appendix K, they are
23 phenomena-specific, and we use them to establish a
24 conservative bias.

25 For Element 4, our applicability

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 evaluation, we took both the bottom-up and top-down
2 approach. For the bottom-up approach, we identified
3 the dominant models and correlations for the hydraulic
4 phenomena, it's in table 8-1 of the topical report.
5 Identified a lot of key parameters and reviewed those
6 models and correlations. Again, a lot of that is in
7 Chapter 8.

8 For the integral performance, the top-down
9 portion of it, we reviewed the codes and evaluated the
10 integral performance of those codes using those
11 integral effects test data. And we compared that test
12 data to NRELAP5 scalability via scaling and distortion
13 analysis. And we note those differences and
14 distortions between the NPM and NIST and look to see
15 how we can account for them using NRELAP5.

16 So our conclusions for the LOCA method is
17 that there are a number of conservatisms built into
18 it. We have both as much from 10 CFR 50, Appendix K,
19 as is applicable to the NuScale design. And we look
20 to make sure that those other unique considerations
21 are considered by other methodology conservatisms.

22 We developed this using the cycle
23 independent bounding LOCA analysis. It is supported
24 by an extensive experimental database. A lot of those
25 new to NuScale using this one, as well as several

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 others. Applicability evaluation is consistent with
2 Reg Guide 1.203, and we maintain -- we look to
3 maintain those figures of merit.

4 So CHF is not challenged, our collapse
5 level in the reactor remains above the top of active
6 fuel. There is no clad or fuel heat-up, and our
7 pressure and temperature remain below design limits.

8 And the next slide, slide 20, really slide
9 21, go into how we kind of extend our LOCA into IORV
10 space. So we're looking to kind of evaluate liquid
11 space, RRV and steam space, RVV and RSV discharge.
12 And these are fairly similar transients to the LOCA.

13 From that, we followed a very similar
14 process as our LOCA, developing the method. And yeah,
15 next slide. On slide 22, we account for a couple of
16 the differences. The main difference is our key
17 acceptance criteria, our MCHFR limit moves to 1.13 and
18 1.37.

19 And our conservatisms are the same as
20 LOCA, but with the following exceptions. That we
21 remove an additional 15% bias in fuel. We have our
22 limiting axial power shapes and radial peaking based
23 on subchannel analysis. The Moody choked flow model
24 for two phase is applied to the initiating valve, and
25 the initial conditions are biased to minimize MCHFR.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So on slide 23 we come to similar
2 conclusions. IORV as an extension of the LOCA method.
3 Maintains its own PIRT assessment and applicability
4 within the LOCA. The minor method differences mainly
5 account for the AOO classification of that.

6 And MCHFR occurs early within that
7 transient, and then rapidly rises, given the flow-to-
8 power ratio. So our primary concern there, that the
9 collapsed liquid in the RPV does remain above the top
10 of active fuel.

11 MEMBER MARCH-LEUBA: The MCHFR occurs
12 early but does not violate the limit, right?

13 MR. PRESSON: Correct.

14 MEMBER MARCH-LEUBA: Because the way you
15 have it written, I said, wait a moment.

16 MR. PRESSON: Yeah, well, and it is still
17 the minimum, or maximum but it does not violate --

18 MEMBER MARCH-LEUBA: I know exactly what
19 you mean, it can be misinterpreted.

20 MR. PRESSON: Yup. And that is our LOCA
21 presentation.

22 CHAIRMAN SUNSERI: Members, any comments
23 or questions for NuScale? No? All right. So you may
24 proceed with the non-LOCA,

25 MEMBER BLEY: It just strikes me that if

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 I were listening in, I would think we have no
2 interest. But we had a Subcommittee meeting on this
3 where we delved into the associated issues in great
4 detail.

5 CHAIRMAN SUNSERI: That's a good point,
6 and we had good, full Committee participation at those
7 subcommittees as well.

8 MEMBER MARCH-LEUBA: And it was two days
9 ago.

10 CHAIRMAN SUNSERI: Yes.

11 MEMBER MARCH-LEUBA: So that's why we're
12 so quiet, because this is just a pro forma
13 presentation.

14 MR. PRESSON: Yeah, two days ago for
15 Chapter 15 and two weeks ago for the original
16 Subcommittee for this. But those transcripts aren't
17 up yet.

18 CHAIRMAN SUNSERI: But it's important to
19 get it on the record for public --

20 MR. PRESSON: Yeah. There was a good full
21 day of conversation on this.

22 VICE CHAIRMAN REMPE: Good, huh?

23 MR. PRESSON: I would say so, yeah. Hey,
24 it's nuclear industry, we value a questioning
25 attitude.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 All right, and our final presentation for
2 this afternoon is on the Non-Loss of Coolant Accident
3 Topical Report. Again, presenters are myself up here,
4 as well as Megan McCloskey, who is our Thermohydraulic
5 Analyst. We have Ben Bristol on the line, who is our
6 Supervisor of System Thermohydraulics, and Paul
7 Infanger, our Licensing Specialist is in the audience
8 as needed.

9 So for slide 3, we go over our outline
10 where we, just the outline of the presentation. We
11 give a scope of the non-LOCA LTR as compared to other
12 Chapter 15 events, as well as other FSAR events. We
13 discuss those non-LOCA events that are covered in the
14 method. We discuss the development of our non-LOCA
15 method and give a general overview of how we perform
16 those analyses and look at a couple of specific
17 events.

18 So slide 4, discussing scope. Our non-
19 LOCA method does look at NRELAP5 system transient
20 analysis of non-LOCA events. It looks at that
21 interface to subchannel and accident radiological
22 analysis. And goes over the short-term transient
23 progression with DHRS cooling. So what is out of
24 scope for the non-LOCA method is the SAFDLs, which are
25 evaluated and downstream subchannel analysis, with its

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 own topical report.

2 All of these out-of-scope items are either
3 captured in topical reports or technical reports.
4 Also includes accident radiological dose analysis,
5 control rod ejection, which we already covered, as
6 well as LOCA, and those IORV events. Peak containment
7 pressure has its own technical report. And the long-
8 term transient is covered in the long-term cooling
9 technical report.

10 So our non-LOCA evaluation method is
11 applicable to the following events. We covered
12 cooldown events, heat-up events, reactivity events,
13 inventory increase and inventory decrease. Most of
14 these are fairly standard events for Chapter 15, but
15 a couple of unique ones for NuScale giving our design
16 our loss of containment vacuum and containment
17 flooding. As well as the heat-up event of an
18 inadvertent operation of DHRS.

19 A quick overview of non-LOCA event
20 acceptance criteria. This table presents those
21 criteria in general, so for the minimum critical heat
22 flux ratio and the maximum fuel center line
23 temperature, you'll note that both of those point to
24 the Footnote 1, where we, that was pretty much as
25 collapsed down to the same AOO acceptance criteria.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And here we have a zoom-in on how our non-
2 LOCA method interacts with those other topical
3 reports. We have our, you developed a design, you
4 look at the events. Our non-LOCA methods covers the
5 system thermohydraulic response. That then passes
6 that information on to VIPRE for subchannel analysis,
7 looking at CHF.

8 And then mass and energy releases from the
9 thermohydraulic response and other inputs are looked
10 at in our accident radiological analysis, which is
11 bounded by our accident source term topical report.

12 MEMBER MARCH-LEUBA: And this might be
13 relevant for some other topic, but not every single
14 transient evaluated within RELAP gets evaluated with
15 VIPRE.

16 MR. PRESSON: Correct.

17 PARTICIPANT: You use screening criteria.

18 MR. PRESSON: Yup.

19 MEMBER MARCH-LEUBA: Say two words about
20 it?

21 MR. PRESSON: Yeah, we'll actually cover
22 that on a later slide, but that is correct, yeah. For
23 slide 8, we look at our margin to acceptance criteria.
24 For non-LOCA, we are looking at MCHFR. Primary
25 pressure, secondary side pressure, radiological

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 release, and establishing those safe, stable
2 conditions to pass on down.

3 For slide 9, the evaluation method
4 development follows a fairly similar path as our LOCA.
5 Followed the same Reg Guide 1.203 process in
6 developing the graded approach. Element 1 is looking
7 at establishing the applicable transients and
8 acceptance criteria and to create that non-LOCA PIRT.

9 Elements 2, 3, and 4 leverage a fair
10 amount of information from LOCA, but it definitely
11 does focus on the differences between high ranked
12 phenomenon, well, the differences between the LOCA and
13 non-LOCA high ranked phenomena, make sure that we have
14 additional NRELAP5 code validation performed to focus
15 on, for example, DHRS and the integral non-LOCA
16 response.

17 Slide 10 covers the results and what was
18 considered in our non-LOCA PIRT, including the general
19 categories of event types, the SSCs that were
20 considered, as well as the phases that are part of our
21 non-LOCA, our pre-trip transient, our post-trip
22 transition, and finally Phase 3 of stable natural
23 circulation.

24 Slide 11 gives a quick summary of
25 NRELAP5's applicability for non-LOCA. As mentioned

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 before, there was a KATHY analysis performed to
2 determine how to address those high ranked phenomena,
3 looking to see what validation was still applicable,
4 as taken from the LOCA evaluation model and adding
5 additional validation and benchmarks for non-LOCA.

6 That also looked to our conservative
7 inputs and make sure that we had suitable subchannel
8 analysis established. Sorry, yeah.

9 Overall conclusion is that the NRELAP5
10 code with the NPM system model is applicable for
11 calculation of the NPM non-LOCA system response, so.

12 Slide 12 goes over that analysis process.
13 Topical report section 4, where we develop that plant
14 base model. We adapt it as needed for the specific
15 events. You perform you steady state and transient
16 calculations within RELAP5, and you evaluate those.
17 You confirm your margins to RCS pressure acceptance,
18 steam generator pressure acceptance criteria.

19 And you, this kind of goes to your point
20 earlier, you identify the cases that you look to
21 examine further with subchannel analysis and extract
22 the boundary conditions as applicable. So we're
23 looking conservative bias directions of maximal
24 reactor power, core exit pressure, core inlet
25 pressure, minimum RCS flow rate.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And the NRELAP5 CHF calculations for non-
2 LOCA may be used as a screening tool to assist
3 analysts in determining limiting cases to be evaluated
4 in that downstream subchannel analysis of that CHF.
5 It's not itself used for those non-LOCA events.

6 So, and 6, you look to identify if any
7 applicable radiological analysis needs to be
8 performed.

9 MEMBER MARCH-LEUBA: How do you identify
10 the step 6, what do you use as criteria?

11 MS. McCLOSKEY: For the events with
12 downstream radiological analysis, we look at the
13 system transient response and which cases have the
14 maximum mass release, which would carry the
15 radioactivity and increase the dose. And the maximum
16 iodine spiking time between reactor trip and isolation
17 of the break.

18 MEMBER MARCH-LEUBA: But if all your
19 analyses show no clad damage, what do you do?

20 MS. McCLOSKEY: Is the question why do we
21 do it, or what do we do?

22 MEMBER MARCH-LEUBA: What do you do if you
23 run all of your transients and none of them results in
24 clad damage? So your core is intact.

25 MS. McCLOSKEY: We still pass the boundary

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 conditions to the radiological analysis, and they use
2 an appropriate source term based on, I think, and I am
3 not radiological analysis analyst, you've got tech
4 spec limits on fuel failure rates and normal operating
5 coolant that can be --

6 MEMBER MARCH-LEUBA: So you assume normal
7 operation failure rates, and that is what is gives you
8 the source term.

9 MS. McCLOSKEY: Again, I'm not an expert
10 on the radiological analysis of what they used for the
11 source term.

12 MEMBER MARCH-LEUBA: Okay, I don't
13 remember, but that sounds familiar.

14 MS. McCLOSKEY: But there are source terms
15 that are evaluated.

16 MEMBER MARCH-LEUBA: It was like one --
17 yeah.

18 MR. PRESSON: From tech spec
19 concentration, just got a note, so.

20 Slide 13 looks at our general methodology
21 and event-specific methodology. In general we're
22 looking at steady state conditions, our treatment of
23 plant controls, loss of power, single failure, making
24 sure we have bounding reactivity parameter input. And
25 then bias the other parameters as needed. And we also

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 look at operator action as needed.

2 For the event-specific methodology, we
3 then dive a little deeper into the description of the
4 event initiation and progression. And we make sure we
5 appropriately scope for the acceptance criteria of
6 interest and target limiting single failures, the loss
7 of power scenarios, and whether or not we need
8 additional sensitivity calculations. The initial
9 condition biases and conservatisms that already
10 existent, or if we need, again, to perform more
11 sensitivities.

12 And then tabulated representative results
13 of those sensitivity calculations. So, and those
14 sample analysis results are provided in Section 8 of
15 the non-LOCA method.

16 So, for conclusions, slide 14. Our non-
17 LOCA system transient evaluation model is developed
18 following that graded approach we discussed in
19 accordance with guidance provided in Reg Guide 1.203.
20 It applies to NPM-type plant design, natural
21 circulation water reactors with helical coil steam
22 generators and an integral pressurizer.

23 NRELAP5 is used to simulate those systems
24 thermohydraulic responses to demonstrate primary and
25 secondary pressure acceptance criteria are met, and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that safe and stable conditions are achieved. And
2 system transient results provide the boundary
3 conditions that are then passed down to our subchannel
4 methods and radiological analyses.

5 And that concludes our non-LOCA.

6 CHAIRMAN SUNSERI: Members, any questions
7 or comments for NuScale?

8 MEMBER MARCH-LEUBA: Not today.

9 CHAIRMAN SUNSERI: Okay, well, good, we
10 appreciate the recap and the presentation. So at this
11 time we can transition over the staff for their
12 comments.

13 So as the presenters are taking their
14 seats, I'll turn to Rebecca and ask if you have any
15 overarching remarks that you want to make at this
16 point.

17 MS. PATTON: No, just thank you.

18 CHAIRMAN SUNSERI: Because I skipped you
19 earlier today. Okay, so Bruce, are you the lead here?
20 All right, well, whenever you're ready.

21 MR. BAVOL: All right, good afternoon,
22 everybody, my name is Bruce Bavol, I'm the Project
23 Manager on the NuScale project. This afternoon from
24 the NRC staff we're going to be talking several
25 topical reports, the first being rod ejection, the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 second being loss of coolant accident analysis, and
2 the third non-loss of coolant analysis.

3 To my right, Chris Van Wert will be
4 leading the rod ejection. We're, since we've talked
5 a lot about these topics, I'm just going to move right
6 into the staff review and turn it over to Chris.

7 CHAIRMAN SUNSERI: Yeah, and I think
8 similar kind of comments. I mean, there's not, you
9 don't have to read every bullet on the slide, we're
10 well versed in the topic to hit the high points and
11 the important message that you want to leave us with.

12 MR. VAN WERT: All right, good afternoon,
13 this is Chris Van Wert. And since we're jumping here
14 into the review, just want to point out that what is
15 included and not included within the review, we did
16 look at the criteria and the methodology as a whole,
17 as well as the assumptions that went into it.

18 And it's worth noting that the analysis
19 itself for the DCA is not part of this review, that is
20 handled separately under the Chapter 5 staff
21 evaluation report. It's also worth noting that the
22 staff did audit calculations and other supporting
23 information during its review.

24 As far as the analysis criteria itself, we
25 did look at the RCS pressure, fuel cladding failure,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 core coolability, and fission product inventory. And
2 we did determine that they either followed the
3 guidance provided in SRP 4.2's Appendix B, or were
4 conservative compared to it.

5 And as we discussed during the
6 Subcommittee, it was also not part of the staff's
7 review, but we were cognizant of the draft guidance
8 that's out there in terms of revised guidance for rod
9 ejection accidents.

10 And we did compare the two to see where
11 NuScale fell within it. But again, since that's draft
12 guidance, that wasn't a criteria that they had to
13 follow. But they were conservative in regards to
14 either criteria.

15 So next was the evaluation of the code
16 suite. In terms of rod ejection, they used CASMO5 to
17 SIMULATE5, you know, SIMULATE-3K and RELAP5 and VIPRE.
18 Most of those, with the exclusion of SIMULATE-3K, were
19 already reviewed and approved as part of another
20 topical report, the nuclear analysis codes and
21 methods, so that was not part of this review.

22 However, SIMULATE-3K was unique to this
23 and the validation was contained within it, so the
24 staff's review did cover it. And we did determine
25 that they successfully demonstrated that they could

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 use it properly and get accurate results.

2 MEMBER MARCH-LEUBA: Has SIMULATE-3K been
3 licensed by any other vendor or facility?

4 MR. VAN WERT: So SIMULATE-3K has been
5 used in licensing actions and has been reviewed by the
6 staff. It has not been submitted by Studsvik as the
7 standalone methodology topic report. So there's no
8 generic, yeah.

9 MEMBER MARCH-LEUBA: But any licensee or
10 vendor?

11 MR. VAN WERT: Licensees have submitted.

12 MEMBER MARCH-LEUBA: Some licensees use
13 it?

14 MR. VAN WERT: Yeah.

15 MEMBER MARCH-LEUBA: Okay, good.

16 MR. VAN WERT: For plant cycle, this
17 attribute did include plant cycle assumptions used by
18 NuScale. And in general, they included ranges and
19 power and cycle time and range of operating conditions
20 and show that they used limiting conditions.

21 The staff also agreed that the assumptions
22 in terms of the automatic systems response of non-
23 safety systems were conservative, and that the
24 methodology regarding timing of loss of AC power
25 conservatively biases the RCS pressure evaluation.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The staff reviewed the methodology itself,
2 including how information is passed between the
3 different codes, the uncertainties, the modeling
4 assumptions, and the handling of reactor trips. And
5 in conclusion, the staff determined that they were
6 conservative and that the methods were acceptable for
7 demonstrating compliance with the acceptance with
8 acceptance criteria.

9 And in conclusion overall, the staff
10 concludes that the criteria used for evaluating REA
11 either follows or is more conservative than the staff
12 guidance, and that the methodology accounts for
13 various potential operating conditions in time in life
14 and conservatively addresses uncertainties in plant
15 conditions.

16 The staff therefore finds the use of this
17 topical report acceptable for evaluating reactivity-
18 initiated accidents from the NuScale plant design.

19 And if there are any questions? And if
20 not, pass it on to Shanlai Liu.

21 CHAIRMAN SUNSERI: Members? No, all
22 right. Continue on.

23 DR. LU: Okay, Shanlai Lu from the staff,
24 NRR.

25 Okay, right away jumping to the -- okay,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the review team might have skipped that, so you
2 already talked about that one.

3 So the design features of course that you
4 guys have already gone through one. Very simple
5 design, there are three reactor vent valves on top of
6 the reactor vessel, two reactor, you know, return
7 valves. And then containment functions as a part of
8 ECCS.

9 So the scope of this topical report of
10 course is number one, it's to underline the LOCA. And
11 then as a part doing part of the review process, they
12 extended this topical report to cover the IORV
13 methodology. And as part of it, it also supports the
14 peak containment pressure and non-LOCA topical report
15 and non-term cooling analysis models.

16 Applicable regulation for LOCA of course
17 10 CFR 50.46. They decided to use Appendix K, which
18 does give them some flexibility to reduce the number
19 of runoffs that don't have to do the best estimate a
20 whole bunch of statistical sampling. Okay, next
21 slide.

22 The review approach, and we did take an
23 early engagement and, so that we can -- we conducted
24 extensive audits, all the way to, you know, a couple
25 months before this some presentation. And because of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that effort, and then we only identified a total
2 number of 13 RAIs, which is 45 RAI -- but through the
3 process we resolved 210 other issues.

4 And those were really resolved based on
5 extensive staff sensitivity studies and based on
6 NRELAP5 confirmatory analysis with TRACE, thanks for
7 our research support.

8 And the primary and, you know, scope of
9 this review is a focus on LOCA and a non-LOCA too.
10 And related to IORV. So the review area number one is
11 PIRT. And based on the staff's review, we conclude
12 that the PIRT process they had followed the CSAU
13 methodology.

14 And we used NRELAP5 code, which is a
15 derivative of NRELAP-3D, which has been used
16 extensively before. But they did add additional NPM
17 special features. We went through all each features
18 before.

19 And in order to confirm and then benchmark
20 the code, they conduct the extensive testing which
21 lasted a very long time, actually, more than ten
22 years. And then they also performed the scaling
23 distortion analysis. We reviewed that one, identified
24 the issues, and they did additional testing. And,
25 which resolved the issues there too.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And as part of IORV analysis methodology,
2 and then we dived very deep into the actual CHF
3 correlations by our staff. And what is used for low
4 and low flow and high flow conditions, including the
5 STERN and the KATHY facility specific fuel databases
6 they used for AOOs. So those are review areas we
7 covered. Next slide.

8 And as I mentioned that we did extensive
9 staff confirmatory analysis, which covers the separate
10 event test and the integral effect test, extensively
11 on the NIST models itself. And we used both TRACE and
12 a RELAP5 code, and more than 55 sets of calculation
13 were performed.

14 And because of all the effort, we were be
15 able to resolve a lot of the, you know, audit issues.
16 So we can zoom in to the RAIs, like total questions
17 are only 45. Those are the confirmatory analysis.

18 Based on the review, we concluded at the
19 end NuScale LOCA EM model. And RELAP5 version 1.4
20 approved for determining critical heat flux and
21 collapsed liquid level for NuScale NPM in compliance
22 with 10 CFR 50.46 key requirements.

23 And the code is, can be used to determine
24 the peak containment pressure, but with the limitation
25 that they have to apply certain specific peak

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 containment pressure analysis criteria there. And the
2 CHF model is approved, subject to limitations and the
3 conditions for low flow and the high flow conditions.

4 So with that, that's the conclusion of
5 staff's presentation on LOCA topical report. All
6 right.

7 CHAIRMAN SUNSERI: Comments from members?
8 All right, Alex, your turn.

9 MS. SIWY: Is this the one that doesn't
10 work?

11 CHAIRMAN SUNSERI: Yeah, I'm sorry, use
12 the one to your right.

13 MS. SIWY: Okay, all right. My name is
14 Alex Siwy and I'm a Technical Review in the Reactor
15 Systems Branch in NRR. To provide a basic summary of
16 the staff's review process, we conducted our review of
17 the non-LOCA topical report in accordance with the
18 applicable NRC regulations and guidance. Our SER is
19 based on Revision 2 of the topical report.

20 The staff conducted audits similar to what
21 was done for LOCA, two audits in four different phases
22 that covered different topics. We examined about 140
23 different issues as part of the audits, and overall,
24 the audits really helped to confirm the staff's
25 understanding of the docketed information and to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 inform RAIs.

2 In total, we issued 33 RAI questions, and
3 to date all of these have been resolved and responses
4 have been incorporated into the topical report as
5 appropriate.

6 So this slide covers the scope of the non-
7 LOCA methodology, which NuScale covered well in their
8 presentation. I think the thing that I would
9 highlight here is that some of the items that are
10 discussed in the topical report the staff is not
11 making conclusions on as part of the topical report
12 review, because we feel that those items are more
13 appropriate for a design-specific application of the
14 methodology. These include items like the limiting
15 loss of power assumptions and single failures.

16 One of the major areas of staff review
17 were the key design features and models that would be
18 particularly relevant for non-LOCA event analysis.
19 The staff reviewed things like the natural circulation
20 design, the helical coil steam generator models, the
21 DHRS modeling, and the fact that the evacuated
22 containment vessel produces the potential for a new
23 type of event.

24 The staff also extensively reviewed the
25 applicability of NRELAP5 to performing non-LOCA

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 transient analyses. As the applicant discussed, they
2 developed the non-LOCA EM based on the LOCA EM using
3 a grade approach. The staff reviewed the applicant's
4 non-LOCA PIRT to ensure that the important phenomena
5 were identified and appropriately captured in the non-
6 LOCA topical report.

7 And the staff reviewed how the applicant
8 addressed each of the highly ranked non-LOCA
9 phenomena, which included methods such as separate and
10 integral effects tests, code-to-code benchmark, use of
11 bounding input values, as well as other analysis
12 methodologies.

13 Related to this topic was one significant
14 issue that we encountered as part of our review. In
15 particular, the staff requested additional
16 justification for how multidimensional flow effects in
17 the RCS and thermal stratification in the reactor pool
18 are addressed as part of the non-LOCA EM. The staff's
19 major concerns on this topic were the potential for
20 reduced RCS flow rates, as well as degradation in DHRS
21 performance.

22 To summarize, the applicant's RAI response
23 resolved the issue, as was confirmed by the staff
24 audit of underlying calculation notes, as well as
25 audit discussions with the applicant.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The staff reviewed each of the NRELAP5
2 assessments against test data presented in the non-
3 LOCA topical report, as well as a couple that were
4 presented as part of the LOCA topical report. And
5 overall, the staff finds that the KAIST, the NIST HP-
6 03 and HP-04 tests served to validate the NRELAP5 DHRS
7 models.

8 The SIET TF-1 test validated the steam
9 generator secondary side phenomena, but the staff had
10 some concerns about the ability of the SIET TF-2 test
11 to fully validate primary to secondary heat transfer.

12 The NLT2A, 2B, and 15P2 integral effects
13 test together demonstrate the applicability of NRELAP5
14 to evaluate non-LOCA transients. And the benchmark
15 against RETRAN-3D provides confidence that the NRELAP5
16 point kinetics model with the thermohydraulic feedback
17 produces results that are consistent with those of an
18 NRC-approved code.

19 There were a couple of significant review
20 issues related to the assessment against NRELAP5, or
21 assessments of NRELAP5 against test data.

22 In particular, the applicant removed steam
23 generator and DHRS heat transfer biases from the
24 methodology in response to staff questions about the
25 steam generator heat transfer uncertainty based on the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 SIET TF-2 concerns that I mentioned on the previous
2 slide. And this was associated with the DCA Chapter
3 15 UOI, as well as concerns about DHRS nodalization.

4 To address these concerns, the applicant
5 provided justification that non-LOCA figures of merit
6 are not sensitive to these biases. And based on its
7 review of the justification, as well as audits of the
8 underlying calculations, the staff finds that the
9 removal of the DHRS and steam generator heat transfer
10 biases is supported for NPM model Revision 2.

11 But we did impose a related limitation and
12 condition because some of the sensitivities were
13 specific to the particular design at hand.

14 The staff also reviewed the general and
15 event-specific non-LOCA methodology. Overall, the
16 process for analyzing non-LOCA events, including the
17 interfaces with other methodologies, provides an
18 acceptable analysis framework. The staff also finds
19 that the deterministic approach using conservative or
20 bounding inputs, initial conditions, and assumptions
21 is acceptable for conservative calculations of non-
22 LOCA events.

23 In addition, the staff reviewed each of
24 the event-specific methodologies and concluded that
25 the application of those methodologies will ensure

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 conservative results.

2 And finally, the staff reviewed the
3 representative non-LOCA event calculations in Section
4 8 of the topical report and concludes that they
5 adequately illustrate how the non-LOCA methodology can
6 be applied to conservative transient analyses.

7 This slide just summarizes the limitations
8 and conditions found in the staff SER. I won't go
9 through them line by line, but there are six different
10 limitations and conditions.

11 And in conclusion, the staff finds that
12 all technical issues from the course of the review
13 have been resolved and that the use of NRELAP5 with
14 the non-LOCA methodology described in the topical
15 report is acceptable for the non-LOCA safety analyses
16 of the NuScale NPM design, subject to the specified
17 limitations and conditions.

18 CHAIRMAN SUNSERI: Very good, thank you.
19 Members, any questions or comments?

20 MEMBER KIRCHNER: I just would like to
21 thank NuScale and the staff for their very good
22 presentations during our February Subcommittee
23 meetings and their excellent short summaries today.
24 Thank you.

25 CHAIRMAN SUNSERI: Any other comments?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 All right, so we'll ask if there are any members in
2 the room that would like to make a comment. And while
3 we're doing that, if we can open up the phone lines
4 for public comment.

5 MR. PRESSON: Hey, Matthew Presson with
6 NuScale. I wanted to confirm for you that the 100 mil
7 corrosion limit is indeed non-proprietary. So good to
8 use.

9 MEMBER BALLINGER: It's only a 100 -- it's
10 a 100, not 80?

11 MR. PRESSON: That is what was emailed to
12 me, yes.

13 MEMBER BALLINGER: Okay. All right.
14 Eighty has been around for the last 15 years or 20
15 years.

16 CHAIRMAN SUNSERI: All right, there's no
17 comments from the room, so we'll turn to the phone
18 line. If there is a member of the public that is on
19 the phone line that wishes to make a comment, now is
20 your opportunity. Please state your name and provide
21 your comment.

22 MR. LEWIS: Marvin Lewis.

23 CHAIRMAN SUNSERI: Okay, Marvin, we'll
24 take yours first.

25 MR. LEWIS: Wonderful, thank you. Look,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 it sounds reasonable -- saying that it's going to mean
2 that the reactor will operate without problems. But
3 at least the verbiage sounds good. I do have a
4 question, mainly about density waves fluctuate --
5 density wave oscillations.

6 When you get the water hammer and
7 everybody runs out of the nuclear power plant, how do
8 you know there's going to be enough people left to
9 handle the -- resume without emergencies, thank you.

10 CHAIRMAN SUNSERI: Thank you for your
11 comment. Ms. Fields, I think you're next.

12 MS. FIELDS: Yes, this is Sarah Fields.
13 I brought this up at the NuScale Subcommittee meeting
14 a few days ago. I do not understand how the NRC will
15 be finalizing the draft rule and submitting it to the
16 Commission on March 19, which is two weeks from now.
17 And then the NRC intends to publish rulemaking effort
18 on June 1.

19 There's still a few things to iron out
20 between the ACRS, NuScale and the NRC that have been
21 discussed over the past few days. The ACRS won't
22 finalize their -- or submit their final letter until
23 June 23, I believe. And then the NRC staff won't
24 finalize the SER until November. And yet the NRC
25 appears to be going ahead with this rulemaking as if

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 all the T's have been crossed and the I's have been
2 dotted, which they haven't.

3 So I think the NRC's schedule for this
4 rulemaking is rather premature. Also, there really is
5 no rush. The prospective COL applicant, the only
6 prospective applicant, is the Utah Associated
7 Municipal Power Systems, or UAMPS.

8 The type of reactor that UAMPS intends to
9 construct and operate would have 25 more percent power
10 than the current NuScale design. Therefore, UAMPS
11 must wait until the NuScale -- after NuScale submits
12 its standard design approval application, which would
13 include that 25% power increase, before they could
14 submit their COL application to the NRC. And the
15 NuScale SDA application's not expected until the
16 latter part of 2021.

17 So basically, there really is no COL
18 applicant out there who will be submitting an
19 application specifically referencing this design
20 certification. So I just wanted to put that out
21 there. I think that the public should be able to wait
22 until all ACRS and NRC staff documents related to this
23 design certification are complete before the
24 rulemaking. Thank you.

25 CHAIRMAN SUNSERI: Thank you. Any other

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 members of the public on the phone line that wish to
2 make a statement? Okay, we will close the phone line
3 at this point, thank you. And we're at a transition
4 point here. Let me poll the Committee here. Do we
5 see the need for a closed session to talk to staff or
6 NuScale about any proprietary information?

7 MEMBER MARCH-LEUBA: I recommend that we
8 go into closed session to read the letters for
9 proprietary content, so NuScale can tell us they're
10 not proprietary. And then we go back to open session
11 to discuss them.

12 VICE CHAIRMAN REMPE: But we should be all
13 done with the transcriber.

14 CHAIRMAN SUNSERI: Yeah, we can do that --

15 MEMBER MARCH-LEUBA: Off the transcript.

16 CHAIRMAN SUNSERI: Yeah, off the. Well,
17 we're going off the record anyway at this point in
18 time. So I think we'll proceed along that, those
19 lines. Walt, is that okay with you?

20 All right, so we are going to go off the
21 record at this point in time. The next time we will
22 be on is at 10:45 tomorrow morning when we'll look at
23 the biannual review of the Nuclear Safety Research
24 Program.

25 We are going into closed session now for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 report writing --

2 VICE CHAIRMAN REMPE: Matt, say again what
3 you said. We're not going to have any more
4 transcribers, right, for the rest of this session or
5 this meeting? Because we're not going to need a
6 transcriber for that or for P&P. P&P's public, but --

7 CHAIRMAN SUNSERI: Well, I don't know
8 about transcribers, I'm just talking about open
9 session.

10 MEMBER MARCH-LEUBA: We'll stay have a
11 transcriber. You need to put your microphone on.

12 VICE CHAIRMAN REMPE: P&P is open.

13 CHAIRMAN SUNSERI: Okay, we are going
14 closed.

15 (Whereupon, the above-entitled matter went
16 off the record at 2:07 p.m.)

17

18

19

20

21

22

23

24

25

February 28, 2020

Docket No. 52-048

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
One White Flint North
11555 Rockville Pike
Rockville, MD 20852-2738

SUBJECT: NuScale Power, LLC Submittal of Presentation Materials Titled “ACRS Full Committee Presentation: NuScale – Steam Generator Design,” PM-0220-69051, Revision 0

The purpose of this submittal is to provide presentation materials to the NRC for use during the upcoming Advisory Committee on Reactor Safeguards (ACRS) NuScale Full Committee Meeting on March 5, 2020. The materials support NuScale’s presentation of the NuScale steam generator design.

The enclosure to this letter is the nonproprietary presentation titled “ACRS Full Committee Presentation: NuScale – Steam Generator Design,” PM-0220-69051, Revision 0.

This letter makes no regulatory commitments and no revisions to any existing regulatory commitments.

If you have any questions, please contact Marty Bryan at 541-452-7172 or at mbryan@nuscalepower.com.

Sincerely,



Zackary W. Rad
Director, Regulatory Affairs
NuScale Power, LLC

Distribution: Robert Taylor, NRC, OWFN-8H12
Michael Snodderly, NRC, OWFN-8H12
Christopher Brown, NRC, OWFN-8H12
Gregory Cranston, NRC, OWFN-8H12
Michael Dudek, NRC, OWFN-8H12
Bruce Baval, NRC, OWFN-8H12

Enclosure: “ACRS Full Committee Presentation: NuScale – Steam Generator Design,” PM-0220-69051, Revision 0

Enclosure:


“ACRS Full Committee Presentation: NuScale – Steam Generator Design,” PM-0220-69051,
Revision 0

ACRS Full Committee Presentation

NuScale

Steam Generator Design

March 5, 2020



Presenters

Kevin Spencer

Engineer, NSSS Engineering

Bob Houser

Manager, Testing and Code Development

Brian Wolf

Supervisor, Code Development




Marty Bryan

Licensing Project Manager


Agenda

- Steam Generator Design
- DCA Revisions


Steam Generator Design



Steam Generator Inlet Flow Restrictor



IFR in Tubesheet



Inlet Flow Restrictor (IFR)

Steam Generator Design

- **Integral Helical Coil SG Design features**
 - Shell side is primary side - Tube side is secondary side
 - Alloy 690 TT (1380 tubes, 74 – 86 ft long, 5/8” OD)
 - Low flow in primary (~1ft/sec)
 - Tube wall degradation allowance (0.010” > ASME min wall)
 - Support 100% volumetric inspection
 - Normal access to shell side of tubes from below during refueling
- **Steam Generator Program and In-service Inspections**
 - Follow guidance of NEI 97-06 & EPRI (COL Item 5.4-1: Develop and implement a SG Program)
- **SG is designed with a flow restrictor at tube inlet to reduce the potential for density wave oscillations (DWO)**

DCA Revisions

- An Action Item has been established for the Combined License applicant (COL Item 3.9-14)

A COL applicant that references the NuScale Power Plant design certification will develop an evaluation methodology for the analysis of secondary-side instabilities in the steam generator design. This methodology will address the identification of potential density wave oscillations in the steam generator tubes, and qualification of the applicable portions of the reactor coolant system integral reactor pressure vessel and steam generator given the occurrence of density wave oscillations, including the effects of reverse fluid flows within the tubes.

DCA Revisions (cont'd)

- FSAR Section 3.9 has been revised and establishes a COL Item for development of an evaluation methodology for analysis of secondary side instabilities.
- FSAR Section 5.4 clarifies language related to secondary side instabilities.

NuScale Conclusion

- The successful completion of ITAAC and the COL Item constitutes the basis for the NRC determination to allow operation of a facility certified under 10 CFR 52

Portland Office

6650 SW Redwood Lane,
Suite 210
Portland, OR 97224
971.371.1592

Corvallis Office

1100 NE Circle Blvd., Suite 200
Corvallis, OR 97330
541.360.0500

Rockville Office

11333 Woodglen Ave., Suite 205
Rockville, MD 20852
301.770.0472

Richland Office

1933 Jadwin Ave., Suite 130
Richland, WA 99354
541.360.0500

Charlotte Office

2815 Coliseum Centre Drive,
Suite 230
Charlotte, NC 28217
980.349.4804



<http://www.nuscalepower.com>

Twitter: @NuScale_Power



Backup Material

ITAAC Closure Path for DWO

- Resolution of DWO is to be achieved through ITAAC activities related to the steam generator
- Tier 1 Table 2.1-2 defines the NuScale Power Module (NPM) ASME Code Class 1, 2, 3, and CS components that comply with ASME Code Section III requirements including:

| Equipment Name | ASME Code Section III |
|---------------------------------|-----------------------|
| RCS Integral RPV/SG/Pressurizer | 1 |

- Number 02.01.01 specifies that “each ASME Code Class 1, 2, and 3 component (including piping systems) of a nuclear power plant requires a Design Report in accordance with NCA-3550”

ITAAC Closure Path for DWO (continued)

- An ITAAC inspection is performed of the NuScale Power Module “ASME Code Class 1, 2, 3, and CS as-built component Design Reports to verify that the requirements of ASME Code Section III are met”
- From Subsection NCA of the 2013 Edition of the ASME Code –
 - NCA-2142.2 requires that Design Specifications identify all loadings (e.g. pressure, temperature, mechanical loads, cycles, and/or transients) and the service limits a component will experience
 - Loading combinations for the RPV (including SG tubes) defined in Table 3.9-3 of DCA
 - Transient (TH) loads are based on time history of design basis transients, described in DCA Section 3.9.1.
 - NCA-3254 and 3255 provide additional information about design specifications
 - NCA-3260 requires that the Design Report evaluate the loads as defined in the design specification



NRC Review of NuScale Steam Generator

NuScale Design Certification Application

ACRS Full Committee Meeting
March 5, 2020

(Open Session)

Agenda

- NRC Staff Review Team
- Summary of Review of Steam Generator (SG) Materials, Design, and Inspection
- Summary of SG Design Issue Not Resolved by Design Certification Application (DCA)
 - Safety Significance
 - Method of Analysis
 - Appendix G to 10 CFR Part 52

NRC Staff Review Team

- Technical Reviewers:
 - Gregory Makar, materials engineering
 - Leslie Terry, materials engineering
 - Yuken Wong, mechanical engineering
 - Peter Yarsky, Office of Research
 - Raymond Skarda, Office of Research
 - Carl Thurston, reactor systems
 - Kaihwa Hsu, mechanical engineering
 - Steven Hambric (consultant)

- Project Management:
 - Marieliz Johnson
 - Bruce Bavol

- Technical Management:
 - Thomas Scarbrough, mechanical engineering
 - Rebecca Patton, reactor systems
 - Steven Bloom, materials engineering

NuScale Steam Generator

SER Sections 5.4.1 and 5.4.2

SG Materials, Design, and Inspection

FINDING: SG Materials and SG Program meet applicable requirements for most review areas:

- Materials acceptable with respect to selection, fabrication, testing, and inspection
- Design limits crevice areas along tubes
- Primary and secondary water chemistry acceptable (based on industry guidelines)
- Design provides primary and secondary access for inspection and for removal of corrosion products and foreign objects

SER Sections 5.4.1 and 5.4.2 SG Materials, Design, and Inspection

FINDING: SG Materials and SG Program meet applicable requirements for most review areas:

(Continued)

- SG Program based on applicable industry guidelines and consistent with the Standard Technical Specifications
- Generic tube plugging criterion determined in accordance with applicable guidance
- Combined License (COL) applicant will develop and implement an SG Program and provide corresponding plant-specific information

SER Sections 5.4.1 and 5.4.2 SG Materials, Design, and Inspection

SG DESIGN – Secondary Flow Oscillations

- NRC staff considers design demonstration of structural and leakage integrity for SG tubes to be incomplete for DCA including:
 - Ability of SG tubes to maintain structural and leakage integrity during density wave oscillation (DWO) in SG secondary fluid system
 - Method of analysis to predict thermal-hydraulic conditions and loads of SG secondary fluid system
- NuScale is working to demonstrate SG tube integrity subsequent to design certification

Regulatory Process for Incomplete SG Tube Integrity

- NRC staff is proposing to specify structural and leakage integrity of SG tubes as not resolved and not receiving finality in NRC draft proposed rule for NuScale design certification.
- Appendix G to 10 CFR Part 52, Section VI, “Issue Resolution,” is being proposed to clarify that SG tube integrity is not resolved within the meaning of §52.63(a)(5)
- Section IV, “Additional Requirements and Restrictions,” is being proposed to state that COL applicant is responsible for providing design information to address SG tube integrity.
- Draft proposed rule currently in concurrence process prior to being provided to the Commission for approval.

SG Secondary Fluid System Method of Analysis


- DCA Part 2, Tier 2, Section 3.9.1.2 states that it lists computer programs used by NuScale for dynamic and static analyses and hydraulic transient load analyses.
- Section 3.9.1.2 does not include the method of analysis to appropriately predict thermal-hydraulic conditions and loads of SG secondary fluid system.
- In demonstrating SG tube integrity, COL applicant will need to provide information demonstrating that 10 CFR Part 50, Appendix A, GDC 4, is met for the method of analysis to predict thermal-hydraulic conditions of SG secondary fluid system and resulting loads, stresses, and deformations from DWO.

Demonstration of SG Tube Integrity

- NuScale has not provided reasonable assurance that flow oscillations that occur in SG secondary fluid system will not cause damage to SG tubes directly from DWO or indirectly by inlet flow restrictors (IFRs).
- COL applicant will need to provide information demonstrating that 10 CFR Part 100 and Part 50, Appendix A, GDC 4 and 31, are met with respect to structural and leakage integrity of SG tubes that might be compromised by adverse effects from DWO in SG secondary fluid system.

DWO Phenomenon

- TF-2 testing involved a full scale mock-up of 252 tubes.
- DWO was observed during TF-2 testing with temperature and flow oscillations in the secondary coolant.
- DWO frequency during TF-2 testing did not excite SG tube structural resonances.




Alloy 690 (Ni-Cr-Fe)

- TF-2 alternating stress intensities for instrumented TF-2 tubes were below fatigue endurance limit, although TF-2 geometry, materials, and operating conditions might not be conservative compared to as-built SG.
- As discussed on the next slides, the staff is concerned about the potential impact of DWO on the SG tubes directly and indirectly by the IFRs.

SG Inlet Flow Restrictor

- SG Inlet Flow Restrictor (IFR) designed to provide necessary pressure drop to limit DWO in the SG tubes.
- Staff evaluated leakage flow instability (LFI) between IFRs and SG tubes during forward flow test (separate from TF-2) and did not identify any concerns.
- However, testing did include DWO conditions.
- NuScale has not validated the final IFR design.



SG Inlet Flow Restrictor – DWO Concerns

- Unstable DWO could cause reverse flow through IFRs
 - Subcooled liquid for modest DWO
 - Slug and two-phase flow for strong DWO
- NuScale has not yet evaluated the potential impacts on SG tubes and IFRs for reverse flow such as:
 - Fatigue of bolted joints, and loose IFR parts
 - LFI in that cantilevered IFRs are less stable under reverse flow
 - Cyclic pressure drops
 - High speed turbulent two-phase flow
 - Cavitation erosion of SG tube walls
 - Wear of IFRs and/or tube walls that could further worsen stability

Post-Design Certification

- COL Applicant will address SG tube integrity in the COL application as follows:
 - Provide validated SG secondary fluid system flow thermal-hydraulic method of analysis
 - Demonstrate that SG tubes will not be damaged by DWO directly or indirectly by IFRs
- COL Holder will verify SG construction including:
 - Complete ITAAC on Tier 1 Table 2.1-4 (#1) to confirm that ASME BPV Code Class components designed to ASME BPV Code Section III
 - Implement Comprehensive Vibration Assessment Program (CVAP) – COL Item 3.9-1
 - Satisfy Tier 1, TF-3 flow testing requirement, and Tier 2, Table 14.2-72 SG flow-induced vibration testing
 - Instrument one tube in initial startup SG testing with strain gages at top, middle, and bottom, for FIV evaluation

Next Steps

- NuScale is preparing errata for Revision 4 to DCA to clarify SG secondary fluid flow issues that could impact SG tubes and IFRs.
- NRC staff discusses SG tube integrity, including SG secondary flow method of analysis, in the draft proposed rule for NuScale design certification to be provided for Commission approval.
 - Draft proposed rule excludes SG tube integrity from finality.
 - NRC staff will address SG tube integrity as part of a NuScale COL application review.
- Other aspects of the NuScale SG design are acceptable to the NRC staff and would be granted finality.

Questions?

March 4, 2020

Docket No. 52-048

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
One White Flint North
11555 Rockville Pike
Rockville, MD 20852-2738

SUBJECT: NuScale Power, LLC Submittal of Presentation Materials Entitled “ACRS Full Committee Presentation: NuScale Topical Report – Rod Ejection Accident Methodology,” PM-0320-69146, Revision 0


The purpose of this submittal is to provide presentation materials to the NRC for use during the upcoming Advisory Committee on Reactor Safeguards (ACRS) NuScale Full Committee Meeting on March 5, 2020. The materials support NuScale’s presentation of the “Rod Ejection Accident Methodology” topical report.

The enclosure to this letter is the nonproprietary presentation entitled “ACRS Full Committee Presentation: NuScale Topical Report – Rod Ejection Accident Methodology,” PM-0320-69146, Revision 0.

This letter makes no regulatory commitments and no revisions to any existing regulatory commitments.

If you have any questions, please contact Matthew Presson at 541-452-7531 or at mpresson@nuscalepower.com.

Sincerely,



Zackary W. Rad
Director, Regulatory Affairs
NuScale Power, LLC

Distribution: Robert Taylor, NRC, OWFN-8H12
Michael Snodderly, NRC, OWFN-8H12
Christopher Brown, NRC, OWFN-8H12
Samuel Lee, NRC, OWFN-8H12
Gregory Cranston, NRC, OWFN-8H12
Michael Dudek, NRC, OWFN-8H12
Rani Franovich, NRC, OWFN-8H12

Enclosure: “ACRS Full Committee Presentation: NuScale Topical Report – Rod Ejection Accident Methodology,” PM-0320-69146, Revision 0

Enclosure:


“ACRS Full Committee Presentation: NuScale Topical Report – Rod Ejection Accident Methodology,” PM-0320-69146, Revision 0

ACRS Full Committee Presentation

NuScale Topical Report

Rod Ejection Accident Methodology

March 5, 2020



Presenters


Kenny Anderson
Nuclear Fuels Analyst

Matthew Presson
Licensing Project Manager

Opening Remarks – NuScale T/H Methods

System T/H Analysis Basis

- NRELAP5 code developed from RELAP5-3D
 - Modified to address NuScale-specific phenomena/systems
- LOCA Evaluation Model (EM) developed following RG 1.203 EMDAP
 - LOCA EM extended to derive EMs for other events as shown in this figure.
 - LOCA EM assessment basis leveraged for non-LOCA.
- Additional supporting EMs include
 - Nuclear Analysis Codes – TR-0716-50350-P-A
 - Critical Heat Flux – TR-0116-21012-P-A
 - Subchannel Analysis – TR-0915-17564-P-A



Agenda

- Event Overview
- Acceptance Criteria
- PCMI Criteria – DG-1327
- Method Flowchart
- Steady State Initialization
- Event Evaluations
- Summary

Overview

- NuScale seeks approval of methodology for modeling rod ejection accident (REA) events
- Bounding reactivity initiated accident (RIA) from General Design Criteria (GDC) 28
- REA is unique in comparison to other Ch. 15 events

| Description | Rod Ejection | Other Events |
|---------------------|---|--------------------------|
| Dominant Physics | Nuclear | Thermal-Hydraulics |
| Timing | milli-sec | sec to hr |
| Spatially | Local | Global |
| Peak power | ~5x Full Power | ~1.2x Full Power |
| Integrated Energy | Low | Low to High |
| Postulated Cause | Failure of ASME Class 1 Pressure Boundary | Single Equipment Failure |
| Acceptance Criteria | Specialized | Generic |



Unique Event Acceptance Criteria

| Criteria Description | Topical Section | Unique? |
|--|-----------------|---------|
| Maximum reactor coolant system pressure | 5.3 | No |
| Hot zero power (HZP) fuel cladding failure | 5.5.2 | Yes |
| FGR effect on cladding differential pressure | N/A | Yes |
| Critical heat flux (CHF) fuel cladding failure | 5.4.1 | No |
| Cladding oxidation-based PCMI failure | 5.5.3 | Yes |
| Cladding excess hydrogen-based PCMI failure | N/A | Yes |
| Incipient fuel melting cladding failure | 5.5.1 | No |
| Peak radial average fuel enthalpy for core cooling | 5.5.2 | Yes |
| Fuel melting for core cooling | 5.5.1 | No |
| Fission product inventory (failed fuel census) | 5.6 | Yes |


- Submitted NuScale design and method inherently precludes fuel failure, thus no accident radiological consequences are evaluated.
- PCMI: Pellet-Clad Mechanical Interaction

Revised PCMI Criteria

- In general, the NuScale REA methodology has adopted the limiting criteria of the 'Clifford Letter' (ML14188C423), now included in draft guide DG-1327 (ML16124A200). In spirit, NuScale is prepared for this regulatory change:
 - Closed session presents example results, showing large margins for enthalpy rise
 - A technical 'formality' inhibits complete adoption at this time. NuScale does not currently have a validated cladding H₂ model to convert local exposure to excess cladding hydrogen
 - Oxidation criteria from NUREG-0800 Section 4.2, Appendix B (ML07074000) is used
 - To simplify method, no exposure is credited (Limit: 75 Δ cal/gm)
 - NuScale M5 cladding less susceptible than other zirc alloy-type clad used in the industry



Unique Event Method (Flowchart)



Steady-State Initialization

- SIMULATE5: Setup the core response analysis
- Code shown to be appropriate in TR-0616-48793-A (Nuclear Analysis Codes and Methods Qualification)
- Determination of the worst rod stuck out (WRSO)
 - Assumption bounds potential for ejected assembly to damage adjacent control rod assembly
 - Due to rapid nature of the event, location does not significantly affect the results in NuScale application




Dynamic Core Response

- SIMULATE-3K: Model transient core response
- Benchmarked to SPERT-III experiment and NEACRP computational benchmark
 - Benchmarks demonstrate the combined transient neutronic, thermal-hydraulic, and fuel pin modeling capabilities
 - SIMULATE-3K results generally in excellent agreement with the results from the two benchmark problems
- Uncertainties applied for each simulation:
 - Delayed Neutron Fraction
 - Ejected Rod Worth
 - Doppler Temperature Coefficient
 - Moderator Temperature Coefficient

CHF Evaluation

- VIPRE-01: Model detailed thermal-hydraulics
- Evaluate critical heat flux (CHF) acceptance c
- Code shown to be appropriate in TR-0915-17: Analysis Methodology)
- Unique event differences in method:
 - Smaller axial nodalization (smaller time steps)
 - Radial power distribution (case-specific)
 - Axial power distribution (peak assembly)
 - Convergence parameters
- Additional parametric sensitivity cases pe application to holistically justify difference




Adiabatic Fuel Heatup

- Hand-Calculation: Model fuel response
- Total energy (from SIMULATE-3K) during the transient is integrated
- Conservative as no energy is allowed to leave the fuel rod
- Energy is then converted into either a temperature or enthalpy increase
- Fuel rod geometry, heat capacity, and power peaking factors taken into account
- Calculated values compared to NRC developed acceptance criteria
 - Example values provided in closed session

Dynamic System Response I

- NRELAP5: Evaluate system response for input to CHF Evaluation
- Code shown to be appropriate in TR-0516-49416 (Non-LOCA Methodologies)
- Transient power from SIMULATE-3K utilized as input
 - No reactivity calculation performed in NRELAP5
- Provides system thermal-hydraulic conditions to subchannel (CHF) evaluation
 - System flow, pressure, and inlet temperature
 - ‘Screens’ cases for potential to be limiting
 - Family of limiting cases evaluated with VIPRE-01



Dynamic System Response II

- NRELAP5: Evaluate system response for pressurization
- Limiting scenario: Low ejected worth that raises the power quickly to just below both the high power and high power rate trip 'setpoints'
- Point-kinetics model used based on bounding static worth
- Peak system pressure calculated compared to acceptance criteria
- Example results to be presented in closed session

Summary

- A conservative analysis method for the unique rod ejection accident
- Topical report provides details and justification for:
 - Software tools and acceptance criteria used
 - Applicability of the method and tools
 - Appropriate treatment of uncertainties
- Results from application of the method provide input to FSAR Chapter 15

Acronyms

- **CHF – Critical Heat Flux**
- **GDC – General Design Criteria**
- **HZP – Hot Zero Power**
- **MCHFR – Minimum Critical Heat Flux Ratio**
- **NEACRP – Nuclear Energy Agency
Committee on Reactor Physics**
- **PCMI – Pellet Clad Mechanical Interaction**
- **REA – Rod Ejection Accident**
- **RIA – Reactivity Initiated Accident**
- **WRSO – Worst Rod Stuck Out**

Portland Office

6650 SW Redwood Lane,
Suite 210
Portland, OR 97224
971.371.1592

Corvallis Office

1100 NE Circle Blvd., Suite 200
Corvallis, OR 97330
541.360.0500

Rockville Office

11333 Woodglen Ave., Suite 205
Rockville, MD 20852
301.770.0472

Richland Office

1933 Jadwin Ave., Suite 130
Richland, WA 99354
541.360.0500

Charlotte Office

2815 Coliseum Centre Drive,
Suite 230
Charlotte, NC 28217
980.349.4804



<http://www.nuscalepower.com>

 [Twitter: @NuScale_Power](https://twitter.com/NuScale_Power)



March 4, 2020

Docket No. 52-048

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
One White Flint North
11555 Rockville Pike
Rockville, MD 20852-2738

SUBJECT: NuScale Power, LLC Submittal of Presentation Materials Entitled "ACRS Full Committee Presentation: NuScale Topical Report, Loss-of-Coolant Accident Evaluation Model," PM-0320-69138, Revision 0

The purpose of this submittal is to provide presentation materials to the NRC for use during the upcoming Advisory Committee on Reactor Safeguards (ACRS) NuScale Full Committee Meeting on March 5, 2020. The materials support NuScale's presentation of the "Loss-of-Coolant Accident Evaluation Model" topical report.

The enclosure to this letter is the nonproprietary presentation entitled "ACRS Full Committee Presentation: NuScale Topical Report, Loss-of-Coolant Accident Evaluation Model," PM-0320-69138, Revision 0.

This letter makes no regulatory commitments and no revisions to any existing regulatory commitments.

If you have any questions, please contact Matthew Presson at 541-452-7531 or at mpresson@nuscalepower.com.

Sincerely,



Zackary W. Rad
Director, Regulatory Affairs
NuScale Power, LLC

Distribution: Robert Taylor, NRC, OWFN-8H12
Michael Snodderly, NRC, OWFN-8H12
Christopher Brown, NRC, OWFN-8H12
Samuel Lee, NRC, OWFN-8H12
Gregory Cranston, NRC, OWFN-8H12
Michael Dudek, NRC, OWFN-8H12
Rani Franovich, NRC, OWFN-8H12

Enclosure: "ACRS Full Committee Presentation: NuScale Topical Report, Loss-of-Coolant Accident Evaluation Model," PM-0320-69138, Revision 0

Enclosure:

“ACRS Full Committee Presentation: NuScale Topical Report, Loss-of-Coolant Accident Evaluation Model,” PM-0320-69138, Revision 0

ACRS Full Committee Presentation

NuScale Topical Report

Loss-of-Coolant Accident Evaluation Model

March 5, 2020



Presenters

Matthew Presson

Licensing Project Manager

Dr. Pravin Sawant

Supervisor Code Validation and Methods

Dr. Selim Kuran

Thermal Hydraulic Analyst

Ben Bristol

Supervisor System Thermal Hydraulics

Agenda

- Methodology Overview
 - Background
 - Regulatory Requirements
 - Methodology Roadmap
- NPM Safety Systems Overview
- Element 1: PIRT
- Element 2: Assessment Base
- Element 3: NRELAP5 Evaluation Model
- Element 4: Applicability Evaluation
- Extension of LOCA EM to IORV
- Conclusions

Background


- Unique NPM Design Features
 - Integrated design eliminates piping and limits potential breaks
 - Coolant captured completely in containment, cooled and returned to RPV using a large pool as ultimate heat sink
- Simple LOCA Progression with Well-Known Phenomena
 - Choked/un-choked flow through break and ECCS valves
 - Core decay heat and RCS stored energy release
 - CNV heat transfer to pool (condensation, conduction, convection)
- EM Development Approach
 - Follows Regulatory Guide 1.203 EMDAP (Table 2-1)
 - Compliance with 10 CFR 50.46 and Appendix K requirements (Table 2-2)

Regulatory Requirements

- 10 CFR 50.46 Acceptance Criteria
 - Max. clad temperature < 2200 °F
 - Cladding oxidation > 0.17 times thickness
 - Hydrogen generation < 0.01 times total hydrogen from oxidation of all cladding
 - Core remains amenable to cooling
 - Long-term cooling maintained
- Maximum PCT at steady state, no clad heat up
- Conservative LOCA EM Acceptance Criteria (FOMs)
 - Core remains covered: collapsed level > TAF
 - MCHFR > CHFR Limit (1.29)
 - Containment pressure and temperature below design limit


Methodology Roadmap

- 10 CFR 50.46 Appendix K Compliance (Section 2.2.3 of LTR)
- RG 1.203 EMDAP (Section 2.1 of LTR)



NPM Safety Systems

- ECCS
 - Opens a boiling/condensing circulation flow path to transfer decay and residual heat to reactor pool
 - Reactor Recirculation Valves (RRV): 2 valves
 - Reactor Vent Valves (RVV): 3 valves
 - Actuation Signals: High CNV level, 24-hour loss of AC power
 - Fail safe: ECCS trip valves open on loss of DC power
- Inadvertent Actuation Block (IAB)
 - Prevents inadvertent opening of ECCS valves at high RCS pressure
 - Actuation based on differential pressure between RPV and CNV
- Module Protection System (MPS)
 - Reactor scram
 - Steam Generator (SG) and Containment (CNV) Isolation
 - Passive safety system activation (ECCS and DHRS)
- Decay Heat Removal System (DHRS)
 - Passive, boiling-condensation system
 - Removes heat from RCS through SG via two trains
 - Each trains capable of removing 100% decay heat
 - Not credited in LOCA EM



Element 1


PIRT

PIRT Process


- Assessment of relative importance of phenomena
 - Unique phases
 - Key components
- PIRT panel included recognized experts and NuScale subject matter experts
 - State-of-knowledge, design description, LOCA description, NRELAP5 calculations
- Figures-of-Merit
 - CHF, Collapsed level above top of the active fuel, CNV P & T
- Rankings
 - Importance: High, Low, Medium, Inactive
 - Knowledge: Well known (small uncertainty), Known (moderate uncertainty, partially known (large uncertainty), very limited

Spatial and Temporal Decomposition

- Phenomena identified for Systems, Structure, Components (SSCs) and LOCA phases
 - Phase 1a: Blowdown
 - Phase 1b: ECCS activation (opening)



System/Subsystem/Module decomposition



Distinct phases of a typical NPM LOCA

Element 2

Assessment Base



NRELAP5 Code

- RELAP5-3D© v4.1.3 used as a baseline code
 - Two-fluid model (thermal and mechanical non-equilibrium) for hydrodynamics with
 - Non-condensable gases with gas phase
 - Semi-implicit scheme for time integration
 - Heat conduction across 1D geometries (slab, cylinder, sphere)
 - Neutron Kinetics with thermal hydraulic feedback
 - Special Process Models
 - Comprehensive control/trip system modeling
- Code configuration control and development consistent with NuScale's NQA-1 2008 / 2009a QA program
- Modifications for NRELAP5:
 - NuScale specific components (e.g., helical coil SG)
 - Regulatory requirements (i.e., Appendix K)
 - Error correction

IET and SET Data

- Extensive database with adequate coverage of all high-ranked phenomena
- Integral effects tests (IET)
 - Six (6) NIST-1 tests
- Separate effects tests (SET)
 - Two (2) NIST-1 SETs
 - Four (4) other NuScale SETs
 - Nine (9) Legacy SETs

NIST-1 Facility



- Primary source of NuScale-Specific IET and SET data
- Design Features
 - Integral Reactor Vessel with electrically heated rod bundle core, helical coil steam generator, and pressurizer
 - Containment with HTP and Cooling Pool
 - DHRS, ECCS, CVCS lines represented
 - ~700 instruments
- Scaling Basis
 - Power/Volume Scaling
 - Reduced height and reduced volume scale
 - Full Pressure and Temperature
 - Same Time Scale (isochronicity)

Element 3

NRELAP5 NPM LOCA

NPM LOCA Model Overview

- Analysis and Justifications
 - NRELAP5 model nodalization and input options
 - Time-step control
 - Initial and boundary condition biases
 - Treatment of setpoints and trips
- LOCA break spectrum
 - Break location and sizes
 - Single failures
 - Power availability
- Methodology sensitivity calculations
 - Required by Appendix K
 - Phenomena-specific
 - To establish conservative biases

Element 4

Applicability Evaluation

Applicability Evaluation

- Evaluated models and correlations (bottom-up)
 - Identified dominant models/correlations for ‘H’ phenomena (Table 8-1 of LTR)
 - Identified key model/correlation parameters and phenomenological domain where models/correlations are used (Tables 8-2 and 8-4)
 - Reviewed models/correlations (Table 8-18 of LTR)
 - Pedigree, Applicability range, Fidelity to SET data, Scalability
- Evaluated integral performance of EM (top-down)
 - Reviewed code governing equations and numerics
 - Evaluated integral performance of code using IET data (Table 8-19 of LTR)
 - Evaluated IET data applicability and NRELAP5 scalability
 - Scaling and distortion analysis
 - Differences and distortions between NPM and NIST can be accounted using NRELAP5

Conclusions

- Number of conservatisms built into the NuScale LOCA EM
 - 10 CFR 50 Appendix K
 - Other methodology conservatisms
- Cycle independent bounding LOCA analysis
- Supported by extensive experiment database, well qualified code, and several sensitivity calculations
- Applicability evaluation consistent with RG 1.203
- CHF not challenged
- Collapsed level in RPV remains above TAF
- No clad or fuel heat-up
- CNV P&T remain below design limits

Appendix B to LOCA LTR

Extension to IORV Event

IORV Background

- LOCA EM Extended to IORV
 - Liquid space (RRV) and steam space (RVV, RSV) discharge
 - Similar transient phenomena and progression
- EM Development Approach
 - Compliance with DSRS for NuScale SMR Design 15.6.6
 - Follows RG 1.203 EMDAP
 - Element 1 (PIRT), Element 2 (Assessment), and Element 4 (Applicability) remains same as LOCA EM
 - Initial LOCA PIRT addressed IORV
 - Element 3 (NRELAP5 Model) unique due to event classification

Differences from LOCA EM

- Minor methodology differences given AOO classification
- Key Acceptance Criteria
 - $MCHFR \geq \text{Limit}$ (≥ 1.13 high flow range, ≥ 1.37 low flow range)
- Conservatisms same as LOCA with exceptions:
 - Fuel properties still biased to maximize stored energy, but additional 15% bias removed
 - Limiting axial power shapes and radial peaking based on subchannel analysis
 - Moody choked flow model for 2-phase flow choking applied to initiating valve
 - Initial conditions biased to minimize MCHFR

Conclusions

- IORV is an extension of LOCA EM given similar transient phenomena and progression
 - PIRT, Assessment, and Applicability same as LOCA
- Minor methodology differences for AOO classification
 - Focused on conservative CHF evaluation
- MCHFR occurs early in transient, then rapidly rises given increasing flow to power ratio
- Collapsed level in RPV remains above TAF

Acronyms

| | | | |
|-------|---|-------------------------|---|
| 1-D | one-dimensional | HP | high pressure |
| 3D | three-dimensional | HS | heat sink |
| AC | alternating current | HTP | heat transfer plate |
| ANS | American Nuclear Society | H2TS | hierarchical two-tiered scaling |
| CCFL | counter current flow limitation | IAB | inadvertent actuation block |
| CHF | critical heat flux | IET | integrated effects test |
| CNV | containment vessel | INL | Idaho National Laboratory |
| CVCS | chemical and volume control system | KATHY | Karlstein thermal-hydraulic test facility |
| DC | direct current | kW | kilowatt |
| DCA | Design Certification Application | LOCA | loss-of-coolant accident |
| DHRS | decay heat removal system | LTR | Licensing Topical Report |
| ECCS | emergency core cooling system | Max | maximum |
| EM | evaluation model | MCHFR | minimum critical heat flux ratio |
| EMDAP | evaluation model development and assessment process | Min | minimum |
| FW | feedwater | Mlb/ft ² ·hr | pounds mass per square foot per hour |
| FSAR | Final Safety Analysis Report | MPS | module protection system |
| FOM | figure of merit | MSIV | main steam isolation valve |
| HL | hot leg | NIST-1 | NuScale Integral System Test Facility |
| | | NPM | NuScale Power Module |

Acronyms

| | |
|-------|--|
| P&T | pressure and temperature |
| PCT | peak cladding temperature |
| PIRT | phenomena identification and ranking table |
| psi | pounds per square inch |
| psia | pounds per square inch absolute |
| PZR | pressurizer |
| QA | Quality Assurance |
| RCS | reactor coolant system |
| RG | Regulatory Guide |
| RRV | reactor recirculation valve |
| RPV | reactor pressure vessel |
| RVV | reactor vent valve |
| SG | steam generator |
| SET | separate effects test |
| SIET | Società Informazioni Esperienze Termoidrauliche |
| StDev | standard deviation |
| TAF | top of active fuel |

March 4, 2020

Docket No. 52-048

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
One White Flint North
11555 Rockville Pike
Rockville, MD 20852-2738

SUBJECT: NuScale Power, LLC Submittal of Presentation Materials Entitled “ACRS Full Committee Presentation: NuScale Topical Report – Non-Loss-of-Coolant Accident,” PM-0320-69141, Revision 0

The purpose of this submittal is to provide presentation materials to the NRC for use during the upcoming Advisory Committee on Reactor Safeguards (ACRS) NuScale Full Committee Meeting on March 5, 2020. The materials support NuScale’s presentation of the “Non-Loss-of-Coolant Accident” topical report.

The enclosure to this letter is the nonproprietary presentation entitled “ACRS Full Committee Presentation: NuScale Topical Report – Non-Loss-of-Coolant Accident,” PM-0320-69141, Revision 0.

This letter makes no regulatory commitments and no revisions to any existing regulatory commitments.

If you have any questions, please contact Matthew Presson at 541-452-7531 or mpresson@nuscalepower.com.

Sincerely,



Zackary W. Rad
Director, Regulatory Affairs
NuScale Power, LLC


Distribution: Robert Taylor, NRC, OWFN-8H12
Michael Snodderly, NRC, OWFN-8H12
Christopher Brown, NRC, OWFN-8H12
Samuel Lee, NRC, OWFN-8H12
Gregory Cranston, NRC, OWFN-8H12
Michael Dudek, NRC, OWFN-8H12
Rani Franovich, NRC, OWFN-8H12

Enclosure: “ACRS Full Committee Presentation: NuScale Topical Report – Non-Loss-of-Coolant Accident,” PM-0320-69141, Revision 0

Enclosure:

“ACRS Full Committee Presentation: NuScale Topical Report – Non-Loss-of-Coolant Accident,”
PM-0320-69141, Revision 0

ACRS Full Committee Presentation



NuScale Topical Report Non-Loss-of-Coolant Accident

March 5, 2020

Presenters

Ben Bristol

Supervisor, System Thermal Hydraulics

Meghan McCloskey

Thermal Hydraulic Analyst

Matthew Presson

Licensing Project Manager

Paul Infanger

Licensing Specialist

Outline

- Scope of non-LOCA LTR
- Non-LOCA events
 - Events and acceptance criteria
 - Interface to other methodologies
 - Factors controlling margin to acceptance criteria
- Development of non-LOCA EM
 - PIRT and gap analysis
 - Focus of NRELAP5 validation for non-LOCA
- General event analysis methodology
- Specific event analysis

Scope of Non-LOCA Topical Report

In Scope

- NRELAP5 system transient analysis of non-LOCA events
- Interface to subchannel and accident radiological analysis
- Short-term transient progression with DHRS cooling

Out of Scope

- SAFDLs evaluated in downstream subchannel analysis
- Accident radiological dose analysis
- Control rod ejection
- LOCA and valve opening events
- Peak containment pressure/temperature analysis
- Long term transient progression with DHRS
 - Riser uncover
 - Return to power

Non-LOCA EM

EM applicable to NuScale Power Module plant design

Applicable initiating events:

- **Cooldown events**
 - Decrease in FW temperature
 - Increase in FW flow
 - Increase in steam flow
Inadvertent opening of SG relief or safety valve
 - Steam piping failures (postulated accident)
 - *Loss of containment vacuum*
Containment flooding
- **Heatup events**
 - Loss of external load
Turbine trip
 - Loss of condenser vacuum
 - Closure of MSIV
 - Loss of non-emergency AC power
 - Loss of normal FW flow
 - Feedwater system pipe breaks (postulated accident)
 - *Inadvertent operation of DHRS*
- **Reactivity events**
 - Uncontrolled bank withdrawal from subcritical
 - Uncontrolled bank withdrawal at power
 - Control rod misoperation
 - Single rod withdrawal
 - Control rod drop
 - Inadvertent decrease in RCS boron concentration
- **Inventory increase event**
 - CVCS malfunction
- **Inventory decrease events**
 - Small line break outside containment (infrequent event)
 - Steam generator tube failure (postulated accident)


NuScale unique event

Non-LOCA Event Acceptance Criteria

| Description | AOO Acceptance Criteria | Infrequent Event Acceptance Criteria | Accident Acceptance Criteria | Analysis |
|---|------------------------------------|---|---|--------------------------------------|
| Reactor Coolant System Pressure ($P_{\text{design}} = 2100$ psia) | $\leq 110\%$ of Design | $\leq 120\%$ of Design | $\leq 120\%$ of Design | Non-LOCA NRELAP5 |
| Steam Generator Pressure ($P_{\text{design}} = 2100$ psia) | $\leq 110\%$ of Design | $\leq 120\%$ of Design | $\leq 120\%$ of Design | Non-LOCA NRELAP5 |
| Minimum Critical Heat Flux Ratio | $>$ Limit | If limit exceed, fuel assumed failed ⁽¹⁾ | If limit exceed, fuel assumed failed ⁽¹⁾ | Subchannel |
| Maximum Fuel Centerline Temperature | $<$ Limit | If limit exceed, fuel assumed failed ⁽¹⁾ | If limit exceed, fuel assumed failed ⁽¹⁾ | Subchannel |
| Containment Integrity | $<$ Limits (pressure, temperature) | $<$ Limits (pressure, temperature) | $<$ Limits (pressure, temperature) | Containment P/T analysis |
| Escalation of an AOO to an accident (AOO) or Consequential loss of system functionality (IE or accident)? | No | No | No | If other acceptance criteria are met |
| Radiological Dose | Normal Operations | $<$ Limit | $<$ Limit | Normal or Accident radiological |

(1) NuScale safety analysis methodologies developed to demonstrate fuel cladding integrity maintained.

Evaluation Models – General Non-LOCA Approach



Non-LOCA Events - Margin to Acceptance Criteria

Design characteristics governing non-LOCA event transient response and margin to acceptance criteria

- MCHFR: Limited by combination of high power, high pressure, high temperature conditions occurring around time of reactor trip, for reactivity insertion events
- Primary pressure: Protected by RSV lift
- Secondary side pressure: Limited by primary side temperature conditions
- Radiological release: MPS designed to rapidly detect and isolate based on measured conditions
- Establishing a safe, stable condition: MPS designed to trip, actuate DHRS to protect adequate inventory in at least 1 steam generator

Non-LOCA EM Development

- Non-LOCA evaluation model developed to perform conservative analyses, following intent of the RG 1.203 EMDAP and applying a graded approach
- Element 1 – Establish applicable transients and acceptance criteria, develop non-LOCA PIRT
- Element 2, 3, 4
 - Leverage NRELAP5 development, NRELAP5 assessments performed during LOCA evaluation model development.
 - Gap analysis performed to evaluate how high ranked phenomena are addressed
 - Focused on differences in high ranked PIRT phenomena between LOCA and non-LOCA
 - Additional NRELAP5 code validation performed focused on DHRS and integral non-LOCA response
 - Suitably conservative initial and boundary conditions applied for non-LOCA analyses
 - Sensitivity calculations used to demonstrate factors controlling margin to acceptance criteria

Non-LOCA PIRT Development

| Event Types |
|------------------------------|
| Increased heat removal |
| Decreased heat removal |
| Reactivity anomaly |
| Increase in RCS inventory |
| Steam generator tube failure |

| SSCs Considered in PIRT | |
|---------------------------|--------------------------------|
| Reactor coolant system | Main feedwater system |
| Containment vessel | Main steam system |
| Decay heat removal system | Chemical volume control system |
| Reactor pool | Containment evacuation system |

| Phase | Identification | RCS Response | DHRS Operation * | PIRT Figures of merit |
|-------|----------------------------|---|------------------|---|
| 1 | pre-trip transient | higher flow levels at full power levels | inactive | CHFR RCS pressure |
| 2 | post-trip transition | transitional flow levels at transitioned power levels | startup | CHFR RCS, secondary, containment pressures |
| 3 | stable natural circulation | lower flow levels at decay power levels | fully effective | CHFR RCS mixture level Subcriticality |

* If DHRS actuated by protection system

- Different non-LOCA events involve different plant systems and responses
- PIRT developed considering all non-LOCA event types and important SSCs
- Short-term response divided into 3 generic phases with associated FoM

NRELAP5 Applicability for Non-LOCA

After non-LOCA PIRT developed, gap analysis performed to determine how to address high-ranked phenomena:

- Validation performed as part of NRELAP5 assessment for LOCA evaluation model
- Additional validation or benchmark for non-LOCA
- Conservative input
- Subchannel analysis

Key areas identified from gap analysis for short-term non-LOCA analysis:

- DHRS modeling and heat transfer
 - NRELAP5 validation against KAIST tests; NIST-1 SETs HP-03, HP-04
 - NPM sensitivity calculations
- Steam generator modeling and heat transfer
 - NRELAP5 validation against SIET-TF1, SIET-TF2 tests
 - NPM sensitivity calculations
- Reactivity event response
 - NRELAP5 benchmark against RETRAN-3D
- NPM non-LOCA integral response
 - NRELAP5 validation against NIST-1 IETs NLT-2a, NLT-2b, NLT-15p2

Overall conclusion: NRELAP5 code, with NPM system model, is applicable for calculation of the NPM non-LOCA system response

Non-LOCA Analysis Process

Topical report Section 4

1. Develop plant base model NRELAP5 input (geometry, control and protection systems, etc)
2. Adapt NRELAP5 base model as necessary for specific event analysis and desired initial conditions
3. Perform steady state and transient analysis calculations with NRELAP5
4. Evaluate results of transient analysis calculations:
 - Confirm margin to maximum RCS pressure acceptance criterion
 - Confirm margin to maximum SG pressure acceptance criterion
 - Confirm appropriate transient run time execution to demonstrate safe, stabilized condition achieved
5. Identify cases for subchannel analysis and extract boundary conditions (if applicable)
 - Conservative bias directions:
 - Maximum reactor power
 - Maximum core exit pressure
 - Maximum core inlet temperature
 - Minimum RCS flow rate
 - NRELAP5 CHF calculations for dummy hot rod may be used as a screening tool to assist analysts in determining limiting cases to be evaluated in downstream subchannel analysis
6. Identify cases for radiological analysis (if applicable)
 - Maximum mass release case
 - Maximum iodine spiking case

Non-LOCA Methodology

General Methodology (Section 7.1):

- Steady-state conditions
- Treatment of plant controls
- Loss of power
- Single failure
- Bounding reactivity parameter input
- Biasing of other parameters: initial conditions, valve characteristics, analytical limits and response times
- Operator action

Event-specific Methodology (Section 7.2)

- Description of event initiation and progression
- Acceptance criteria ‘of interest’
- Limiting single failure, loss of power scenarios, or need for sensitivity calculations
- Initial condition biases and conservatisms, or need for sensitivity calculations
- Tabulated representative results of sensitivity calculations

Example analysis results provided in Section 8

Conclusions

- Non-LOCA system transient evaluation model developed following a graded approach in accordance with guidance provided in RG 1.203
- Applies to NPM-type plant design natural circulation water reactor with helical coil SG and integral pressurizer
- NRELAP5 used to simulate the system thermal-hydraulic response
 - Demonstrate primary and secondary pressure acceptance criteria are met
 - Demonstrate safe, stabilized condition achieved
- System transient results provide boundary conditions to downstream subchannel and radiological analyses

Presentation to the ACRS Full Committee

Staff Review of NuScale Topical Report

TR-0716-50350, Revision 1, “Rod Ejection Accident Methodology”

TR-0516-49422, “Loss-of-Coolant Accident Analysis Methodology”

TR-0516-49416, “Non-Loss-of-Coolant Accident Analysis Methodology”

Presenters:

Chris Van Wert – Senior Reactor Systems Engineer, Office Nuclear Reactor Regulation

Shanlai Lu – Senior Nuclear Engineer, Office Nuclear Reactor Regulation

Alex Siwy – Reactor Systems Engineer, Office Nuclear Reactor Regulation

March 5, 2020

(Open Session)

Presentation to the ACRS Full Committee
Staff Review of NuScale Topical Report

TR-0716-50350, REVISION 1

“Rod Ejection Accident Methodology”

Presenters:

Chris Van Wert – Senior Reactor Systems Engineer, Office of Nuclear Reactor Regulation

March 5, 2020
(Open Session)



NRC Technical Review Areas/Contributors

- NUCLEAR METHODS, SYSTEMS & NEW REACTORS BRANCH / NRR:
Rebecca Patton (BC)

- ADVANCED REACTOR TECHNICAL BRANCH / NRR:
Jeff Schmidt
Chris Van Wert



Staff Review Timeline

TR-0716-50350, “ROD EJECTION ACCIDENT METHODOLOGY”

- NuScale submitted Topical Report (TR)-0716-50350, “Rod Ejection Accident Methodology,” Revision 1, on November 15, 2019, (Agencywide Documents Access and Management System (ADAMS) Accession No. ML19319C684).
- Staff briefed advisory committee on reactor safeguards (ACRS) subcommittee on February 19, 2020.
- Staff plans to issue its final SER in March 2020.
- Staff plans to publish the “-A” (approved) version of the TR prior to finishing Phase 6 of the NuScale DCA.



Staff Review

- The staff's review included:
 - Evaluation of the analysis criteria
 - Evaluation of the code suite used within the analysis methodology
 - Evaluation of the plant and cycle assumptions used in the analysis methodology
 - Evaluation of the rod ejection accident analysis methodology
- The staff's review does not include the licensing basis Reactivity Initiated Accident (RIA) analysis for the NuScale Design Certification Application (DCA)
 - Contained in Section 15.4.8 of the Safety Evaluation Report (SER) for the NuScale Design Certification
- During its review, staff audited calculations and other supporting information



Analysis Criteria

- The staff reviewed the proposed analysis criteria
 - Reactor Coolant System Pressure
 - Fuel Cladding Failure
 - Core Coolability
 - Fission Product
- The staff concluded that the proposed criteria either followed or were conservative to the guidance provided in Standard Review Plan (SRP) Section 4.2 Appendix B
- Staff also notes that DG-1327, “Pressurized Water Reactor Control Rod Ejection and Boiling Water Reactor Control Rod Drop Accidents” is currently being developed.
 - Draft guidance is not staff requirements, but the staff notes that the more stringent internal limits imposed by NuScale would not exceed the draft guidance limits as they currently stand



Evaluation of Code Suite

- The NuScale REA analysis is based on the following codes and packages:
 - CASMO5/SIMULATE5: provides reactor core physics parameters
 - SIMULATE-3K: 3-dimensional nodal reactor kinetics code which supplies power input to downstream analyses
 - NRELAP5: transient system response
 - VIPRE-01: subchannel analysis
- Applicability of CASMO5, SIMULATE5, NRELAP5, and VIPRE-01 has been reviewed and approved for NuScale in TR-0616-48793-P-A, Revision 1, “Nuclear Analysis Codes and Methods Qualification”.
- The validation of SIMULATE-3K is included as part of TR-0716-50350 and is therefore included in the staff’s review.
 - Staff concluded that NuScale successfully validated S3K against experimental data and the NEACRP control rod ejection problem computational benchmark

Plant and Cycle Assumptions

- The staff reviewed the plant and cycle assumptions used in the NuScale rod ejection analysis methodology
 - The staff determined that the methodology included ranges in power, time in cycle, and core power that covered a wide range of operating conditions and would capture the most limiting condition
 - The staff agreed that the assumptions associated with the automatic system response of non-safety systems were conservative
 - The staff determined that the methodology regarding the timing of loss of AC power conservatively biases the reactor coolant system (RCS) pressure evaluation



Rod Ejection Accident Analysis Methodology

- The staff reviewed the analysis methodology including steady-state initialization, dynamic core response, dynamic system response, subchannel critical heat flux evaluation, and the adiabatic heatup fuel response
- The staff's review included the methodology by which information is passed between codes, application of uncertainties, modelling assumptions used for inputs, and handling of reactor trips.
- The staff concluded that the methodology for calculating the system response, subchannel, and fuel response analyses was conservative and acceptable for demonstrating compliance with the acceptance criteria

Staff SER Conclusions

- The staff concludes that the NuScale criteria used for evaluating REA either follows or is more conservative than staff guidance
- The staff concludes that the methodology accounts for the various potential operating conditions and time in life, and conservatively addresses uncertainties and plant conditions
- The staff finds the use of TR-0716-50350-P acceptable for evaluating reactivity initiated accidents for the NuScale plant design.

Questions?

Presentation to the ACRS Full Committee
Staff Review of NuScale Topical Report

TR-0516-49422

**“Loss-of-Coolant Accident Analysis
Methodology”**

Presenters:

Dr. Shanlai Lu – Senior Nuclear Engineer, Office of Nuclear Reactor Regulation

March 5, 2020

(Open Session)

Review Team

- **NRC**

Mr. Carl Thurston

Dr. Shanlai Lu

Dr. Peter Lien

Mr. Antonio Barrett

Dr. Weidong Wang

Dr. Tim Drzewiecki

Mr. Ron Harrington

Dr. Syed Haider

- **NuMark Associates**

Mr. Marvin Smith

Dr. Donald Rowe

Dr. Leonard Ward

Mr. Bert Dunn

- **Brook Haven National Lab**

Dr. Upendra Rohatgi

Design Features And Scope


3 RVVs 2 RRVs each its own IAB, trip valve and trip reset valve

Containment functions as part of ECCS

- A methodology to analyze LOCA
- A methodology to analyze IORV
- Support Peak Containment Pressure, Non-LOCA TR and Long Term Cooling Analysis

Applicable Regulation:

10CFR50.46 Appendix K



Review Approaches

- Early Engagement And Extensive Audits Through Electronic Reading Room
 - Pre-application engagement
 - Initial on-site visits and audit meetings
 - Two phases of continuing audits throughout review period
- Issues Raised:
 - 45 RAI Questions
 - 210 Audit Issues
- Staff performed sensitivity analysis with NRELAP5 and confirmatory analysis with TRACE

Review Areas

- Phenomena Identification and Ranking Table
Following CSAU method, NuScale identified twenty-one phenomena as important to capture in the LOCA model
- NRELAP5 code is used to model NPM
Steam Generator Model, Containment Wall Condensation Model, Critical Flow Model, CHF Correlations. NPM Model and Nodalization
- NIST Tests, Scaling and Distortion Analysis
A new scaling analysis approach was used with distortion analysis to justify the applicability of NIST IETs
- IORV Analysis Methodology
Two different sets of CHF correlations are used for low flow and high flow conditions. STERN and KATHY facilities provide specific fuel CHF databases

NRC Sensitivity & Confirmatory Analyses

- Separate Effect Tests (SETs):
 - KAIST model: DHRS tube condensation experiment, non-LOCA
 - SIET model: helical coil steam generator tube/shell side heat transfer, non-LOCA
 - NIST-1 model: high pressure condensation test (HP-02)
- Integral Effect Tests (IETs):
 - NIST-1 models: loss of coolant accident (LOCA) and inadvertent emergency core cooling system (ECCS) operations
 - NPM models: licensing calculation confirmation and sensitivity studies, LOCA, non-LOCA
- Both TRACE and NRELAP5 codes were used. More than fifty five sets of calculations were performed. RAIs were issued and NRELAP5 code was updated from V1.3 to V1.4. Good agreements were obtained with NuScale analysis results

Conclusions

- NuScale LOCA EM and NRELAP5 V1.4 are approved for determining critical heat flux and collapsed liquid level for NuScale reactor in compliance with 10CFR 50.46 Appendix K requirements
- NRELAP5 computer code V1.4 is also determined applicable to predict containment pressure and temperature subject to specific modeling requirements
- The CHF modeling is approved subject to limitations and conditions

Questions?

Presentation to the ACRS Full Committee
Staff Review of NuScale Topical Report

TR-0516-49416

**“Non-Loss-of-Coolant Accident
Analysis Methodology”**

Presenters:

March 5, 2020
(Open Session)

NRC Staff Review Team

- NRC Technical Reviewers:
 - Antonio Barrett, NRR
 - Jeff Schmidt, NRR
 - Alex Siwy, NRR
 - Ray Skarda, RES
 - Peter Lien, RES
 - Ron Harrington, RES
 - Jason Thompson, RES
- Consultants (Energy Research, Inc.):
 - Mohsen Khatib-Rahbar
 - Walter Tauche (subcontractor)
 - Morgan Libby
 - Michael Zavisca

Review Process Overview

- Staff conducted its review in accordance with applicable NRC regulations and guidance
- Safety evaluation report (SER) is based on TR-0516-49416, Revision 2
- Two audits conducted in four phases
 - About 140 audit issues
 - Helped to confirm staff's understanding and inform requests for additional information (RAIs)
- 33 RAI questions issued
 - All resolved and responses incorporated into TR-0516-49416, Revision 2, as appropriate

Non-LOCA Methodology Scope

- Provides a methodology for performing system transient analysis of specified non-LOCA design-basis events for the NuScale Power Module (NPM)
- Evaluates primary and secondary pressure figures of merit
- Includes interfaces with other methodologies, both upstream and downstream
- Covers time frame during which mixture level is above top of riser and natural circulation is maintained
- Includes certain event-specific assumptions and conservative bias directions for initial conditions
- The staff is evaluating some items discussed in the TR as part of a design-specific application of the methodology

Key Design Features and Models for Non-LOCA

- Staff focused its review on several key features of the NuScale design and their representation in the NRELAP5 model:
 - Natural circulation design
 - Helical coil steam generators (SGs)
 - Transfer heat from reactor coolant system (RCS) to feedwater
 - Passive decay heat removal system (DHRS) condensers
 - Transfer decay heat to reactor pool using the SGs
 - Evacuated containment vessel

Applicability of NRELAP5 to Non-LOCA Analysis

- The applicant developed the non-LOCA evaluation model (EM) from the LOCA EM using graded approach described in RG 1.203
- The staff reviewed the applicant's non-LOCA phenomena identification and ranking table (PIRT) to ensure that important phenomena were identified and captured in the non-LOCA TR
- The staff reviewed how the applicant addressed highly ranked non-LOCA phenomena:
 - Separate effects tests: NIST HP-03, HP-04, KAIST, and SIET
 - Integral effects tests: NIST NLT-02a, NLT-02b, NLT-15p2
 - Code-to-code benchmark against RETRAN-3D
 - Use of bounding input values
 - Other analysis methodologies (e.g., subchannel)

Significant Review Issue – Multi-Dimensional Flow Effects

- Staff requested additional justification for how multi-dimensional flow effects in the RCS and thermal stratification in the reactor pool are addressed (RAI 9351, Question 15.00.02-31)
- Staff's major concerns were the potential for reduced RCS flow rates and degradation in DHRS performance
- The applicant's RAI response resolved the issue, as supported by the staff audit of underlying calculation notes and audit discussions with the applicant

NRELAP5 Assessments Against Test Data

The staff finds that:

- The KAIST, NIST-1 HP-03, and NIST-1 HP-04 tests validate the NRELAP5 DHRS models
- The SIET TF-1 tests validated steam generator secondary side phenomena, but the staff had concerns about the ability of the SIET TF-2 tests to fully validate primary-to-secondary heat transfer
- The NLT-02a, NLT-02b, and NLT-15p2 integral effects tests together demonstrate applicability of NRELAP5 to evaluate non-LOCA transients
- The benchmark against RETRAN-3D provides confidence that the NRELAP5 point kinetics model produces results similar to those from an NRC-approved code

Significant Review Issues – NRELAP5 Assessments

- The applicant removed steam generator and DHRS heat transfer biases from the methodology in response to staff questions about:
 - Steam generator heat transfer uncertainty based on the SIET TF-2 tests, associated with DCA Chapter 15 Unclear Open Item 15.0.2-4 (RAI 9466, Question 15.00.02-6)
 - DHRS nodalization (RAI 9374, Question 15.00.02-22)
- The applicant provided justification that non-LOCA figures of merit are not sensitive to these biases
- Based on its review of the justification and audits of underlying calculations, the staff finds that removal of the heat transfer biases is supported for NPM model Revision 2
- The staff imposed the associated Limitation/Condition 3

General and Event-Specific Non-LOCA Methodology

- The staff reviewed the overall non-LOCA analysis process and finds that it provides an acceptable analysis framework
- The staff finds that the deterministic approach using conservative or bounding inputs, initial conditions, and assumptions is acceptable for conservative calculations of non-LOCA events
- The staff reviewed each event-specific methodology and ensured that they will ensure conservative results when implemented
- The staff reviewed the representative non-LOCA event calculations in the TR and concludes that they illustrate how the non-LOCA methodology can be used for conservative transient analyses

Staff SER Limitation and Condition Summary

- I. Future changes to LOCA TR must be assessed for impacts to Non-LOCA EM
- II. Non-LOCA EM scope limited to non-LOCA events defined in the TR prior to the time of riser uncover for evaluation of primary and secondary pressures and potential for loss of system functionality
- III. Additional justification must be provided for elimination of SG and DHRS heat transfer biases if applying methodology to a design other than NPM model Revision 2 or a model update made pursuant to a change process specifically approved by NRC for changes to the NPM model
- IV. Any credit for secondary MSIVs (not safety-related) must be approved through design review
- V. Event-specific electrical power assumptions, single failures, and operator actions must be approved through design review
- VI. Non-LOCA EM use limited to NRELAP5 v1.4 and NPM model Revision 2, unless changes are made pursuant to a change process specifically approved by the NRC staff for changes to NRELAP5 and the NPM model

Conclusions

- All technical issues from the course of the review have been resolved
- Use of NRELAP5 with the non-LOCA methodology described in the TR is acceptable for the non-LOCA safety analyses of the NuScale NPM design subject to the specified limitations and conditions

Acronyms

- ACRS Advisory Committee on Reactor Safeguards
- DCA design certification application
- DHRS decay heat removal system
- EM evaluation model
- LOCA loss-of-coolant accident
- NPM NuScale Power Module
- PIRT phenomena identification and ranking table
- RAI request for additional information
- RCS reactor coolant system
- RIA Reactivity Initiated Accident
- SER safety evaluation report
- SG steam generator
- TR topical report