

Official Transcript of Proceedings
NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
Fuels, Materials and Structures Subcommittee
Open Session

Docket Number: (n/a)

Location: teleconference

Date: Thursday, August 24, 2023

Work Order No.: NRC-2512

Pages 1-35

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1716 14th Street, N.W.
Washington, D.C. 20009
(202) 234-4433

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA

NUCLEAR REGULATORY COMMISSION

+ + + + +

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

+ + + + +

FUELS, MATERIALS, AND STRUCTURES SUBCOMMITTEE

+ + + + +

OPEN SESSION

+ + + + +

THURSDAY

AUGUST 24, 2023

+ + + + +

The Subcommittee met via hybrid in-person and Video Teleconference, at 8:30 a.m. EDT, Ronald Ballinger, Chairman, presiding.

COMMITTEE MEMBERS:

RONALD G. BALLINGER, Chair

CHARLES H. BROWN, JR., Member

VICKI BIER, Member

VESNA DIMITRIJEVIC, Member

GREGORY HALNON, Member

WALT KIRCHNER, Member

JOSE MARCH-LEUBA, Member

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

DAVID PETTI, Member
JOY L. REMPE, Member
THOMAS ROBERTS, Member
MATTHEW SUNSERI, Member

ACRS CONSULTANT:

DENNIS BLEY
STEVE SCHULTZ

DESIGNATED FEDERAL OFFICIAL:

ZENA ABDULLAHI
WEIDONG WANG

ALSO PRESENT:

TIMOTHY CREDE, Westinghouse
LESLIE FIELDS, NRR
GEROND GEORGE, NRR
JOSEPH MESSINA, NRR
BRIAN MOUNT, Dominion Energy
PATRICK RAYNAUD, RES

P-R-O-C-E-E-D-I-N-G-S

8:31 a.m.

CHAIR BALLINGER: The meeting will now come to order, everybody. This is the meeting of the Fuels, Materials and Structures Subcommittee of the Advisory Committee on Reactor Safeguards. I'm Ron Ballinger, chairman of today's subcommittee meeting.

ACRS members present and in attendance are Tom Roberts, Jose March-Leuba, Matt Sunseri, Dave Petti, Joy Rempe. I don't know if Robert, Bob Martin is going to be here or not. Vicki Bier, Greg Halnon, and Charles Brown. And on line will be I'm sure Vesna Dimitrijevic, yes, and Walt -- yes, Walt Kirchner.

Our consultants, Stephen Schultz and Dennis Bley are also -- Steve is here in person and Dennis is online.

Weidong Wang is the Designated Federal Official present in person and Zena Abdullahi is present virtually, as opposed to virtually present, as DFO as well.

During today's meeting, the subcommittee will review the NRC's staff safety evaluation for approving PWROG's hydrogen-based transient cladding strain limit topic report. The subcommittee will hear presentations by and hold discussions with the NRC

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 staff, PWROG, and their consultants.

2 Part of the presentations by the applicant
3 and the NRC staff may be closed to discuss information
4 as proprietary to the licensee and its contractors
5 pursuant to 5 U.S.C. 552(b)(c)(4).

6 Attendance at the meeting that deals with
7 such information will be limited to the NRC staff and
8 its consultants, PWROG, and those individuals and
9 organizations who have entered into an appropriate
10 confidentiality agreement with them. Consequently, we
11 will need to confirm that we have only eligible
12 observers and participants in the closed part of the
13 in-person meeting, as well as those attending
14 virtually.

15 The ACRS Section of the U.S. NRC public
16 website provides our charter, bylaws, agendas, letter
17 reports, and full transcripts of all full and
18 subcommittee meetings including slides presented here.
19 The meeting notice and agenda for this meeting are
20 posted and we have not received any requests for any
21 written statements or requests to make oral statements
22 from the public prior to this meeting.

23 The subcommittee will gather information,
24 analyze relevant issues and facts, and formulate
25 proposed positions and actions, as appropriate, for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 deliberation by the full committee.

2 A transcript of the meeting is being kept
3 and the open portion will be made available. Today's
4 meeting is being held in person and over Microsoft
5 Teams for ACRS staff and members, NRC staff, and the
6 applicant. There is also a telephone bridge line and
7 a Microsoft Teams link allowing participation of the
8 public to join the open session.

9 When addressing the subcommittee, the
10 participants should first identify themselves and
11 speak with sufficient clarity and volume so that they
12 may be readily heard. When not speaking, we request
13 that participants mute their computer microphones or
14 by phone press *6.

15 We'll now proceed with the meeting and I'd
16 like to start by calling on Gerond George. You're
17 there, I saw you, to make the NRC opening remarks.
18 Before you go, we will have to decide at the end of
19 this whether we recommend a letter, but we have
20 information indicating that they would like a letter,
21 so keep that in your mind when you ask questions and
22 that's part of the presentation, because we're going
23 to have to come up with a letter.

24 MR. GEORGE: Thank you, Chairman
25 Ballinger. Before I get to my opening remarks, I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 would say there was a request not to have a letter.
2 We did not need to have a letter.

3 CHAIR BALLINGER: You're apparently not
4 close enough to the microphone.

5 MR. GEORGE: Okay, can you hear me now?
6 Hello.

7 CHAIR BALLINGER: Yes, that's an AT&T
8 advertisement.

9 MR. GEORGE: Yes, Gerond George, Branch
10 Chief, Licensing Projects Branch. Before I get to my
11 opening remarks, I think there's a little confusion.
12 I guess we had stated we did not need a letter for
13 this review.

14 CHAIR BALLINGER: Oh, okay. I've been
15 under the impression all along that you wanted a
16 letter when you read the 635 page NRC NUREG on
17 statistics.

18 MR. GEORGE: I'm not sure what you're
19 talking about, but I'll get to my opening remarks and
20 I guess we can handle the letter later.

21 CHAIR BALLINGER: Okay, sure. By the way,
22 whether we have a letter or not is not up to me. It's
23 actually not up to you. It's up to the subcommittee.

24 MR. GEORGE: Subcommittee. That's right,
25 that's right. Understand. Thank you.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Thank you, Chairman Ballinger, thanks for
2 having us today. The NRC staff will present the
3 safety evaluation for the Pressurized Water Reactor
4 Owners Group 21001, the hydrogen-based transient
5 cladding strain limit.

6 The topical report proposes an alternative
7 to the hydrogen-based cladding strain limit currently
8 used in our regs, regulation. We would like to thank
9 the PWR Owners Group for providing the information and
10 committing the resources for this review. Because of
11 these efforts, our tech reviewers were able to
12 complete a comprehensive and efficient review in a
13 very short amount of time. So thank you, guys, very
14 much for that.

15 And that would be it for my opening
16 remarks. Thank you for your time today.

17 CHAIR BALLINGER: Okay, now I'm in a bit
18 of a quandary. Who's doing the presentation first?
19 I mean it's the PWROG folks, but I don't see anybody.

20 MR. GEORGE: I believe they are behind
21 you. They need to walk up to the front. We won't
22 make you guys turn around.

23 MR. MOUNT: Is this close enough to the
24 mic?

25 CHAIR BALLINGER: That sounds pretty good.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. MOUNT: Good morning. My name is
2 Brian Mount. I'm the chairman for the Analysis
3 Committee of the PWROG and I work for Dominion Energy.
4 I'd like to thank the ACRS for taking an interest in
5 our topical report and the NRC' SC on it.

6 Just to give you a brief little history of
7 how we got here, as we've been looking at trying to
8 improve our fuel economics, we keep pushing up against
9 various limits and most recently that was the cladding
10 strain limit that we've pushed into. Whenever we
11 approach a limit, we always try to find ways to
12 recover margin either through improvements and
13 analytical inputs or if there's ways to improve the
14 limit itself.

15 As part of this, we went off and started
16 looking at what other activities were going on in the
17 industry, within the NRC, and we saw that there are
18 already hydrogen-based limits out there. We also came
19 across the National Lab, the PNNL report, where they
20 were looking at hydrogen-based credit -- or clad
21 strain limit. With these ideas and these limits, we
22 were thinking this was an excellent opportunity for us
23 to improve our design limits and support even further
24 fuel economic improvements or now what we are hearing
25 is longer operating cycles, potential power uprates.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Ironically, every time we find a way to improve our
2 margins, somebody is coming to look for it.

3 So as the NRC mentioned earlier, we are
4 very appreciative of the NRC's review. This was a
5 very well-run review. We are very appreciative of the
6 preparedness that the staff came into. We had an
7 audit with them. They were well prepared. They were
8 very pointed in what they wanted and the information
9 they needed to support filling the holes in the draft
10 that Zena had prepared.

11 And with that, I'd like to turn it over to
12 Mr. Tim Crede, who was our technical lead at
13 Westinghouse for us. And although Tim is here, he was
14 supported by a large number of other experts within
15 Westinghouse to get to this report in such a good
16 position for the NRC review. Thank you.

17 MR. CREDE: Thank you, Brian. Good
18 morning, everybody. Can you hear me all right? Thank
19 you.

20 Just a logistics questions first. Do you
21 want me to share my screen around the slides or who's
22 changing the slides?

23 CHAIR BALLINGER: I guess that's up to
24 you.

25 MEMBER REMPE: I thought you were sharing

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 --

2 MR. CREDE: Okay. Do you want to try it?
3 Okay.

4 MR. MOUNT: Leslie Fields.

5 MR. CREDE: All right, so my name is Tim
6 Crede. I work for Westinghouse in the Fuel Rod and
7 Thermal-Hydraulic Design Group. I was the technical
8 lead on the project, although as Brian mentioned, I
9 certainly had a very large and excellent support
10 staff.

11 We can go to the next slide.

12 CHAIR BALLINGER: See if you've got a
13 speaker on because we're getting feedback.

14 MR. CREDE: All right, so just the agenda
15 for the open session, I wanted to go through a little
16 bit of an introduction, talk about some background,
17 give a high-level overview of the project, discuss the
18 alternate strain limit that we proposed, a quick
19 summary, and conclusions and then take any questions.

20 Next slide, please. So back in 2019,
21 Westinghouse partnered with the PWR Owners Group to
22 develop a new project. We were looking at an
23 alternative way to evaluate transient cladding strain.
24 Specifically, we were looking at a new limit. So the
25 current limit that Westinghouse uses is taken straight

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 out of NUREG-0800, the NRC Standard Review Plan. But
2 we wanted a more data-driven and performance-based
3 limit, something that was derived from test data
4 specific to Westinghouse cladding outward. And the
5 limit from the SRP is appropriate. It's conservative,
6 but it is not based on our Westinghouse measured data.

7 So what we were looking for is to develop
8 further, more accurate strain limit that would have
9 the benefit of increasing margin, what is typically
10 the limiting time and life for transient cladding
11 strain analyses which would allow utilities to pursue
12 some of the programs Brian mentioned, uprates, loaded
13 pattern optimization, cycle end extensions, things
14 like that because for many of these plants, their most
15 limiting fuel performance criterion does tend to be
16 transient cladding strain. So we were looking for
17 ways to both make the limit more accurate and a little
18 side bonus is to recover some of that margin.

19 Next slide, please. So just a little bit
20 of a background. If you do look at NUREG-0800 and
21 look at Section 4.2, you will see that this is where
22 we take our strain limit from, the current limit. I
23 won't read it verbatim, but effectively what it says
24 is that during a Condition II overpower, a transient
25 event, we have thermal swelling of the fuel pellet.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 It stands out at a rate faster than cladding expands.
2 And it applies a stress strain on the cladding.
3 There's some pellet cladding, mechanical interaction
4 there.

5 And the purpose of the limit is to prevent
6 an over training of the cladding during these
7 Condition II transient events. So specifically, the
8 outer diameter cladding pre-transient can't increase
9 by more than one percent during the transient events.

10 Next slide, please. So the current one
11 percent limits remains valid and conservative design
12 limits. We are certainly not asking that the SRP be
13 updated or changed. What we wanted to look at,
14 however, is an alternative to that one percent limit
15 that are using a generic one percent limit. We wanted
16 one specifically for Westinghouse fuel. And when I
17 say Westinghouse fuel, that is restricted to ZIRLO and
18 Optimized ZIRLO which were our licensed cladding
19 alloys at the time.

20 And when we looked at the data, what we
21 noticed is that there's a very strong correlation
22 between the material strengths or yield strengths,
23 alternate tensile strength of our alloys and the
24 hydrogen content. And the hydrogen content of
25 cladding changes over time. It's a function of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 oxidation process. As the fuel rod oxidizes, it's
2 creating a zirconium oxide, as well as some free
3 hydrogen, some amount of which is then absorbed back
4 into the cladding.

5 Next slide, please. And so what we saw is
6 not unique to Westinghouse fuel. There is a very well-
7 established correlation between hydrogen content and
8 material strength. It's something that we also
9 noticed in a lot of open source material. As Brian
10 mentioned, we saw it in a similar strain limit that
11 was developed by PNNL. A lot of other scientific
12 papers that we were able to find also indicated that
13 there's a strong correlation between the hydrogen
14 absorbed in the cladding and its material strength.

15 And the reason -- the reason is as that
16 hydrogen gets absorbed, it is soluble up to a point.
17 Once it hits the terminal solid and solubility limit
18 instead of being soluble what we would call the excess
19 hydrogen, the hydrogen above the solubility limit
20 starts to form zirconium hydride platelets in the
21 cladding and these hydrides can act as cracked
22 propagation pathways such that it makes it easier to
23 fail when you have high PCMI such as you would expect
24 to see during an Condition II transient.

25 Next slide, please. And so the alternate

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 limit that we're proposing instead of a flat one
2 percent is a function of uniform elongation. Uniform
3 elongation is associated with the materials' ultimate
4 tensile strength. It is effectively the amount of
5 strain at which the deformation ceases to become
6 stable and uniform. It is bend necking and things
7 like that start to occur and you actually start to see
8 a breakdown of the material. So the limit we're
9 proposing is rather than a straight one percent flat
10 limit, it's actually a function of the uniform
11 elongation.

12 Next slide, please.

13 MEMBER MARCH-LEUBA: Pardon me, just for
14 my education. When we look at all the top materials,
15 you know (unintelligible) like Dr. Ballinger. When
16 you said percent, I see that the units are -- it's
17 percent units per meter? What is the one percent?

18 MR. CREDE: It's percent increase of the
19 cladding diameter. So we take the ratio of the pre-
20 transient and the post-transient cladding diameter.

21 MEMBER MARCH-LEUBA: And you go back to
22 the previous slide. So in -- doesn't this .01 in the
23 excess scale, there is one percent?

24 MR. CREDE: Yes.

25 MEMBER MARCH-LEUBA: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. CREDE: And this is just a generic
2 figure. The numbers are just what I put into Excel to
3 make it plot, just to show what it looks like. These
4 are not specific to any actuals here. But yes, this
5 would be the one percent strain.

6 MEMBER HALNON: Hey, Tim, the process of
7 hydrogen getting into -- is that a consistent process
8 without any variables that could affect it differently
9 causing the calculation to be --

10 MR. CREDE: It is how we model. We
11 assume a fractional hydrogen pickup, so if you have a
12 certain amount of oxidation, we assume a certain
13 fraction of the hydrogen that's been generated is
14 absorbed into the cladding. And that is not something
15 that we created or developed as part of this. We have
16 a preexisting approved corrosion model where we have
17 -- one we did a few years ago for -- ZIRLO and
18 Optimized ZIRLO. And it established the hydrogen
19 pickup fraction that we assumed. But yes, we assume
20 a steady hydrogen accumulation throughout life.

21 MEMBER HALNON: Okay.

22 CHAIR BALLINGER: He's being a little bit
23 more theoretical than he needs to be. These are
24 empirical correlations.

25 MR. CREDE: Yes. Thank you.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 CHAIR BALLINGER: For an oxidizing
2 environment, it's usually seven percent of the
3 hydrogen produced ends up in the cladding. For
4 hydrogen over pressure environment which is PWR, it's
5 like 25 percent usually, right?

6 MEMBER HALNON: Okay, so we're ballparking
7 this.

8 CHAIR BALLINGER: To say the least. But
9 it's been ballparked for 40 years.

10 MEMBER HALNON: Tim, you mentioned it's
11 for ZIRLO and for Optimized ZIRLO Westinghouse
12 cladding.

13 MR. CREDE: Correct.

14 MEMBER HALNON: Is it different for each
15 or have you confined the data so that you're looking
16 for one that would represent both of those cladding
17 materials?

18 MR. CREDE: So we weren't sure how we were
19 going to do it when we first started. When we looked
20 at the data, we saw that the uniform elongations were
21 both alloys, was very, very similar. And so the limit
22 that we developed does apply to single limit for both.

23 If you look at other alloys, they would
24 need slightly different ones. If you look at the PNNL
25 model, their database is mostly zirc 2 and zirc 4. It

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 behaviors similarly, but it is different. In our
2 cases, they were close enough, we have one model for
3 both. If we would do other alloys, it could be
4 different.

5 MEMBER KIRCHNER: Tim, this is Walt
6 Kirchner. I'm attending virtually. Could you just
7 explain -- I know we're not in a closed session, but
8 just for the public and the record, why ZIRLO and
9 Optimized ZIRLO is different from the older circuloid
10 clads and why this might be appropriate to apply to
11 these newer alloys.

12 MR. CREDE: Yes. So I can give a more
13 detailed answer at the closed session, but for the
14 open session what I will say is that Westinghouse
15 ZIRLO and Optimized ZIRLO alloys have components in
16 them and additives that are added in addition to the
17 zirconium that make the material strength a little bit
18 higher than what you would typically see with zirc 4
19 or zirc 2. It is a material reason that we
20 manufactured to have a little bit more material
21 strength.

22 MEMBER KIRCHNER: And this is manifested
23 in primarily by less hydrogen uptake?

24 MR. CREDE: No, no. The material strength
25 itself is tied to the hydrogen uptake over time, but

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 even when you would have very low hydrogen and it
2 would be soluble, you would still expect a higher
3 material strength for ZIRLO and Optimized ZIRLO
4 because of the additives and the manufacturing process
5 that it undergoes.

6 MEMBER KIRCHNER: Okay. Thank you.

7 MEMBER ROBERTS: This is Tom Roberts. Can
8 you talk briefly about the limitation that is
9 applicable to Condition II over power events?

10 MR. CREDE: Yes, yes, absolutely. So the
11 reason we sort of limited to Condition II events is
12 because those are the only times really where or how
13 we evaluate it that you would see that high stress.
14 Obviously, you would see high stress at high strains
15 for Condition III and IV, major accidents, but we
16 don't use this limit for those accidents. They have
17 their own methods and procedures and everything to
18 look at LOCA and drop rod, rod ejection, things like
19 that.

20 When we do our fuel performance
21 evaluations, we are focused on ensuring that the
22 cladding will not fail during Condition I and
23 Condition II and we don't look at it for Condition I
24 operation because the strain never gets high enough to
25 be a concern. With older methodologies at 4, we used

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 to have a steady-state strain limit, but it was
2 recognized when we submit it at 5 that it was overly
3 conservative and they got rid of it. We focus on the
4 Condition II strain limit because that is the most
5 restrictive.

6 MEMBER ROBERTS: Okay, thank you, sir.
7 The Condition III and IV, the more severe action
8 scenarios, the existing limits are not being reached
9 yet, is that the issue?

10 MR. CREDE: Right. We would not apply
11 this to those accidents. So they have different
12 criteria that they use to evaluate. Effectively, the
13 cladding can't fail under those conditions. They use
14 different sets of analyses to not ensure that it
15 doesn't fail, but -- or that we don't under predict
16 how many rods are actually failed. But this is not --
17 this does not change or affect the way we look at
18 Condition III and IV accidents.

19 MEMBER ROBERTS: Okay, thank you, sir.
20 Condition II are essentially AOs where you're
21 required to show that the plant can still be operated
22 after the event?

23 MR. CREDE: Correct, yes.

24 MEMBER ROBERTS: Okay. Thank you.

25 MR. CREDE: Unless there are other

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 questions, I think, Leslie, you can go ahead. No,
2 sorry, I'm too far.

3 So the alternate limit that we propose as
4 part of this project that we used are the measure data
5 that we had available to develop a uniform elongation
6 strain limit. We made it a function of the total
7 hydrogen content of both the soluble and the insoluble
8 or excess hydrogen. To determine the solubility
9 limit, we used the Kerns correlation. The Kerns
10 correlation is a very common model for solubility. It
11 was developed back in the late '60s. It's been used
12 ever since. It's part of the more recent NRC Reg.
13 Guide 1.236, the PNNL model that we looked as part of
14 this, and also used the Kerns model. It's a very,
15 very common and widely used method for calculating
16 solubility. That's what we used here as well.

17 And so what the limit looks like is your
18 uniform elongation unit is flat when the claddings has
19 very little hydrogen because when the hydrogen is
20 soluble, it doesn't affect the material strength so
21 the limit itself is a flat line. Once you exceed the
22 solubility, you begin to form those zirconium hydrides
23 in the cladding. That's where you see the strain
24 limit start to degrade and it continues to degrade as
25 we absorb more and more hydrogen into the cladding.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 When you see the form and the form will be
2 in the closed session, I apologize, but it looks very,
3 very similar to the same strain limit that was
4 developed by PNNL. Obviously, the numbers are a
5 little bit different because the materials are a
6 little bit different, but the formula model is exactly
7 the same and what you would expect. It's a flat,
8 uniform elongation limit until you start to degrade
9 the material strength and then the limit drops off the
10 board.

11 Last slide, please.

12 So just to summarize, again, Westinghouse
13 and the PWR Owners Group partnered to develop a new
14 and alternative strain limit, a function of the
15 hydrogen content. We are not trying to replace the
16 current one for said limit. This is an alternative.
17 The one percent limit continues to be a valid method
18 for design. But this limit does represent more of a
19 data-driven, material-based limit that is specific to
20 Westinghouse cladding alloys. It meets the NRC's
21 requirement so that we maintain clarity and integrity
22 during the conditions of operation and that does
23 include Condition I operation as well.

24 It has the benefit of recovering margin.
25 The most limiting time in life is strain which in most

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 cases tends to be right around the point of cladding
2 gap closure because at that early burn up we don't
3 have a whole lot of hydrogen accumulated in the
4 cladding and it does explicitly count for the strength
5 and that utility loss that we do see with accelerated
6 hydrogen pick up.

7 MEMBER MARCH-LEUBA: So just for context,
8 so I understand. You're saying you want to keep both
9 metals available. Is this because the hydrogen base
10 method is more expensive to put in? You have to do
11 additional calculations? And if you don't need it,
12 you don't have to do that expense because basically
13 you're using either one percent or one and a half
14 percent.

15 MR. CREDE: So yes -- please.

16 MEMBER MARCH-LEUBA: I mean unless you
17 want to go to closed session.

18 MR. CREDE: No, no, no.

19 MR. MOUNT: So the one percent limit
20 that's in the SRP as applicable for BWRs, PWRs, so
21 it's a much more generic, widespread limit. The Owners
22 Group project has been only focused on ZIRLO and
23 Optimized ZIRLO cladding materials and only the select
24 number of participants who have joined the project are
25 able to take advantage of it, so we can't --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MEMBER MARCH-LEUBA: You can't force other
2 people to use your method, but you plan to use your
3 method?

4 MR. MOUNT: Correct.

5 MEMBER MARCH-LEUBA: It's not an issue of
6 it's very difficult to implement and it will cost a
7 lot of money. It's just other people didn't join your
8 group and therefore, they may not want to --

9 MR. MOUNT: And mainly with -- like I
10 said, the other cladding materials in the boiler, we
11 don't want to leave them without a limit.

12 MEMBER MARCH-LEUBA: The most important
13 part from ACRS's point of view is not a technical
14 reason. It's an implementation; I'm just stating.

15 MEMBER KIRCHNER: Tim, just a general
16 question and Brian, you mentioned earlier that this
17 was an issue -- part of the initiation here was that
18 others were doing this and you mentioned PNNL's work
19 there. What was PNNL's objective? Were they trying
20 to demonstrate that even with this new information
21 that the one percent limit was conservative or to
22 evaluate what level of conservatism was within that
23 limit?

24 MR. CREDE: I'm not -- I believe they were
25 commissioned by the NRC to develop that limit. I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 think they were looking more at long term storage
2 concerns and things like that. They were interested
3 because at cold conditions, at storage conditions,
4 when the temperature drops, your solubility drops, so
5 you have a lot more hydrides in the cladding and I
6 think they were looking at the material strength more
7 so for storage concerns.

8 CHAIR BALLINGER: What we're talking about
9 here is at temperature. The solubility for hydrogen
10 at room temperature is basically zero, so anything
11 that's in solution at high temperature is going to
12 come out of solution as soon as they shut the plant,
13 shut the plant down.

14 MEMBER KIRCHNER: Good. Thank you.
15 Appreciate that.

16 MR. CREDE: Absolutely. Are we all set?
17 Unless there are other questions that was all I had.

18 CHAIR BALLINGER: Okay, so we need to
19 transition to the staff and I'm not sure who the
20 presenter is. Okay, thanks.

21 Thank you very much and we'll see you in
22 a little bit again.

23 Who's controlling the slides for you?
24 There you go. Thank you.

25 MR. MESSINA: Good morning. My name is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Joseph Messina. I am a reactor systems engineer in
2 the Nuclear Methods and Fuel Analysis Branch of NRR.
3 Also here today with me on the side of the room is a
4 co-reviewer of the topical report, Patrick Raynaud,
5 who is a senior materials engineer in the Office of
6 Research, who is on rotation to NRR during the
7 duration of this review. So he assisted with it.

8 Next slide, please. So in this
9 presentation, I'll be discussing the applicable
10 guidance and regulations for the review, followed by
11 some background information on hydrogen criteria,
12 hydrogen-based criteria before we get into the review
13 focal points. I'll end the presentation with
14 limitations and conditions, as well as conclusion.

15 Next slide, please. So first, I wanted to
16 provide an overview of what's proposed in the topical
17 report. The topical report, as PWR Owners Group said,
18 proposes a change in cladding strain limit as a
19 function of cladding hygiene content for Condition II
20 transients which are AOOs. I provided a non-
21 exhaustive list of some examples of Condition II
22 transients on the slide here and I'm not going to read
23 them out, but just for your reference and this limit
24 is intended to be an alternative to the one percent
25 transient clad strain recommended in SRP 42.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Next slide, please. So here I'll provide
2 some of the applicable regulation and guidance. So
3 for this review, GDC-10 applies. GDC-10 establishes
4 our SAFDLs, Specified Acceptable Fuel Design Limits,
5 to ensure that the cladding does not fail during
6 steady state or the focus of this review the effects
7 of AOOs.

8 Also, SRP-42, as mentioned, talks about a
9 one percent transient clad strain limit. They say
10 that there's no criterion for failure by PCMI or PCI,
11 but two related criteria should be applied. And
12 that's the one percent transient clad strain limit and
13 avoiding fuel melting.

14 And the PWR Owners Group is obviously
15 requesting an alternative to this recommended one --
16 this one percent.

17 Next slide, please. Before I get into the
18 details of the review, I wanted to provide some
19 background and context on hydrogen-based limits. This
20 is not something brand new. The NRC has accepted
21 cladding hydrogen as a surrogate for burn up effects
22 in comparable regulatory applications. For example, in
23 Reg. Guide 1.236 on control rod drop and control rod
24 ejection accidents, it establishes PCMI curves, as
25 shown in the bottom left, which is peak entropy rise

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 as a function of excess cladding hydrogen and there
2 are different curves for different temperatures, so
3 like hot zero power, cold zero power, as well as for
4 the different cladding types, SRA, so stress relief
5 annealed cladding, as well as RXA, recrystallizing
6 annealed cladding.

7 Additionally, draft rule though it's still
8 with the Commission, 50.46 Charlie establishes alloy-
9 specific hydrogen-based oxidation limits, as shown in
10 the curve on the right, which is your ECR, so
11 equivalent cladding reacted, as a function of hydrogen
12 content. And as you see, hydrogen has a negative
13 effect on the ductility of your cladding in reactor.
14 So realistically, it's better that they provide a
15 transient clad strain limit based on actual data
16 rather than just a steady one percent for the entire
17 lifetime of the rod.

18 Next slide, please. Since there are no
19 specific guidance or review for an alternative to the
20 one percent transient strain clad limit in the SRP,
21 it's important to look at some of the primary focal
22 areas of our review. And these can be broken down
23 into four categories. I'll go into detail in each of
24 these categories in the closed session.

25 In the open session, I'll just briefly

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 touch on each of them. So the first bullet,
2 validation of the limit, this was the bulk of the
3 review. There were a lot of questions on this, such
4 as is there enough data? Is this data appropriate to
5 model PCMI? Are the figures of merit appropriate?
6 How bounding is the limit? And are there any trends
7 and experimental data that might not be captured? So
8 by that I mean should there be an additional variable
9 that's not considered or should there be a separate
10 limit, for example, Optimized ZIRLO versus ZIRLO
11 cladding. So we looked into all of those as part of
12 our quote unquote validation of the model.

13 Next, this second sub-bullet, the impact
14 of AOO on post-transient fuel performance. So if the
15 cladding undergoes an AOO, it will likely at least the
16 limiting rods will likely exceed the yield strength.
17 And the uniform elongation which is the strain
18 corresponding to the ultimate tensile strain would be
19 above -- if you get close to that, you're above the
20 yield strength. And once you would exceed the yield
21 strength, you put some plasticity on the cladding and
22 there's some strain hardening. And also, if you have
23 enough strain of the cladding, you might get reopening
24 of the pellet cladding gap which is obviously
25 detrimental to the transfer, but also would likely due

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 to a rise in a fission gas release.

2 CHAIR BALLINGER: I have a question about
3 that. There's the no lift off criteria during
4 operation.

5 MR. MESSINA: Yes.

6 CHAIR BALLINGER: But after an AOO, if
7 you've opened the gap, do they have to redo a
8 calculation or is it basically all over, you have to
9 take the fuel out?

10 MR. MESSINA: So as long as the transient
11 cladding strain limit is not exceed, they can put that
12 fuel back into the reactor and I do discuss some of
13 how the Owners Group would discuss that and the
14 impacts of that in the closed session.

15 The second to last bullet, integration
16 with other methods, this was primarily just a check to
17 make sure that they're using approved models for
18 inputs and how they calculate, how they use the model
19 exactly. And lastly, since the SOP does state that
20 the one percent is for both PCMI and PCI or PCISCC,
21 pellet cladding interaction stress corrosion cracking
22 to be specific, we have to look at well, is there
23 going to be any impact on PCI? Are we going to see
24 more PCI failures? So we looked into that as well.

25 Next slide, please. So this slide just

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 contains our five limitations and conditions of the
2 topical. They're not very interesting and they're
3 relatively straight forward, nothing controversial in
4 them. So first of all, they should be used for PWRs
5 with Optimized ZIRLO or ZIRLO cladding. It's to note
6 that Westinghouse's most recent cladding axiom which
7 is the evolution of the ZIRLO cladding types, it's not
8 applicable to that cladding. So if they wanted to
9 either -- if they wanted to do something other than
10 one percent transient clad strain before that, they
11 would have to come in to the NRC for approval.

12 CHAIR BALLINGER: Is this a limited issue?

13 MR. MESSINA: I believe so and I believe
14 it has to do with the axiom cladding -- the timing.
15 So the axiom cladding topical report was -- it went to
16 ACRS last October and this topical came in last
17 summer. So I envision they may want to come in in the
18 future with data to support an alternate strain limit
19 for that.

20 The third bullet, it's not applicable to
21 cladding with radial hydrides, oxides following, or
22 hydride boosting. The cladding primarily had
23 circumstantial hydrides in the testing, so those --
24 the limit goes out the door once you introduce some of
25 these things.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 CHAIR BALLINGER: Basically, with some
2 kind of constraint on the quality control for the
3 cladding itself, so that you don't end up with the
4 texture that results in radial hydrides, so there's an
5 indirect effect, right?

6 MR. MESSINA: Yes, and primarily we wanted
7 them to be aware that if they notice anything like
8 that, they should not be continuing to use this limit
9 because it would not be applicable.

10 MEMBER KIRCHNER: Ron, this is Walt. Yes,
11 the radial hydrides, that goes back to fabrication
12 technique, doesn't it in QA?

13 MR. MESSINA: Yes.

14 MEMBER KIRCHNER: So by the trademark
15 ZIRLO and Optimized ZIRLO, you would not expect to see
16 radial hydrides. I mean, isn't this, Joseph, just a
17 different way of putting a limit on the applicability
18 of the actual cladding that this UE can be -- a limit
19 can be applied to?

20 CHAIR BALLINGER: That's what I was
21 inferring.

22 MEMBER KIRCHNER: That's what I'm
23 thinking, Ron.

24 MR. MESSINA: So lastly, the two last
25 ones, it should be used with PAD5, a few performance

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 codes, so we looked at the models in PAD5 that were
2 used to generate inputs for the cladding strain limit.
3 And then lastly, the Condition II transients as I had
4 discussed previously.

5 CHAIR BALLINGER: Not to put you on the
6 spot, but I will, is there any reason for staff to
7 believe that other types of cladding, modern ones,
8 would not be able to use the same, if they were able
9 to develop the data, use the same limits?

10 MR. MESSINA: I envision M5 --

11 CHAIR BALLINGER: Like M5 for example.

12 MR. MESSINA: I envision M5 would be able
13 to do something similar, but as for the exact number
14 it probably would differ because fabrication has such
15 a great impact on the behavior.

16 CHAIR BALLINGER: But the hydrogen
17 absorption is so much lower.

18 MR. MESSINA: Yes.

19 CHAIR BALLINGER: On these modern
20 claddings, so --

21 MR. MESSINA: Okay, next slide.

22 MEMBER KIRCHNER: Before you go on,
23 Joseph, this is Walt again, I find it a little strange
24 that you limit it to the PAD5 code. Now that's the --
25 if I'm correct, that's the Westinghouse fuel

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 performance code.

2 MR. MESSINA: Correct.

3 MEMBER KIRCHNER: For example, I want to
4 use the FAST code that NRC developed with PNNL. Why
5 would this model not work in the FAST code?

6 MR. MESSINA: Well, primarily what we're
7 getting at with that condition and limitation is they
8 need to use an NRC-approved code.

9 MEMBER KIRCHNER: Okay, yes.

10 MR. MESSINA: Your example of FAST, they
11 could not use FAST because FAST has technically not
12 been NRC reviewed, despite being an NRC code.

13 MEMBER KIRCHNER: Right, okay, all right.
14 Fair enough. Thank you.

15 PARTICIPANT: And Joseph, on that point,
16 as you said, what you've done -- a detailed review of
17 the PADS code and how this has been input to it. So
18 you basically have done the code review associated
19 with this element.

20 MR. MESSINA: Part of it, yes. Next
21 slide, please.

22 MEMBER MARCH-LEUBA: Basically, you use
23 PAD5 to list how much hydrogen is in the cladding for
24 the experiments. Just kind of embedded into the
25 correlation. If you used a different code, you might

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 have come up with a different hydrogen content?

2 MR. MESSINA: Possibly, yes. I believe
3 so.

4 MEMBER MARCH-LEUBA: Because you used PAD5
5 to develop your correlation data. It's more accurate
6 to continue to use PAD5, so if you want to use
7 something different, you have to use the 5 or
8 reanalyze the raw data.

9 MR. MESSINA: Thank you.

10 CHAIR BALLINGER: Again, it's not the
11 issue, it's the way PAD5 does the calculation. That's
12 independent of the amount of hydrogen that's actually
13 absorbed.

14 MR. MESSINA: True.

15 CHAIR BALLINGER: During certain
16 operations.

17 MR. MESSINA: And actually the test -- the
18 data for hydrogen was mostly measured data, not a
19 calculated, I believe.

20 So the conclusions, we find -- the NRC
21 staff finds the proposed limit to be acceptable
22 because the data is adequately representative of PCMI.
23 The limit is reasonably bounding of the data to
24 sufficient confidence that arrives that means the
25 limit should not fail during a Condition II event by

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 PCMI. The limit integrates acceptably with existing
2 fuel performance methodologies to capture the relevant
3 phenomena associated with transient cladding strain
4 and fuel behavior before and after AOOs as well as
5 during AOOs because PAD5 has their method for how they
6 approach these Condition II events.

7 And lastly, it's not expected to impact
8 the number of PCI SEC failures.

9 That's it for me. Any questions?

10 CHAIR BALLINGER: Questions from the
11 members?

12 Okay, this is going to be the end of the
13 open session, so we now need to go out and ask for
14 public comment. So if there are members of the public
15 that wish to make a comment, please state your name
16 and your organization and then make your comment.

17 Hearing none so far, so thank you again.
18 So now we need to make a transition to the closed
19 session and so I would suggest that we make a break
20 until 9:30. Again, everything is squared away on
21 who's going to be here or not. So we'll take what now
22 amounts to a ten-minute break. Thank you.

23 (Whereupon, the above-entitled matter went
24 off the record at 9:20 p.m.)

25

A large, central version of the PWROG logo is displayed. The acronym "PWROG" is in a very large, bold, black, sans-serif font. The letter "O" is blue. Below it, the text "PWR Owners Group" is in a smaller, black, sans-serif font. The entire logo is set against a background of a large, light gray, stylized atomic symbol icon with three overlapping elliptical orbits.

Global Expertise • One Voice

**ACRS Fuels, Materials, and Structures Subcommittee – Open Session
PWROG-21001-P/NP, Hydrogen-Based Transient Cladding Strain Limit**

Brian L. Mount (Dominion), Tim M. Crede (Westinghouse)

August 24, 2023

Westinghouse Non-Proprietary Class 3



Agenda

- Introduction
- Background and Overview
- Proposed Alternate Cladding Strain Limit
- Summary and Conclusions



Introduction

- In 2019, the PWR Owners Group (PWROG) approved a project to develop a new design limit for the transient cladding strain fuel performance criterion
- The current strain limit for Westinghouse fuel is contained in Section 4.2, “Fuel System Design” of NUREG-800, the NRC Standard Review Plan (SRP)
- The project objective was to develop an alternative, data-driven and performance-based design limit derived from test data and specific to current cladding materials
 - The new strain limit is a more accurate reflection of measured strain data
 - It also increases margin at the limiting time in life, to support licensees who are limited by the cladding strain design criterion when they pursue increased fuel duty, optimized loading pattern development, extended cycle lengths, etc.



Background and Overview

- NUREG-0800, Section 4.2 Revision 3, SRP Acceptance Criteria B. “Fuel Rod Failure,” vi. states:

“The first criterion limits uniform strain of the cladding to no more than 1 percent. In this context, uniform strain (elastic and inelastic) is defined as transient-induced deformation with gauge lengths corresponding to cladding dimensions.”

- The objective of the strain limit is to prevent fuel failures from over-straining the cladding due to thermal swelling of the fuel pellet during Condition II overpower transient events

Background and Overview

- The current 1% cladding strain limit is a valid and conservative design limit for zirconium-based cladding
- However, a review of measured strain data for Westinghouse fuel determined that a 1% cladding strain limit does not reflect the true behavior of current cladding alloys, **ZIRLO®** and **Optimized ZIRLO™** High Performance Fuel Cladding Material
- Additionally, the material yield strength (YS) and ultimate tensile stress (UTS) are impacted by the hydrogen content of the cladding and change over time
 - Hydrogen is absorbed into the cladding material as a result of the oxidation process




Proposed Alternate Cladding Strain Limit

- There is a well-established relationship between the hydrogen content and material strength
 - This is based on Westinghouse measured data, as well as other scientific organizations
- The material strength of the cladding is reduced as excess hydrogen begins to form zirconium hydride (ZrH) platelets
 - Hydrogen in the cladding is soluble until it reaches the terminal solid solubility (TSS) limit, which is a function of the cladding temperatures
 - Hydrogen above the TSS is “excess” hydrogen and leads to the formation of hydrides
- Hydrides act as crack propagation pathways through the cladding which make it more likely to result in cladding failure due to pellet-cladding mechanical interaction (PCMI)

Proposed Alternate Cladding Strain Limit

- Instead of a constant 1% strain limit, the new design limit is based on uniform elongation (UE)
 - UE corresponds to the UTS of the cladding
 - UE represents the strain at which deformation ceases to be uniform and stable





Proposed Alternate Cladding Strain Limit

- Westinghouse used available measured data to develop an alternative UE strain limit as a function of the total (soluble and excess) hydrogen content
 - The TSS is determined using the Kearns solubility correlation, which is a common model utilized by the NRC for PCMI cladding failure thresholds (see NRC Regulation Guide 1.236)
- The UE limit is a constant value at low hydrogen values (i.e., when the hydrogen is soluble) and degrades slowly once excess hydrogen begins to form ZrH platelets in the cladding
 - The UE limit is comparable to a strain limit developed by Pacific Northwest National Laboratory (PNNL) for zirconium-based cladding



Summary and Conclusions

- The PWROG approved a project to develop a hydrogen-based design limit for transient cladding strain
 - This is an alternative to the 1% strain limit contained in Section 4.2 of the SRP
- It represents a data-drive, performance-based design limit based on measured strain test data for Westinghouse cladding alloys
- The hydrogen-based strain limit:
 - Meets the NRC requirement for maintaining cladding integrity during Condition II overpower transient events,
 - Recovers margin at the historically limiting time in life (near the point of gap closure), and
 - Explicitly accounts for the cladding strength and ductility loss with hydrogen pickup



Questions?

NRC Review of PWROG-21001, Hydrogen-Based Transient Cladding Strain Limit

ACRS Fuels, Materials, and Structures SC
Open Session
August 24, 2023

Joseph Messina, Patrick Raynaud
Nuclear Methods and Fuel Analysis
Office of Nuclear Reactor Regulation




Outline

- Applicable guidance and regulations
- Historical background
- Review focal points
- Limitations and conditions
- Conclusion

Overview

- In PWROG-21001, the PWROG proposed a transient cladding strain (TCS) limit that is a function of cladding hydrogen content for condition II transients
 - Condition II transients include:
 - Feedwater (FW) malfunctions causing a decrease in FW temperature
 - FW malfunction causing an increase in FW flow
 - Excessive increase in secondary FW flow
 - Loss of normal FW
 - Inadvertent opening of a steam generator safety or relief valve
 - Uncontrolled rod cluster control assembly bank withdrawal at power
 - Uncontrolled boron dilution
 - Inadvertent ECCS actuation at power
- H-based TCS limit intended to be an alternative to the 1% TCS limit currently utilized



Applicable Regulations and Guidance

- **GDC-10**: Establishes specified acceptable fuel design limits to ensure that the fuel is “not damaged” during normal operation, including the effects of anticipated operational occurrences (AOOs)
 - “Not damaged” means that fuel rods do not fail, fuel system dimensions remain within operational tolerances, and functional capabilities are not reduced below those assumed in the safety analyses during normal operation and AOOs
- **SRP 4.2 paragraph II.1.B.vi**: States that no criterion exists for fuel failure resulting from pellet-cladding interaction (PCI) or pellet-cladding mechanical interaction (PCMI), but that two related criteria should be applied:
 - 1) the strain of the cladding during a transient should not exceed 1%; and
 - 2) fuel melting should be avoided

Hydrogen-Based Limits – Historical Perspective

- The NRC has accepted cladding hydrogen content as a reasonable surrogate to BU effects in other comparable regulatory applications
- Historically, there is precedent for the use of hydrogen-based limits:
 - **RG 1.236** establishes hydrogen-based enthalpy failure criteria for PCMI during PWR control rod ejection and BWR control rod drop accidents
 - **Draft final rule 50.46c** establishes alloy-specific hydrogen-based oxidation limits

Fig. 5 of RG 1.236





Figure 5. PCMI Cladding Failure Threshold—SRA Cladding below 500 Degrees F

Fig. 2 of Draft RG 1.224 (to support 50.46c)



Review Focal Points

- The NRC review focused on several areas:
 - Validation of limit
 - Quantity and quality of experimental data?
 - Is the experimental data representative of PCMI?
 - Are the figures of merit appropriate to accurately model PCMI?
 - Does the limit sufficiently bound the data?
 - Are there any potentially non-conservative regions?
 - Are there any trends in the experimental data that may not be captured by the limit?
 - Impact of AOO on post-transient fuel performance
 - Integration with other methods
 - Impact on PCI-SCC

Limitations and Conditions

The PWROG hydrogen-based TCS is limited to:

1. Use in Westinghouse or Combustion Engineering PWRs
2. Use with ZIRLO or Optimized ZIRLO cladding
3. Not applicable to cladding with radial hydrides, oxide spalling, or hydride blistering
4. Use with PAD5 fuel performance code
5. Condition II transients

Conclusion

The NRC staff find the hydrogen-based TCS limit in PWROG-21001 to be acceptable because:

1. the data presented is adequately representative of the PCMI phenomenon;
2. the proposed hydrogen-based TCS limit is reasonably bounding of the data so that there is a high degree of confidence that fuel rods that meet the limit will not fail due to PCMI during a Condition II event;
3. the proposed hydrogen-based TCS limit integrates acceptably with existing fuel performance methodologies to capture the relevant phenomena associated with TCS and fuel behavior before and after AOOs; and
4. the proposed hydrogen-based TCS limit is not expected to impact the number of PCI-SCC failures

Questions?