

# **NRC Meeting: Risk Significance Methodology**



**Date: 25 October 2023**

**Presented By: Sean McCloskey**

**SMR, LLC, A Holtec International Company  
Krishna P. Singh Technology Campus  
One Holtec Boulevard  
Camden, NJ 08104, USA**

**[Not Export Controlled]**

# Meeting Agenda

- Introductions
- Purpose & Outcome
- Regulations
- Guidance
- Need for Absolute Risk Significance Criteria
- SMR-160+ Risk Significance Criteria
- Basis for Risk Significance Criteria
  - ✓ Basis for CDF Criteria
  - ✓ Basis for LRF Criteria
- Benefits
- Open Forum

# Introductions



- NRC Staff

- Holtec Staff

# Purpose and Outcome

## ■ Purpose

To provide a high-level overview of the SMR-160+ risk significance methodology

## ■ Outcome

To inform the NRC staff for their review of the LTR

# Regulations

## ■ RG 1.200

✓ RAW  $\geq 2.0$



✓ FV  $\geq 0.005$

✓ “It is recognized that for those new reactor designs with substantially lower risk profiles (e.g., internal events CDF below  $10^{-6}$ /year) that the quantitative screening value should be adjusted according to the corresponding baseline risk value.”

# Regulations (Cont.)

## ■ RG 1.174

- ✓ Allows risk-informed decision making with adequate justification to reduce unnecessary burden on licensees
- ✓ Provides a benchmark for an acceptable change in absolute risk
- ✓ Metrics are based on the current fleet with CDF  $\sim 1 \times 10^{-5}/\text{yr}$  and LRF  $\sim 1 \times 10^{-6}/\text{yr}$



## Guidance

- ACRS Guidance on SRP Chapter 19 and Section 17.4 (ML14196A119)
  - ✓ ACRS noted that the RG 1.200 criteria may produce an inappropriately large population of SSCs that are subject to enhanced availability and reliability controls, with commensurate undue burden for both the licensee and regulatory staff
  - ✓ ACRS recommended that risk significance criteria be consistent for a broad spectrum of designs and absolute levels of overall plant risk

## Guidance (Cont.)

### ■ NEI 00-04 and RG 1.201

- ✓ Recommended to perform system-level SSC categorization to ensure that all functions (which are primarily a system-level attribute) are appropriately considered for risk significance



# Need for Absolute Risk Significance Criteria



- Relative risk criteria artificially raises importance of SSCs for a design with significantly lower CDF than the current fleet
  - ✓ RG 1.200 criteria are based on relative risk for current fleet of reactors (CDF of  $\sim 1 \times 10^{-5}/\text{yr}$ )
  - ✓ SMR-160+ CDF expected to be significantly lower than the current fleet
- Example
  - ✓ For a design with CDF of  $1 \times 10^{-5}$ , a RAW of 2 implies a change in CDF of  $1 \times 10^{-5}$
  - ✓ For a design with CDF of  $1 \times 10^{-7}$ , a RAW of 2 implies a change in CDF of  $1 \times 10^{-7}$

## SMR-160+ Risk Significance Criteria



Parameter	Core Damage Criteria for Risk Significance	Large Release Criteria for Risk Significance
Component level	Conditional CDF $\geq 3 \times 10^{-6}/\text{yr}$	Conditional LRF $\geq 3 \times 10^{-7}/\text{yr}$
System level	Conditional CDF $\geq 1 \times 10^{-5}/\text{yr}$	Conditional LRF $\geq 1 \times 10^{-6}/\text{yr}$
Basic event/contributor	Total FV $\geq 0.20$	

- Based on all plant conditions including, operating, low power, and shutdown conditions for internal and external events resulting in core damage and a large radiological release to the environment

# Basis for CDF Criteria

CDF Criteria for Risk Significance	Basis
Component level CCDF $\geq 3 \times 10^{-6}/\text{yr}$	<ul style="list-style-type: none"> <li>Consistent with RG 1.174 risk-acceptance guidelines, which state that increases in CDF between <math>10^{-6}</math> and <math>10^{-5}</math> are considered if CDF can reasonably be shown to be <math>&lt; 1 \times 10^{-4}/\text{yr}</math></li> <li>The component-level threshold of <math>3 \times 10^{-6}</math> represents approximately the midpoint (on a log scale) of the Region II range identified in RG 1.174</li> <li>Order of magnitude below NRC safety goal of CDF <math>\leq 1 \times 10^{-4}/\text{yr}</math>, with an extra half-order of magnitude (on a log scale) of margin to account for uncertainties in the PRA model</li> </ul>
System level CCDF $\geq 1 \times 10^{-5}/\text{yr}$	<ul style="list-style-type: none"> <li>The system-level value of <math>1 \times 10^{-5}</math> represents the upper end of the Region II range for CDF identified in RG 1.174 for making permanent changes to a plant's licensing basis</li> <li>Order of magnitude below NRC safety goal of CDF <math>\leq 1 \times 10^{-4}/\text{yr}</math></li> </ul>
Basic event FV $\geq 0.20$	<ul style="list-style-type: none"> <li>Threshold more conservative than criteria for operating plants (i.e., CDF of <math>1 \times 10^{-5}/\text{yr}</math> * FV of 0.005 = <math>5 \times 10^{-8}/\text{yr}</math> is greater than the SMR-160+ CDF of <math>1 \times 10^{-7}/\text{yr}</math> * FV of 0.2 = <math>2 \times 10^{-8}/\text{yr}</math>)</li> <li>Using FV of 0.2 instead of 0.5 conservatively identifies more risk significant basic events</li> </ul>

# Basis for LRF Criteria



LRF Criteria for Risk Significance	Basis
Component level CLRF $\geq 3 \times 10^{-7}/\text{yr}$	<ul style="list-style-type: none"> <li>Consistent with RG 1.174 risk-acceptance guidelines, which state that increases in LRF between <math>10^{-7}</math> and <math>10^{-6}</math> are considered if LRF can reasonably be shown to be <math>&lt; 1 \times 10^{-5}/\text{yr}</math></li> <li>The component-level threshold of <math>3 \times 10^{-7}</math> represents approximately the midpoint (on a log scale) of the Region II range identified in RG 1.174</li> <li>Order of magnitude below NRC safety goal of LRF <math>\leq 1 \times 10^{-5}/\text{yr}</math>, with an extra half-order of magnitude (on a log scale) of margin to account for uncertainties in the PRA model</li> </ul>
System level CLRF $\geq 1 \times 10^{-6}/\text{yr}$	<ul style="list-style-type: none"> <li>The system-level value of <math>1 \times 10^{-6}</math> represents the upper end of the Region II range for LRF identified in RG 1.174 for making permanent changes to a plant's licensing basis</li> <li>Order of magnitude below NRC safety goal of LRF <math>\leq 1 \times 10^{-5}/\text{yr}</math></li> </ul>
Basic event FV $\geq 0.20$	<ul style="list-style-type: none"> <li>Threshold more conservative than criteria for operating plants (i.e., LRF of <math>1 \times 10^{-6}/\text{yr}</math> * FV of 0.005 = <math>5 \times 10^{-9}/\text{yr}</math> is greater than the SMR-160+ LRF of <math>1 \times 10^{-8}/\text{yr}</math> * FV of 0.2 = <math>2 \times 10^{-9}/\text{yr}</math>)</li> <li>Using FV of 0.2 instead of 0.5 conservatively identifies more risk significant basic events</li> </ul>

# Benefits

- Directly addresses the ratio limitations of traditional importance measures
- Consistent with the ACRS recommendation that risk significance criteria be consistent for a broad spectrum of designs and absolute levels of overall plant risk
- Consistent with NEI recommendation to consider risk significance at a functional (system) level
- Allows the licensee to focus resources on the SSCs important to absolute risk

# Open Forum



## Risk Importance Measures

- Fussell-Vesely (FV), commonly known as fraction of total risk

✓ 
$$FV = \frac{P(top) - P(top | A \text{ success})}{P(top)}$$

- Risk Achievement Worth (RAW), or risk increase ratio given a SSC fails

✓ 
$$RAW = \frac{P(top | A \text{ failed})}{P(top)}$$

- Conditional CDF (CCDF), or increased CDF when a SSC fails

✓ 
$$CCDF = CDF * RAW$$

- Conditional LRF (CLRF), or increased LRF when a SSC fails

✓ 
$$CLRF = LRF * RAW$$