

Callaway Energy Center 2024 Annual Radioactive Effluent Release Report

Renewed Facility Operating License NPF-30

Docket Numbers 50-483 and 72-1045



Callaway Energy Center 2024 Annual Radioactive Effluent Release Report

Renewed Facility Operating License NPF-30
Docket Numbers 50-483 and 72-1045

1. Introduction

This Annual Radioactive Effluent Release Report (ARERR) is submitted by Union Electric Co., dba Ameren Missouri, in accordance with the requirements of 10 CFR 50.36a and 10 CFR 72.44(d)(3), Callaway Energy Center Technical Specification 5.6.3, and HI-STORM UMAX Certificate of Compliance Appendix A, Section 5.1.c. This report is for the period January 1, 2024, to December 31, 2024.

The doses to the Member of the Public from all liquid and gaseous effluents discharged during the reporting period were small fractions of the NRC and EPA regulatory limits and the Radioactive Effluent Control limits in the Offsite Dose Calculation Manual.

Abstract

The Annual Radioactive Effluent Release Report covers the operation of the Callaway Energy Center during the year 2024. The report includes a summary of the quantities of radioactive liquid and gaseous effluents and solid waste released from the unit. The report also includes an annual summary of hourly meteorological data collected during the year and an assessment of radiation dose to the Member of the Public from liquid and gaseous effluents.

Radionuclide concentrations in liquid and gaseous effluents were obtained by effluent sampling and radiological analysis in accordance with the requirements of FSAR-SP/ODCM Radiological Effluent Control (REC) Table 16.11-1 and Table 16.11-4. Gamma spectroscopy was the primary analysis technique used to determine the radionuclide composition and concentration of liquid and gaseous effluents. Composite samples were analyzed for the hard to detect nuclides by an independent laboratory. Tritium and gross alpha were measured for both liquid and gaseous effluents using liquid scintillation counting and gas flow proportional counting techniques, respectively. The total radioactivity in effluent releases was determined from the measured concentrations of each radionuclide present and the total volume of effluents discharged.

2. Gaseous Effluents

The quantity of radioactive material released in gaseous effluents during the reporting period is summarized in Table A-1. The quarterly and annual sums of all radionuclides discharged in gaseous effluents are reported in Tables A-1A and A-1B. All gaseous effluent releases are considered to be ground level.

The quantity of ^{14}C released in gaseous effluents was calculated as described in EPRI Technical Report 1021106¹.

There were no radioactive effluents from the Independent Spent Fuel Storage Installation (ISFSI). The HI-STORM UMAX Canister Storage System does not create any radioactive materials or have any radioactive waste treatment systems. Specification 3.1.1, "Multi-Purpose Canister (MPC)", provides assurance that there are no radioactive effluents from the ISFSI.²

3. Liquid Effluents

The quantity of radioactive material released in liquid effluents during the reporting period is summarized in Table A-2. The quarterly and annual sums of all radionuclides discharged in liquid effluents are reported in Table A-2A. All liquid effluents were discharged in batch mode; there were no continuous liquid

¹ *Estimation of Carbon- 14 in Nuclear Power Plant Gaseous Effluents*, Technical Report 1021106, Electric Power Research Institute, December 2010.

² Certificate of Compliance No. 1040, Appendix A, Technical Specifications for the HI-STORM UMAX Canister Storage System, Specification 5.1.

discharges for the reporting period. Dilution by the Missouri River, in the form of the near- field dilution factor, is utilized in the ODCM dose calculation methodology.

4. Solid Waste Storage and Shipments

The volume and activity of solid waste shipped for disposal is provided in Table A-3.

5. Dose Assessments

The annual evaluation of dose to the Member of the Public is calculated in accordance with the methodology and parameters in the ODCM and is reported in Tables A-4 and A-5.

5.1 Table A-4, Dose Assessments, 10 CFR 50, Appendix I

The dose assessments reported in Table A-4 were calculated using the methodology and parameters in the ODCM and demonstrate compliance with 10 CFR 50, Appendix I. The gamma air dose and beta air dose were calculated at the nearest Site Boundary location with the highest value of X/Q, as described in the ODCM. The maximum organ dose from gaseous effluents was calculated for the ingestion, inhalation, and ground plane pathways at the location of the nearest resident with the highest value of D/Q, as described in the ODCM. The organ dose does not include the dose from ^{14}C , which is listed separately.

5.2 Table A-5, EPA 40 CFR 190 Individual in the Unrestricted Area

The dose assessments reported in Table A-5 are the doses to the Member of the Public from activities within the Site Boundary plus the doses at the location of the Nearest Residence. A large portion of the residual land of the Callaway Site is managed by the State of Missouri Department of Conservation as the Reform Wildlife Management Area. Pursuant to the guidance provided in Regulatory Guide 1.21, rev.2, the dose reported in Table A-5 is the sum of the dose from gaseous effluents (at the Nearest Resident location and within the Site Boundary), plus the dose contribution due to activities within the Site Boundary and the organ dose from inhalation of ^{14}C (at the Nearest Resident location and within the Site Boundary). The dose assessments in Table A-5 demonstrate compliance with 10 CFR 20.1301(e) and 40 CFR 190.

6. Supplemental Information

6.1 Abnormal Releases or Abnormal Discharges

There were no abnormal releases during the reporting period.

6.2 Non- routine Planned Discharges

There were no non-routine planned discharges during the reporting period.

6.3 Radioactive Waste Treatment System Changes

There were no major changes to the liquid or gaseous radwaste treatment system during the reporting period.

6.4 Annual Land Use Census Changes

There were no changes identified in the locations for dose calculation. Changes in sample locations identified in the Land Use Census are described in the Annual Radioactive Environmental Operating Report.

6.5 Effluent Monitoring System Non- functionality

No Effluent monitor EOSLs went beyond 30 days for the year 2024.

6.6 Offsite Dose Calculation Manual Changes

The Offsite Dose Calculation Manual consists of two documents: APA-ZZ-01003, "Offsite Dose Calculation Manual" (contains Methodology and Parameters) and FSAR-SP Chapter 16.11, "Offsite Dose Calculation Manual Radiological Effluent Controls (RECs)".

APA-ZZ-01003 was revised in June 2021. A complete copy of APA-ZZ-01003, rev. 26 is attached to this report in Appendix C. A description of the changes is provided in Appendix B to APA-ZZ-01003.

There are no changes to FSAR 16.11 for 2024. A complete copy of FSAR-SP Chapter 16.11 is also included in Appendix C.

6.7 Process Control Program Changes

APA-ZZ-01011, "Process Control Program" was revised during the reporting period. Current revision is 018, effective 02/29/2024.

Page(s)	Section or Step Number	Description
		Changes covered by CR 202308337 and CR 202308250-001
All	All	Formatted procedure to align with Callaway Standards
3	4.1	Added, "Shipping Health Physicist and/or Radwaste Supervision provide NOS Quality Supply potential vendor information and receive vendor approval from Quality Supply before implementing use of vendor for PCP-related activities. [Ref: 6.2.14]"
5	5.2 Note	Added new note for clarity
5	5.2.1	Deleted the verbiage that stated, "the preparation and review process described in APA-ZZ-00101, Processing Procedures, Manuals, and Desktop Instructions" because APA-ZZ-00101 doesn't apply to this procedure.
15	6.2.14	New Reference, "CR 202308250-001"

6.8 Corrections to Previous Reports

There were no major changes or corrections to previous reports, during the reporting period.

We did have minor corrections as shown below:

1. Ni-65 was improperly recorded (values were incorrect for Bone, Liver, Total Body, and Gi-LLI) in our Integrated Effluent Workbook (IEW) going back 14 years. There was no effect to the Liquid Dose summary, only the Gaseous Dose Summary in the years when Ni-63 was detected as part of our Gaseous discharge (2010, 2011, 2022, 2023). 2023 was corrected prior to submission. There were no changes to the data for 2010 or 2011.
2. There were blank lines in Table 8 Meat tab of the IEW, where Sn-113 and Te-127m should be located. This did not affect our reports.

Neither of these issues created any significant changes in final dose and both meet the requirements for 'minor corrections', to be reported in our next annual report after being found. This is that next annual report.

See CR202403366 for a full description of the evaluation the data for the ARERR for years 2022 back to 2012

Original 2022 ARERR Table A-4 Gaseous Effluent Dose area affected:

Max. organ dose10 (mrem)	1.57E-03	6.10E-03	3.76E-03	2.36E-03	1.38E-02
% Limit	0.02%	0.08%	0.05%	0.03%	0.09%

Revised after Ni-63 corrections:

Max. organ dose10 (mrem)	1.58E-03	6.10E-03	3.76E-03	2.36E-03	1.38E-02
% Limit	0.02%	0.08%	0.05%	0.03%	0.09%

6.9 Other Information Related to Radioactive Effluents

Meteorological dispersion parameters, data recovery rate, and Joint Frequency Tables for the monitoring period are attached as Appendix B.

Appendix A

Tables of Quantities Released in Liquid and Gaseous Radioactive Effluents and in Solid Radioactive Waste Shipments

Tables of Doses from the Discharge of Liquid and Gaseous Radioactive Effluents

Table A-1: Gaseous Effluents- Summation of All Releases							
Summation of All Releases	Unit	Quarter 1	Quarter 2	Quarter 3	Quarter 4	Total	Estimated Uncertainty (%) ³
Fission & Activation Gases	Ci	1.03E+00	7.35E-02	8.41E-01	6.35E-02	2.01E+00	20
<i>Average Release Rate</i>	μCi/s	1.31E-01	9.32E-03	1.07E-01	8.05E-03	6.37E-02	
<i>% of Limit</i>	%	N/A	N/A	N/A	N/A	N/A	
¹³¹Iodine	Ci	ND*	ND*	ND*	ND*	ND*	N/A
<i>Average Release Rate</i>	μCi/s	N/A	N/A	N/A	N/A	N/A	
<i>% of Limit</i>	%	N/A	N/A	N/A	N/A	N/A	
Particulates	Ci	ND*	ND*	ND*	ND*	ND*	N/A
<i>Average Release Rate</i>	μCi/s	N/A	N/A	N/A	N/A	N/A	
<i>% of Limit</i>	%	N/A	N/A	N/A	N/A	N/A	
Gross Alpha	Ci	1.07E-07	2.49E-07	1.62E-07	1.55E-07	6.73E-07	
³H	Ci	8.36E+00	1.17E+01	2.45E+01	1.02E+01	5.49E+01	14
<i>Average Release Rate</i>	μCi/s	1.06E+00	1.49E+00	3.11E+00	1.30E+00	1.74E+00	
<i>% of Limit</i>	%	N/A	N/A	N/A	N/A	N/A	
¹⁴C⁴	Ci	3.20E+00	3.20E+00	3.20E+00	3.20E+00	1.28E+01	

*ND means measurements were performed but no activity was detected.

³ Safety Analysis calculation 87-063-00, January 6, 1988

⁴ ¹⁴C activity is estimated based on EPRI report TR-1021106, *Estimation of ¹⁴C in Nuclear Power Plant Effluents*, December, 2010.

Table A-1A: Gaseous Effluents- Ground Level Release- Batch Mode						
Fission & Activation Gases	Units	Quarter 1	Quarter 2	Quarter 3	Quarter 4	Total for the year
⁴¹ Ar	Ci	4.71E-02	5.97E-02	5.51E-02	6.33E-02	2.25E-01
⁸⁵ Kr	Ci	8.15E-04	ND*	ND*	1.94E-04	1.01E-03
^{131m} XE	Ci	1.09E-05	ND*	ND*	ND*	1.09E-05
¹³¹ XE	Ci	2.92E-06	ND*	ND*	ND*	2.92E-06
Iodines & Halogens	Units	Quarter 1	Quarter 2	Quarter 3	Quarter 4	Total for the year
	Ci	ND*	ND*	ND*	ND*	ND*
Particulates	Units	Quarter 1	Quarter 2	Quarter 3	Quarter 4	Total for the year
	Ci	ND*	ND*	ND*	ND*	ND*
³ H	Ci	6.22E-02	2.64E-01	3.27E-01	1.65E-01	8.19E-01
Gross α	Ci	ND*	ND*	ND*	ND*	ND*
¹⁴ C	Ci	3.58E-02	3.58E-02	3.58E-02	3.58E-02	1.43E-01

*ND means measurements were performed but no activity was detected.

Table A-1B: Gaseous Effluents - Ground Level Release - Continuous Mode						
Fission & Activation Gases	Units	Quarter 1	Quarter 2	Quarter 3	Quarter 4	Total for the year
⁴¹ Ar	Ci	9.83E-01	1.38E-02	7.86E-01	ND*	1.78E+00
Iodines & Halogens	Units	Quarter 1	Quarter 2	Quarter 3	Quarter 4	Total for the year
⁸² Br	Ci	1.02E-06	ND*	3.40E-06	ND*	4.42E-06
Particulates	Units	Quarter 1	Quarter 2	Quarter 3	Quarter 4	Total for the year
⁶³ Ni	Ci	ND*	ND*	ND*	ND*	ND*
³ H	Ci	8.29E+00	1.15E+01	2.42E+01	1.01E+01	5.41E+01
Gross α	Ci	1.07E-07	2.49E-07	1.62E-07	1.55E-07	6.73E-07
¹⁴ C	Ci	3.16E+00	3.16E+00	3.16E+00	3.16E+00	1.26E+01

*ND means measurements were performed but no activity was detected.

Table A-2: Liquid Effluents- Summation of All Releases

Summation of All Liquid Releases	Unit	Quarter 1	Quarter 2	Quarter 3	Quarter 4	Total	Estimated Uncertainty (%) ⁵
Fission and Activation Products⁶	Ci	3.64E-02	8.39E-03	1.55E-02	5.56E-03	6.59E-02	20
<i>Avg Diluted Conc</i>	μCi/ml	2.52E-07	8.29E-08	1.32E-07	4.12E-08	1.32E-07	
<i>% of Limit</i>	%	N/A	N/A	N/A	N/A	N/A	
³H	Ci	1.31E+02	6.20E+01	1.32E+02	3.26E+02	6.52E+02	14
<i>Avg Diluted Conc</i>	μCi/ml	9.08E-04	6.12E-04	1.12E-03	2.42E-03	1.31E-03	
<i>% of Limit</i>	%	N/A	N/A	N/A	N/A	N/A	
Dissolved & Entrained Gases	Ci	ND*	ND*	ND*	ND*	ND*	27
<i>Avg Diluted Conc</i>	μCi/ml	ND*	ND*	ND*	ND*	ND*	
<i>% of Limit</i>	%	N/A	N/A	N/A	N/A	N/A	
Gross α	Ci	ND*	1.31E-04	1.24E-04	ND*	2.55E-04	29
<i>Avg Diluted Conc</i>	μCi/ml	0.00E+00	1.30E-09	1.05E-09	0.00E+00	5.11E-10	
Vol Liquid Effluent⁷	Liters	4.06E+06	3.06E+06	3.35E+06	3.07E+06	1.35E+07	
Dilution Volume⁸	Liters	1.41E+08	9.81E+07	1.14E+08	1.32E+08	4.85E+08	
Avg river flow⁹	m ³ /s	1.28E+03	3.64E+03	2.33E+03	1.39E+03	2.16E+03	
Time period for releases	hrs	9.48E+01	6.68E+01	7.87E+01	9.18E+01	3.32E+02	

*ND means measurements were performed but no activity was detected.

⁵ Safety Analysis calculation 87-063-00, January 6, 1988

⁶ Excludes ³H, noble gases, and gross alpha.

⁷ Primary system liquid effluent plus secondary liquid effluent, prior to dilution.

⁸ Does not include Missouri River dilution.

⁹ Average Missouri River flow for the year at the Hermann, MO monitoring station as reported by the USGS.

Table A-2A: Liquid Effluents- Batch Mode						
Fission & Activation Products	Units	Quarter 1	Quarter 2	Quarter 3	Quarter 4	Total for the year
⁵¹ Cr	Ci	8.20E-04	9.83E-05	1.10E-04	4.87E-05	1.08E-03
⁵⁴ Mn	Ci	ND*	ND*	ND*	ND*	ND*
⁵⁸ Co	Ci	3.92E-03	8.42E-04	4.76E-04	ND*	5.23E-03
⁶⁰ Co	Ci	2.64E-03	1.42E-03	1.39E-03	1.84E-04	5.64E-03
⁶³ Ni	Ci	4.08E-04	7.93E-04	2.68E-03	2.27E-03	6.15E-03
^{117m} Sn	Ci	ND*	3.74E-06	ND*	ND*	3.74E-06
¹²⁴ Sb	Ci	4.00E-03	2.14E-04	5.35E-05	ND*	4.27E-03
¹²⁵ Sb	Ci	2.45E-02	5.02E-03	1.07E-02	3.03E-03	4.32E-02
¹²⁶ Sb	Ci	ND*	ND*	ND*	ND*	ND*
¹³² Te	Ci	9.57E-06	ND*	ND*	ND*	9.57E-06
¹³⁷ Cs	Ci	2.64E-05	ND*	7.06E-05	3.59E-05	1.33E-04
¹³⁸ Cs	Ci	1.11E-04	ND*	ND*	ND*	1.11E-04
Total	Ci	3.64E-02	8.39E-03	1.55E-02	5.56E-03	6.59E-02
Dissolved & Entrained Gases	Units	Quarter 1	Quarter 2	Quarter 3	Quarter 4	Total for the year
	Ci	ND*	ND*	ND*	ND*	ND*
Total	Ci	ND*	ND*	ND*	ND*	ND*
³ H	Ci	1.31E+02	6.20E+01	1.32E+02	3.26E+02	6.52E+02
Gross α	Ci	ND*	1.31E-04	1.24E-04	ND*	2.55E-04

*ND means measurements were performed but no activity was detected.

Table A-3: Low-Level Waste Shipped for 2024

Resins, Filters, And Evaporator Bottoms			
Waste Class	Volume		Curies Shipped
	ft ³	m ³	
A	3.74E+02	1.06E+01	1.37E+00
B	0.00E+00	0.00E+00	0.00E+00
C	0.00E+00	0.00E+00	0.00E+00
Unclassified	0.00E+00	0.00E+00	0.00E+00
All	3.74E+02	1.06E+01	1.37E+00
Major Nuclides for the Above Table: H-3, C-14, Mn-54, Fe-55, Co-58, Co-60, Ni-63, Sr-90, Nb-94, Tc-99, Sb-125, I-129, Cs-137, Pu-238, Pu-240, Pu-241, Am-241, Cm-242, Cm-244			
Dry Active Waste (DAW)			
Waste Class	Volume		Curies Shipped
	ft ³	m ³	
A	6.40E+03	1.81E+02	7.25E-02
B	0.00E+00	0.00E+00	0.00E+00
C	0.00E+00	0.00E+00	0.00E+00
Unclassified	0.00E+00	0.00E+00	0.00E+00
All	6.40E+03	1.81E+02	7.25E-02
Major Nuclides for the Above Table: H-3, C-14, Cr-51, Mn-54, Fe-55, Fe-59, Co-58, Co-60, Ni-63, Sr-90, Zr-95, Nb-95, Tc-99, Sb-125, I-129, Cs-137, Pu-238, Pu-239, Pu-241, Am-241, Cm-242, Cm-244			
Irradiated Components			
Waste Class	Volume		Curies Shipped
	ft ³	m ³	
A	0.00E+00	0.00E+00	0.00E+00
B	0.00E+00	0.00E+00	0.00E+00
C	0.00E+00	0.00E+00	0.00E+00
Unclassified	0.00E+00	0.00E+00	0.00E+00
All	0.00E+00	0.00E+00	0.00E+00
Major Nuclides for the Above Table: N/A			

Table A-3: Low-Level Waste for 2024 (continued)			
Other Waste			
Waste Class	Volume		Curies Shipped
	ft ³	m ³	
A	4.77E+02	1.35E+01	2.17E-01
B	0.00E+00	0.00E+00	0.00E+00
C	0.00E+00	0.00E+00	0.00E+00
Unclassified	0.00E+00	0.00E+00	0.00E+00
All	4.77E+02	1.35E+01	2.17E-01
Major Nuclides for the Above Table: H-3, C-14, Co-60, Tc-99, I-129, Cs-137			
Sum Of All Low-Level Waste Shipped From Site			
Waste Class	Volume		Curies Shipped
	ft ³	m ³	
A	7.25E+03	2.05E+02	1.66E+00
B	0.00E+00	0.00E+00	0.00E+00
C	0.00E+00	0.00E+00	0.00E+00
Unclassified	0.00E+00	0.00E+00	0.00E+00
All	7.25E+03	2.05E+02	1.66E+00
Major Nuclides for the Above Table: H-3, C-14, Cr-51, Mn-54, Fe-55, Fe-59, Co-58, Co-60, Ni-63, Sr-90, Zr-95, Nb-94, Nb-95, Tc-99, Sb-125, I-129, Cs-137, Pu-238, Pu-239, Pu-240, Pu-241, Am-241, Cm-242, Cm-244			

SOLIDIFICATION AGENT

None used.

IRRADIATED FUEL SHIPMENTS (Disposition)

There were no shipments of irradiated fuel during the reporting period.

Table A-4: Dose Assessments, 10 CFR 50, Appendix I					
	Quarter 1	Quarter 2	Quarter 3	Quarter 4	Yearly total
Liquid Effluent Dose Limit, Total Body (mrem)	1.5	1.5	1.5	1.5	3
Total Body Dose (mrem)	3.03E-04	1.16E-04	4.30E-04	6.71E-04	1.51E-03
% Limit	0.02%	0.01%	0.03%	0.04%	0.05%
Liquid Effluent Dose Limit, Maximum Organ (mrem)	5	5	5	5	10
Maximum Organ Dose (mrem)	3.85E-04	1.82E-04	8.23E-04	7.38E-04	1.80E-03
% Limit	0.01%	0.00%	0.02%	0.01%	0.02%
Gaseous Effluent Dose Limit, Gamma Air (mrad)	5	5	5	5	10
Gamma Air Dose (mrad)	1.08E-03	7.72E-05	8.82E-04	6.65E-05	2.11E-03
% Limit	0.02%	0.00%	0.02%	0.00%	0.02%
Gaseous Effluent Dose Limit, Beta Air (mrad)	10	10	10	10	20
Beta Air Dose (mrad)	3.81E-04	2.72E-05	3.11E-04	2.35E-05	7.43E-04
% Limit	0.00%	0.00%	0.00%	0.00%	0.00%
Gaseous Effluent Dose Limit, Maximum Organ (mrem)	7.5	7.5	7.5	7.5	15
Maximum organ dose ¹⁰ (mrem)	4.30E-03	6.04E-03	1.26E-02	5.27E-03	2.82E-02
% Limit	0.06%	0.08%	0.17%	0.07%	0.19%
¹⁴C Maximum organ dose (mrem)¹¹	4.00E-03	4.00E-03	4.00E-03	4.00E-03	1.60E-02

¹⁰ Iodine, ³H, and particulates with greater than an 8 day half- life.

¹¹ Not included in above totals

Table A-5: EPA 40 CFR 190 Individual in the Unrestricted Area			
	Whole Body	Thyroid	Max Other Organ
Dose Limit	25 mrem	75 mrem	25 mrem
Dose	3.30E-02	3.30E-02	4.72E-02
% Limit	0.13%	0.04%	0.19%

Appendix B

*Meteorological Dispersion Parameters and Joint Frequency Tables; Totals of Hours
at Each Wind Speed & Direction for the period January 1, 2024- December 31, 2024*

Meteorological Dispersion Parameters for the Reporting Period

Nearest Resident Dispersion Parameters

Direction: NNW

Distance: 2913 meters

X/Q, Undecayed and Undepleted: 1.95E-06

X/Q Decayed and Undepleted: 1.81E-06

X/Q Decayed and Depleted: 1.60E-06

D/Q Deposition rate: 2.89E-09

Site Boundary Dispersion Parameters

Direction: S

Distance: 1300 meters

X/Q, Undecayed and Undepleted: 3.70E-06

X/Q Decayed and Undepleted: 3.56E-06

X/Q Decayed and Depleted: 3.24E-06

D/Q Deposition rate: 5.23E-09

Meteorological Data Recovery Rate

10 meters elevation	Hours of valid data: 8684
	Total hours in period: 8784
	Recovery rate: 98.86%
60 meters elevation	Hours of valid data: 8784
	Total hours in period: 8784
	Recovery rate: 100%

Callaway Energy Center
2024 Annual Radioactive Effluent Release Report

Joint Frequency Distribution: Hours at Wind and Direction												
January - December, 2024												
All Stabilities												
Elevations::	Winds	10M	Stability	60M								
Wind Direction Sector	Wind Speed Range (m/s)											
	<0.5	0.5-1	1.1-1.5	1.6-2	2.1-3	3.1-4	4.1-5	5.1-6	6.1-8	8.1-10	>10.00	Total
N	21	70	70	64	119	95	70	31	20	1	0	561
NNE	6	45	50	51	117	85	34	15	2	0	0	405
NE	5	35	69	50	83	51	16	3	3	0	0	315
ENE	12	40	49	30	79	58	19	1	0	0	0	288
E	7	38	50	48	68	54	40	13	1	0	0	319
ESE	10	46	58	84	106	105	38	12	6	0	0	465
SE	16	69	107	161	298	129	38	11	1	0	0	830
SSE	23	85	84	139	287	192	99	47	15	0	0	971
S	17	65	59	51	230	163	105	59	57	7	3	816
SSW	10	36	26	42	147	171	80	31	8	3	0	554
SW	9	48	35	49	90	79	50	22	14	1	0	397
WSW	5	43	32	31	54	27	21	10	0	0	0	223
W	11	39	43	61	112	57	46	27	28	1	0	425
WNW	7	74	82	88	153	87	57	33	12	0	0	593
NW	18	64	85	95	198	95	93	51	23	0	0	722
NNW	21	52	59	58	134	110	57	38	11	0	0	540
Tot	198	849	958	1102	2275	1558	863	404	201	13	3	8424
Hours of	Calm		260								
Hours of	Variable	Direction		0								
Hours of	Valid	Data . . .		8684								recovery rate:
Hours of	Missing	Data . . .		100								98.86%
Hours in	Period		8784								

Callaway Energy Center
2024 Annual Radioactive Effluent Release Report

Joint Frequency Distribution: Hours at Wind and direction												
January - December, 2024												
Stability	Class	A	Extremely	Unstable	based	on	Lapse	Rate				
Elevations::	Winds	10m	Stability	60m								
Wind Direction Sector	Wind Speed Range (m/s)											
	<0.5	0.5-1	1.1-1.5	1.6-2	2.1-3	3.1-4	4.1-5	5.1-6	6.1-8	8.1-10	>10.00	Total
N	0	0	0	1	1	0	1	0	0	0	0	3
NNE	0	0	0	0	0	1	0	0	0	0	0	1
NE	0	0	0	0	0	0	0	0	0	0	0	0
ENE	0	0	0	0	0	1	0	0	0	0	0	1
E	0	0	0	0	0	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0	2	3	0	0	5
SE	0	0	0	1	1	4	5	3	1	0	0	15
SSE	0	0	0	0	0	4	2	1	3	0	0	10
S	0	0	0	0	2	1	5	4	6	4	0	22
SSW	0	0	0	0	0	8	4	8	1	1	0	22
SW	0	0	0	0	0	0	3	4	3	1	0	11
WSW	0	0	0	0	0	0	0	3	0	0	0	3
W	0	0	0	0	0	1	2	0	0	0	0	3
WNW	0	0	0	0	3	1	5	6	0	0	0	15
NW	0	0	0	0	0	2	7	3	5	0	0	17
NNW	0	0	0	0	0	0	1	0	0	0	0	1
Tot	0	0	0	2	7	23	35	34	22	6	0	129
Hours of	Calm		0								
Hours of	Variable	Direction		0								
Hours of	Valid	Data ...		129								
Hours of	Missing	Data ...		100								
Hours in	Period		8784								

Callaway Energy Center
2024 Annual Radioactive Effluent Release Report

Joint Frequency Distribution: Hours at Wind and direction												
January - December, 2024												
Stability	Class	B	Moderately Unstable	based	on	Lapse	Rate					
Elevations::	Winds	10m	Stability	60m								
Wind Direction Sector	Wind Speed Range (m/s)											
	<0.5	0.5-1	1.1-1.5	1.6-2	2.1-3	3.1-4	4.1-5	5.1-6	6.1-8	8.1-10	>10.00	Total
N	0	0	0	0	0	2	4	1	2	0	0	9
NNE	0	0	0	0	0	3	1	0	0	0	0	4
NE	0	0	0	0	1	0	1	0	0	0	0	2
ENE	0	0	0	0	0	0	2	0	0	0	0	2
E	0	0	0	0	0	1	1	0	0	0	0	2
ESE	0	0	0	0	1	6	2	1	0	0	0	10
SE	0	1	2	0	5	10	2	0	0	0	0	20
SSE	0	0	0	1	9	7	11	2	1	0	0	31
S	0	0	1	1	12	9	10	3	8	3	0	47
SSW	0	0	0	1	5	7	8	5	1	2	0	29
SW	0	0	0	1	1	6	9	3	3	0	0	23
WSW	0	0	0	0	2	0	1	0	0	0	0	3
W	0	0	0	0	2	1	4	5	1	0	0	13
WNW	0	0	1	0	7	8	5	2	0	0	0	23
NW	0	0	2	1	9	8	8	6	1	0	0	35
NNW	0	1	0	0	2	3	2	0	0	0	0	8
Tot	0	2	6	5	56	71	71	28	17	5	0	261
Hours of	Calm		0								
Hours of	Variable	Direction		0								
Hours of	Valid	Data ...		261								
Hours of	Missing	Data ...		100								
Hours in	Period		8784								

Callaway Energy Center
2024 Annual Radioactive Effluent Release Report

Joint Frequency Distribution: Hours at Wind and direction												
January - December, 2024												
Stability	Class	C	Slightly	Unstable	based	on	Lapse	Rate				
Elevations::	Winds	10m	Stability	60m								
Wind Direction Sector	Wind Speed Range (m/s)											
	<0.5	0.5-1	1.1-1.5	1.6-2	2.1-3	3.1-4	4.1-5	5.1-6	6.1-8	8.1-10	>10.00	Total
N	0	0	1	2	2	8	5	3	0	0	0	21
NNE	0	0	0	1	6	10	6	1	0	0	0	24
NE	0	1	0	0	4	4	2	0	0	0	0	11
ENE	0	3	0	0	4	4	7	0	0	0	0	18
E	0	0	0	0	2	5	3	0	0	0	0	10
ESE	0	2	0	1	5	8	6	1	1	0	0	24
SE	0	2	2	5	21	14	5	1	0	0	0	50
SSE	0	2	2	10	11	11	6	4	0	0	0	46
S	0	4	3	3	28	16	13	6	12	0	0	85
SSW	0	3	0	5	19	24	16	5	4	0	0	76
SW	1	4	1	0	8	8	7	3	3	0	0	35
WSW	0	0	1	1	5	2	3	1	0	0	0	13
W	1	0	0	3	12	4	2	4	4	0	0	30
WNW	0	4	2	5	11	3	3	4	0	0	0	32
NW	0	0	1	3	17	6	8	6	3	0	0	44
NNW	0	0	1	4	6	11	4	3	0	0	0	29
Tot	2	25	14	43	161	138	96	42	27	0	0	548
Hours of	Calm		0								
Hours of	Variable	Direction		0								
Hours of	Valid	Data ...		548								
Hours of	Missing	Data ...		100								
Hours in	Period		8784								

Callaway Energy Center
2024 Annual Radioactive Effluent Release Report

Joint Frequency Distribution: Hours at Wind and direction												
January - December, 2024												
Stability	Class	D	Neutral		based	on	Lapse	Rate				
Elevations::	Winds	10m	Stability	60m								
Wind Direction Sector	Wind Speed Range (m/s)											
	<0.5	0.5-1	1.1-1.5	1.6-2	2.1-3	3.1-4	4.1-5	5.1-6	6.1-8	8.1-10	>10.00	Total
N	5	13	16	18	52	62	53	26	14	1	0	260
NNE	0	10	13	16	65	64	24	14	2	0	0	208
NE	1	4	15	13	48	42	13	3	2	0	0	141
ENE	2	9	14	18	50	46	9	1	0	0	0	149
E	1	5	11	26	42	40	32	10	0	0	0	167
ESE	1	9	9	34	56	57	26	5	2	0	0	199
SE	0	10	25	48	119	57	18	6	0	0	0	283
SSE	8	21	17	27	56	46	40	23	8	0	0	246
S	4	14	11	16	55	49	40	26	23	0	3	241
SSW	2	6	9	15	42	60	37	8	1	0	0	180
SW	2	7	9	18	36	36	20	11	5	0	0	144
WSW	1	8	13	14	19	12	11	6	0	0	0	84
W	4	3	10	25	52	36	30	17	23	1	0	201
WNW	0	13	17	29	98	57	36	19	10	0	0	279
NW	2	9	15	25	97	60	66	35	14	0	0	323
NNW	4	15	19	21	57	67	40	28	9	0	0	260
Tot	37	156	223	363	944	791	495	238	113	2	3	3365
Hours of	Calm		32								
Hours of	Variable	Direction		0								
Hours of	Valid	Data ...		3397								
Hours of	Missing	Data ...		100								
Hours in	Period		8784								

Callaway Energy Center
2024 Annual Radioactive Effluent Release Report

Joint Frequency Distribution: Hours at Wind and direction												
January - December, 2024												
Stability	Class	E	Slightly	Stable	based	on	Lapse	Rate				
Elevations::	Winds	10m	Stability	60m								
Wind Direction Sector	Wind Speed Range (m/s)											
	<0.5	0.5-1	1.1-1.5	1.6-2	2.1-3	3.1-4	4.1-5	5.1-6	6.1-8	8.1-10	>10.00	Total
N	7	14	17	28	51	22	7	1	4	0	0	151
NNE	1	8	10	20	36	7	3	0	0	0	0	85
NE	0	9	25	28	28	5	0	0	1	0	0	96
ENE	7	9	15	10	24	7	1	0	0	0	0	73
E	3	17	20	20	24	8	4	3	1	0	0	100
ESE	5	21	29	37	42	34	4	3	0	0	0	175
SE	9	28	41	69	112	40	8	1	0	0	0	308
SSE	5	16	20	32	79	82	40	17	3	0	0	294
S	3	10	21	16	72	73	32	20	8	0	0	255
SSW	2	8	10	11	55	63	15	5	1	0	0	170
SW	2	15	12	18	30	25	11	1	0	0	0	114
WSW	2	14	12	7	17	12	6	0	0	0	0	70
W	2	10	18	25	33	15	8	1	0	0	0	112
WNW	4	19	16	32	31	18	8	2	2	0	0	132
NW	4	12	20	29	49	19	4	1	0	0	0	138
NNW	13	10	12	9	43	27	10	7	2	0	0	133
Tot	69	220	298	391	726	457	161	62	22	0	0	2406
Hours of	Calm		95								
Hours of	Variable	Direction		0								
Hours of	Valid	Data ...		2501								
Hours of	Missing	Data ...		100								
Hours in	Period		8784								

Callaway Energy Center
2024 Annual Radioactive Effluent Release Report

Joint Frequency Distribution: Hours at Wind and direction												
January - December, 2024												
Stability	Class	F	Moderately	Stable	based	on	Lapse	Rate				
Elevations::	Winds	10m	Stability	60m								
Wind Direction Sector	Wind Speed Range (m/s)											
	<0.5	0.5-1	1.1-1.5	1.6-2	2.1-3	3.1-4	4.1-5	5.1-6	6.1-8	8.1-10	>10.00	Total
N	2	11	14	6	12	1	0	0	0	0	0	46
NNE	2	10	15	11	10	0	0	0	0	0	0	48
NE	2	8	13	9	2	0	0	0	0	0	0	34
ENE	2	12	17	2	1	0	0	0	0	0	0	34
E	1	9	17	2	0	0	0	0	0	0	0	29
ESE	3	7	20	12	2	0	0	0	0	0	0	44
SE	4	18	20	31	36	3	0	0	0	0	0	112
SSE	6	13	18	34	91	31	0	0	0	0	0	193
S	3	16	13	10	58	15	5	0	0	0	0	120
SSW	2	9	4	8	26	9	0	0	0	0	0	58
SW	3	10	8	11	10	4	0	0	0	0	0	46
WSW	1	15	6	9	10	1	0	0	0	0	0	42
W	3	7	11	6	9	0	0	0	0	0	0	36
WNW	0	17	20	13	2	0	0	0	0	0	0	52
NW	5	16	18	26	17	0	0	0	0	0	0	82
NNW	0	7	8	15	20	2	0	0	0	0	0	52
Tot	39	185	222	205	306	66	5	0	0	0	0	1028
Hours of	Calm		76								
Hours of	Variable	Direction		0								
Hours of	Valid	Data ...		1104								
Hours of	Missing	Data ...		100								
Hours in	Period		8784								

Callaway Energy Center
2024 Annual Radioactive Effluent Release Report

Joint Frequency Distribution: Hours at Wind and direction												
January - December, 2024												
Stability	Class	G	Extremely	Stable	based	on	Lapse	Rate				
Elevations::	Winds	10m	Stability	60m								
Wind Direction Sector	Wind Speed Range (m/s)											
	<0.5	0.5-1	1.1-1.5	1.6-2	2.1-3	3.1-4	4.1-5	5.1-6	6.1-8	8.1-10	>10.00	Total
N	7	32	22	9	1	0	0	0	0	0	0	71
NNE	3	17	12	3	0	0	0	0	0	0	0	35
NE	2	13	16	0	0	0	0	0	0	0	0	31
ENE	1	7	3	0	0	0	0	0	0	0	0	11
E	2	7	2	0	0	0	0	0	0	0	0	11
ESE	1	7	0	0	0	0	0	0	0	0	0	8
SE	3	10	17	7	4	1	0	0	0	0	0	42
SSE	4	33	27	35	41	11	0	0	0	0	0	151
S	7	21	10	5	3	0	0	0	0	0	0	46
SSW	4	10	3	2	0	0	0	0	0	0	0	19
SW	1	12	5	1	5	0	0	0	0	0	0	24
WSW	1	6	0	0	1	0	0	0	0	0	0	8
W	1	19	4	2	4	0	0	0	0	0	0	30
WNW	3	21	26	9	1	0	0	0	0	0	0	60
NW	7	27	29	11	9	0	0	0	0	0	0	83
NNW	4	19	19	9	6	0	0	0	0	0	0	57
Tot	51	261	195	93	75	12	0	0	0	0	0	687
Hours of	Calm		57								
Hours of	Variable	Direction		0								
Hours of	Valid	Data ...		744								
Hours of	Missing	Data ...		100								
Hours in	Period		8784								

Callaway Energy Center
2024 Annual Radioactive Effluent Release Report

Joint Frequency Distribution: Hours at Wind and direction												
January - December, 2024												
All	Stabilities											
Elevations::	Winds	60m	Stability	60m								
Wind Direction Sector	Wind Speed Range (m/s)											
	<0.5	0.5-1	1.1-1.5	1.6-2	2.1-3	3.1-4	4.1-5	5.1-6	6.1-8	8.1-10	>10.00	Total
N	2	4	10	14	44	71	147	101	108	15	3	519
NNE	0	6	10	12	53	112	113	99	49	2	0	456
NE	2	9	12	13	49	96	92	55	18	2	0	348
ENE	2	5	5	15	70	86	102	66	13	0	0	364
E	0	8	8	12	59	83	107	71	14	0	0	362
ESE	1	7	8	14	41	88	110	99	35	3	0	406
SE	0	16	34	56	213	207	142	56	31	0	0	755
SSE	2	7	13	26	121	165	211	182	124	14	0	865
S	1	8	17	23	86	133	178	193	235	70	23	967
SSW	3	14	10	15	76	87	121	170	218	19	13	746
SW	2	8	14	24	56	54	92	114	188	33	8	593
WSW	1	8	13	9	47	42	55	50	62	20	1	308
W	2	8	6	24	43	65	71	37	68	30	29	383
WNW	1	6	14	13	61	77	92	106	131	51	17	569
NW	1	2	6	22	63	90	99	129	152	67	16	647
NNW	0	6	8	14	45	72	90	101	94	18	0	448
Tot	20	122	188	306	1127	1528	1822	1629	1540	344	110	8736
Hours of	Calm		48								
Hours of	Variable	Direction		0								
Hours of	Valid	Data ...		8784								recovery rate:
Hours of	Missing	Data ...		0								100.00%
Hours in	Period		8784								

Callaway Energy Center
2024 Annual Radioactive Effluent Release Report

Joint Frequency Distribution: Hours at Wind and direction												
January - December, 2024												
Stability	Class	A	Extremely	Unstable	based	on	Lapse	Rate				
Elevations::	Winds	60m	Stability	60m								
Wind Direction Sector	Wind Speed Range (m/s)											
	<0.5	0.5-1	1.1-1.5	1.6-2	2.1-3	3.1-4	4.1-5	5.1-6	6.1-8	8.1-10	>10.00	Total
N	0	0	0	0	0	0	1	1	0	0	0	2
NNE	0	0	0	0	0	1	1	0	0	0	0	2
NE	0	0	0	0	0	0	0	0	0	0	0	0
ENE	0	0	0	0	0	1	0	0	0	0	0	1
E	0	0	0	0	0	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0	0	5	0	0	5
SE	0	0	0	0	1	1	6	2	1	0	0	11
SSE	0	0	0	0	0	1	3	0	5	1	0	10
S	0	0	0	0	1	0	2	6	5	5	5	24
SSW	0	0	0	0	0	1	2	3	11	2	1	20
SW	0	0	0	0	0	0	0	1	8	3	3	15
WSW	0	0	0	0	0	0	0	0	0	3	0	3
W	0	0	0	0	0	0	1	0	1	2	0	4
WNW	0	0	0	0	0	0	2	4	13	8	1	28
NW	0	0	0	0	0	0	0	1	3	4	1	9
NNW	0	0	0	0	0	0	0	1	0	0	0	1
Tot	0	0	0	0	2	5	18	19	52	28	11	135
Hours of	Calm		0								
Hours of	Variable	Direction		0								
Hours of	Valid	Data ...		135								
Hours of	Missing	Data ...		0								
Hours in	Period		8784								

Callaway Energy Center
2024 Annual Radioactive Effluent Release Report

Joint Frequency Distribution: Hours at Wind and direction												
January - December, 2024												
Stability	Class	B	Moderately	Unstable	based	on	Lapse	Rate				
Elevations::	Winds	60m	Stability	60m								
Wind Direction Sector	Wind Speed Range (m/s)											
	<0.5	0.5-1	1.1-1.5	1.6-2	2.1-3	3.1-4	4.1-5	5.1-6	6.1-8	8.1-10	>10.00	Total
N	0	0	0	0	0	0	4	3	0	0	0	7
NNE	0	0	0	0	1	2	1	1	2	1	0	8
NE	0	0	0	0	0	0	1	0	0	0	0	1
ENE	0	0	0	0	0	0	0	3	0	0	0	3
E	0	0	0	0	0	0	1	0	0	0	0	1
ESE	0	0	0	0	0	1	2	2	0	0	0	5
SE	0	0	0	0	3	8	7	0	1	0	0	19
SSE	0	0	0	1	6	6	7	9	3	0	0	32
S	0	0	0	0	4	10	7	9	4	5	3	42
SSW	0	0	0	0	2	6	8	5	6	0	5	32
SW	0	0	0	0	2	0	6	6	11	3	1	29
WSW	0	0	0	0	0	0	0	1	3	0	0	4
W	0	0	0	0	0	2	1	1	3	4	0	11
WNW	0	0	0	0	2	4	2	8	8	5	0	29
NW	0	0	0	0	0	2	9	4	18	4	0	37
NNW	0	0	0	0	0	1	2	1	0	0	0	4
Tot	0	0	0	1	20	42	58	53	59	22	9	264
Hours of	Calm		0								
Hours of	Variable	Direction		0								
Hours of	Valid	Data ...		264								
Hours of	Missing	Data ...		0								
Hours in	Period		8784								

Callaway Energy Center
2024 Annual Radioactive Effluent Release Report

Joint Frequency Distribution: Hours at Wind and direction												
January - December, 2024												
Stability	Class	C	Slightly	Unstable	based	on	Lapse	Rate				
Elevations::	Winds	60m	Stability	60m								
Wind Direction Sector	Wind Speed Range (m/s)											
	<0.5	0.5-1	1.1-1.5	1.6-2	2.1-3	3.1-4	4.1-5	5.1-6	6.1-8	8.1-10	>10.00	Total
N	0	0	0	0	0	4	5	3	0	0	0	12
NNE	0	0	0	0	2	9	11	10	2	0	0	34
NE	0	0	0	0	3	5	4	2	0	0	0	14
ENE	0	0	0	1	6	6	3	3	0	0	0	19
E	0	0	0	0	2	1	5	4	0	0	0	12
ESE	0	0	0	0	1	1	5	3	3	0	0	13
SE	0	0	0	0	9	18	12	3	1	0	0	43
SSE	0	0	0	4	18	14	11	3	5	0	0	55
S	0	0	0	1	15	18	13	5	16	9	2	79
SSW	0	0	0	1	19	18	15	12	7	3	3	78
SW	0	0	0	2	3	9	8	10	15	5	0	52
WSW	0	0	0	0	4	3	2	3	5	1	0	18
W	0	0	0	2	6	2	2	0	2	2	3	19
WNW	0	0	0	1	6	13	4	4	8	5	2	43
NW	0	0	0	2	4	10	7	7	10	6	1	47
NNW	0	0	0	0	1	7	7	2	9	0	0	26
Tot	0	0	0	14	99	138	114	74	83	31	11	564
Hours of	Calm		0								
Hours of	Variable	Direction		0								
Hours of	Valid	Data ...		564								
Hours of	Missing	Data ...		0								
Hours in	Period		8784								

Callaway Energy Center
2024 Annual Radioactive Effluent Release Report

Joint Frequency Distribution: Hours at Wind and direction												
January - December, 2024												
Stability	Class	D	Neutral	Stability	based	on	Lapse	Rate				
Elevations::	Winds	60m	Stability	60m								
Wind Direction Sector	Wind Speed Range (m/s)											
	<0.5	0.5-1	1.1-1.5	1.6-2	2.1-3	3.1-4	4.1-5	5.1-6	6.1-8	8.1-10	>10.00	Total
N	1	3	6	8	26	29	75	36	60	9	3	256
NNE	0	1	5	3	32	63	43	29	26	1	0	203
NE	1	4	6	10	20	52	32	15	6	1	0	147
ENE	1	4	3	12	41	41	47	14	5	0	0	168
E	0	4	3	6	26	30	32	22	9	0	0	132
ESE	0	5	3	10	25	34	30	37	18	2	0	164
SE	0	7	9	15	73	78	48	32	20	0	0	282
SSE	1	0	7	14	55	58	48	41	32	7	0	263
S	0	3	9	14	35	44	41	32	70	24	11	283
SSW	2	7	4	10	25	27	40	42	34	4	3	198
SW	0	4	9	13	24	18	30	37	42	8	4	189
WSW	0	2	9	5	18	14	26	19	24	11	1	129
W	1	3	4	10	17	32	36	10	27	20	26	186
WNW	0	0	7	6	39	41	43	39	48	26	11	260
NW	1	0	4	13	42	43	48	43	62	51	12	319
NNW	0	3	3	9	26	36	43	45	50	14	0	229
Tot	8	50	91	158	524	640	662	493	533	178	71	3408
Hours of	Calm		7								
Hours of	Variable	Direction		0								
Hours of	Valid	Data . . .		3415								
Hours of	Missing	Data . . .		0								
Hours in	Period		8784								

Callaway Energy Center
2024 Annual Radioactive Effluent Release Report

Joint Frequency Distribution: Hours at Wind and direction												
January - December, 2024												
Stability	Class	E	Slightly	Stable	based	on	Lapse	Rate				
Elevations::	Winds	60m	Stability	60m								
Wind Direction Sector	Wind Speed Range (m/s)											
	<0.5	0.5-1	1.1-1.5	1.6-2	2.1-3	3.1-4	4.1-5	5.1-6	6.1-8	8.1-10	>10.00	Total
N	1	1	2	3	10	24	35	32	24	6	0	138
NNE	0	1	1	3	8	27	35	35	13	0	0	123
NE	1	4	2	1	13	30	31	16	1	1	0	100
ENE	0	0	1	2	9	26	17	23	2	0	0	80
E	0	3	2	4	21	29	25	18	5	0	0	107
ESE	0	1	3	2	11	38	51	33	9	1	0	149
SE	0	3	11	13	79	75	59	19	7	0	0	266
SSE	1	2	2	1	28	50	82	79	52	6	0	303
S	1	4	5	4	19	22	38	63	104	27	2	289
SSW	0	4	2	0	10	12	20	47	95	6	1	197
SW	0	1	4	7	17	17	29	36	77	14	0	202
WSW	1	2	2	1	12	13	12	11	26	5	0	85
W	1	2	1	9	11	15	17	14	23	2	0	95
WNW	0	3	3	3	9	11	23	36	37	7	3	135
NW	0	2	2	2	7	18	19	54	37	2	2	145
NNW	0	2	2	2	7	11	19	33	9	4	0	89
Tot	6	35	45	57	271	418	512	549	521	81	8	2503
Hours of	Calm		17								
Hours of	Variable	Direction		0								
Hours of	Valid	Data ...		2520								
Hours of	Missing	Data ...		0								
Hours in	Period		8784								

Callaway Energy Center
2024 Annual Radioactive Effluent Release Report

Joint Frequency Distribution: Hours at Wind and direction												
January - December, 2024												
Stability	Class	F	Moderately	Stable	based	on	Lapse	Rate				
Elevations::	Winds	60m	Stability	60m								
Wind Direction Sector	Wind Speed Range (m/s)											
	<0.5	0.5-1	1.1-1.5	1.6-2	2.1-3	3.1-4	4.1-5	5.1-6	6.1-8	8.1-10	>10.00	Total
N	0	0	2	2	4	8	11	13	9	0	0	49
NNE	0	0	1	3	4	5	13	18	4	0	0	48
NE	0	0	2	0	4	6	11	16	6	0	0	45
ENE	0	0	1	0	7	7	13	12	1	0	0	41
E	0	1	1	0	5	10	31	15	0	0	0	63
ESE	0	0	0	0	2	6	13	21	0	0	0	42
SE	0	3	7	15	33	18	9	0	0	0	0	85
SSE	0	1	1	2	7	30	43	41	23	0	0	148
S	0	1	2	4	3	20	35	56	26	0	0	147
SSW	1	1	1	1	4	14	13	49	56	4	0	144
SW	1	2	1	2	5	4	12	19	32	0	0	78
WSW	0	1	0	1	6	8	7	9	4	0	0	36
W	0	0	1	2	4	7	11	8	11	0	0	44
WNW	1	2	2	2	4	6	11	13	4	0	0	45
NW	0	0	0	2	8	12	9	11	13	0	0	55
NNW	0	0	0	2	4	14	12	10	13	0	0	55
Tot	3	12	22	38	104	175	254	311	202	4	0	1125
Hours of	Calm		6								
Hours of	Variable	Direction		0								
Hours of	Valid	Data ...		1131								
Hours of	Missing	Data ...		0								
Hours in	Period		8784								

Callaway Energy Center
2024 Annual Radioactive Effluent Release Report

Joint Frequency Distribution: Hours at Wind and direction												
January - December, 2024												
Stability	Class	G	Extremely	Stable	based	on	Lapse	Rate				
Elevations::	Winds	60m	Stability	60m								
Wind Direction Sector	Wind Speed Range (m/s)											
	<0.5	0.5-1	1.1-1.5	1.6-2	2.1-3	3.1-4	4.1-5	5.1-6	6.1-8	8.1-10	>10.00	Total
N	0	0	0	1	4	6	16	13	15	0	0	55
NNE	0	4	3	3	6	5	9	6	2	0	0	38
NE	0	1	2	2	9	3	13	6	5	0	0	41
ENE	1	1	0	0	7	5	22	11	5	0	0	52
E	0	0	2	2	5	13	13	12	0	0	0	47
ESE	1	1	2	2	2	8	9	3	0	0	0	28
SE	0	3	7	13	15	9	1	0	1	0	0	49
SSE	0	4	3	4	7	6	17	9	4	0	0	54
S	0	0	1	0	9	19	42	22	10	0	0	103
SSW	0	2	3	3	16	9	23	12	9	0	0	77
SW	1	1	0	0	5	6	7	5	3	0	0	28
WSW	0	3	2	2	7	4	8	7	0	0	0	33
W	0	3	0	1	5	7	3	4	1	0	0	24
WNW	0	1	2	1	1	2	7	2	13	0	0	29
NW	0	0	0	3	2	5	7	9	9	0	0	35
NNW	0	1	3	1	7	3	7	9	13	0	0	44
Tot	3	25	30	38	107	110	204	130	90	0	0	737
Hours of	Calm		18								
Hours of	Variable	Direction		0								
Hours of	Valid	Data ...		755								
Hours of	Missing	Data ...		0								
Hours in	Period		8784								

Appendix C

Changes to the Callaway Energy Center Offsite Dose Calculation Manual for the year 2024

APA-ZZ-01003, "Off-Site Dose Calculation Manual," current revision 026, was revised 06/18/2021, and FSAR-SP Ch. 16.11, "Offsite Dose Calculation Manual Radiological Effluent Controls" was revised in 2023. A complete copy of each is provided in this appendix.



APA-ZZ-01003

OFF-SITE DOSE CALCULATION MANUAL

MINOR Revision 026

Contents

1.	PURPOSE AND SCOPE	5
2.	LIQUID EFFLUENTS	5
2.1.	Liquid Effluent Monitors	5
2.1.1.	Continuous Liquid Effluent Monitors.....	7
2.1.2.	Radioactive Liquid Batch Release Effluent Monitors.....	7
2.2.	Calculation of Liquid Effluent Monitor Setpoints.....	7
2.2.1.	CALCULATION OF THE ECV SUM.....	7
2.2.2.	CALCULATION OF THE MAXIMUM PERMISSIBLE LIQUID EFFLUENT DISCHARGE FLOW RATE.....	8
2.2.3.	CALCULATION OF LIQUID EFFLUENT MONITOR SETPOINT	9
2.3.	Liquid Effluent Concentration Measurements.....	10
2.4.	Dose due to Liquid Effluents.....	10
2.4.1.	THE MAXIMUM EXPOSED INDIVIDUAL	10
2.4.2.	CALCULATION OF DOSE FROM LIQUID EFFLUENTS	11
2.4.3.	SUMMARY, CALCULATION OF DOSE DUE TO LIQUID EFFLUENTS	13
2.5.	Liquid Radwaste Treatment System	13
2.6.	Liquid Effluents Dose Factors	13
3.	GASEOUS EFFLUENTS	13
3.1.	Gaseous Effluent Monitors	13
3.1.1.	CONTINUOUS RELEASE GASEOUS EFFLUENT MONITORS	14
3.1.2.	BATCH RELEASE GASEOUS EFFLUENT MONITORS	16
3.2.	Gaseous Effluent Monitor Setpoints.....	16
3.2.1.	TOTAL BODY DOSE RATE SETPOINT CALCULATIONS	16
3.2.2.	SKIN DOSE RATE SETPOINT CALCULATION	17
3.3.	Calculation of Dose and Dose Rate from Gaseous Effluents	18
3.3.1.	DOSE RATE FROM GASEOUS EFFLUENTS	18
3.3.2.	DOSE DUE TO GASEOUS EFFLUENTS.....	20
3.4.	Gaseous Radwaste Treatment System.....	22
3.5.	Gaseous Effluents Dose Factors	23
4.	DOSE AND DOSE COMMITMENT FROM URANIUM FUEL CYCLE SOURCES	23

4.1.	Calculation of Dose and Dose Commitment from Uranium Fuel Cycle Sources.....	23
4.1.1.	IDENTIFICATION OF THE MEMBER OF THE PUBLIC	24
4.1.2.	TOTAL DOSE TO THE NEAREST RESIDENT	24
4.1.3.	TOTAL DOSE TO THE CRITICAL RECEPTOR WITHIN THE SITE BOUNDARY	25
5.	RADIOLOGICAL ENVIRONMENTAL MONITORING	29
5.1.	Description Of The Radiological Environmental Monitoring Program	29
5.2.	Performance Testing Of Environmental Thermoluminescence Dosimeters	29
6.	ANNUAL AVERAGE ATMOSPHERIC DISPERSION PARAMETERS	29
6.1.	Annual Atmospheric Dispersion Parameters	29
6.1.1.	Determination of Dispersion Estimates for Special Receptor Locations	29
6.1.2.	Atmospheric Dispersion Parameters for Farming Areas within the Site Boundary	30
6.2.	Annual Meteorological Data Processing.....	30
7.	REPORTING REQUIREMENTS.....	31
7.1.	Annual Radiological Environmental Operating Report.....	31
7.2.	Annual Radioactive Effluent Release Report.....	31
8.	RADIOACTIVE EFFLUENT CONTROLS (REC)	31
9.	ADMINISTRATIVE CONTROLS.....	31
9.1.	Major Changes to Liquid and Gaseous Radwaste Treatment Systems	31
9.2.	Changes to the Offsite Dose Calculation Manual (ODCM)	32
10.	BIBLIOGRAPHY	32
	Table 1: Ingestion Dose Commitment Values (A_{it}) for Adult Age Group.....	37
	Table 2: Bioaccumulation Factor (Bf_i)	40
	Table 3: Dose Factor for Exposure to a Semi- Infinite Cloud of Noble Gases.....	41
	Table 4: Ground Plane Pathway Dose Factors (R_i)	42
	Table 5: Child Inhalation Pathway Dose Factors (R_i)	43
	Table 6: Child Grass- Cow – Milk Pathway Dose Factors (R_i).....	45
	Table 7: Child Grass- Goat – Milk Pathway Dose Factors (R_i).....	47

Table 8: Child Grass- Cow- Meat Pathway Dose Factors (R_i)	49
Table 9: Child Vegetation Pathway Dose Factors (R_i)	51
Table 10: Highest Annual Average Atmospheric Dispersion Parameters	53
Table 11: Application of Atmospheric Dispersion Parameters for Release Permits	54
Table 12: Application of Atmospheric Dispersion Parameters Annual Radioactive Effluent Release Report	55
Table 13: Meteorological Data Selection Hierarchy	56
Table 14: Adult Inhalation Pathway Dose Factors (R_i)	57
Table 15: Adult Grass- Cow – Milk Pathway Dose Factors (R_i)	59
Table 16: Adult Grass- Goat – Milk Pathway Dose Factors (R_i)	61
Table 17: Adult Grass- Cow- Meat Pathway Dose Factors (R_i)	63
Table 18: Adult Vegetation Pathway Dose Factors (R_i)	65
Appendix A: Methodology for Calculating Dose from ^{14}C in Gaseous Effluents	67
Appendix B: Record of Revisions	80

OFF-SITE DOSE CALCULATION MANUAL

1. Purpose and Scope

The Offsite Dose Calculation Manual (ODCM) describes the methodology and parameters used in the calculation of off-site doses resulting from radioactive gaseous and liquid effluents, in the calculation of gaseous and liquid effluent monitoring Alarm/Trip Setpoints, and in the conduct of the Radiological Environmental Monitoring Program. The ODCM also contains the Radioactive Effluent Controls and Radiological Environmental Monitoring Program required by T/S 5.5.4 and FSAR-SP Chapter 16.11.4, and descriptions of the information that should be included in the Annual Radiological Environmental Operating and Annual Effluent Release Reports required by T/S 5.6.2 and T/S 5.6.3

Compliance with the Radiological Effluent Controls limits demonstrates compliance with the limits of 10 CFR 20.1301.^{1,2,3}

The ODCM consists of two parts: FSAR-SP Chapter 16.11 which contains the Radiological Effluent Controls (RECs), and APA-ZZ-01003, which contains the methodology and parameters used to implement the RECs.

2. Liquid Effluents

2.1. Liquid Effluent Monitors

Gross radioactivity monitors which provide for automatic termination of liquid effluent releases are present on the liquid effluent lines. Flow rate measurement devices are present on the liquid effluent lines and the discharge line (cooling tower blowdown). Setpoints, precautions, and limitations applicable to the operation of the Callaway Plant liquid effluent monitors are provided in the appropriate Plant Procedures. Setpoint values are calculated to assure that alarm and trip actions occur prior to exceeding ten times the Effluent Concentration Values (ECV) limits in 10 CFR Part 20 at the release point to the Unrestricted Area. The calculated alarm and trip action setpoints for the liquid effluent line monitors and flow measuring devices must satisfy the following equation:

$$\frac{cf}{F + f} \leq C$$

Eq. 1

Where:

¹ Statements of Consideration, Federal Register, Vol. 56, No. 98, Tuesday, May 21, 1991, Subpart D, page 23374

² 10 CFR 50.36 a (b)

³ Letter, F. J. Congel to J. F. Schmidt, dated April 23, 1991

C is the liquid effluent concentration value (ECV) implementing REC 16.11.1.1 for the site in $\mu\text{Ci/ml}$;

c is the setpoint, in ($\mu\text{Ci/ml}$), of the radioactivity monitor measuring the radioactivity concentration in the effluent line prior to dilution and subsequent release. The setpoint, which is inversely related to the volumetric flow of the effluent line and directly related to the volumetric flow of the dilution stream plus the effluent stream, represents a value, which, if exceeded, would result in concentrations exceeding ten times the values of 10 CFR Part 20 Appendix B, Table 2, Column 2, in the Unrestricted Area;

f is the undiluted waste flow rate as measured at the radiation monitor location, in volume per unit time, but in the same units as **F**, below; and

F is the dilution water flow rate setpoint as measured prior to the release point, in volume per unit time. If **F** is large compared to **f**, then $F + f \cong F$.⁴

The radioactive liquid waste stream is diluted by the plant discharge line prior to entry into the Missouri River. The dilution flow is obtained from the cooling tower blowdown, but should this become unavailable, the plant water treatment facility supplies the necessary dilution flow via a bypass line. No direct discharge of wastewater from the liquid radioactive waste treatment system without the use of dilution flow from the cooling tower blowdown or cooling tower bypass is permitted. A minimum of 3000 gpm dilution flow from the cooling tower blowdown or cooling tower bypass needs to be used to discharge from the liquid radioactive waste treatment system.⁵

The limiting concentration which corresponds to the liquid radwaste effluent monitor setpoint is to be calculated using methodology from the expression above. Thus, the expression for determining the setpoint of the liquid radwaste effluent line monitor becomes:

$$c \leq \frac{C(F + f)}{f} (\mu\text{Ci} / \text{ml})$$

Eq. 2

The alarm/trip setpoint calculations are based on the minimum dilution flow rate (corresponding to the dilution flow rate setpoint), the maximum effluent stream flow rate, and the actual isotopic analysis. Due to the possibility of a simultaneous release from more than one release pathway, a portion of the total site release limit is allocated to each pathway. The determination and usage of the allocation factor is discussed in Section 2.2. In the event the alarm/trip setpoint is reached, an evaluation will be performed using actual dilution and effluent flow values and actual isotopic analysis to ensure that REC 16.11.1.1 limits were not exceeded.

⁴ NUREG-0133, pages AA-1 thru AA-3

⁵ Ameren Missouri Callaway Energy Center State of Missouri National Pollutant Discharge Elimination System (NPDES) Permit, MO-0098001

2.1.1. Continuous Liquid Effluent Monitors

There are no continuous liquid release pathways. Steam Generator Blowdown is discharged to the discharge monitoring tanks for batch release.^{6,7}

2.1.2. Radioactive Liquid Batch Release Effluent Monitors

The radiation monitor associated with the liquid effluent batch release system is:⁸

<u>Monitor I.D.</u>	<u>Description</u>
HB-RE-18	Liquid Radwaste Discharge Monitor

This effluent stream is normally considered to be radioactive. The sampling frequency, minimum analysis frequency, and the type of analysis performed are per FSAR-SP Table 16.11-1.

2.2. Calculation of Liquid Effluent Monitor Setpoints

The dependence of the setpoint, **c**, on the radionuclide distribution, yields, calibration, and monitor parameters, requires that several variables be considered in setpoint calculations.⁹

2.2.1. Calculation of the ECV Sum

The isotopic concentration of the release(s) being considered must be determined. This is obtained from the analyses required per FSAR-SP Table 16.11-1, and is used to calculate an ECV sum (ECVSUM):

$$ECVSUM = \left(\sum (C_i) / (ECV_i) \right) \\ i = g, a, s, t, f$$

Eq. 3

Where:

C_g is the concentration of each measured gamma emitting nuclide observed by gamma-ray spectroscopy of the waste sample;

C_a is the concentration of ²³⁷Np, ²³⁸Pu, ^{239/240}Pu, ²⁴¹Pu, ²⁴¹Am, ²⁴²Cm, & ^{243/244}Cm, in the quarterly composite sample based on previous composite sample analyses;

C_s is the measured concentrations of ⁸⁹Sr and ⁹⁰Sr as determined by analysis of the quarterly composite sample based on previous composite sample analyses;

C_t is the measured concentration of ³H in the waste sample; and

⁶ MP 19-0114

⁷ UOTH 20200008

⁸ FSAR-SP, Section 11.5.2.2.3.2

⁹ NUREG-0133, pages AA-1 thru AA-3

C_f is the measured concentration of ^{55}Fe & ^{63}Ni as determined by analysis of the quarterly composite sample based on previous composite sample analyses.

ECV_g , ECV_s , ECV_a , ECV_f , and ECV_t are ten times the limiting concentrations of the appropriate radionuclides from 10 CFR 20, Appendix B, Table 2, Column 2. For dissolved or entrained noble gases, the concentration shall be limited to 2×10^{-4} $\mu\text{Ci/ml}$ total activity.

For the case $ECVSUM \leq 1$, the monitor tank effluent concentration meets the limits of REC 16.11.1.1 without dilution and the effluent may be released at any desired flow rate. If $ECVSUM > 1$ then dilution is required to ensure compliance with the concentration limits of REC 16.11.1.1. If simultaneous releases are occurring or are anticipated, an allocation fraction, N , must be applied so that available dilution flow may be apportioned among simultaneous discharge pathways. The value of N may be any value between 0 and 1 for a particular discharge point, provided that the sum of the allocation fractions for all discharge points must be ≤ 1 .

2.2.2. Calculation of the Maximum Permissible Liquid Effluent Discharge Flow Rate

The maximum permissible liquid effluent discharge flow rate is calculated by:

$$f_{max} \leq (F + f_p) \cdot SF \cdot N \div (ECVSUM)$$

Eq. 4

Where:

f_{max} is the maximum permissible liquid effluent discharge flow rate, (in gallons/minute);

f_p is the expected undiluted liquid effluent flow rate, in gpm;

N is the allocation fraction which apportions dilution flow among simultaneous discharge pathways (see discussion above); and

SF is the safety factor; an administrative factor used to compensate for statistical fluctuations and errors of measurements. This factor also provides a margin of safety in the calculation of the maximum liquid effluent discharge flow rate (f_{max}). The value of SF should be ≤ 1 .

F and $ECVSUM$ are previously defined.

The dilution water supply is furnished with a flow monitor which isolates the liquid effluent discharge if the dilution flow rate falls below its setpoint value.

In the event that f_{max} is less than f_p , then the value of f_{max} is substituted into the equation for f_p , and a new f_{max} value is calculated. This substitution is performed for three iterations in order to calculate the correct value of f_{max} .

2.2.3. Calculation of Liquid Effluent Monitor Setpoint

The liquid effluent monitors are NaI(Tl) based systems and respond primarily to gamma radiation. Accordingly, their setpoint is based on the total concentration of gamma emitting nuclides in the effluent:

$$c = 0.95 \cdot \left[bkg + \left[\left(\sum C_g \right) \div SF \right] \right]$$

Eq. 5

Where:

c is the monitor setpoint as previously defined, in $\mu\text{Ci/ml}$;

bkg is the monitor background prior to discharge, in $\mu\text{Ci/ml}$, adjusted for monitor response; and

0.95 is a factor for conservatism to ensure the monitor trips prior to exceeding the limits of REC 16.11.1.1

$\sum C_g$ and **SF** are as previously defined.

The monitor's background is controlled at an appropriate limit to ensure adequate sensitivity. Utilizing the methodology of ANSI N13.10-1974, the background must be maintained at a value of less than or equal to $9 \times 10^{-6} \mu\text{Ci/ml}$ (relative to ^{137}Cs) in order to detect a change of $4 \times 10^{-7} \mu\text{Ci/ml}$ of ^{137}Cs .¹⁰

In the event that there is no detectable gamma activity in the effluent or if the value of $\left\{ \left(\sum C_g \right) \div SF \right\}$ is less than the background of the monitor, then the monitor setpoint will be set at twice the current background of the monitor.

As previously stated, the monitor's response is dependent on the gamma emitting radionuclide distribution of the effluent. Accordingly, a database conversion factor is calculated for each release based upon the results of the gamma spectrometric analysis of the effluent sample and the measured response of the monitor to National Institute of Standards and Technology (NIST) traceable calibration sources:

$$DBCF_c = \left(\sum (C_g) \right) \div (CMR) \times (ECF)$$

Eq. 6

DBCF_c is the monitor data base conversion factor which converts count rate into concentration ($\mu\text{Ci/ml}$);

¹⁰ HPCI 9605, "Calculation of Maximum Background Value for HB-RE-18"

CMR is the calculated response of the radiation monitor to the liquid effluent;

ECF is the conversion factor for ^{137}Cs , which converts count rate into concentration ($\mu\text{Ci/ml}$).

C_g is as previously defined.

The new value of the DBCF_c is calculated and entered into the monitor data base prior to each discharge. A more complete discussion of the derivation and calculation of the CMR is given in HPCI 8710.

2.3. Liquid Effluent Concentration Measurements

Liquid batch releases are discharged as a discrete volume and each release is authorized based upon the sample analysis and the dilution flow rate existing in the discharge line at the time of release. To assure representative sampling, each liquid monitor tank is isolated and thoroughly mixed by recirculation of tank contents prior to sample collection. The methods for mixing, sampling, and analyzing each batch are outlined in applicable plant procedures. The allowable release rate limit is calculated for each batch based upon the pre-release analysis, dilution flow-rate, and other procedural conditions, prior to authorization for release. The liquid effluent discharge is monitored prior to entering the dilution discharge line and will automatically be terminated if the pre-selected alarm/trip setpoint is exceeded. Concentrations are determined primarily from the gamma isotopic and ^3H analyses of the liquid batch sample. For ^{89}Sr , ^{90}Sr , ^{55}Fe , ^{63}Ni , ^{237}Np , ^{238}Pu , $^{239/240}\text{Pu}$, ^{241}Pu , ^{241}Am , ^{242}Cm , & $^{243/244}\text{Cm}$, the measured concentrations from the previous quarterly composite analyses are used until laboratory results become available. Composite samples are collected for each batch release and analyzed in accordance with FSAR-SP Table 16.11-1. The dose from liquids discharged as continuous releases is calculated by utilizing the last measured values of samples in accordance with FSAR-SP Table 16.11-1.

2.4. Dose due to Liquid Effluents

2.4.1. The Maximum Exposed Individual

The cumulative dose determination considers the dose contributions from the maximum exposed individual's consumption of fish and potable water, as appropriate. Normally, the adult is considered to be the maximum exposed individual.¹¹

The Callaway Plant's liquid effluents are discharged to the Missouri River. As there are no potable water intakes within 10 miles of the discharge point,^{12,13} this pathway does not require routine evaluation. Therefore, the dose contribution from fish consumption is expected to account for more than 95% of the total man-rem dose from discharges to the Missouri River.

¹¹ NUREG-0133, Section 4.3

¹² Environmental Report, OLS, Table 2.1-19

¹³ FSAR-SA Section 11.2.3.3.4

Dose from recreational activities is expected to contribute the additional 5%, which is considered to be negligible.¹⁴

2.4.2. Calculation of Dose from Liquid Effluents

The dose contributions for the total time period $\sum_{l=1}^m \Delta t_l$ are calculated at least once each 31 days and a cumulative summation of the total body and individual organ doses is maintained for each calendar quarter. Dose is calculated for all radionuclides identified in liquid effluents released to Unrestricted Areas using the following expression:¹⁵

$$D_{\tau} = \sum_i \left[A_{i\tau} \sum_{l=1}^m \Delta t_l C_{il} F_l \right]$$

Eq. 7

Where:

D_{τ} is the cumulative dose commitment to the total body or any organ, τ , from the liquid effluents for the total period $\sum_{l=1}^m \Delta t_l$ in mrem.

Δt_l is the length of the l^{th} time period over which C_{il} and F_l are averaged for all liquid releases, in hours. Δt_l corresponds to the actual duration of the release(s).

C_{il} is the average measured concentration of radionuclide, i , in undiluted liquid effluent during the time period Δt_l from any liquid release, in ($\mu\text{Ci/ml}$).

$A_{i\tau}$ is the site- related ingestion dose commitment factor to the total body or any organ τ for each identified principal alpha, gamma and beta emitter listed in FSAR-SP Table 16.11-1, in (mrem/hr) per ($\mu\text{Ci/ml}$).

F_l is the near field average dilution factor for C_{il} during any liquid effluent release:

$$F_l = \frac{f_{max}}{(F + f_{max}) \cdot 89.77}$$

Eq. 8

Where:

F_{max} is the maximum undiluted effluent flow rate during the release;

F is the average dilution flow; and

¹⁴ FSAR-SA, Section 11.2.3.4.3

¹⁵ NUREG-0133, Section 4.3

89.77 is site specific applicable factor for the mixing effect of the discharge structure.^{16,17,18}

The term $C_{i,l}$ is the undiluted concentration of radioactive material in liquid waste at the common release point determined in accordance with REC 16.11.1.1, Table 16.11-1, "Radioactive Liquid Waste Sampling and Analysis Program". All dilution factors beyond the sample point(s) are included in the F_i term.

As there are currently no potable water intakes within 10 river miles of the discharge point, the drinking water pathway is not included in dose estimates to the maximally exposed individual. Should future potable water intakes be constructed within 10 river miles downstream of the discharge point, then this manual will be revised to include this pathway in dose estimates.¹⁹

The $A_{i\tau}$ values given in Table 1 were calculated according to:²⁰

$$A_{i\tau} = k_0 (U_w/D_w + U_F BF_i + U_I BI_i) DF_i$$

Eq. 9

Since there are no drinking water pathways, and CEC is a freshwater site, the terms for drinking water consumption (U_w/D_w) and invertebrate consumption ($U_I BI_i$) go to zero and the equation simplifies to:

$$A_{i\tau} = k_0 U_F BF_i DF_i$$

Eq. 10

Where:

k_0 is a constant of units conversion, $1.14 \times 10^5 = (10^6 \text{ pCi}/\mu\text{Ci} \cdot 10^3 \text{ ml/kg} / 8760 \text{ hr/yr})$

U_F is the adult fish consumption, 21 kg/yr ²¹

BF_i is the bioaccumulation factor for nuclide, i , in fresh water fish, pCi/kg per pCi/L. ^{22,23}

DF_i is the dose conversion factor for nuclide, i , for adults for organ, τ , in mrem/pCi.

¹⁶ NEO-54

¹⁷ UOTH 83-58

¹⁸ CAR 200700053- Attachments: Phase 1 final draft

¹⁹ FSAR-SP, Section 11.2.3.3.4

²⁰ NUREG-0133, Section 4.3.1

²¹ NUREG-0133, Section 4.3.1, pp. 16

²² UCRL- 50564, Table 6

²³ NUREG/CR-4013, pp. 3.17

2.4.3. Summary, Calculation of Dose Due to Liquid Effluents

The dose contribution for the total time period $\sum_{l=1}^m \Delta t_l$ is determined by calculation at least

once per 31 days and a cumulative summation of the total body and organ doses is maintained for each calendar quarter. The projected dose contribution from liquid effluents for which radionuclide concentrations are determined by periodic composite and grab sample analysis may be approximated by using the last measured value. Dose contributions are determined for all radionuclides identified in liquid effluents released to Unrestricted Areas. Nuclides which are not detected in the analyses are reported as "less than" the Minimum Detectable Activity (MDA) and are not reported as being present at the Lower Limit of Detection (LLD) for that nuclide. The "less than" values are not used in the dose calculations.

2.5. Liquid Radwaste Treatment System

The Liquid Radwaste Treatment System is described in FSAR-SP Chapter 11.2.

The Operability of the Liquid Radwaste Treatment System ensures this system will be available for use when liquids require treatment prior to their release to the environment. Operability is demonstrated through compliance with REC 16.11.1.1. and 16.11.1.2.

Projected doses due to liquid releases to Unrestricted Areas are determined each 31 days. The prior 31 day period is used to calculate compliance. This may be modified as appropriate to account for changes in radwaste treatment which may have a significant effect on the projected doses.

2.6. Liquid Effluents Dose Factors

The dose conversion factors provided in Table 1 were derived from the appropriate dose conversion factors of Regulatory Guide 1.109, Table 2.2 and other sources as necessary.^{24,25}

3. Gaseous Effluents

3.1. Gaseous Effluent Monitors

Noble gas activity monitors are present on the containment building ventilation system, plant unit ventilation system, and radwaste building ventilation system.

The alarm/trip (alarm & trip) setpoint for any gaseous effluent radiation monitor is determined based on the instantaneous noble gas total body and skin dose rate limits of REC 16.11.2.1, at the Site Boundary location with the highest annual average X/Q value.

²⁴ HPCI 0406

²⁵ HPCI 1604

Each gaseous monitor channel is provided with a two level system which provides sequential alarms on increasing radioactivity levels. These setpoints are designated as alert setpoints and alarm/trip setpoints.²⁶

The radiation monitor alarm/trip setpoints for each release point are based on the radioactive noble gases in gaseous effluents. It is not considered practicable to apply instantaneous alarm/trip setpoints to integrating radiation monitors sensitive to radioiodines, radioactive materials in particulate form and radionuclides other than noble gases. The exception is GL-RE-202. The only effluent released from the Laundry Decon Facility Dryer Exhaust is in the particulate form. Conservative assumptions may be necessary in establishing setpoints to account for system variables, such as the measurement system efficiency and detection capabilities during normal, anticipated, and unusual operating conditions, variability in release flow and principal radionuclides, and the time lag between alarm/trip action and the final isolation of the radioactive effluent.²⁷ FSAR-SP Table 16.11-6 provides the instrument surveillance requirements, such as calibration, source checks, functional tests, and channel checks.

3.1.1. Continuous Release Gaseous Effluent Monitors

The radiation detection monitors associated with continuous gaseous effluent releases are:^{28,29}

<u>Monitor I.D.</u>	<u>Description</u>
GT-RE-21	Unit Vent
GH-RE-10	Radwaste Building Vent
GL-RE-202	Laundry Decon Facility Dryer Exhaust Monitor

Each of the above continuously monitors gaseous radioactivity concentrations downstream of the last point of potential influent, and therefore measures effluents and not inplant concentrations.

The unit vent monitor continuously monitors the effluent from the unit vent for gaseous radioactivity. The unit vent, via ventilation exhaust systems, continuously purges various tanks and sumps normally containing low-level radioactive aerated liquids that can potentially generate airborne activity. The exhaust systems which supply air to the unit vent are from the fuel building, auxiliary building, the access control area, the containment purge, and the condenser air discharge.

²⁶ FSAR-SP Section 11.5.2.1.2

²⁷ NUREG- 0133, section 5.1.1

²⁸ FSAR-SP Section 11.5.2.3.3.1

²⁹ FSAR-SP Section 11.5.2.3.3.2

The unit vent monitor provides alarm functions only, and does not terminate releases from the unit vent.

The Radwaste Building ventilation effluent monitor continuously monitors for gaseous radioactivity in the effluent duct downstream of the exhaust filter and fans. The flow path provides ventilation exhaust for all parts of the building structure and components within the building and provides a discharge path for the waste gas decay tank release line. These components represent potential sources for the release of gaseous and air particulate and iodine activities in addition to the drainage sumps, tanks, and equipment purged by the waste processing system.

This monitor will isolate the waste gas decay tank discharge line upon a high gaseous radioactivity alarm.

The Laundry Decon Facility Dryer Exhaust Monitor continuously monitors the effluent of the dryer exhaust for particulate radioactivity during operation of the dryers. This effluent point is designed to release an insignificant quantity of radioactivity. The items to be placed in the dryers are typically washed before drying removing most of the radioactive material. The dryer effluent then passes through a HEPA filter before being sampled and released.

The Laundry Decon Facility Dryer Exhaust Monitor will secure the dryers and exhaust fans and isolate the dryer effluent upon a high radioactivity alarm or for a monitor failure.

The continuous Unit Vent and Radwaste Building Vent gaseous effluent monitor setpoints are established using the methodology described in Section 3.2. Since there are two continuous gaseous effluent release points, a fraction of the total dose rate limit (DRL) will be allocated to each release point. Neglecting the batch releases, the plant Unit Vent monitor has been allocated 0.7 DRL and the Radwaste Building Vent monitor has been allocated 0.3 DRL. These allocation factors may be changed as required to support plant operational needs, but shall not be allowed to exceed unity (i.e., 1.0). Therefore, a particular monitor reaching the setpoint would not necessarily mean the dose rate limit at the Site Boundary is being exceeded; the alarm only indicates that the specific release point is contributing a greater fraction of the dose rate limit than was allocated to the associated monitor, and will necessitate an evaluation of both systems.

For a loss of all isokinetic sampling and/or all heat tracing for the Unit Vent or Radwaste Building Vent grab samplers, one hour is allowed to restore a sampler to service. If sampling cannot be restored within one hour, all batch releases and ventilation not required for the operation of the plant should be secured. The best available sampling should be maintained during this period and normal sampling returned to service as soon as possible.

3.1.2. Batch Release Gaseous Effluent Monitors

The radiation monitors associated with batch release gaseous effluents are:^{30,31,32}

<u>Monitor I.D.</u>	<u>Description</u>
GT-RE-22, GT-RE-33	Containment Purge System
GH-RE-10	Radwaste Building Vent

The Containment Purge System continuously monitors the containment purge exhaust duct during purge operations for gaseous radioactivity. The primary purpose of these monitors is to isolate the containment purge system on high gaseous activity via the ESFAS.

The sample points are located outside the containment between the containment isolation dampers and the containment purge filter adsorber unit.

The Radwaste Building Vent monitor was previously described.

A pre-release isotopic analysis is performed for each batch release to determine the identity and quantity of the principal radionuclides. The alarm/trip setpoint(s) is adjusted accordingly to ensure that the limits of REC 16.11.2.1 are not exceeded.

3.2. Gaseous Effluent Monitor Setpoints

The alarm/trip setpoint for the Unit Vent and Radwaste Building Vent gaseous effluent monitors is determined based on the more restrictive of the total body dose rate (Eq. 11) and skin dose rate (Eq. 13) as calculated for the Site Boundary. In the event there is no noble gas activity in the sample, then the high alarm setpoint is set to the default value of 2.2E-02 $\mu\text{Ci/cc}$. This corresponds to 50% of the 500 mrem/yr limit of REC 16.11.2.1.³³ Each monitor is allocated only 50% of the limit such that the sum total of the two monitors cannot exceed the limit.

The alarm/ trip setpoint for the Laundry Decon Facility Exhaust Monitor is set to less than or equal to 2,000 cpm above equilibrium background. The maximum allowed background is 2,000 cpm as discussed in HPCI 99-05.

3.2.1. Total Body Dose Rate Setpoint Calculations

To ensure that the limits of REC 16.11.2.1 are met, the alarm/trip setpoint based on the total body dose rate is calculated according to:

$$S_{tb} \leq D_{tb} R_{tb} F_s F_a$$

³⁰ FSAR-SP Section 11.5.2.3.3.2

³¹ FSAR-SP Section 11.5.2.3.2.3

³² FSAR-SP Section 11.5.2.3.2.2

³³ HPCI 8403, page 9

Eq. 11

Where:

S_{tb} is the alarm/trip setpoint based on the total body dose rate ($\mu\text{Ci/cc}$);

D_{tb} is the REC 16.11.2.1 dose rate limit of 500 mrem/yr, conservatively interpreted as a continuous release over a one year period;

F_s is the safety factor; a conservative factor used to compensate for statistical fluctuations and errors of measurement. (For example, $F_s = 0.5$ corresponds to a 100% variation.) Default value is $F_s = 0.1$.

F_a is the allocation factor which will modify the required dilution factor such that simultaneous gaseous releases may be made without exceeding the limits of REC 16.11.2.1.

R_{tb} is a factor used to convert dose rate to the effluent concentration as measured by the effluent monitor, in ($\mu\text{Ci/cc}$) per (mrem/yr) to the total body, determined according to:

$$R_{tb} = C \div \left[\left(\overline{X/Q} \right) \sum_i (K_i Q_i) \right]$$

Eq. 12

Where:

C is the reading of a noble gas monitor corresponding to the sample radionuclide concentrations for the release. Concentrations are determined in accordance with FSAR-SP Table 16.11-4. The mixture of radionuclides determined via grab sampling of the effluent stream or source is correlated to a calibration factor to determine monitor response. The monitor response is based on concentration, not release rate, and is in units of ($\mu\text{Ci/cc}$);

$\overline{X/Q}$ is the highest calculated annual average relative concentration for any area at or beyond the Site Boundary in (sec/m^3) (Table 10, Table 11, and Table 12);

K_i is the total body dose factor due to gamma emissions for each identified noble gas radionuclide, in (mrem/yr) per ($\mu\text{Ci/m}^3$) (Table 3); and

Q_i is the rate of release of noble gas radionuclide, i, in ($\mu\text{Ci/sec}$).

Q_i is calculated as the product of the ventilation path flow rate and the measured activity of the effluent stream as determined by sampling.

3.2.2. Skin Dose Rate Setpoint Calculation

To ensure that the limits of REC 16.11.2.1 are met, the alarm/trip setpoint based on the skin dose rate is calculated according to:

$$S_s \leq D_s R_s F_s F_a$$

Eq. 13

Where:

F_s and **F_a** are as previously defined;

S_s is the alarm/trip setpoint based on the skin dose rate;

D_s is the REC 16.11.2.1 dose rate limit of 3000 mrem/yr, conservatively interpreted as a continuous release over a one year period; and

R_s is the factor used to convert dose rate to the effluent concentration as measured by the effluent monitor, in (μCi/cc) per (mrem/yr) to the skin, determined according to:

$$R_s = C \div \left[\left(\overline{X/Q} \right) \sum_i (L_i + 1.1M_i) Q_i \right]$$

Eq. 14

Where:

L_i is the skin dose factor due to beta emissions for each identified noble gas radionuclide, in (mrem/yr) per (μCi/m³);

1.1 is a factor of units conversion; 1 mrad air dose = 1.1 mrem skin dose; and

M_i is the air dose factor due to gamma emissions for each identified noble gas radionuclide, in (mrad/yr) per (μCi/m³).

C, $\overline{(X/Q)}$, and **Q_i** are previously defined.

3.3. Calculation of Dose and Dose Rate from Gaseous Effluents

3.3.1. Dose Rate from Gaseous Effluents

The following methodology is applicable to the location (Site Boundary or beyond) characterized by the values of the parameter X/Q which results in the maximum total body or skin dose rate. In the event that the analysis indicates a different location for the total body and skin dose limitations, the location selected for consideration is that which minimizes the allowable release values.³⁴

The factors **K_i**, **L_i**, and **M_i** relate the radionuclide airborne concentrations to various dose rates, assuming a semi-infinite cloud model.

3.3.1.1. *Dose Rate from Noble Gases*

³⁴ NUREG-0133, Section 5.1.2

The release rate limit for noble gases is determined according to the following general relationships:³⁵

$$D_{tb} = \sum_i \left[K_i Q_i \left(\overline{X/Q} \right) \right] \leq 500 \text{ mrem/yr}$$

Eq. 15

$$D_s = \sum_i \left[(L_i + 1.1 M_i) \left(\overline{X/Q} \right) Q_i \right] \leq 3000 \text{ mrem/yr}$$

Eq. 16

Where:

Q_i is the release rate of noble gas radionuclides, i , in gaseous effluents, from all vent releases in ($\mu\text{Ci/sec}$); and

1.1 is a factor of units conversion factor; 1 mrad air dose = 1.1 mrem skin dose.

L_i , M_i , K_i , $\overline{X/Q}$, D_{tb} and D_s are as previously identified.

3.3.1.2. Dose Rate from Radionuclides Other than Noble Gases

The release rate limit for ^{131}I and ^{133}I , for ^3H , and for all radioactive materials in particulate form with half-lives greater than 8 days is determined according to:³⁶

$$D_o = \sum_i R_i \left[\overline{X/Q} \right] Q_i \leq 1500 \text{ mrem/yr}$$

Eq. 17

Where:

D_o is the dose rate to any critical organ, in (mrem/yr);

R_i is the dose parameter for radionuclides other than noble gases for the inhalation pathway for the child, based on the critical organ, in (mrem/yr) per ($\mu\text{Ci/m}^3$); and

Q_i is the release rate of radionuclides other than noble gases, i , in gaseous effluents, from all vent releases in ($\mu\text{Ci/sec}$).

$\overline{X/Q}$ is as previously defined.

The dose parameter (R_i) includes the internal dosimetry of radionuclide, i , and the receptor's breathing rate, which are functions of the receptor's age. The child age group has been

³⁵ NUREG-0133, Section 5.1.2

³⁶ NUREG-0133, Section 5.2.1

selected as the limiting age group. All radiodines are assumed to be released in elemental form.³⁷

R_i values were calculated according to:³⁸

$$R_i = K' (BR) DFA_i$$

Eq. 18

Where:

K' is a factor of units conversion factor: 1×10^6 pCi/ μ Ci;

BR is the breathing rate from Regulatory Guide 1.109, Table E-5 (m^3/yr);

DFA_i is the maximum organ inhalation dose factor for the i^{th} radionuclide, in (mrem/pCi). The total body is considered as an organ in the selection of DFA_i.^{39,40}

The results of periodic tritium, iodine and particulate samples of the Unit Vent and Radwaste Vent are used to verify the dose rate limit was not exceeded for the period during which the samples or composite samples were obtained.

3.3.2. Dose Due to Gaseous Effluents

3.3.2.1. Air Dose Due to Noble Gases

The air dose at the Site Boundary due to noble gases is calculated according to the following methodology:⁴¹

During any calendar quarter, for gamma radiation:

$$D_g = 3.17E-08 \sum_i \left[M_i \left(\overline{X/Q} \right) Q_i \right] \leq 5 \text{ mrad}$$

Eq. 19

During any calendar quarter, for beta radiation:

$$D_b = 3.17E-08 \sum_i \left[N_i \left(\overline{X/Q} \right) Q_i \right] \leq 10 \text{ mrad}$$

Eq. 20

During any calendar year, for gamma radiation:

³⁷ NUREG-0133, Section 5.2.1

³⁸ NUREG-0133, Section 5.2.1.1

³⁹ Regulatory Guide 1.109, Appendix E, Table E-9

⁴⁰ ZZ-48

⁴¹ NUREG-0133, Section 5.3.1

$$D_g = 3.17E-08 \sum_i \left[M_i \left(\overline{X/Q} \right) Q_i \right] \leq 10 \text{ mrad}$$

Eq. 21

During any calendar year, for beta radiation:

$$D_b = 3.17E-08 \sum_i \left[N_i \left(\overline{X/Q} \right) Q_i \right] \leq 20 \text{ mrad}$$

Eq. 22

Where:

D_g is the air dose in mrad, from gamma radiation due to noble gases released in gaseous effluent;

D_b is the air dose in mrad, from beta radiation due to noble gases released in gaseous effluents;

N_i is the air dose factor due to beta emissions for each identified noble gas radionuclide, i, in (mrad/yr) per (μCi/m³);

Q_i is the releases of noble gas radionuclides, i, in gaseous effluents, for all gaseous releases in (μCi). Releases are cumulative over the calendar quarter or year as appropriate. Q_i is calculated as the product of the ventilation flow rate and the measured activity of the effluent stream as determined by sampling; and

3.17x10⁻⁸ is the inverse of the number of seconds per year.

$\overline{X/Q}$ & M_i are as previously defined.

3.3.2.2. **Dose Due to Radionuclides Other than Noble Gases**

The dose to a Member of the Public from ¹³¹I and ¹³³I, for ³H, and all radionuclides in particulate form with half-lives greater than 8 days in gaseous effluents released to areas at and beyond the Site Boundary, is calculated according to the following expressions:

During any calendar quarter:

$$\sum_j D_{l,j} \leq 7.5 \text{ mrem}$$

Eq. 23

During any calendar year:

$$\sum_j D_{l,j} \leq 15 \text{ mrem}$$

Eq. 24

For each pathway, j, (i.e., for inhalation, ground plane, meat, cow- milk, goat- milk, and vegetation) D_{l,j} is calculated according to the expression:

$$D_{l,j} = 3.17E-8 \sum_i R_{l,i,j} [W_j Q_i]$$

Eq. 25

Where:

$D_{l,j}$ is the dose in mrem, to a Member of the Public from radionuclides other than noble gases, from pathway j , received by organ l (including total body);

$R_{l,i,j}$ is the dose factor for each identified radionuclide, i , in m^2 (mrem/yr) per ($\mu\text{Ci/sec}$) or (mrem/yr) per ($\mu\text{Ci}/m^3$) as appropriate, for the pathway j , and exposed organ l , appropriate to the age group of the critical Member of the Public receptor;

W_j is the $\overline{X/Q}$ for the inhalation and tritium pathways, in sec/m^3 and is the $\overline{D/Q}$ for the food and ground plane pathways, in meters^{-2} .

$\overline{D/Q}$ is the average relative deposition of the effluent at or beyond the Site Boundary, considering depletion of the plume during transport;

Q_i is the release of radioiodines, radioactive materials in particulate form, and radionuclides other than noble gases, i , in gaseous effluents, for all gaseous releases in μCi . Releases are cumulative over the calendar quarter or year as appropriate. Q_i is calculated as the product of ventilation flow rate and the measured activity of the effluent stream as determined by sampling; and

3.17×10^{-8} is the inverse of the number of seconds per year.

$\overline{X/Q}$ is as previously defined. Refer to Table 10, Table 11, and Table 12 for applicability;

Although the annual average relative concentration $\overline{X/Q}$ and the average relative deposition rate $\overline{D/Q}$ are generally considered to be at the approximate receptor location in lieu of the Site Boundary for these calculations, it is acceptable to consider the ingestion, inhalation, and ground plane pathways to coexist at the location of the nearest residence with the highest value of $\overline{X/Q}$.⁴² The Total Body dose from ground plane deposition is added to the dose for each individual organ.⁴³

3.4. Gaseous Radwaste Treatment System

The gaseous radwaste treatment system and the ventilation exhaust system are available for use whenever gaseous effluents require treatment prior to being released to the environment. The gaseous radwaste treatment system is designed to allow for the retention of all gaseous fission products to be discharged from the reactor coolant system. The retention system

⁴² NUREG-0133, Section 5.3.1

⁴³ Regulatory Guide 1.109, Appendix C, Section 1

consists of eight (8) waste gas decay tanks. Normally, waste gases will be retained for at least 60 days prior to discharge. When practicable, waste gas decay tanks are discharged outside the growing season or at night such that ^{14}C released from the waste gas system will not be incorporated into the ingestion pathways and will result in a lower dose to the Member of the Public. For this purpose, the growing season is defined as April 1 through November 1.⁴⁴ These systems will provide reasonable assurance that the releases of radioactive materials in gaseous effluents will be kept ALARA.

The Operability of the gaseous radwaste treatment system ensures this system will be available for use when gases require treatment prior to their release to the environment. Operability is demonstrated through compliance with REC 16.11.2.1, 16.11.2.2, and 16.11.2.3.

Projected doses (gamma air, beta air, and organ dose) due to gaseous effluents at or beyond the Site Boundary are determined each 31 days. The prior 31 day period is used to calculate compliance. This may be modified as appropriate to account for changes in radwaste treatment which may have a significant effect on the projected doses.

3.5. Gaseous Effluents Dose Factors

The dose conversion factors were derived from the appropriate dose conversion factors in Regulatory Guide 1.109 and other sources as necessary.^{45,46} Particulate nuclides with a half-life of less than 8 days are not considered.⁴⁷ ^{90}Y , ^{140}La , and ^{144}Pr are included because the parent half-life is greater than 8 days, and equilibrium is assumed.

4. Dose and Dose Commitment from Uranium Fuel Cycle Sources

4.1. Calculation of Dose and Dose Commitment from Uranium Fuel Cycle Sources

The annual dose or dose commitment to a Member of the Public for Uranium Fuel Cycle Sources is determined as:

- Dose to the total body and internal organs due to gamma ray exposure from submersion in a cloud of radioactive noble gases, ground plane exposure, and direct radiation from the Unit, onsite storage of low-level radioactive waste, and outside storage tanks;
- Thyroid dose due to inhalation and ingestion of radioiodines; and
- Organ dose due to inhalation and ingestion of radioactive material.

It is assumed that total body dose from sources of gamma radiation irradiates internal body organs at the same numerical rate.⁴⁸

⁴⁴ Hammer, Gregory, R., "Climate of Missouri", monograph available from the National Climatic Data Center (NCDC) of the National Oceanic and Atmospheric Administration (NOAA), January, 2006.

⁴⁵ ZZ-78

⁴⁶ ZZ-250

⁴⁷ Inspection Report 50-483/92002 (DRSS)

⁴⁸ NUREG-0543, Section III, page 8

The dose from gaseous effluents is considered to be the summation of the dose at the individual's residence and the dose to the individual from activities within the Site Boundary.

Since the doses via liquid releases are very conservatively evaluated, there is reasonable assurance that no real individual will receive a significant dose from radioactive liquid release pathways. Therefore, only doses to individuals via airborne pathways and doses resulting from direct radiation are considered in determining compliance to 40 CFR 190.⁴⁹

There are no other Uranium Fuel Cycle Sources within 8 km of the Callaway Plant.

4.1.1. Identification of the Member of the Public

The Member of the Public is considered to be a real individual, including all persons not occupationally associated with the Callaway Plant, but who may use portions of the plant site for recreational or other purposes not associated with the plant.⁵⁰ Accordingly, it is necessary to characterize this individual with respect to his utilization of areas both within and at or beyond the Site Boundary and identify, as far as possible, major assumptions which could be reevaluated if necessary to demonstrate continued compliance with 40 CFR 190 through the use of more realistic assumptions.^{51,52}

The evaluation of Total Dose from the Uranium Fuel Cycle should consider the dose to two Critical Receptors: (a) The Nearest Resident, and (b) The Critical Receptor within the Site Boundary.

4.1.2. Total Dose to the Nearest Resident

The dose to the Nearest Resident is due to plume exposure from noble gases, ground plane exposure, and inhalation and ingestion pathways. It is conservatively assumed that each ingestion pathway (meat, milk, and vegetation) exists at the location of the Nearest Resident.

⁴⁹ NUREG-0543, Section IV, page 9

⁵⁰ NUREG-0133, Section 3.8

⁵¹ NUREG-0543, Section IV, page 9

⁵² NUREG-0543, section III, page 6

It is assumed that direct radiation dose from operation of the Unit and storage of radioactive material, and dose from gaseous effluents due to activities within the Site Boundary is negligible for the Nearest Resident. The total Dose from the Uranium Fuel Cycle to the Nearest Resident is calculated using the methodology discussed in Section 3 for exposure to radioactive particulates, radioiodines, and tritium, using concurrent meteorological data for the location of the Nearest Resident with the highest value of \bar{X}/\bar{Q} . The following equation has been derived for calculating annual total body and internal organ dose from exposure to noble gas radionuclides, $D_{ng, NR}$:

$$D_{ng, NR} = 3.17E - 08(f_{occ})(\bar{X}/\bar{Q}) \sum_i K_i Q_i$$

Eq. 26

Where:

$D_{ng, NR}$ is the total body dose in mrem, to the nearest resident from exposure to noble gas radionuclides released in gaseous effluents.

3.17×10^{-8} is the inverse of the number of seconds per year.

f_{occ} is the occupancy factor for the nearest resident (i.e. 1.00).

Q_i is the release of noble gas radionuclides, i , in gaseous effluents, for all gaseous releases in μCi . Q_i is calculated as the product of ventilation flow rate and the measured activity of the effluent stream as determined by sampling.

(\bar{X}/\bar{Q}) and K_i are as previously defined. The location of the Nearest Resident in each meteorological sector is determined from the Annual Land Use Census conducted in accordance with the Requirements of REC 16.11.4.2.

4.1.3. Total Dose to the Critical Receptor within the Site Boundary

The Union Electric Company has entered into an agreement with the State of Missouri Department of Conservation for management of the residual lands surrounding the Callaway Plant, including some areas within the Site Boundary. Under the terms of this agreement, certain areas have been opened to the public for low intensity recreational uses (hunting, hiking, sightseeing, etc.) but recreational use is excluded in an area immediately surrounding the plant site (refer to Figure 4.1). Much of the residual lands within the Site Boundary are leased to area farmers by the Department of Conservation to provide income to support management and development costs. Activities conducted under these leases are primarily

comprised of farming (animal feed), grazing, and forestry. Crops for human consumption are specifically prohibited by the lease.^{53,54,55}

Based on the utilization of areas within the Site Boundary, it is reasonable to assume that the critical receptor within the Site Boundary is a farmer, and that his dose from activities within the Site Boundary is due to exposure incurred while conducting his farming activities. The previous tenant estimated that he spent approximately 1100 hours per year working the farm plots of the Reform Conservation Area.⁵⁶

Any reevaluation of assumptions should consider only real receptors and real pathways using realistic assumptions, and should include a reevaluation of the occupancy period at the locations of real exposure (e.g. a real individual would not simultaneously exist at each point of maximum exposure).

4.1.3.1. Total Dose to the Farmer from Gaseous Effluents

The Total Dose to the farmer from gaseous effluents is calculated for the adult age group using the methodology discussed in Section 3 for radioactive particulates, radioiodines, and tritium, utilizing historical meteorological data from Table 10 for activities within the Site Boundary and corrected for the farmer's occupancy (i.e. the ratio of 1100 hours of farming activities within the Reform Conservation area in a year to 8760 total hours in a year). The following equation has been derived for calculating annual total body and internal organ dose from exposure to noble gas radionuclides, $D_{ng,F}$:

$$D_{ng,F} = 3.17E - 08(f_{occ})(\overline{X/Q}) \sum_i K_i Q_i$$

Eq. 27

Where:

$D_{ng,F}$ is the total body dose in mrem, to the farmer from exposure to noble gas radionuclides released in gaseous effluents.

3.17×10^{-8} is the inverse of the number of seconds per year.

f_{occ} is the occupancy factor for the farmer which is the ratio of 1100 hours of farming activities in a year to 8760 total hours in a year.

Q_i is the release of noble gas radionuclides, i , in gaseous effluents, for all gaseous releases in μCi . Q_i is calculated as the product of ventilation flow rate and the measured activity of the effluent stream as determined by sampling.

⁵³ Environmental Report, OLS, Section 2.1.2.3

⁵⁴ Environmental Report, OLS, Section 2.1.3.3.4

⁵⁵ Management Agreement for the Public Use of Lands, Exhibit A.

⁵⁶ Private communication, H.C. Lindeman & B.F. Holderness, August 6, 1986

$(\overline{X/Q})$ and K_i are as previously defined.


The Reform Conservation Area farm plots are leased to several different farmers therefore there is no dose calculation for the farmer's residence. It is assumed that food ingestion pathways do not exist within the Site Boundary, therefore the gaseous effluents dose within the Site Boundary is due to plume exposure from Noble Gases and the ground plane and inhalation pathways.

4.1.3.1.1. Direct Radiation Dose

The direct radiation dose to the Member of Public due to activities within the Site Boundary is insignificant.^{57,58}

⁵⁷ HPCI 1206

⁵⁸ HPCI 1505



5. Radiological Environmental Monitoring

5.1. Description Of The Radiological Environmental Monitoring Program

The Radiological Environmental Monitoring Program is intended to provide background data for pre- operation and to supplement the radiological effluent release monitoring program during plant operation. Radiation exposure to the public from the various specific pathways and direct radiation is evaluated by this program.

Some deviations from the sampling frequency may be necessary due to seasonal unavailability, hazardous conditions, or other legitimate reasons. Efforts are made to obtain all required samples within the required time frame. Any deviation(s) in sampling frequency or location is documented in the Annual Radiological Environmental Operating Report.

Sampling, reporting, and analytical requirements are given in FSAR-SP Tables 16.11-7, 16.11-8, and 16.11-9.

Airborne, waterborne, direct radiation, and ingestion samples collected under the monitoring program are analyzed by an independent, third-party laboratory. With the exception of direct radiation, the laboratory is required to participate in an Interlaboratory Analyses Program per Reg. Guide 4.15.⁵⁹ The laboratory participates in an Interlaboratory crosscheck program administered by Environmental Resources Associates (ERA), Mixed Analyte Performance Evaluation Program (MAPEP), or equivalent program. This participation includes all of the determinations (sample medium - radionuclide combination) that are both offered by ERA and/or MAPEP and are also included in the environmental monitoring program.

5.2. Performance Testing Of Environmental Thermoluminescence Dosimeters

Dosimeters used for monitoring of direct radiation dose in the Radiological Environmental Monitoring Program are tested for accuracy and precision to demonstrate compliance with the applicable portions of Regulatory Guide 4.13.

6. Annual Average Atmospheric Dispersion Parameters

6.1. Annual Atmospheric Dispersion Parameters

The dispersion values presented in Table 10 were determined through the analysis of five years of on-site meteorological data.⁶⁰ The straight-line Gaussian dispersion model XOQDOQ⁶¹ was used for determination of the long-term atmospheric dispersion parameters. A more detailed discussion of the methodology and input data utilized to calculate these parameters can be found in HPCI 1503.

6.1.1. Determination of Dispersion Estimates for Special Receptor Locations

⁵⁹ Regulatory Guide 4.15, rev. 1, section 6.3.2

⁶⁰ HPCI 1503

⁶¹ NUREG/CR2919

XOQDOQ is utilized to obtain dispersion parameters for 22 standard distances. Dispersion parameters at the Site Boundary and at special receptor locations are estimated by logarithmic interpolation according to:⁶²

$$X = X_1 \left(d/d_1 \right)^B$$

Eq. 28

Where:

$$B = \frac{\ln (X_2/X_1)}{\ln (d_2/d_1)}$$

Eq. 29

X_1 , X_2 are the atmospheric dispersion parameters at distance d_1 and d_2 , respectively, from the source. The distances d_1 and d_2 are selected such that they satisfy the relationship $d_1 < d < d_2$.

6.1.2. Atmospheric Dispersion Parameters for Farming Areas within the Site Boundary

The dispersion parameters for farming areas within the Site Boundary are intended for a narrow scope application; that of calculating the dose to the current farmer⁶³ from gaseous effluents while he conducts farming activities within the Site Boundary.

For the purpose of these calculations, it was assumed that all of the farmer's time, approximately 1100 hours per year, is spent on croplands of the Reform Conservation Area, including plots within the Site Boundary, and that his time is divided among the plots proportional to the acreage of each plot. Fractional acreage/time- weighted dispersion parameters were calculated for each plot as described in HPCI 1502. The weighted dispersion parameters for each plot were summed (according to type) in order to produce a composite value of the dispersion parameters which are presented in Table 10. These dispersion parameters therefore represent the distributed activities of the farmer within the Site Boundary and his estimated occupancy period.

6.2. Annual Meteorological Data Processing

The annual atmospheric dispersion parameters utilized in the calculation of doses for demonstration of compliance with the numerical dose objectives of 10 CFR 50, Appendix I, are determined using XOQDOQ.⁶⁴ Multiple sensors are utilized to ensure 90% valid data recovery for the wind speed, wind direction, and ambient air temperature parameters as required by Regulatory Guide 1.23. The selection hierarchy is presented in Table 13.

The input parameters to XOQDOQ are documented in HPCI 1503.

⁶² FSAR-SA 2.3.5.2.1.2

⁶³ The farming plots are leased by the Missouri Department of Conservation to multiple farmers through a bidding process. This represents a composite of those persons farming the plots within the Site Boundary.

⁶⁴ NUREG/CR-2919

A quality check of the meteorological data is performed prior to processing to ensure the validity of the calculated dispersion parameters.

7. Reporting Requirements

7.1. Annual Radiological Environmental Operating Report

The reporting requirements for the Annual Radiological Environmental Operating Report (AREOR) have been relocated to FSAR-SP 16.11.5.1.

7.2. Annual Radioactive Effluent Release Report

The reporting requirements for the Annual Radioactive Effluent Release Report (ARERR) have been relocated to FSAR-SP 16.11.5.2. The application of atmospheric dispersion parameters in the ARERR is presented in Table 12.

8. Radioactive Effluent Controls (REC)

The Radioactive Effluent Controls were relocated to FSAR-SP Chapter 16.11, "Offsite Dose Calculation Manual Radioactive Effluent Controls". The former ODCM REC numbers appear on each of the RECs in FSAR-SP Chapter 16.11, and may be used as a cross-reference between the previous and the current numbering system if necessary.

9. Administrative Controls

9.1. Major Changes to Liquid and Gaseous Radwaste Treatment Systems

A summary of Licensee-initiated major changes to the Radwaste Treatment Systems (liquid and gaseous) must be reported to the Commission in the Annual Radioactive Effluent Release Report (ARERR) for the period in which the evaluation was reviewed by the On-Site Review Committee (ORC). On site documentation must contain:

- A summary of the evaluation that led to the determination that the change could be made in accordance with 10 CFR 50.59;
- Sufficient detailed information to totally support the reason for the change without benefit of additional or supplemental information;
- A detailed description of the equipment, components and process involved and the interfaces with other plant systems;
- An evaluation of the change, which shows the predicted releases of radioactive materials in liquid and gaseous effluents that differ from those previously predicted in the License application and amendments thereto;
- An evaluation of the change, which shows the expected maximum exposures to a Member of the Public in the Unrestricted Area and to the general population that differ from those previously estimated in the License application and amendments thereto;

- A comparison of the predicted releases of radioactive materials, in liquid and gaseous effluents, to the actual releases for the period prior to when the changes are to be made;
- An estimate of the exposure to plant operating personnel as a result of the change; and
- Documentation of the fact that the change was reviewed and found acceptable by the ORC.

Changes to the Radwaste Treatment Systems shall become effective upon review and approval by the ORC.

9.2. Changes to the Offsite Dose Calculation Manual (ODCM)

All changes to the ODCM shall be performed pursuant to T/S AC 5.5.1

Review for each revision of the ODCM must include the Radiation Protection Department.

10. Bibliography

ANSI N42.18-2004, "Specification & Performance of On-Site Instrumentation for Continuously Monitoring Radioactivity in Effluents". (2004)

CAR 200700053 – "Missouri River Low Flow Trend for 2006", Attachments: Phase 1 Final Draft

CDP-ZZ-00200, Appendix B, "Primary Plant Systems Tables", rev. 41. April, 2018.

Certificate of Compliance No. 1040, Appendix A, Technical Specifications for the HI-STORM UMAX Canister Storage System. April, 2015.

EGG-PHY-9703, "Technical Evaluation Report for the evaluation of ODCM Revision 0 (May, 1990) Callaway Plant, Unit 1", transmitted via letter, Samuel J. Collins (USNRC) to D. F. Schnell (UE), dated July 12, 1996.

EPRI TR-1021106, "Estimation of ^{14}C in Nuclear Power Plant Effluents", December, 2010

Generic Letter 89-01, "Guidance for the Implementation of Programmatic Controls for RETS in the Administrative Controls Section of Technical Specifications and the Relocation of Procedural Details of Current RETS to the Offsite Dose Calculation Manual or Process Control Program", US Nuclear Regulatory Commission. (1989)

Hammer, Gregory, R., "Climate of Missouri", monograph available from the National Climatic Data Center (NCDC) of the National Oceanic and Atmospheric Administration (NOAA), January, 2006

HPCI 8403, "Setpoints and Associated Bases for Process and Effluent Radioactivity Monitors (SP System)". June, 1984.

HPCI 8710, "Methodology for Calculating the Response of Gross NaI(Tl) Monitors to Liquid Effluent Streams", rev. 1, April, 2005.

HPCI 8902, "Calculation of ODCM Dose Commitment Factors", rev. 0. September, 1989.

HPCI 9605, "Calculation of Maximum Background Value for HB-RE-18", rev.0. September, 1996

HPCI 9905, "Calculation of Setpoint for GL-RE-202", rev.0. April, 1999.

HPCI 0406 "Calculation of Liquid Effluent Dose Commitment Factors (A_{it}) for the Adult Age Group", rev. 1. November, 2004.

HPCI 0509, "Radiological Environmental Monitoring Program (REMP) Calculation of Direct Dose from RAM Storage at Stores II", rev. 0. April, 2005.

HPCI 0510, "Radiological Environmental Monitoring Program (REMP) Calculation of Direct Dose from RAM Storage in the Radwaste Yard", rev. 0. April, 2005.

HPCI 0601, "Equipment Hatch Platform and Missile Shield Modification Direct Dose Calculation to the Member of the Public", rev. 0. January, 2006.

HPCI 1003, "Evaluation of the 2010 Land Use Census", rev. 0. December, 2010.

HPCI 1102, "Dose to the Member of the Public from the Release of ^{14}C in Gaseous Effluents for 2010", rev.0. July, 2011.

HPCI 1206, "Evaluation of Direct Radiation Dose to the Member of the Public Due to Activities within the site Boundary", rev. 0. August, 2012.

HPCI 1502, "Atmospheric Dispersion Parameters for Activities Inside the Site Boundary", rev. 1. October, 2020.

HPCI 1503, "Calculation of Long- Term Meteorological Dispersion Parameters", rev. 1. April, 2015

HPCI 1504, "Evaluation of the 2014 Annual Land Use Census", rev. 1. March, 2015

HPCI 1505, "Evaluation of Direct Radiation Dose to the Member of the Public from the Independent Spent Fuel Storage Facility", rev. 1. July, 2015.

HPCI 1508, "Evaluation of the 2015 Land Use Census", rev.0. March, 2016.

HPCI 1604, " Calculation of ^{126}Sb Ingestion Dose Commitment Factors (A_{ir})", rev. 1. January, 2018.

HPCI 1802, "Calculation of $^{117\text{m}}\text{Sn}$ Dose Commitment Factors (A_{ir}) and Effluents Management Software (EMS) Nuclide Data for Liquid Effluents", rev. 0. May, 2018.

IAEA Technical Reports Series no. 421, "Management of Waste Containing Tritium and Carbon- 14", 2004

Internal USNRC memo, F. J. Congel to V. L. Miller, et al, dated April 17, 1992.

Kunz, C., "Carbon-14 Discharge at Three Light- Water Reactors", *Health Physics*, vol. 49, pages 25- 35, 1985

LDCN 18-0006, "Remove BMRE52 from FSAR-SP Tables 16.11-2 and 16.11-3", BT 201805280

Letter, F. J. Congel to J. F. Schmidt, dated April 23, 1992.

Letter, F. J. Congel to J. F. Schmidt, dated December 9, 1991.

Letter, F. J. Congel to J. F. Schmidt, dated June 8, 1993.

Letter, F. J. Congel to J. F. Schmidt, dated September 14, 1992.

Management Agreement for the Public Use of Lands, Union Electric Company and the State of Missouri Department of Conservation, January 15, 2009.

Memo, F. J. Congel, "Eigth Set of Questions and Answers on 10 CFR Part 20", May 26, 1994.

Modification MP 19-0114, "Retire BMRE0052". October 7, 2019.

NCRP Report 81, "Carbon-14 in the Environment", January 1985

Neeb, Karl- Heinz, *The Radiochemistry of Nuclear Power Plants with Light Water Reactors*, Walter de Gruyter, Berlin, 1997

NEO-54, memo, D. W. Capone to S. E. Miltenberger, dated January 5, 1983; Union Electric Company correspondence.

NUREG-0017, "Calculation of Releases of Radioactive Materials in Gaseous and Liquid Effluents from Pressurized Water Reactors PWR-GALE Code," April, 1985

NUREG-0133, "Preparation of Radiological Effluent Technical Specification for Nuclear Power Plants", U.S. Nuclear Regulatory Commission. (1978)

NUREG-0543, "Methods for Demonstrating LWR Compliance with the EPA Uranium Fuel Cycle Standard (40 CFR Part 190)", U. S. Nuclear Regulatory Commission. (1980)

NUREG-1301, "Offsite Dose Calculation Manual Guidance: Standard Radiological Effluent Controls for Pressurized Water Reactors, Generic Letter 89-01, Supplement No. 1", April, 1991

NUREG/CR-2919, "XOQDOQ, Computer Program For the Meteorological Evaluation of Routine Effluent Releases at Nuclear Power Stations", U.S. Nuclear Regulatory Commission. (1982)

NUREG/CR-6204, "Questions and Answers Based on Revised 10 CFR 20", May, 1994

Regulatory Guide 1.109, "Calculation of Annual Doses to Man from Routine Releases of Reactor Effluents for the Purposes of Evaluating Compliance with 10 CFR Part 50, Appendix I", Revision 1, U. S. Nuclear Regulatory Commission. (1977)

Regulatory Guide 1.111, "Methods for Estimating Atmospheric Transport and Dispersion of Gaseous Effluents in Routine Releases from Light-Water-Cooled Reactors", Revision 1, U. S. Nuclear Regulatory Commission. (1977)

Regulatory Guide 1.21, "Measuring, Evaluating, and Reporting Radioactive Material in Liquid and Gaseous Effluents and Solid Waste", (Revision 2), U. S. Nuclear Regulatory Commission. (2009)

Regulatory Guide 4.13, "Performance, Testing, and procedural specifications for Thermoluminescence Dosimetry: Environmental Applications "(Revision 1), U. S. Nuclear Regulatory Commission. (1977)

Regulatory Guide 4.15, "Quality Assurance for Radiological Monitoring Programs (Normal Operations) – Effluent Streams and the Environment" (Revision 1), U. S. Nuclear Regulatory Commission. (1979)

State of Missouri National Pollutant Discharge Elimination System (NPDES) Permit MO-0098001, Ameren Missouri Callaway Energy Center, July 1, 2020.

Statements of Consideration, Federal Register, Vol. 56, No. 98, Tuesday, May 21, 1991, Subpart D, page 23374.

Title 10, "Energy", Chapter 1, Code of Federal Regulations, Part 20; U.S. Government Printing Office, Washington, D.C. 20402.

Title 10, "Energy", Chapter 1, Code of Federal Regulations, Part 72, Subpart F; U.S. Government Printing Office, Washington, D.C. 20402.

Title 10, "Energy", Chapter 1, Code of Federal Regulations, Part 50, Appendix I; U.S. Government Printing Office, Washington, D.C. 20402.

Title 40, "Protection of Environment", Chapter 1, Code of Federal Regulations, Part 190; U.S. Government Print Office, Washington, D.C. 20402.

Union Electric Company Callaway Plant Environmental Report, Operating License Stage

Union Electric Company Callaway Plant, Unit 1, Final Safety Analysis Report- Standard Plant

UOTH 83-58, "Documentation of ODCM Dose Factors and Parameters". (1983)

UOTH 20200008, "Justification to support removal of Radiation Monitor BM-RE-052 from FSAR-SP Chapter 16.11". (2020)

USNRC Inspection Report 50-483/92002(DRSS), Section 5, page 5.

Westinghouse Calculation Note CN-TA-02-135, "Callaway (SCP) RSG IGOR/RETRAN Base Deck, May 16, 2003

ZZ-250, Rev. 1, "ODCM Gaseous Pathway Dose Factors for Child Age Group and Ground Plane Dose Factors". (1998)

ZZ-48, "Calculation of Inhalation and Ingestion Dose Commitment Factors for the Adult and Child". (1988)

ZZ-57, "Dose Factors for Eu-154". (1989)

ZZ-78, Rev. 2, "ODCM Gaseous Pathway Dose Factors for Adult Age Group". (1992)

Table 1: Ingestion Dose Commitment Values (A_{IC}) for Adult Age Group⁶⁵(mrem/hr) per (μ Ci/ml)

Nuclide	Bone	Liver	Total Body	Thyroid	Kidney	Lung	GI-LLI
³ H	0.00E+00	2.26E-01	2.26E-01	2.26E-01	2.26E-01	2.26E-01	2.26E-01
⁷ Be	1.31E-02	2.98E-02	1.45E-02	0.00E+00	3.15E-02	0.00E+00	5.17E+00
²⁴ Na	4.07E+02	4.07E+02	4.07E+02	4.07E+02	4.07E+02	4.07E+02	4.07E+02
⁵¹ Cr	0.00E+00	0.00E+00	1.27E+00	7.61E-01	2.81E-01	1.69E+00	3.20E+02
⁵⁴ Mn	0.00E+00	4.38E+03	8.35E+02	0.00E+00	1.30E+03	0.00E+00	1.34E+04
⁵⁶ Mn	0.00E+00	1.10E+02	1.95E+01	0.00E+00	1.40E+02	0.00E+00	3.51E+03
⁵⁵ Fe	6.58E+02	4.55E+02	1.06E+02	0.00E+00	0.00E+00	2.54E+02	2.61E+02
⁵⁹ Fe	1.04E+03	2.44E+03	9.36E+02	0.00E+00	0.00E+00	6.82E+02	8.14E+03
⁵⁷ Co	0.00E+00	2.09E+01	3.48E+01	0.00E+00	0.00E+00	0.00E+00	5.31E+02
⁵⁸ Co	0.00E+00	8.92E+01	2.00E+02	0.00E+00	0.00E+00	0.00E+00	1.81E+03
⁶⁰ Co	0.00E+00	2.56E+02	5.65E+02	0.00E+00	0.00E+00	0.00E+00	4.81E+03
⁶³ Ni	3.11E+04	2.16E+03	1.04E+03	0.00E+00	0.00E+00	0.00E+00	4.50E+02
⁶⁵ Ni	1.26E+02	1.64E+01	7.49E+00	0.00E+00	0.00E+00	0.00E+00	4.17E+02
⁶⁴ Cu	0.00E+00	9.97E+00	4.68E+00	0.00E+00	2.51E+01	0.00E+00	8.50E+02
⁶⁵ Zn	2.32E+04	7.37E+04	3.33E+04	0.00E+00	4.93E+04	0.00E+00	4.64E+04
⁶⁹ Zn	4.93E+01	9.43E+01	6.56E+00	0.00E+00	6.13E+01	0.00E+00	1.42E+01
⁸² Br	0.00E+00	0.00E+00	2.27E+03	0.00E+00	0.00E+00	0.00E+00	2.60E+03
⁸³ Br	0.00E+00	0.00E+00	4.04E+01	0.00E+00	0.00E+00	0.00E+00	5.82E+01
⁸⁴ Br	0.00E+00	0.00E+00	5.24E+01	0.00E+00	0.00E+00	0.00E+00	4.11E-04
⁸⁵ Br	0.00E+00	0.00E+00	2.15E+00	0.00E+00	0.00E+00	0.00E+00	1.01E-15
⁸⁶ Rb	0.00E+00	1.01E+05	4.71E+04	0.00E+00	0.00E+00	0.00E+00	1.99E+04
⁸⁸ Rb	0.00E+00	2.90E+02	1.54E+02	0.00E+00	0.00E+00	0.00E+00	4.00E-09
⁸⁹ Rb	0.00E+00	1.92E+02	1.35E+02	0.00E+00	0.00E+00	0.00E+00	1.12E-11
⁸⁹ Sr	2.21E+04	0.00E+00	6.35E+02	0.00E+00	0.00E+00	0.00E+00	3.55E+03
⁹⁰ Sr	5.44E+05	0.00E+00	1.34E+05	0.00E+00	0.00E+00	0.00E+00	1.57E+04
⁹¹ Sr	4.07E+02	0.00E+00	1.64E+01	0.00E+00	0.00E+00	0.00E+00	1.94E+03
⁹² Sr	1.54E+02	0.00E+00	6.68E+00	0.00E+00	0.00E+00	0.00E+00	3.06E+03
⁹⁰ Y	5.76E-01	0.00E+00	1.54E-02	0.00E+00	0.00E+00	0.00E+00	6.10E+03
^{91m} Y	5.44E-03	0.00E+00	2.11E-04	0.00E+00	0.00E+00	0.00E+00	1.60E-02
⁹¹ Y	8.44E+00	0.00E+00	2.26E-01	0.00E+00	0.00E+00	0.00E+00	4.64E+03
⁹² Y	5.06E-02	0.00E+00	1.48E-03	0.00E+00	0.00E+00	0.00E+00	8.86E+02
⁹³ Y	1.60E-01	0.00E+00	4.43E-03	0.00E+00	0.00E+00	0.00E+00	5.09E+03
⁹⁵ Zr	2.40E-01	7.70E-02	5.21E-02	0.00E+00	1.21E-01	0.00E+00	2.44E+02

Table 1: Ingestion Dose Commitment Values (A_{ic}) for Adult Age Group

(mrem/hr) per (μ Ci/ml)

Nuclide	Bone	Liver	Total Body	Thyroid	Kidney	Lung	GI-LLI
⁹⁷ Zr	1.33E-02	2.68E-03	1.22E-03	0.00E+00	4.04E-03	0.00E+00	8.30E+02
⁹⁵ Nb	4.47E+02	2.48E+02	1.34E+02	0.00E+00	2.46E+02	0.00E+00	1.51E+06
⁹⁹ Mo	0.00E+00	1.03E+02	1.96E+01	0.00E+00	2.34E+02	0.00E+00	2.39E+02
^{99m} Tc	8.87E-03	2.51E-02	3.19E-01	0.00E+00	3.81E-01	1.23E-02	1.48E+01
¹⁰¹ Tc	9.12E-03	1.31E-02	1.29E-01	0.00E+00	2.37E-01	6.72E-03	3.95E-14
¹⁰³ Ru	4.43E+00	0.00E+00	1.91E+00	0.00E+00	1.69E+01	0.00E+00	5.17E+02
¹⁰⁵ Ru	3.69E-01	0.00E+00	1.46E-01	0.00E+00	4.76E+00	0.00E+00	2.26E+02
¹⁰⁶ Ru	6.58E+01	0.00E+00	8.33E+00	0.00E+00	1.27E+02	0.00E+00	4.26E+03
¹⁰⁹ Cd	0.00E+00	5.55E+02	1.94E+01	0.00E+00	5.31E+02	0.00E+00	5.60E+03
^{110m} Ag	8.85E-01	8.18E-01	4.86E-01	0.00E+00	1.61E+00	0.00E+00	3.34E+02
¹¹³ Sn	5.67E+04	1.61E+03	3.26E+03	9.19E+02	0.00E+00	0.00E+00	1.69E+05
^{117m} Sn	2.79E+03	1.62E+02	6.99E+02	5.21E+01	0.00E+00	0.00E+00	0.00E+00
¹²² Sb	5.48E-01	1.12E-02	1.66E-01	7.73E-03	0.00E+00	2.94E-01	0.00E+00
¹²⁴ Sb	6.70E+00	1.27E-01	2.66E+00	1.63E-02	0.00E+00	5.22E+00	1.90E+02
¹²⁵ Sb	4.29E+00	4.79E-02	1.02E+00	4.36E-03	0.00E+00	3.30E+00	4.72E+01
¹²⁶ Sb	2.75E+00	5.59E-02	9.92E-01	1.68E-02	0.00E+00	1.68E+00	2.25E+02
^{127m} Te	6.48E+03	2.32E+03	7.90E+02	1.66E+03	2.63E+04	0.00E+00	2.17E+04
¹²⁷ Te	1.05E+02	3.78E+01	2.28E+01	7.80E+01	4.29E+02	0.00E+00	8.31E+03
^{129m} Te	1.10E+04	4.11E+03	1.74E+03	3.78E+03	4.60E+04	0.00E+00	5.54E+04
¹²⁹ Te	3.01E+01	1.13E+01	7.33E+00	2.31E+01	1.26E+02	0.00E+00	2.27E+01
^{131m} Te	1.66E+03	8.10E+02	6.75E+02	1.28E+03	8.21E+03	0.00E+00	8.04E+04
¹³¹ Te	1.89E+01	7.88E+00	5.96E+00	1.55E+01	8.26E+01	0.00E+00	2.67E+00
¹³² Te	2.41E+03	1.56E+03	1.47E+03	1.72E+03	1.50E+04	0.00E+00	7.38E+04
¹³⁰ I	2.71E+01	8.01E+01	3.16E+01	6.79E+03	1.25E+02	0.00E+00	6.89E+01
¹³¹ I	1.49E+02	2.14E+02	1.22E+02	7.00E+04	3.66E+02	0.00E+00	5.64E+01
¹³² I	7.29E+00	1.95E+01	6.82E+00	6.82E+02	3.11E+01	0.00E+00	3.66E+00
¹³³ I	5.14E+01	8.87E+01	2.70E+01	1.30E+04	1.55E+02	0.00E+00	7.97E+01
¹³⁴ I	3.81E+00	1.03E+01	3.70E+00	1.79E+02	1.64E+01	0.00E+00	9.01E-03
¹³⁵ I	1.59E+01	4.17E+01	1.54E+01	2.75E+03	6.68E+01	0.00E+00	4.70E+01
¹³⁴ Cs	2.98E+05	7.09E+05	5.79E+05	0.00E+00	2.29E+05	7.61E+04	1.24E+04
¹³⁶ Cs	3.12E+04	1.23E+05	8.86E+04	0.00E+00	6.85E+04	9.38E+03	1.40E+04
¹³⁷ Cs	3.82E+05	5.22E+05	3.42E+05	0.00E+00	1.77E+05	5.89E+04	1.01E+04
¹³⁸ Cs	2.64E+02	5.22E+02	2.59E+02	0.00E+00	3.84E+02	3.79E+01	2.23E-03
¹³⁹ Ba	9.29E-01	6.62E-04	2.72E-02	0.00E+00	6.19E-04	3.75E-04	1.65E+00

⁶⁵ UOTH 83-58, Calculation 88-002-00-F, ZZ-48, ZZ-57, ZZ-78, HPCI 8902, HPCI 0406, HPCI 1604, HPCI 1802.

Table 1: Ingestion Dose Commitment Values (A_{ic}) for Adult Age Group(mrem/hr) per (μ Ci/ml)

Nuclide	Bone	Liver	Total Body	Thyroid	Kidney	Lung	GI-LLI
^{140}Ba	1.94E+02	2.44E-01	1.27E+01	0.00E+00	8.30E-02	1.40E-01	4.00E+02
^{141}Ba	4.51E-01	3.41E-04	1.52E-02	0.00E+00	3.17E-04	1.93E-04	2.13E-10
^{142}Ba	2.04E-01	2.10E-04	1.28E-02	0.00E+00	1.77E-04	1.19E-04	2.87E-19
^{140}La	1.50E-01	7.54E-02	1.99E-02	0.00E+00	0.00E+00	0.00E+00	5.54E+03
^{142}La	7.66E-03	3.48E-03	8.68E-04	0.00E+00	0.00E+00	0.00E+00	2.54E+01
^{141}Ce	2.24E-02	1.52E-02	1.72E-03	0.00E+00	7.04E-03	0.00E+00	5.79E+01
^{143}Ce	3.95E-03	2.92E+00	3.23E-04	0.00E+00	1.29E-03	0.00E+00	1.09E+02
^{144}Ce	1.17E+00	4.88E-01	6.27E-02	0.00E+00	2.90E-01	0.00E+00	3.95E+02
^{143}Pr	5.51E-01	2.21E-01	2.73E-02	0.00E+00	1.27E-01	0.00E+00	2.41E+03
^{144}Pr	1.80E-03	7.48E-04	9.16E-05	0.00E+00	4.22E-04	0.00E+00	2.59E-10
^{147}Nd	3.76E-01	4.35E-01	2.60E-02	0.00E+00	2.54E-01	0.00E+00	2.09E+03
^{154}Eu	3.68E+01	4.52E+00	3.22E+00	0.00E+00	2.17E+01	0.00E+00	3.28E+03
^{181}Hf	4.00E-02	1.94E-01	1.80E-02	0.00E+00	4.18E-02	0.00E+00	2.21E+02
^{187}W	2.96E+02	2.47E+02	8.65E+01	0.00E+00	0.00E+00	0.00E+00	8.10E+04
^{237}Np	3.28E+04	2.85E+03	1.33E+03	0.00E+00	9.86E+03	0.00E+00	1.90E+03
^{239}Np	2.85E-02	2.80E-03	1.54E-03	0.00E+00	8.74E-03	0.00E+00	5.75E+02
^{238}Pu	5.70E+03	8.03E+02	1.43E+02	0.00E+00	6.13E+02	0.00E+00	6.12E+02
$^{239}\text{Pu}^*$	6.59E+03	8.88E+02	1.60E+02	0.00E+00	6.80E+02	0.00E+00	5.68E+02
^{241}Pu	1.38E+02	7.07E+00	2.78E+00	0.00E+00	1.28E+01	0.00E+00	1.17E+01
^{241}Am	4.90E+04	1.72E+04	3.24E+03	0.00E+00	2.44E+04	0.00E+00	4.44E+03
^{242}Cm	1.23E+03	1.26E+03	8.20E+01	0.00E+00	3.72E+02	0.00E+00	4.74E+03
$^{243}\text{Cm}^{**}$	3.82E+04	1.44E+04	2.24E+03	0.00E+00	1.05E+04	0.00E+00	4.67E+03

*Includes ^{240}Pu contribution**Includes ^{244}Cm contribution

Table 2: Bioaccumulation Factor (B _f) ⁶⁶ (pCi/kg) per (pCi/liter)			
Element	B _f Fish (Freshwater)	Element	B _f Fish (Freshwater)
H	9.0 E - 01	Rh	1.0 E + 01
Be	2.0 E + 00	Ag	2.3 E + 00
Na	1.0 E + 02	Cd	2.0 E + 02
Cr	2.0 E + 02	Sn	3.0 E + 03
Mn	4.0 E + 02	Sb	1.0 E + 00
Fe	1.0 E + 02	Te	4.0 E + 02
Co	5.0 E + 01	I	1.5 E + 01
Ni	1.0 E + 02	Cs	2.0 E + 03
Cu	5.0 E + 01	Ba	4.0 E + 00
Zn	2.0 E + 03	La	2.5 E + 01
Br	4.2 E + 02	Ce	1.0 E + 00
Rb	2.0 E + 03	Pr	2.5 E + 01
Sr	3.0 E + 01	Nd	2.5 E + 01
Y	2.5 E + 01	Eu	2.5 E + 01
Zr	3.3 E + 00	Hf	3.3 E + 00
Nb	3.0 E + 04	W	1.2 E + 03
Mo	1.0 E + 01	Np	1.0 E + 01
Tc	1.5 E + 01	Pu	3.5 E + 00
Ru	1.0 E + 01	Am	2.5 E + 01
		Cm	2.5 E + 01

⁶⁶ Values from Regulatory Guide 1.109, Rev. 1, Table A-1 and HPCI 0406.

Table 3: Dose Factor for Exposure to a Semi- Infinite Cloud of Noble Gases⁶⁷

Radionuclide	Total Body Dose Factor K_i (mrem/yr) per ($\mu\text{Ci}/\text{m}^3$)	Skin Dose Factor L_i (mrem/yr) per ($\mu\text{Ci}/\text{m}^3$)	Gamma Air Dose Factor M_i (mrad/yr) per ($\mu\text{Ci}/\text{m}^3$)	Beta Air Dose Factor N_i (mrad/yr) per ($\mu\text{Ci}/\text{m}^3$)
^{83m} Kr	7.56 E-02	-----	1.93 E+01	2.88 E+02
^{85m} Kr	1.17E+03	1.46E+03	1.23 E+03	1.97 E+03
⁸⁵ Kr	1.61 E+01	1.34 E+03	1.72 E+01	1.95 E+03
⁸⁷ Kr	5.92 E+03	9.73 E+03	6.17 E+03	1.03 E+04
⁸⁸ Kr	1.47 E+04	2.37 E+03	1.52 E+04	2.93 E+03
⁸⁹ Kr	1.66 E+04	1.01 E+04	1.73 E+04	1.06 E+04
⁹⁰ Kr	1.56 E+04	7.29 E+03	1.63 E+04	7.83 E+03
^{131m} Xe	9.15 E+01	4.76 E+02	1.56 E+02	1.11 E+03
^{133m} Xe	2.51 E+02	9.94 E+02	3.27 E+02	1.48 E+03
¹³³ Xe	2.94 E+02	3.06 E+02	3.53 E+02	1.05 E+03
^{135m} Xe	3.12 E+03	7.11 E+02	3.36 E+03	7.39 E+02
¹³⁵ Xe	1.81 E+03	1.86 E+03	1.92 E+03	2.46 E+03
¹³⁷ Xe	1.42 E+03	1.22 E+04	1.51 E+03	1.27 E+04
¹³⁸ Xe	8.83 E+03	4.13 E+03	9.21 E+03	4.75 E+03
⁴¹ Ar	8.84 E+03	2.69 E+03	9.30 E+03	3.28 E+03

⁶⁷ Values from Reg. Guide 1.109, Table B-1 multiplied by a units conversion factor of 1E6 to convert from pCi to μCi .

Table 4: Ground Plane Pathway Dose Factors (R_i)⁶⁸(m²mrem/yr) per (μCi/sec)

Nuclide	Total Body	Skin	Nuclide	Total Body	Skin
³ H	0.00E+00	0.00E+00	¹¹³ Sn	1.43E+07	4.09E+07
⁷ Be	2.24E+07	3.21E+07	¹²⁴ Sb	8.74E+08	1.23E+09
⁵¹ Cr	4.66E+06	5.51E+06	¹²⁵ Sb	3.57E+09	5.19E+09
⁵⁴ Mn	1.39E+09	1.63E+09	^{127m} Te	9.17E+04	1.08E+05
⁵⁵ Fe	0.00E+00	0.00E+00	^{129m} Te	1.98E+07	2.31E+07
⁵⁹ Fe	2.73E+08	3.21E+08	¹³⁰ I	5.51E+06	6.69E+06
⁵⁷ Co	2.98E+08	4.37E+08	¹³¹ I	1.72E+07	2.09E+07
⁵⁸ Co	3.79E+08	4.44E+08	¹³² I	1.25E+06	1.47E+06
⁶⁰ Co	2.15E+10	2.53E+10	¹³³ I	2.45E+06	2.98E+06
⁶³ Ni	0.00E+00	0.00E+00	¹³⁴ I	4.47E+05	5.31E+05
⁶⁵ Zn	7.47E+08	8.59E+08	¹³⁵ I	2.53E+06	2.95E+06
⁸⁶ Rb	8.99E+06	1.03E+07	¹³⁴ Cs	6.85E+09	8.00E+09
⁸⁹ Sr	2.16E+04	2.51E+04	¹³⁶ Cs	1.51E+08	1.71E+08
⁹⁰ Sr	0.00E+00	0.00E+00	¹³⁷ Cs	1.03E+10	1.20E+10
⁹⁰ Y	5.36E+06	6.32E+06	¹⁴⁰ Ba	2.05E+07	2.35E+07
⁹¹ Y	1.07E+06	1.21E+06	¹⁴⁰ La	1.47E+08	1.66E+08
⁹⁵ Zr	2.45E+08	2.84E+08	¹⁴¹ Ce	1.37E+07	1.54E+07
⁹⁵ Nb	2.50E+08	2.94E+08	¹⁴⁴ Ce	6.96E+07	8.04E+07
¹⁰³ Ru	1.08E+08	1.26E+08	¹⁴³ Pr	0.00E+00	0.00E+00
¹⁰⁶ Ru	4.22E+08	5.07E+08	¹⁴⁴ Pr	4.35E+07	5.00E+07
^{110m} Ag	3.44E+09	4.01E+09	¹⁴⁷ Nd	8.39E+06	1.01E+07
¹⁰⁹ Cd	3.76E+07	1.54E+08	¹⁵⁴ Eu	2.21E+10	3.15E+10
			¹⁸¹ Hf	1.97E+08	2.82E+08

⁶⁸ ZZ-250, rev. 1

Table 5: Child Inhalation Pathway Dose Factors (R_i)⁶⁹(mrem/yr) per ($\mu\text{Ci}/\text{m}^3$)

Nuclide	Bone	Liver	Total Body	Thyroid	Kidney	Lung	GI-LLI
³ H	0.00E+00	1.12E+03	1.12E+03	1.12E+03	1.12E+03	1.12E+03	1.12E+03
⁷ Be	8.47E+02	1.44E+03	9.25E+02	0.00E+00	0.00E+00	6.47E+04	2.55E+03
⁵¹ Cr	0.00E+00	0.00E+00	1.54E+02	8.55E+01	2.43E+01	1.70E+04	1.08E+03
⁵⁴ Mn	0.00E+00	4.29E+04	9.51E+03	0.00E+00	1.00E+04	1.58E+06	2.29E+04
⁵⁵ Fe	4.74E+04	2.52E+04	7.77E+03	0.00E+00	0.00E+00	1.11E+05	2.87E+03
⁵⁹ Fe	2.07E+04	3.34E+04	1.67E+04	0.00E+00	0.00E+00	1.27E+06	7.07E+04
⁵⁷ Co	0.00E+00	9.03E+02	1.07E+03	0.00E+00	0.00E+00	5.07E+05	1.32E+04
⁵⁸ Co	0.00E+00	1.77E+03	3.16E+03	0.00E+00	0.00E+00	1.11E+06	3.44E+04
⁶⁰ Co	0.00E+00	1.31E+04	2.26E+04	0.00E+00	0.00E+00	7.07E+06	9.62E+04
⁶³ Ni	8.21E+05	4.63E+04	2.80E+04	0.00E+00	0.00E+00	2.75E+05	6.33E+03
⁶⁵ Zn	4.25E+04	1.13E+05	7.03E+04	0.00E+00	7.14E+04	9.95E+05	1.63E+04
⁸⁶ Rb	0.00E+00	1.98E+05	1.14E+05	0.00E+00	0.00E+00	0.00E+00	7.99E+03
⁸⁹ Sr	5.99E+05	0.00E+00	1.72E+04	0.00E+00	0.00E+00	2.16E+06	1.67E+05
⁹⁰ Sr	1.01E+08	0.00E+00	6.44E+06	0.00E+00	0.00E+00	1.48E+07	3.43E+05
⁹⁰ Y	4.11E+03	0.00E+00	1.11E+02	0.00E+00	0.00E+00	2.62E+05	2.68E+05
⁹¹ Y	9.14E+05	0.00E+00	2.44E+04	0.00E+00	0.00E+00	2.63E+06	1.84E+05
⁹⁵ Zr	1.90E+05	4.18E+04	3.70E+04	0.00E+00	5.96E+04	2.23E+06	6.11E+04
⁹⁵ Nb	2.35E+04	9.18E+03	6.55E+03	0.00E+00	8.62E+03	6.14E+05	3.70E+04
¹⁰³ Ru	2.79E+03	0.00E+00	1.07E+03	0.00E+00	7.03E+03	6.62E+05	4.48E+04
¹⁰⁶ Ru	1.36E+05	0.00E+00	1.69E+04	0.00E+00	1.84E+05	1.43E+07	4.29E+05
^{110m} Ag	1.69E+04	1.14E+04	9.14E+03	0.00E+00	2.12E+04	5.48E+06	1.00E+05
¹⁰⁹ Cd	0.00E+00	5.48E+05	2.59E+04	0.00E+00	4.96E+05	1.05E+06	2.78E+04
¹¹³ Sn	1.13E+05	3.12E+03	8.62E+03	2.33E+03	0.00E+00	1.46E+06	2.26E+05
¹²⁴ Sb	5.74E+04	7.40E+02	2.00E+04	1.26E+02	0.00E+00	3.24E+06	1.64E+05
¹²⁵ Sb	9.84E+04	7.59E+02	2.07E+04	9.10E+01	0.00E+00	2.32E+06	4.03E+04
^{127m} Te	2.49E+04	8.55E+03	3.02E+03	6.07E+03	6.36E+04	1.48E+06	7.14E+04
^{129m} Te	1.92E+04	6.85E+03	3.04E+03	6.33E+03	5.03E+04	1.76E+06	1.82E+05

⁶⁹ ZZ-250, rev. 1

Table 5: Child Inhalation Pathway Dose Factors (R_i)

(mrem/yr) per ($\mu\text{Ci}/\text{m}^3$)

Nuclide	Bone	Liver	Total Body	Thyroid	Kidney	Lung	GI-LLI
^{130}I	8.18E+03	1.64E+04	8.44E+03	1.85E+06	2.45E+04	0.00E+00	5.11E+03
^{131}I	4.81E+04	4.81E+04	2.73E+04	1.62E+07	7.88E+04	0.00E+00	2.84E+03
^{132}I	2.12E+03	4.07E+03	1.88E+03	1.94E+05	6.25E+03	0.00E+00	3.20E+03
^{133}I	1.66E+04	2.03E+04	7.70E+03	3.85E+06	3.38E+04	0.00E+00	5.48E+03
^{134}I	1.17E+03	2.16E+03	9.95E+02	5.07E+04	3.30E+03	0.00E+00	9.55E+02
^{135}I	4.92E+03	8.73E+03	4.14E+03	7.92E+05	1.34E+04	0.00E+00	4.44E+03
^{134}Cs	6.51E+05	1.01E+06	2.25E+05	0.00E+00	3.30E+05	1.21E+05	3.85E+03
^{136}Cs	6.51E+04	1.71E+05	1.16E+05	0.00E+00	9.55E+04	1.45E+04	4.18E+03
^{137}Cs	9.07E+05	8.25E+05	1.28E+05	0.00E+00	2.82E+05	1.04E+05	3.62E+03
^{140}Ba	7.40E+04	6.48E+01	4.33E+03	0.00E+00	2.11E+01	1.74E+06	1.02E+05
^{140}La	6.44E+02	2.25E+02	7.55E+01	0.00E+00	0.00E+00	1.83E+05	2.26E+05
^{141}Ce	3.92E+04	1.95E+04	2.90E+03	0.00E+00	8.55E+03	5.44E+05	5.66E+04
^{144}Ce	6.77E+06	2.12E+06	3.61E+05	0.00E+00	1.17E+06	1.20E+07	3.89E+05
^{143}Pr	1.85E+04	5.55E+03	9.14E+02	0.00E+00	3.00E+03	4.33E+05	9.73E+04
^{144}Pr	5.96E-02	1.85E-02	3.00E-03	0.00E+00	9.77E-03	1.57E+03	1.97E+02
^{147}Nd	1.08E+04	8.73E+03	6.81E+02	0.00E+00	4.81E+03	3.28E+05	8.21E+04
^{154}Eu	1.01E+07	9.21E+05	8.40E+05	0.00E+00	4.03E+06	6.14E+06	1.10E+05
^{181}Hf	2.78E+04	1.01E+05	1.25E+04	0.00E+00	2.05E+04	1.06E+06	6.62E+04

Table 6: Child Grass- Cow – Milk Pathway Dose Factors (R_i)⁷⁰(m²mrem/yr) per (μCi/sec)

Nuclide	Bone	Liver	Total Body	Thyroid	Kidney	Lung	GI-LLI
³ H	0.00E+00	1.57E+03	1.57E+03	1.57E+03	1.57E+03	1.57E+03	1.57E+03
⁷ Be	7.50E+03	1.28E+04	8.20E+03	0.00E+00	1.25E+04	0.00E+00	7.12E+05
⁵¹ Cr	0.00E+00	0.00E+00	1.02E+05	5.66E+04	1.55E+04	1.03E+05	5.40E+06
⁵⁴ Mn	0.00E+00	2.10E+07	5.59E+06	0.00E+00	5.89E+06	0.00E+00	1.76E+07
⁵⁵ Fe	1.12E+08	5.94E+07	1.84E+07	0.00E+00	0.00E+00	3.36E+07	1.10E+07
⁵⁹ Fe	1.20E+08	1.95E+08	9.70E+07	0.00E+00	0.00E+00	5.64E+07	2.03E+08
⁵⁷ Co	0.00E+00	3.84E+06	7.78E+06	0.00E+00	0.00E+00	0.00E+00	3.15E+07
⁵⁸ Co	0.00E+00	1.21E+07	3.72E+07	0.00E+00	0.00E+00	0.00E+00	7.08E+07
⁶⁰ Co	0.00E+00	4.32E+07	1.27E+08	0.00E+00	0.00E+00	0.00E+00	2.39E+08
⁶³ Ni	2.97E+10	1.59E+09	1.01E+09	0.00E+00	0.00E+00	0.00E+00	1.07E+08
⁶⁵ Zn	4.14E+09	1.10E+10	6.86E+09	0.00E+00	6.95E+09	0.00E+00	1.94E+09
⁸⁶ Rb	0.00E+00	8.78E+09	5.40E+09	0.00E+00	0.00E+00	0.00E+00	5.65E+08
⁸⁹ Sr	6.63E+09	0.00E+00	1.89E+08	0.00E+00	0.00E+00	0.00E+00	2.57E+08
⁹⁰ Sr	1.12E+11	0.00E+00	2.84E+10	0.00E+00	0.00E+00	0.00E+00	1.51E+09
⁹⁰ Y	3.38E+03	0.00E+00	9.05E+01	0.00E+00	0.00E+00	0.00E+00	9.62E+06
⁹¹ Y	3.91E+04	0.00E+00	1.04E+03	0.00E+00	0.00E+00	0.00E+00	5.20E+06
⁹⁵ Zr	3.84E+03	8.43E+02	7.51E+02	0.00E+00	1.21E+03	0.00E+00	8.80E+05
⁹⁵ Nb	3.72E+05	1.45E+05	1.03E+05	0.00E+00	1.36E+05	0.00E+00	2.68E+08
¹⁰³ Ru	4.29E+03	0.00E+00	1.65E+03	0.00E+00	1.08E+04	0.00E+00	1.11E+05
¹⁰⁶ Ru	9.25E+04	0.00E+00	1.15E+04	0.00E+00	1.25E+05	0.00E+00	1.44E+06
^{110m} Ag	2.09E+08	1.41E+08	1.13E+08	0.00E+00	2.63E+08	0.00E+00	1.68E+10
¹⁰⁹ Cd	0.00E+00	3.86E+06	1.79E+05	0.00E+00	3.45E+06	0.00E+00	1.25E+07
¹¹³ Sn	6.11E+08	1.26E+07	3.48E+07	9.29E+08	0.00E+00	0.00E+00	4.32E+08
¹²⁴ Sb	1.09E+08	1.41E+06	3.81E+07	2.40E+05	0.00E+00	6.03E+07	6.80E+08
¹²⁵ Sb	8.71E+07	6.72E+05	1.83E+07	8.07E+04	0.00E+00	4.86E+07	2.08E+08
^{127m} Te	2.08E+08	5.61E+07	2.47E+07	4.98E+07	5.94E+08	0.00E+00	1.69E+08
^{129m} Te	2.72E+08	7.59E+07	4.22E+07	8.76E+07	7.98E+08	0.00E+00	3.31E+08

⁷⁰ ZZ-250, rev. 1

Table 6: Child Grass- Cow – Milk Pathway Dose Factors (R_i) $(\text{m}^2\text{mrem/yr}) \text{ per } (\mu\text{Ci/sec})$

Nuclide	Bone	Liver	Total Body	Thyroid	Kidney	Lung	GI-LLI
^{130}I	1.73E+06	3.50E+06	1.80E+06	3.85E+08	5.23E+06	0.00E+00	1.64E+06
^{131}I	1.30E+09	1.31E+09	7.46E+08	4.34E+11	2.15E+09	0.00E+00	1.17E+08
^{132}I	6.92E-01	1.27E+00	5.85E-01	5.90E+01	1.95E+00	0.00E+00	1.50E+00
^{133}I	1.72E+07	2.13E+07	8.05E+06	3.95E+09	3.54E+07	0.00E+00	8.57E+06
^{134}I	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
^{135}I	5.41E+04	9.74E+04	4.61E+04	8.63E+06	1.49E+05	0.00E+00	7.42E+04
^{134}Cs	2.27E+10	3.72E+10	7.84E+09	0.00E+00	1.15E+10	4.14E+09	2.00E+08
^{136}Cs	1.01E+09	2.78E+09	1.80E+09	0.00E+00	1.48E+09	2.21E+08	9.78E+07
^{137}Cs	3.23E+10	3.09E+10	4.56E+09	0.00E+00	1.01E+10	3.62E+09	1.93E+08
^{140}Ba	1.17E+08	1.03E+05	6.84E+06	0.00E+00	3.34E+04	6.12E+04	5.94E+07
^{140}La	1.78E+02	6.23E+01	2.10E+01	0.00E+00	0.00E+00	0.00E+00	1.74E+06
^{141}Ce	2.19E+04	1.09E+04	1.62E+03	0.00E+00	4.79E+03	0.00E+00	1.36E+07
^{144}Ce	1.62E+06	5.09E+05	8.67E+04	0.00E+00	2.82E+05	0.00E+00	1.33E+08
^{143}Pr	7.19E+02	2.16E+02	3.57E+01	0.00E+00	1.17E+02	0.00E+00	7.76E+05
^{144}Pr	5.04E+00	1.56E+00	2.53E-01	0.00E+00	8.24E-01	0.00E+00	3.35E+03
^{147}Nd	4.45E+02	3.61E+02	2.79E+01	0.00E+00	1.98E+02	0.00E+00	5.71E+05
^{154}Eu	9.43E+04	8.48E+03	7.75E+03	0.00E+00	3.73E+04	0.00E+00	1.97E+06
^{181}Hf	6.44E+02	2.35E+03	2.91E+02	0.00E+00	4.76E+02	0.00E+00	8.66E+05

Table 7: Child Grass- Goat – Milk Pathway Dose Factors (R_i)⁷¹(m²mrem/yr) per (μCi/sec)

Nuclide	Bone	Liver	Total Body	Thyroid	Kidney	Lung	GI-LLI
³ H	0.00E+00	3.20E+03	3.20E+03	3.20E+03	3.20E+03	3.20E+03	3.20E+03
⁷ Be	9.00E+02	1.53E+03	9.84E+02	0.00E+00	1.50E+03	0.00E+00	8.55E+04
⁵¹ Cr	0.00E+00	0.00E+00	1.22E+04	6.79E+03	1.85E+03	1.24E+04	6.48E+05
⁵⁴ Mn	0.00E+00	2.52E+06	6.71E+05	0.00E+00	7.06E+05	0.00E+00	2.11E+06
⁵⁵ Fe	1.45E+06	7.72E+05	2.39E+05	0.00E+00	0.00E+00	4.36E+05	1.43E+05
⁵⁹ Fe	1.56E+06	2.53E+06	1.26E+06	0.00E+00	0.00E+00	7.34E+05	2.64E+06
⁵⁷ Co	0.00E+00	4.61E+05	9.33E+05	0.00E+00	0.00E+00	0.00E+00	3.78E+06
⁵⁸ Co	0.00E+00	1.46E+06	4.46E+06	0.00E+00	0.00E+00	0.00E+00	8.50E+06
⁶⁰ Co	0.00E+00	5.19E+06	1.53E+07	0.00E+00	0.00E+00	0.00E+00	2.87E+07
⁶³ Ni	3.56E+09	1.91E+08	1.21E+08	0.00E+00	0.00E+00	0.00E+00	1.28E+07
⁶⁵ Zn	4.97E+08	1.32E+09	8.23E+08	0.00E+00	8.34E+08	0.00E+00	2.32E+08
⁸⁶ Rb	0.00E+00	1.05E+09	6.48E+08	0.00E+00	0.00E+00	0.00E+00	6.78E+07
⁸⁹ Sr	1.39E+10	0.00E+00	3.97E+08	0.00E+00	0.00E+00	0.00E+00	5.39E+08
⁹⁰ Sr	2.35E+11	0.00E+00	5.95E+10	0.00E+00	0.00E+00	0.00E+00	3.16E+09
⁹⁰ Y	4.06E+02	0.00E+00	1.09E+01	0.00E+00	0.00E+00	0.00E+00	1.15E+06
⁹¹ Y	4.69E+03	0.00E+00	1.25E+02	0.00E+00	0.00E+00	0.00E+00	6.25E+05
⁹⁵ Zr	4.60E+02	1.01E+02	9.01E+01	0.00E+00	1.45E+02	0.00E+00	1.06E+05
⁹⁵ Nb	4.46E+04	1.74E+04	1.24E+04	0.00E+00	1.63E+04	0.00E+00	3.21E+07
¹⁰³ Ru	5.14E+02	0.00E+00	1.98E+02	0.00E+00	1.29E+03	0.00E+00	1.33E+04
¹⁰⁶ Ru	1.11E+04	0.00E+00	1.38E+03	0.00E+00	1.50E+04	0.00E+00	1.73E+05
^{110m} Ag	2.51E+07	1.69E+07	1.35E+07	0.00E+00	3.15E+07	0.00E+00	2.01E+09
¹⁰⁹ Cd	0.00E+00	4.64E+05	2.15E+04	0.00E+00	4.14E+05	0.00E+00	1.50E+06
¹¹³ Sn	7.33E+07	1.51E+06	4.18E+06	1.11E+08	0.00E+00	0.00E+00	5.18E+07
¹²⁴ Sb	1.30E+07	1.69E+05	4.57E+06	2.88E+04	0.00E+00	7.24E+06	8.16E+07
¹²⁵ Sb	1.05E+07	8.06E+04	2.19E+06	9.68E+03	0.00E+00	5.83E+06	2.50E+07
^{127m} Te	2.50E+07	6.73E+06	2.97E+06	5.98E+06	7.13E+07	0.00E+00	2.02E+07
^{129m} Te	3.26E+07	9.10E+06	5.06E+06	1.05E+07	9.57E+07	0.00E+00	3.98E+07

⁷¹ ZZ-250, rev. 1

Table 7: Child Grass- Goat – Milk Pathway Dose Factors (R_i) $(\text{m}^2\text{mrem/yr})$ per $(\mu\text{Ci/sec})$

Nuclide	Bone	Liver	Total Body	Thyroid	Kidney	Lung	GI-LLI
^{130}I	2.08E+06	4.20E+06	2.16E+06	4.62E+08	6.27E+06	0.00E+00	1.96E+06
^{131}I	1.57E+09	1.57E+09	8.95E+08	5.21E+11	2.58E+09	0.00E+00	1.40E+08
^{132}I	8.30E-01	1.53E+00	7.02E-01	7.08E+01	2.34E+00	0.00E+00	1.80E+00
^{133}I	2.06E+07	2.55E+07	9.66E+06	4.74E+09	4.25E+07	0.00E+00	1.03E+07
^{134}I	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
^{135}I	6.49E+04	1.17E+05	5.53E+04	1.04E+07	1.79E+05	0.00E+00	8.90E+04
^{134}Cs	6.80E+10	1.12E+11	2.35E+10	0.00E+00	3.46E+10	1.24E+10	6.01E+08
^{136}Cs	3.04E+09	8.35E+09	5.40E+09	0.00E+00	4.45E+09	6.63E+08	2.93E+08
^{137}Cs	9.68E+10	9.27E+10	1.37E+10	0.00E+00	3.02E+10	1.09E+10	5.80E+08
^{140}Ba	1.41E+07	1.23E+04	8.21E+05	0.00E+00	4.01E+03	7.35E+03	7.13E+06
^{140}La	2.14E+01	7.47E+00	2.52E+00	0.00E+00	0.00E+00	0.00E+00	2.08E+05
^{141}Ce	2.63E+03	1.31E+03	1.95E+02	0.00E+00	5.75E+02	0.00E+00	1.63E+06
^{144}Ce	1.95E+05	6.11E+04	1.04E+04	0.00E+00	3.38E+04	0.00E+00	1.59E+07
^{143}Pr	8.63E+01	2.59E+01	4.28E+00	0.00E+00	1.40E+01	0.00E+00	9.31E+04
^{144}Pr	6.05E-01	1.87E-01	3.04E-02	0.00E+00	9.89E-02	0.00E+00	4.03E+02
^{147}Nd	5.34E+01	4.33E+01	3.35E+00	0.00E+00	2.37E+01	0.00E+00	6.85E+04
^{154}Eu	1.13E+04	1.02E+03	9.29E+02	0.00E+00	4.47E+03	0.00E+00	2.37E+05
^{181}Hf	7.73E+01	2.81E+02	3.49E+01	0.00E+00	5.72E+01	0.00E+00	1.04E+05

Table 8: Child Grass- Cow- Meat Pathway Dose Factors (R_i)⁷² $(\text{m}^2\text{mrem/yr})$ per $(\mu\text{Ci/sec})$

Nuclide	Bone	Liver	Total Body	Thyroid	Kidney	Lung	GI-LLI
³ H	0.00E+00	2.34E+02	2.34E+02	2.34E+02	2.34E+02	2.34E+02	2.34E+02
⁷ Be	7.38E+03	1.26E+04	8.07E+03	0.00E+00	1.23E+04	0.00E+00	7.00E+05
⁵¹ Cr	0.00E+00	0.00E+00	8.80E+03	4.88E+03	1.33E+03	8.92E+03	4.67E+05
⁵⁴ Mn	0.00E+00	8.02E+06	2.14E+06	0.00E+00	2.25E+06	0.00E+00	6.73E+06
⁵⁵ Fe	4.58E+08	2.43E+08	7.52E+07	0.00E+00	0.00E+00	1.37E+08	4.50E+07
⁵⁹ Fe	3.77E+08	6.10E+08	3.04E+08	0.00E+00	0.00E+00	1.77E+08	6.35E+08
⁵⁷ Co	0.00E+00	5.92E+06	1.20E+07	0.00E+00	0.00E+00	0.00E+00	4.85E+07
⁵⁸ Co	0.00E+00	1.64E+07	5.03E+07	0.00E+00	0.00E+00	0.00E+00	9.59E+07
⁶⁰ Co	0.00E+00	6.94E+07	2.05E+08	0.00E+00	0.00E+00	0.00E+00	3.84E+08
⁶³ Ni	2.92E+10	1.56E+09	9.92E+08	0.00E+00	0.00E+00	0.00E+00	1.05E+08
⁶⁵ Zn	3.76E+08	1.00E+09	6.23E+08	0.00E+00	6.31E+08	0.00E+00	1.76E+08
⁸⁶ Rb	0.00E+00	5.77E+08	3.55E+08	0.00E+00	0.00E+00	0.00E+00	3.71E+07
⁸⁹ Sr	4.82E+08	0.00E+00	1.38E+07	0.00E+00	0.00E+00	0.00E+00	1.87E+07
⁹⁰ Sr	1.04E+10	0.00E+00	2.64E+09	0.00E+00	0.00E+00	0.00E+00	1.40E+08
⁹⁰ Y	1.93E+05	0.00E+00	5.16E+03	0.00E+00	0.00E+00	0.00E+00	5.49E+08
⁹¹ Y	1.80E+06	0.00E+00	4.82E+04	0.00E+00	0.00E+00	0.00E+00	2.40E+08
⁹⁵ Zr	2.67E+06	5.86E+05	5.22E+05	0.00E+00	8.39E+05	0.00E+00	6.11E+08
⁹⁵ Nb	4.26E+06	1.66E+06	1.18E+06	0.00E+00	1.56E+06	0.00E+00	3.07E+09
¹⁰³ Ru	1.55E+08	0.00E+00	5.96E+07	0.00E+00	3.90E+08	0.00E+00	4.01E+09
¹⁰⁶ Ru	4.44E+09	0.00E+00	5.54E+08	0.00E+00	6.00E+09	0.00E+00	6.91E+10
^{110m} Ag	8.40E+06	5.67E+06	4.53E+06	0.00E+00	1.06E+07	0.00E+00	6.75E+08
¹⁰⁹ Cd	0.00E+00	1.91E+06	8.84E+04	0.00E+00	1.70E+06	0.00E+00	6.18E+06
¹¹³ Sn	2.18E+09	4.48E+07	1.24E+08	3.31E+09	0.00E+00	0.00E+00	1.54E+09
¹²⁴ Sb	2.93E+07	3.80E+05	1.03E+07	6.46E+04	0.00E+00	1.62E+07	1.83E+08
¹²⁵ Sb	2.85E+07	2.20E+05	5.97E+06	2.64E+04	0.00E+00	1.59E+07	6.81E+07
^{127m} Te	1.78E+09	4.78E+08	2.11E+08	4.25E+08	5.07E+09	0.00E+00	1.44E+09
^{129m} Te	1.79E+09	5.00E+08	2.78E+08	5.78E+08	5.26E+09	0.00E+00	2.19E+09

⁷² ZZ-250, rev. 1

Table 8: Child Grass- Cow- Meat Pathway Dose Factors (R_i) $(\text{m}^2\text{mrem/yr}) \text{ per } (\mu\text{Ci/sec})$

Nuclide	Bone	Liver	Total Body	Thyroid	Kidney	Lung	GI-LLI
^{130}I	3.06E-06	6.18E-06	3.18E-06	6.80E-04	9.23E-06	0.00E+00	2.89E-06
^{131}I	1.66E+07	1.67E+07	9.47E+06	5.51E+09	2.74E+07	0.00E+00	1.48E+06
^{132}I	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
^{133}I	5.70E-01	7.05E-01	2.67E-01	1.31E+02	1.17E+00	0.00E+00	2.84E-01
^{134}I	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
^{135}I	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
^{134}Cs	9.23E+08	1.51E+09	3.20E+08	0.00E+00	4.69E+08	1.68E+08	8.17E+06
^{136}Cs	1.62E+07	4.46E+07	2.89E+07	0.00E+00	2.38E+07	3.54E+06	1.57E+06
^{137}Cs	1.33E+09	1.28E+09	1.89E+08	0.00E+00	4.16E+08	1.50E+08	8.00E+06
^{140}Ba	4.39E+07	3.85E+04	2.56E+06	0.00E+00	1.25E+04	2.29E+04	2.22E+07
^{140}La	3.33E+02	1.17E+02	3.93E+01	0.00E+00	0.00E+00	0.00E+00	3.25E+06
^{141}Ce	2.22E+04	1.11E+04	1.65E+03	0.00E+00	4.86E+03	0.00E+00	1.38E+07
^{144}Ce	2.32E+06	7.27E+05	1.24E+05	0.00E+00	4.02E+05	0.00E+00	1.89E+08
^{143}Pr	3.34E+04	1.00E+04	1.66E+03	0.00E+00	5.43E+03	0.00E+00	3.61E+07
^{144}Pr	5.63E+02	1.74E+02	2.83E+01	0.00E+00	9.21E+01	0.00E+00	3.75E+05
^{147}Nd	1.17E+04	9.48E+03	7.34E+02	0.00E+00	5.20E+03	0.00E+00	1.50E+07
^{154}Eu	1.12E+07	1.01E+06	9.20E+05	0.00E+00	4.43E+06	0.00E+00	2.34E+08
^{181}Hf	4.77E+06	1.74E+07	2.15E+06	0.00E+00	3.53E+06	0.00E+00	6.41E+09

Table 9: Child Vegetation Pathway Dose Factors (R_i)⁷³(m²mrem/yr) per (μCi/sec)

Nuclide	Bone	Liver	Total Body	Thyroid	Kidney	Lung	GI-LLI
³ H	0.00E+00	4.01E+03	4.01E+03	4.01E+03	4.01E+03	4.01E+03	4.01E+03
⁷ Be	3.38E+05	5.76E+05	3.70E+05	0.00E+00	5.65E+05	0.00E+00	3.21E+07
⁵¹ Cr	0.00E+00	0.00E+00	1.17E+05	6.50E+04	1.78E+04	1.19E+05	6.21E+06
⁵⁴ Mn	0.00E+00	6.65E+08	1.77E+08	0.00E+00	1.86E+08	0.00E+00	5.58E+08
⁵⁵ Fe	8.01E+08	4.25E+08	1.32E+08	0.00E+00	0.00E+00	2.40E+08	7.87E+07
⁵⁹ Fe	3.98E+08	6.43E+08	3.20E+08	0.00E+00	0.00E+00	1.87E+08	6.70E+08
⁵⁷ Co	0.00E+00	2.99E+07	6.04E+07	0.00E+00	0.00E+00	0.00E+00	2.45E+08
⁵⁸ Co	0.00E+00	6.44E+07	1.97E+08	0.00E+00	0.00E+00	0.00E+00	3.76E+08
⁶⁰ Co	0.00E+00	3.78E+08	1.12E+09	0.00E+00	0.00E+00	0.00E+00	2.10E+09
⁶³ Ni	3.95E+10	2.11E+09	1.34E+09	0.00E+00	0.00E+00	0.00E+00	1.42E+08
⁶⁵ Zn	8.13E+08	2.17E+09	1.35E+09	0.00E+00	1.36E+09	0.00E+00	3.80E+08
⁸⁶ Rb	0.00E+00	4.52E+08	2.78E+08	0.00E+00	0.00E+00	0.00E+00	2.91E+07
⁸⁹ Sr	3.60E+10	0.00E+00	1.03E+09	0.00E+00	0.00E+00	0.00E+00	1.39E+09
⁹⁰ Sr	1.24E+12	0.00E+00	3.15E+11	0.00E+00	0.00E+00	0.00E+00	1.67E+10
⁹⁰ Y	3.01E+06	0.00E+00	8.04E+04	0.00E+00	0.00E+00	0.00E+00	8.56E+09
⁹¹ Y	1.86E+07	0.00E+00	4.99E+05	0.00E+00	0.00E+00	0.00E+00	2.48E+09
⁹⁵ Zr	3.86E+06	8.48E+05	7.55E+05	0.00E+00	1.21E+06	0.00E+00	8.85E+08
⁹⁵ Nb	7.48E+05	2.91E+05	2.08E+05	0.00E+00	2.74E+05	0.00E+00	5.39E+08
¹⁰³ Ru	1.53E+07	0.00E+00	5.90E+06	0.00E+00	3.86E+07	0.00E+00	3.97E+08
¹⁰⁶ Ru	7.45E+08	0.00E+00	9.30E+07	0.00E+00	1.01E+09	0.00E+00	1.16E+10
^{110m} Ag	3.21E+07	2.17E+07	1.73E+07	0.00E+00	4.04E+07	0.00E+00	2.58E+09
¹⁰⁹ Cd	0.00E+00	2.45E+08	1.14E+07	0.00E+00	2.18E+08	0.00E+00	7.94E+08
¹¹³ Sn	1.58E+09	3.25E+07	9.00E+07	2.40E+09	0.00E+00	0.00E+00	1.12E+09
¹²⁴ Sb	3.52E+08	4.57E+06	1.23E+08	7.77E+05	0.00E+00	1.95E+08	2.20E+09
¹²⁵ Sb	4.99E+08	3.85E+06	1.05E+08	4.63E+05	0.00E+00	2.78E+08	1.19E+09
^{127m} Te	1.32E+09	3.56E+08	1.57E+08	3.16E+08	3.77E+09	0.00E+00	1.07E+09
^{129m} Te	8.41E+08	2.35E+08	1.31E+08	2.71E+08	2.47E+09	0.00E+00	1.03E+09

⁷³ ZZ-250, rev. 1

Table 9: Child Vegetation Pathway Dose Factors (R_i) $(\text{m}^2\text{mrem/yr})$ per $(\mu\text{Ci/sec})$

Nuclide	Bone	Liver	Total Body	Thyroid	Kidney	Lung	GI-LLI
^{130}I	6.16E+05	1.24E+06	6.41E+05	1.37E+08	1.86E+06	0.00E+00	5.82E+05
^{131}I	1.43E+08	1.44E+08	8.17E+07	4.76E+10	2.36E+08	0.00E+00	1.28E+07
^{132}I	9.23E+01	1.70E+02	7.80E+01	7.87E+03	2.60E+02	0.00E+00	2.00E+02
^{133}I	3.53E+06	4.37E+06	1.65E+06	8.12E+08	7.28E+06	0.00E+00	1.76E+06
^{134}I	1.56E-04	2.89E-04	1.33E-04	6.65E-03	4.42E-04	0.00E+00	1.92E-04
^{135}I	6.26E+04	1.13E+05	5.33E+04	9.98E+06	1.73E+05	0.00E+00	8.59E+04
^{134}Cs	1.60E+10	2.63E+10	5.55E+09	0.00E+00	8.15E+09	2.93E+09	1.42E+08
^{136}Cs	8.24E+07	2.27E+08	1.47E+08	0.00E+00	1.21E+08	1.80E+07	7.96E+06
^{137}Cs	2.39E+10	2.29E+10	3.38E+09	0.00E+00	7.46E+09	2.68E+09	1.43E+08
^{140}Ba	2.77E+08	2.43E+05	1.62E+07	0.00E+00	7.90E+04	1.45E+05	1.40E+08
^{140}La	3.36E+04	1.18E+04	3.96E+03	0.00E+00	0.00E+00	0.00E+00	3.28E+08
^{141}Ce	6.56E+05	3.27E+05	4.86E+04	0.00E+00	1.43E+05	0.00E+00	4.08E+08
^{144}Ce	1.27E+08	3.98E+07	6.78E+06	0.00E+00	2.21E+07	0.00E+00	1.04E+10
^{143}Pr	1.46E+05	4.37E+04	7.23E+03	0.00E+00	2.37E+04	0.00E+00	1.57E+08
^{144}Pr	7.88E+03	2.44E+03	3.97E+02	0.00E+00	1.29E+03	0.00E+00	5.25E+06
^{147}Nd	7.15E+04	5.79E+04	4.48E+03	0.00E+00	3.18E+04	0.00E+00	9.17E+07
^{154}Eu	1.66E+08	1.50E+07	1.37E+07	0.00E+00	6.57E+07	0.00E+00	3.48E+09
^{181}Hf	4.90E+05	1.79E+06	2.21E+05	0.00E+00	3.63E+05	0.00E+00	6.59E+08

Table 10: Highest Annual Average Atmospheric Dispersion Parameters

Location^(b)	Meteorological Sector	Distance (meters)	X/Q Undecayed/undepleted (sec/m³)	X/Q Decayed/Undepleted (sec/m³)	X/Q Decayed/Depleted (sec/m³)	D/Q (m⁻²)
Site Boundary ⁷⁴	SSW	1400	1.8E-6	1.7E-6	1.6E-6	4.5E-9
Nearest Residence ^{75,76}	NNW	2900	1.1E-6	1.0E-6	9.0E-7	3.0E-9
Farming Areas within the Site Boundary ^{77,78}	N/A	N/A	1.6E-6	1.6E-6	1.4E-6	5.3E-9

⁷⁴ Dispersion parameters from HPCI 1503⁷⁵ Dispersion parameters from HPCI 1504⁷⁶ All ingestion dose pathways are assumed to exist at the location of the nearest resident⁷⁷ Dispersion parameters from HPCI 1502⁷⁸ These values were derived for a narrow scope application. Extreme caution should be exercised when determining their suitability for use in other applications

Table 11: Application of Atmospheric Dispersion Parameters for Release Permits

Dose Pathway	Dispersion Parameter	Controlling Age Group	REC	Controlling Location
Noble Gas, Beta Air & Gamma Air	X/Q, decayed/undepleted (2.26 day half-life)	N/A	16.11.2.2	Site Boundary
Noble Gas, Total Body & Skin	X/Q, decayed/undepleted (2.26 day half-life)	N/A	16.11.2.1	Site Boundary
Inhalation	X/Q, decayed/depleted (8 day half-life)	Child	16.11.2.1 16.11.2.3	Nearest Resident Site Boundary
Ground Plane Deposition	D/Q	N/A	16.11.2.3	Nearest Resident
Ingestion pathways	D/Q*	Child	16.11.2.3	Nearest Resident

*For ^3H , X/Q decayed/depleted is used instead of D/Q.⁷⁹

⁷⁹ Regulatory Guide 1.109, Appendix C, Section 3.a

Table 12: Application of Atmospheric Dispersion Parameters Annual Radioactive Effluent Release Report				
Dose Pathway	Dispersion Parameter	Controlling Age Group	Dispersion Values⁸⁰	Controlling Location
Noble Gas, Beta Air & Gamma Air Dose	X/Q, decayed/undepleted (2.26 day half-life)	N/A	Concurrent	Site Boundary Nearest Resident
Noble Gas, Total Body & Skin Dose	X/Q, decayed/undepleted (2.26 day half-life)	N/A	Concurrent	Site Boundary Nearest Resident
			Historical	Inside Site Boundary
Ground Plane Deposition Dose	D/Q	N/A	Concurrent	Site Boundary Nearest Resident
			Historical	Inside Site Boundary
Inhalation Dose	X/Q, decayed/depleted (8 day half-life)	Child	Concurrent	Site Boundary Nearest Resident
		Adult	Concurrent	Nearest Residence
			Historical	Inside Site Boundary
Ingestion Dose Pathways	D/Q (For H ³ , X/Q, decayed/depleted is used instead of D/Q.) ⁸¹	Child	Concurrent	Site Boundary Nearest Resident
¹⁴ C All Dose Pathways ⁸²	X/Q, undecayed/undepleted	Child	Historical	Nearest Resident
		Adult	Historical	Inside Site Boundary

⁸⁰ Historical, i.e., 10 year average, dispersion parameters for activities inside the Site Boundary are provided in Table 10.

⁸¹ Regulatory Guide 1.109, Appendix C, Section 3.a

⁸² See Appendix A

Table 13: Meteorological Data Selection Hierarchy				
Parameter	Primary	First Alternate	Second Alternate	Third Alternate
Wind Speed	10m A	10m B	60m A	60m B
Wind Direction	10m A	10m B	60m A	60m B
Air Temperature	10m A	10m B		
Wind Variability	10m A	10m B	60m A	60m B
Temp Difference	60-10m A	60-10m B		
Dew point/Relative Humidity	10m A	60m B		
Precipitation	1m			

(a) 'A' indicates Alpha train meteorological instrumentation.

(b) 'B' indicates Bravo train meteorological instrumentation.

Table 14: Adult Inhalation Pathway Dose Factors (R_i)⁸³ (mrem/yr) per ($\mu\text{Ci}/\text{m}^3$)							
Nuclide	Bone	Liver	Total Body	Thyroid	Kidney	Lung	GI-LLI
³ H	ND	1.26E+03	1.26E+03	1.26E+03	1.26E+03	1.26E+03	1.26E+03
⁷ Be	4.27E+02	9.68E+02	4.70E+02	ND	ND	4.21E+04	5.35E+03
⁵¹ Cr	ND	ND	1.00E+02	5.95E+01	2.28E+01	1.44E+04	3.32E+03
⁵⁴ Mn	ND	3.96E+04	6.30E+03	ND	9.84E+03	1.40E+06	7.74E+04
⁵⁵ Fe	2.46E+04	1.70E+04	3.94E+03	ND	ND	7.21E+04	6.03E+03
⁵⁹ Fe	1.18E+04	2.78E+04	1.06E+04	ND	ND	1.02E+06	1.88E+05
⁵⁷ Co	ND	6.92E+02	6.71E+02	ND	ND	3.70E+05	3.14E+04
⁵⁸ Co	ND	1.58E+03	2.07E+03	ND	ND	9.28E+05	1.06E+05
⁶⁰ Co	ND	1.15E+04	1.48E+04	ND	ND	5.97E+06	2.85E+05
⁶³ Ni	4.32E+05	3.14E+04	1.45E+04	ND	ND	1.78E+05	1.34E+04
⁶⁵ Zn	3.24E+04	1.03E+05	4.66E+04	ND	6.90E+04	8.64E+05	5.34E+04
⁸⁶ Rb	ND	1.35E+05	5.90E+04	ND	ND	ND	1.66E+04
⁸⁹ Sr	3.04E+05	ND	8.72E+03	ND	ND	1.40E+06	3.50E+05
⁹⁰ Sr	9.92E+07	ND	6.10E+06	ND	ND	9.60E+06	7.22E+05
⁹⁰ Y	2.09E+03	ND	5.61E+01	ND	ND	1.70E+05	5.06E+05
⁹¹ Y	4.62E+05	ND	1.24E+04	ND	ND	1.70E+06	3.85E+05
⁹⁵ Zr	1.07E+05	3.44E+04	2.33E+04	ND	5.42E+04	1.77E+06	1.50E+05
⁹⁵ Nb	1.41E+04	7.82E+03	4.21E+03	ND	7.74E+03	5.05E+05	1.04E+05
¹⁰³ Ru	1.53E+03	ND	6.58E+02	ND	5.83E+03	5.05E+05	1.10E+05
¹⁰⁶ Ru	6.91E+04	ND	8.72E+03	ND	1.34E+05	9.36E+06	9.12E+05
^{110m} Ag	1.08E+04	1.00E+04	5.94E+03	ND	1.97E+04	4.63E+06	3.02E+05
¹⁰⁹ Cd	ND	3.67E+05	1.31E+04	ND	3.57E+05	6.83E+05	5.82E+04
¹¹³ Sn	5.72E+04	2.18E+03	4.39E+03	1.24E+03	ND	9.44E+05	1.18E+05
¹²⁴ Sb	3.12E+04	5.89E+02	1.24E+04	7.55E+01	ND	2.48E+06	4.06E+05
¹²⁵ Sb	5.34E+04	5.95E+02	1.26E+04	5.40E+01	ND	1.74E+06	1.01E+05
^{127m} Te	1.26E+04	5.77E+03	1.57E+03	3.29E+03	4.58E+04	9.60E+05	1.50E+05
^{129m} Te	9.76E+03	4.67E+03	1.58E+03	3.44E+03	3.66E+04	1.16E+06	3.83E+05

⁸³ ZZ-78, rev. 2

Table 14: Adult Inhalation Pathway Dose Factors (R_i) (mrem/yr) per ($\mu\text{Ci}/\text{m}^3$)							
Nuclide	Bone	Liver	Total Body	Thyroid	Kidney	Lung	GI-LLI
^{130}I	4.58E+03	1.34E+04	5.28E+03	1.14E+06	2.09E+04	ND	7.69E+03
^{131}I	2.52E+04	3.58E+04	2.05E+04	1.19E+07	6.13E+04	ND	6.28E+03
^{132}I	1.16E+03	3.26E+03	1.16E+03	1.14E+05	5.18E+03	ND	4.06E+02
^{133}I	8.64E+03	1.48E+04	4.52E+03	2.15E+06	2.58E+04	ND	8.88E+03
^{134}I	6.44E+02	1.73E+03	6.15E+02	2.98E+04	2.75E+03	ND	1.01E+00
^{135}I	2.68E+03	6.98E+03	2.57E+03	4.48E+05	1.11E+04	ND	5.25E+03
^{134}Cs	3.73E+05	8.48E+05	7.28E+05	ND	2.87E+05	9.76E+04	1.04E+04
^{136}Cs	3.90E+04	1.46E+05	1.10E+05	ND	8.56E+04	1.20E+04	1.17E+04
^{137}Cs	4.78E+05	6.21E+05	4.28E+05	ND	2.22E+05	7.52E+04	8.40E+03
^{140}Ba	3.90E+04	4.90E+01	2.57E+03	ND	1.67E+01	1.27E+06	2.18E+05
^{140}La	3.44E+02	1.74E+02	4.58E+01	ND	ND	1.36E+05	4.58E+05
^{141}Ce	1.99E+04	1.35E+04	1.53E+03	ND	6.26E+03	3.62E+05	1.20E+05
^{144}Ce	3.43E+06	1.43E+06	1.84E+05	ND	8.48E+05	7.78E+06	8.16E+05
^{143}Pr	9.36E+03	3.75E+03	4.64E+02	ND	2.16E+03	2.81E+05	2.00E+05
^{144}Pr	3.01E-02	1.25E-02	1.53E-03	ND	7.05E-03	1.02E+03	2.15E-08
^{147}Nd	5.27E+03	6.10E+03	3.65E+02	ND	3.56E+03	2.21E+05	1.73E+05
^{154}Eu	5.92E+06	7.28E+05	5.18E+05	ND	3.49E+06	4.67E+06	2.72E+05
^{181}Hf	1.41E+04	6.82E+04	6.32E+03	ND	1.48E+04	6.85E+05	1.39E+05

Table 15: Adult Grass- Cow – Milk Pathway Dose Factors (R_i)⁸⁴ (m ² mrem/yr) per (μCi/sec)							
Nuclide	Bone	Liver	Total Body	Thyroid	Kidney	Lung	GI-LLI
³ H	ND	7.63E+02	7.63E+02	7.63E+02	7.63E+02	7.63E+02	7.63E+02
⁷ Be	1.63E+03	3.72E+03	1.81E+03	ND	3.93E+03	ND	6.45E+05
⁵¹ Cr	ND	ND	2.86E+04	1.71E+04	6.30E+03	3.79E+04	7.19E+06
⁵⁴ Mn	ND	8.42E+06	1.61E+06	ND	2.50E+06	ND	2.58E+07
⁵⁵ Fe	2.51E+07	1.74E+07	4.05E+06	ND	ND	9.68E+06	9.96E+06
⁵⁹ Fe	2.97E+07	6.98E+07	2.68E+07	ND	ND	1.95E+07	2.33E+08
⁵⁷ Co	ND	1.28E+06	2.13E+06	ND	ND	ND	3.25E+07
⁵⁸ Co	ND	4.72E+06	1.06E+07	ND	ND	ND	9.56E+07
⁶⁰ Co	ND	1.64E+07	3.62E+07	ND	ND	ND	3.08E+08
⁶³ Ni	6.73E+09	4.67E+08	2.26E+08	ND	ND	ND	9.73E+07
⁶⁵ Zn	1.37E+09	4.37E+09	1.97E+09	ND	2.92E+09	ND	2.75E+09
⁸⁶ Rb	ND	2.60E+09	1.21E+09	ND	ND	ND	5.12E+08
⁸⁹ Sr	1.45E+09	ND	4.17E+07	ND	ND	ND	2.33E+08
⁹⁰ Sr	4.68E+10	ND	1.15E+10	ND	ND	ND	1.35E+09
⁹⁰ Y	7.43E+02	ND	1.99E+01	ND	ND	ND	7.87E+06
⁹¹ Y	8.59E+03	ND	2.30E+02	ND	ND	ND	4.73E+06
⁹⁵ Zr	9.44E+02	3.03E+02	2.05E+02	ND	4.75E+02	ND	9.59E+05
⁹⁵ Nb	9.65E+04	5.37E+04	2.89E+04	ND	5.31E+04	ND	3.26E+08
¹⁰³ Ru	1.02E+03	ND	4.39E+02	ND	3.89E+03	ND	1.19E+05
¹⁰⁶ Ru	2.04E+04	ND	2.58E+03	ND	3.94E+04	ND	1.32E+06
^{110m} Ag	5.82E+07	5.39E+07	3.20E+07	ND	1.06E+08	ND	2.20E+10
¹⁰⁹ Cd	ND	1.13E+06	3.95E+04	ND	1.08E+06	ND	1.14E+07
¹¹³ Sn	1.34E+08	3.81E+06	7.73E+06	2.18E+06	ND	ND	4.02E+08
¹²⁴ Sb	2.57E+07	4.86E+05	1.02E+07	6.24E+04	ND	2.00E+07	7.31E+08
¹²⁵ Sb	2.04E+07	2.28E+05	4.87E+06	2.08E+04	ND	1.58E+07	2.25E+08
^{127m} Te	4.58E+07	1.64E+07	5.58E+06	1.17E+07	1.86E+08	ND	1.54E+08
^{129m} Te	6.02E+07	2.25E+07	9.53E+06	2.07E+07	2.51E+08	ND	3.03E+08

⁸⁴ ZZ-78, rev. 2

Table 15: Adult Grass- Cow – Milk Pathway Dose Factors (R _i)							
(m ² mrem/yr) per (μCi/sec)							
Nuclide	Bone	Liver	Total Body	Thyroid	Kidney	Lung	GI-LLI
¹³⁰ I	4.21E+05	1.24E+06	4.91E+05	1.05E+08	1.94E+06	ND	1.07E+06
¹³¹ I	2.97E+08	4.25E+08	2.43E+08	1.39E+ 11	7.28E+08	ND	1.12E+08
¹³² I	1.65E-01	4.42E-01	1.55E-01	1.55E+01	7.04E-01	ND	8.30E-02
¹³³ I	3.88E+06	6.75E+06	2.06E+06	9.92E+08	1.18E+07	ND	6.07E+06
¹³⁴ I	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	ND	0.00E+00
¹³⁵ I	1.29E+04	3.37E+04	1.25E+04	2.23E+06	5.41E+04	ND	3.81E+04
¹³⁴ Cs	5.65E+09	1.35E+10	1.10E+10	ND	4.35E+09	1.45E+09	2.35E+08
¹³⁶ Cs	2.63E+08	1.04E+09	7.48E+08	ND	5.79E+08	7.93E+07	1.18E+08
¹³⁷ Cs	7.38E+09	1.01E+ 10	6.61E+09	ND	3.43E+09	1.14E+09	1.95E+08
¹⁴⁰ Ba	2.69E+07	3.38E+04	1.76E+06	ND	1.15E+04	1.93E+04	5.54E+07
¹⁴⁰ La	4.14E+0 1	2.09E+01	5.51E+00	ND	ND	ND	1.53E+06
¹⁴¹ Ce	4.85E+03	3.28E+03	3.72E+02	ND	1.52E+03	ND	1.25E+07
¹⁴⁴ Ce	3.58E+05	1.50E+05	1.92E+04	ND	8.87E+04	ND	1.21E+08
¹⁴³ Pr	1.58E+02	6.34E+01	7.83E+00	ND	3.66E+01	ND	6.92E+05
¹⁴⁴ Pr	1.10E+00	4.58E-01	5.61E-02	ND	2.58E-01	ND	1.59E-07
¹⁴⁷ Nd	9.42E+0 1	1.09E+02	6.51E+00	ND	6.36E+01	ND	5.23E+05
¹⁵⁴ Eu	2.37E+04	2.91E+03	2.07E+03	ND	1.39E+04	ND	2.11E+06
¹⁸¹ Hf	1.42E+02	6.92E+02	6.41E+ 1	ND	1.49E+02	ND	7.87E+05

Table 16: Adult Grass- Goat – Milk Pathway Dose Factors (R_i)⁸⁵ ($\text{m}^2\text{mrem/yr}$) per ($\mu\text{Ci/sec}$)							
Nuclide	Bone	Liver	Total Body	Thyroid	Kidney	Lung	GI-LLI
³ H	ND	1.56E+03	1.56E+03	1.56E+03	1.56E+03	1.56E+03	1.56E+03
⁷ Be	1.96E+02	4.47E+02	2.17E+02	ND	4.72E+02	ND	7.74E+04
⁵¹ Cr	ND	ND	3.43E+03	2.05E+03	7.56E+02	4.56E+03	8.63E+05
⁵⁴ Mn	ND	1.01E+06	1.93E+05	ND	3.01E+05	ND	3.10E+06
⁵⁵ Fe	3.27E+05	2.26E+05	5.26E+04	ND	ND	1.26E+05	1.30E+05
⁵⁹ Fe	3.87E+05	9.08E+05	3.48E+05	ND	ND	2.54E+05	3.03E+06
⁵⁷ Co	ND	1.54E+05	2.56E+05	ND	ND	ND	3.90E+06
⁵⁸ Co	ND	5.66E+05	1.27E+06	ND	ND	ND	1.15E+07
⁶⁰ Co	ND	1.97E+06	4.35E+06	ND	ND	ND	3.70E+07
⁶³ Ni	8.08E+08	5.60E+07	2.71E+07	ND	ND	ND	1.17E+07
⁶⁵ Zn	1.65E+08	5.24E+08	2.37E+08	ND	3.51E+08	ND	3.30E+08
⁸⁶ Rb	ND	3.12E+08	1.45E+08	ND	ND	ND	6.15E+07
⁸⁹ Sr	3.05E+09	ND	8.75E+07	ND	ND	ND	4.89E+08
⁹⁰ Sr	9.84E+10	ND	2.41E+10	ND	ND	ND	2.84E+09
⁹⁰ Y	8.92E+01	ND	2.39E+00	ND	ND	ND	9.46E+05
⁹¹ Y	1.03E+03	ND	2.76E+01	ND	ND	ND	5.68E+05
⁹⁵ Zr	1.13E+02	3.63E+01	2.46E+01	ND	5.70E+01	ND	1.15E+05
⁹⁵ Nb	1.16E+04	6.45E+03	3.47E+03	ND	6.37E+03	ND	3.91E+07
¹⁰³ Ru	1.22E+02	ND	5.27E+01	ND	4.67E+02	ND	1.43E+04
¹⁰⁶ Ru	2.45E+03	ND	3.10E+02	ND	4.73E+03	ND	1.59E+05
^{110m} Ag	6.99E+06	6.47E+06	3.84E+06	ND	1.27E+07	ND	2.64E+09
¹⁰⁹ Cd	ND	1.36E+05	4.74E+03	ND	1.30E+05	ND	1.37E+06
¹¹³ Sn	1.61E+07	4.58E+05	9.28E+05	2.62E+05	ND	ND	4.83E+07
¹²⁴ Sb	3.09E+06	5.84E+04	1.23E+06	7.50E+03	ND	2.41E+06	8.78E+07
¹²⁵ Sb	2.46E+06	2.74E+04	5.84E+05	2.50E+03	ND	1.89E+06	2.70E+07
^{127m} Te	5.50E+06	1.97E+06	6.70E+05	1.41E+06	2.23E+07	ND	1.84E+07
^{129m} Te	7.23E+06	2.70E+06	1.14E+06	2.48E+06	3.02E+07	ND	3.64E+07

⁸⁵ ZZ-78, rev. 2

Table 16: Adult Grass- Goat – Milk Pathway Dose Factors (R_i) (m ² mrem/yr) per (μCi/sec)							
Nuclide	Bone	Liver	Total Body	Thyroid	Kidney	Lung	GI-LLI
¹³⁰ I	5.05E+05	1.49E+06	5.88E+05	1.26E+08	2.32E+06	ND	1.28E+06
¹³¹ I	3.56E+08	5.09E+08	2.92E+08	1.67E+11	8.72E+08	ND	1.34E+08
¹³² I	1.98E-01	5.29E-01	1.85E-01	1.85E+01	8.43E-01	ND	9.95E-02
¹³³ I	4.65E+06	8.09E+06	2.47E+06	1.19E+09	1.41E+07	ND	7.27E+06
¹³⁴ I	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	ND	0.00E+00
¹³⁵ I	1.54E+04	4.04E+04	1.49E+04	2.67E+06	6.48E+04	ND	4.57E+04
¹³⁴ Cs	1.70E+10	4.04E+10	3.30E+10	ND	1.31E+10	4.34E+09	7.07E+08
¹³⁶ Cs	7.91E+08	3.12E+09	2.25E+09	ND	1.74E+09	2.38E+08	3.55E+08
¹³⁷ Cs	2.22E+10	3.03E+10	1.99E+10	ND	1.03E+10	3.42E+09	5.87E+08
¹⁴⁰ Ba	3.23E+06	4.06E+03	2.12E+05	ND	1.38E+03	2.32E+03	6.65E+06
¹⁴⁰ La	4.97E+00	2.51E+00	6.62E-01	ND	ND	ND	1.84E+05
¹⁴¹ Ce	5.82E+02	3.94E+02	4.46E+01	ND	1.83E+02	ND	1.50E+06
¹⁴⁴ Ce	4.30E+04	1.80E+04	2.31E+03	ND	1.07E+04	ND	1.45E+07
¹⁴³ Pr	1.90E+01	7.61E+00	9.40E-01	ND	4.39E+00	ND	8.31E+04
¹⁴⁴ Pr	1.33E-01	5.50E-02	6.74E-03	ND	3.10E-02	ND	1.91E-08
¹⁴⁷ Nd	1.13E+01	1.31E+01	7.82E-01	ND	7.64E+00	ND	6.28E+04
¹⁵⁴ Eu	2.84E+03	3.49E+02	2.49E+02	ND	1.67E+03	ND	2.53E+05
¹⁸¹ Hf	1.71E+01	8.31E+01	7.70E+00	ND	1.79E+01	ND	9.46E+04

Table 17: Adult Grass- Cow- Meat Pathway Dose Factors (R_i)⁸⁶ (m^2mrem/yr) per ($\mu Ci/sec$)							
Nuclide	Bone	Liver	Total Body	Thyroid	Kidney	Lung	GI-LLI
³ H	ND	3.25E+02	3.25E+02	3.25E+02	3.25E+02	3.25E+02	3.25E+02
⁷ Be	4.57E+03	1.04E+04	5.07E+03	ND	1.10E+04	ND	1.81E+06
⁵¹ Cr	ND	ND	7.04E+03	4.21E+03	1.55E+03	9.34E+03	1.77E+06
⁵⁴ Mn	ND	9.17E+06	1.75E+06	ND	2.73E+06	ND	2.81E+07
⁵⁵ Fe	2.93E+08	2.02E+08	4.72E+07	ND	ND	1.13E+08	1.16E+08
⁵⁹ Fe	2.65E+08	6.24E+08	2.39E+08	ND	ND	1.74E+08	2.08E+09
⁵⁷ Co	ND	5.63E+06	9.36E+06	ND	ND	ND	1.43E+08
⁵⁸ Co	ND	1.82E+07	4.08E+07	ND	ND	ND	3.69E+08
⁶⁰ Co	ND	7.51E+07	1.66E+08	ND	ND	ND	1.41E+09
⁶³ Ni	1.89E+10	1.31E+09	6.33E+08	ND	ND	ND	2.73E+08
⁶⁵ Zn	3.56E+08	1.13E+09	5.11E+08	ND	7.57E+08	ND	7.13E+08
⁸⁶ Rb	ND	4.87E+08	2.27E+08	ND	ND	ND	9.60E+07
⁸⁹ Sr	3.01E+08	ND	8.65E+06	ND	ND	ND	4.83E+07
⁹⁰ Sr	1.24E+10	ND	3.05E+09	ND	ND	ND	3.59E+08
⁹⁰ Y	1.21E+05	ND	3.24E+03	ND	ND	ND	1.28E+09
⁹¹ Y	1.13E+06	ND	3.02E+04	ND	ND	ND	6.23E+08
⁹⁵ Zr	1.87E+06	6.00E+05	4.06E+05	ND	9.42E+05	ND	1.90E+09
⁹⁵ Nb	3.15E+06	1.75E+06	9.43E+05	ND	1.73E+06	ND	1.06E+10
¹⁰³ Ru	1.05E+08	ND	4.53E+07	ND	4.01E+08	ND	1.23E+10
¹⁰⁶ Ru	2.80E+09	ND	3.54E+08	ND	5.40E+09	ND	1.81E+11
^{110m} Ag	6.68E+06	6.18E+06	3.67E+06	ND	1.21E+07	ND	2.52E+09
¹⁰⁹ Cd	ND	1.59E+06	5.55E+04	ND	1.52E+06	ND	1.60E+07
¹¹³ Sn	1.37E+09	3.88E+07	7.86E+07	2.22E+07	ND	ND	4.09E+09
¹²⁴ Sb	1.98E+07	3.74E+05	7.84E+06	4.79E+04	ND	1.54E+07	5.61E+08
¹²⁵ Sb	1.91E+07	2.13E+05	4.54E+06	1.94E+04	ND	1.47E+07	2.10E+08
^{127m} Te	1.11E+09	3.98E+08	1.36E+08	2.85E+08	4.53E+09	ND	3.74E+09
^{129m} Te	1.13E+09	4.23E+08	1.79E+08	3.89E+08	4.73E+09	ND	5.71E+09

⁸⁶ ZZ-78, rev. 2

Table 17: Adult Grass- Cow- Meat Pathway Dose Factors (R _i)							
(m ² mrem/yr) per (μCi/sec)							
Nuclide	Bone	Liver	Total Body	Thyroid	Kidney	Lung	GI-LLI
¹³⁰ I	2.12E-06	6.27E-06	2.47E-06	5.31E-04	9.78E-06	ND	5.40E-06
¹³¹ I	1.08E+07	1.54E+07	8.82E+06	5.04E+09	2.64E+07	ND	4.06E+06
¹³² I	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	ND	0.00E+00
¹³³ I	3.67E-01	6.39E-01	1.95E-01	9.38E+01	1.11E+00	ND	5.74E-01
¹³⁴ I	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	ND	0.00E+00
¹³⁵ I	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	ND	0.00E+00
¹³⁴ Cs	6.57E+08	1.56E+09	1.28E+09	ND	5.06E+08	1.68E+08	2.74E+07
¹³⁶ Cs	1.20E+07	4.76E+07	3.42E+07	ND	2.65E+07	3.63E+06	5.40E+06
¹³⁷ Cs	8.71E+08	1.19E+09	7.81E+08	ND	4.04E+08	1.34E+08	2.31E+07
¹⁴⁰ Ba	2.87E+07	3.61E+04	1.88E+06	ND	1.23E+04	2.07E+04	5.91E+07
¹⁴⁰ La	2.21E+02	1.11E+02	2.94E+01	ND	ND	ND	8.18E+06
¹⁴¹ Ce	1.40E+04	9.49E+03	1.08E+03	ND	4.41E+03	ND	3.63E+07
¹⁴⁴ Ce	1.46E+06	6.09E+05	7.82E+04	ND	3.61E+05	ND	4.92E+08
¹⁴³ Pr	2.10E+04	8.40E+03	1.04E+03	ND	4.85E+03	ND	9.18E+07
¹⁴⁴ Pr	3.52E+02	1.46E+02	1.79E+01	ND	8.24E+01	ND	5.06E-05
¹⁴⁷ Nd	7.07E+03	8.17E+03	4.89E+02	ND	4.77E+03	ND	3.92E+07
¹⁵⁴ Eu	8.02E+06	9.86E+05	7.01E+05	ND	4.72E+06	ND	7.14E+08
¹⁸¹ Hf	3.01E+06	1.46E+07	1.35E+06	ND	3.14E+06	ND	1.66E+10

Table 18: Adult Vegetation Pathway Dose Factors (R_i)⁸⁷ ($\text{m}^2\text{mrem/yr}$) per ($\mu\text{Ci/sec}$)							
Nuclide	Bone	Liver	Total Body	Thyroid	Kidney	Lung	GI-LLI
³ H	ND	2.26E+03	2.26E+03	2.26E+03	2.26E+03	2.26E+03	2.26E+03
⁷ Be	9.24E+04	2.11E+05	1.03E+05	ND	2.23E+05	ND	3.66E+07
⁵¹ Cr	ND	ND	4.64E+04	2.78E+04	1.02E+04	6.16E+04	1.17E+07
⁵⁴ Mn	ND	3.13E+08	5.97E+07	ND	9.31E+07	ND	9.59E+08
⁵⁵ Fe	2.10E+08	1.45E+08	3.38E+07	ND	ND	8.08E+07	8.31E+07
⁵⁹ Fe	1.26E+08	2.96E+08	1.14E+08	ND	ND	8.28E+07	9.88E+08
⁵⁷ Co	ND	1.17E+07	1.95E+07	ND	ND	ND	2.97E+08
⁵⁸ Co	ND	3.07E+07	6.89E+07	ND	ND	ND	6.23E+08
⁶⁰ Co	ND	1.67E+08	3.69E+08	ND	ND	ND	3.14E+09
⁶³ Ni	1.04E+10	7.21E+08	3.49E+08	ND	ND	ND	1.50E+08
⁶⁵ Zn	3.17E+08	1.01E+09	4.56E+08	ND	6.75E+08	ND	6.36E+08
⁸⁶ Rb	ND	2.19E+08	1.02E+08	ND	ND	ND	4.33E+07
⁸⁹ Sr	9.97E+09	ND	2.86E+08	ND	ND	ND	1.60E+09
⁹⁰ Sr	6.05E+11	ND	1.48E+11	ND	ND	ND	1.75E+10
⁹⁰ Y	7.67E+05	ND	2.06E+04	ND	ND	ND	8.14E+09
⁹¹ Y	5.11E+06	ND	1.37E+05	ND	ND	ND	2.81E+09
⁹⁵ Zr	1.17E+06	3.77E+05	2.55E+05	ND	5.91E+05	ND	1.19E+09
⁹⁵ Nb	2.40E+05	1.34E+05	7.19E+04	ND	1.32E+05	ND	8.11E+08
¹⁰³ Ru	4.77E+06	ND	2.06E+06	ND	1.82E+07	ND	5.57E+08
¹⁰⁶ Ru	1.93E+08	ND	2.44E+07	ND	3.72E+08	ND	1.25E+10
^{110m} Ag	1.05E+07	9.75E+06	5.79E+06	ND	1.92E+07	ND	3.98E+09
¹⁰⁹ Cd	0.00E+00	8.36E+07	2.92E+06	ND	8.00E+07	ND	8.43E+08
¹¹³ Sn	4.16E+08	1.18E+07	2.40E+07	6.75E+06	ND	ND	1.25E+09
¹²⁴ Sb	1.04E+08	1.96E+06	4.11E+07	2.51E+05	ND	8.07E+07	2.94E+09
¹²⁵ Sb	1.37E+08	1.53E+06	3.25E+07	1.39E+05	ND	1.05E+08	1.50E+09
^{127m} Te	3.49E+08	1.25E+08	4.26E+07	8.92E+07	1.42E+09	ND	1.17E+09
^{129m} Te	2.51E+08	9.38E+07	3.98E+07	8.64E+07	1.05E+09	ND	1.27E+09

⁸⁷ ZZ-78, rev. 2

Table 18: Adult Vegetation Pathway Dose Factors (R_i) ($\text{m}^2\text{mrem/yr}$) per ($\mu\text{Ci/sec}$)							
Nuclide	Bone	Liver	Total Body	Thyroid	Kidney	Lung	GI-LLI
^{130}I	3.93E+05	1.16E+06	4.57E+05	9.81E+07	1.81E+06	ND	9.97E+05
^{131}I	8.08E+07	1.16E+08	6.62E+07	3.79E+10	1.98E+08	ND	3.05E+07
^{132}I	5.77E+01	1.54E+02	5.40E+01	5.40E+03	2.46E+02	ND	2.90E+01
^{133}I	2.09E+06	3.63E+06	1.11E+06	5.33E+08	6.33E+06	ND	3.26E+06
^{134}I	9.69E-05	2.63E-04	9.42E-05	4.56E-03	4.19E-04	ND	2.30E-07
^{135}I	3.90E+04	1.02E+05	3.77E+04	6.74E+06	1.64E+05	ND	1.15E+05
^{134}Cs	4.67E+09	1.11E+10	9.08E+09	ND	3.59E+09	1.19E+09	1.94E+08
^{136}Cs	4.27E+07	1.69E+08	1.21E+08	ND	9.38E+07	1.29E+07	1.91E+07
^{137}Cs	6.36E+09	8.70E+09	5.70E+09	ND	2.95E+09	9.81E+08	1.68E+08
^{140}Ba	1.29E+08	1.61E+05	8.42E+06	ND	5.49E+04	9.24E+04	2.65E+08
^{140}La	1.58E+04	7.98E+03	2.11E+03	ND	ND	ND	5.86E+08
^{141}Ce	1.97E+05	1.33E+05	1.51E+04	ND	6.19E+04	ND	5.10E+08
^{144}Ce	3.29E+07	1.38E+07	1.77E+06	ND	8.16E+06	ND	1.11E+10
^{143}Pr	6.26E+04	2.51E+04	3.10E+03	ND	1.45E+04	ND	2.74E+08
^{144}Pr	2.03E+03	8.43E+02	1.03E+02	ND	4.75E+02	ND	2.92E-04
^{147}Nd	3.33E+04	3.85E+04	2.31E+03	ND	2.25E+04	ND	1.85E+08
^{154}Eu	4.85E+07	5.97E+06	4.25E+06	ND	2.86E+07	ND	4.32E+09
^{181}Hf	1.40E+05	6.82E+05	6.32E+04	ND	1.47E+05	ND	7.76E+08

Appendix A: Methodology for Calculating Dose from ^{14}C in Gaseous Effluents

1) Introduction

The purpose of this Appendix is to provide methodology and parameters for calculating (1) the quantity of ^{14}C released in gaseous effluents, (2) the dose to the Member of the Public at the nearest receptor location due to ^{14}C released in gaseous effluents, and (3) the dose from ^{14}C released in gaseous effluents to the Member of the Public due to activities within the Site Boundary.

The quantity of ^{14}C discharged can be estimated⁸⁸ by sample measurements, or by use of a normalized ^{14}C source term and scaling factors based on power generation,⁸⁹ or by use of the GALE code,⁹⁰ or by use of the EPRI site specific or proxy methodologies.⁹¹ *Any of these methodologies is acceptable for estimating the ^{14}C discharged in gaseous effluents.*

2) Assumptions

- a. The total quantity of ^{14}C produced during the year is assumed to be released during the year in which it was produced.
- b. The quantity of ^{14}C produced is determined using the methodology in EPRI TR-1021106.
- c. For conservatism, it is assumed that all ^{14}C produced is released in gaseous effluents.
- d. The dose contribution of ^{14}C from liquid effluents is much less than that contributed by gaseous effluents, therefore evaluation of ^{14}C in liquid effluents is not required.⁹²
- e. The dose to the Member of the Public is determined in accordance with the methodology and parameters in Regulatory Guide 1.109.
- f. ^{14}C has a long half- life with respect to the plume transit time. ^{14}C is discharged as CH_4 or CO_2 gas and does not deplete or undergo chemical change before it reaches the receptor location. Therefore the appropriate dispersion parameter is X/Q (undecayed and undepleted).

⁸⁸ Regulatory Guide 1.21, rev. 2, Section 1.9

⁸⁹ NCRP Report 81

⁹⁰ NUREG- 0017

⁹¹ EPRI TR-1021106, Section 4.

⁹² Regulatory Guide 1.21, rev. 2, Section 1.9

- g. The inhalation pathway is assumed to exist at the Nearest Residence location with the highest value of X/Q, undecayed/ undepleted as determined by the annual Land Use Census.
- h. The ingestion pathways are assumed to exist at the nearest receptor location with the highest value of X/Q, undecayed/ undepleted as determined by the annual Land Use Census. For conservatism, the Nearest Residence location may be considered the highest nearest receptor location for the ingestion pathways.
- i. The appropriate dispersion parameters for activities within the Site Boundary is provided in Table 10.
- j. ^{14}C is not a gamma- emitting nuclide; therefore the ground plane pathway is negligible.
- k. As a first approximation, it is assumed that the child age group exists at the Nearest Residence and ingestion pathway locations.
- l. Only $^{14}\text{CO}_2$ discharged during periods of photosynthesis is considered for the ingestion pathways.
- m. All of the ^{14}C produced is assumed to contribute to the inhalation dose pathway, regardless of chemical form.

3) Applicable Dose Limits

10 CFR 50, Appendix I, states, "The calculated annual total quantity of all radioactive iodine and radioactive material in particulate form above background to be released from each light-water-cooled nuclear power reactor in effluents to the atmosphere will not result in an estimated annual dose or dose commitment from such *radioactive iodine and radioactive material in particulate form* for any individual in an unrestricted area from all pathways of exposure in excess of 15 millirems to any organ."⁹³ Radiological Effluent Control (REC) 16.11.2.3 limits the annual dose to the Member of the Public from ^{131}I , ^{133}I , ^3H , and *particulates* with half-lives greater than 8 days released in gaseous effluents to 15 mrem to any organ.⁹⁴ ^{14}C is released as a gas in the form of CH_4 or CO_2 and is not a radioiodine, tritium, or particulate, therefore the design objectives in 10 CFR 50, Appendix I and the limits of REC 16.11.2.3 do not apply to ^{14}C .

10 CFR 20.1301(a)(1) limits the annual TEDE dose to the Member of the Public to 100 mrem.

⁹³ 10 CFR 50, Appendix I, section II, paragraph C

⁹⁴ NUREG-1301, REC 3.11.2.3

40 CFR 190.10(a) limits the total annual dose from the uranium fuel cycle to the Member of the Public to 25 mrem to the whole body or any organ. 40 CFR 190 is implemented by REC 16.11.3.1. This limit includes dose from the release of gaseous effluents to areas at or beyond the Site Boundary, the dose from gaseous effluents due to activities within the Site Boundary, and the dose from direct radiation. The methodology for calculating the total annual dose from the uranium fuel cycle is provided in Section 4.

10 CFR 72.104 requires that the annual dose equivalent to any real individual who is located beyond the controlled area must not exceed 25 mrem to the whole body, 75 mrem to the thyroid and 25 mrem to any other critical organ as a result of exposure to planned discharges of radioactive materials and direct radiation from Independent Spent Fuel Storage Installation (ISFSI) operations. There are no radioactive effluents from the ISFSI. The HI-STORM UMAX Canister Storage System does not create any radioactive materials or have any radioactive waste treatment systems. COC Specification 3.1.1, "Multi-Purpose Canister (MPC)", provides assurance that there are no radioactive effluents from the ISFSI.⁹⁵ ^{14}C is a weak beta emitter and does not contribute to direct radiation dose.

4) Estimation of ^{14}C in Gaseous Effluents

^{14}C exists in all PWR systems, and any location or system that contains tritium most likely also will contain ^{14}C in some chemical form. Measurements of ^{14}C concentrations in various liquid systems have been performed, and some of the reported data are included in EPRI TR-1021106.⁹⁶ As a general rule, ^{14}C in the primary coolant is essentially all organic with a significant fraction as a gaseous species. If the RCS liquid or gas is exposed to an oxidizing environment, such as during the forced oxidation during the shutdown evolution and during refueling outages, a slow transformation from an organic to an inorganic chemical form can occur.

Dissolved nitrogen gas and ammonia in the RCS could contribute to the ^{14}C source term. The dissolved nitrogen could become significant in the latter stages of the fuel cycle due to the introduction of increased quantities of non-borated water for boron dilution. Callaway maintains a hydrogen gas overpressure on the RCS which effectively eliminates dissolved nitrogen gas and ammonia in the RCS, therefore the RCS ammonia concentration is assumed to be 0.⁹⁷

In general, ^{14}C is produced in light water moderated nuclear power reactors by $^{14}\text{N}(n,p)^{14}\text{C}$ reactions with nitrogen impurities in the coolant and by $^{17}\text{O}(n,\alpha)^{14}\text{C}$ reactions in the coolant. ^{14}C produced in a nuclear power reactor can be released directly to the environment from the coolant in a gaseous form or in much smaller quantities as liquid

⁹⁵ Certificate of Compliance No. 1040, Appendix A, Specification 5.1.

⁹⁶ EPRI TR-1021106, Section 4.1

⁹⁷ CDP-ZZ-00200, Appendix B, Table 1.1, "Reactor Coolant System-MODES 1, 2, 3, and 4", page 6 of 23

effluents.⁹⁸ Kunz estimated the fraction of ^{14}C in liquid and solid wastes at <5% of that in gaseous discharges⁹⁹. Regulatory Guide 1.21 states that the dose contribution from ^{14}C in liquid discharges is insignificant and evaluation of ^{14}C released in liquid effluents is not required.¹⁰⁰

The release and removal pathways from the primary coolant include VCT venting, boron dilution, inventory buildup on the letdown demineralizers and filters, and reactor coolant leakage. Letdown system removal is approximately 1 Ci/yr.¹⁰¹ The ^{14}C production balance is shown in Figure 1.




Figure 1: ^{14}C Production Balance

5) Chemical Form of ^{14}C in Gaseous Effluents

Since the PWR operates with a reducing chemical environment, most, if not all, of the ^{14}C species initially produced are in the reduced, i.e., organic, form and contain only a single carbon atom. Possible species include methane ($^{14}\text{CH}_4$), methanol ($^{14}\text{CH}_3\text{OH}$), formaldehyde ($\text{H}_2^{14}\text{C}=\text{O}$ or the *gem*-diol $\text{H}_2^{14}\text{C}(\text{OH})_2$), and formic acid (H^{14}COOH). In theory, the only ionic species produced will be formic acid ($\text{H}^{14}\text{CO}_2\text{H}$), and some or all of the formic acid will be removed by the letdown demineralizers. Formaldehyde is soluble in water and may partially be chemisorbed on the ion exchange resin. A quasi-equilibrium is established in the coolant between the initially produced species and other possible species in the reactor coolant. The most chemically reduced species and probably the most prevalent species is $^{14}\text{CH}_4$ which partitions between the liquid and gas phases in the VCT and pressurizer.¹⁰² The airborne ^{14}C released from PWRs is predominantly hydrocarbons (75–95%), mainly methane (CH_4), with only a small fraction

⁹⁸ IAEA Report 421, Section 3.1.3

⁹⁹ Kunz, 1985

¹⁰⁰ Regulatory Guide 1.21, rev. 2, section 1.09

¹⁰¹ EPRI TR-1021106, Section 4.1

¹⁰² EPRI TR-1021106, Section 4.1

in the form of CO₂.^{103,104} Regulatory Guide 1.21 states that ¹⁴C releases in PWRs occur primarily as a mix of organic carbon and CO₂ in gaseous waste from the waste gas system.¹⁰⁵ NUREG-0017¹⁰⁶ concludes that 16.4% of the ¹⁴C produced in a PWR will be released via the waste gas processing system, and the remainder, 83.6%, from the Reactor Building and the Auxiliary Building.

Due to the presence of high temperature hydrogen recombiners in the Callaway waste gas system, 100% of the ¹⁴C released through the waste gas system is assumed to be released from the waste gas decay tanks in the oxidized, i.e., inorganic form as CO₂. The ¹⁴C released from the unit vent is assumed to be in the reduced (organic) form as CH₄, therefore 16.4% of the ¹⁴C produced is released through the Waste Gas Decay tanks (WGDT) as CO₂, and 83.6% is released via the Unit Vent as CH₄.




Figure 2: ¹⁴C Gaseous Discharge Balance

6) ¹⁴C Source Term Estimation

The neutron absorption cross section for the ¹⁷O(n,α)¹⁴C reaction is shown in Figure 3. The ¹⁷O(n,α)¹⁴C reaction has a 1/v region and a significant high energy neutron cross section. Given a constant neutron flux and target concentration, the rate of production of a species, N_a, in atoms per second is given by:

$$N_a = N_T \cdot \{(\sigma_t \cdot \phi_t) + (\sigma_e \cdot \phi_e) + (\sigma_f \cdot \phi_f)\}$$

Where:

N_a is the rate of production, atoms/sec

¹⁰³ IAEA Report 421, Section 3.1.3

¹⁰⁴ Neeb, section 4.2.4

¹⁰⁵ Regulatory Guide 1.21, rev. 2, section 1.09

¹⁰⁶ NUREG-0017, Section 2.2.25.2

NT is the number of ^{17}O or ^{14}N target atoms per kg of coolant

σ_t is the effective neutron cross section for thermal neutron absorption, cm^2

ϕ_t is the thermal neutron flux, $\text{n/cm}^2\text{-sec}$

σ_e is the effective neutron cross section for epithermal energy neutron absorption, cm^2

ϕ_e is the epithermal neutron flux, $\text{n/cm}^2\text{-sec}$

σ_f is the effective neutron cross section for fast neutron absorption, cm^2

ϕ_f is the fast neutron flux, $\text{n/cm}^2\text{-sec}$




Figure 3: ENDF/B VII Cross Sections for ^{17}O

Table 19: Effective Cross Section for the $^{17}\text{O}(n,\alpha)^{14}\text{C}$ Reaction in the PWR as a Function of Neutron Energy¹⁰⁷

Neutron Group	Group Energy	Effective Cross Section
Thermal	≤ 0.625 eV	0.121 barns
Epithermal (E)	> 0.625 eV - < 1 MeV	0.0291 barns
Fast (F)	≥ 1 MeV	0.1124 barns

The source term of each species A_i , is given by:

¹⁰⁷ EPRI TR-1021106, Section 4.3.2.2

$$A_a \text{ (dps)} = N_a \cdot \lambda_a$$

$$A_a (\mu\text{Ci}) = \frac{N_a \cdot \lambda_a}{3.7E4}$$

Where A_a is the activity of species a, N_a is the number of atoms of species a, λ_a is the decay constant of species a, in seconds. The ^{14}C production rate from the $^{17}\text{O}(n,\alpha)^{14}\text{C}$ reaction is calculated for the three group flux distribution according to:¹⁰⁸

$$^{14}\text{C production rate} = \frac{(1E-24 \cdot \lambda \cdot N \cdot \{(\sigma_t \phi_t) + (\sigma_e \phi_e) + (\sigma_f \phi_f)\})}{3.7E4}$$

Where:

$^{14}\text{C Production rate}$ is ^{14}C rate of production, $\mu\text{Ci/sec-kg}$

N is the number of target atoms per unit mass of coolant ($1.27E22$ atoms $^{17}\text{O}/\text{kg H}_2\text{O}$);

σ_t is the effective neutron cross section for thermal neutron absorption, in barns;

ϕ_t is the thermal neutron flux, $\text{n/cm}^2\text{-sec}$;

σ_e is the effective neutron cross section for epithermal energy neutron absorption, in barns;

ϕ_e is the epithermal neutron flux, $\text{n/cm}^2\text{-sec}$;

σ_f is the effective neutron cross section for fast neutron absorption, in barns;

ϕ_f is the fast neutron flux, $\text{n/cm}^2\text{-sec}$;

$1.0E-24$ is a units conversion factor, $1.0E-24 \text{ cm}^2/\text{barn}$;

λ is the ^{14}C decay constant, $3.833E-12/\text{sec}$; and

$3.7E4$ is a units conversion factor, $3.7E4 \text{ d}/(\text{sec-}\mu\text{Ci})$.

The activity of ^{14}C produced is thus the product of the production rate, the coolant mass in the active core region, and time:

$$A_c = \text{Production rate} \cdot \text{coolant mass} \cdot \text{time}$$

Where:

A_c is the activity of ^{14}C produced, in μCi ;

The **coolant mass** is the mass of water in the active core region, in kg, corrected for core average temperature and pressure;

The **time** is the time period of reactor operation, in sec;

The Callaway reactor is a Westinghouse Model F, four loop Pressurized Water Reactor (PWR) rated at $3565 \text{ MW}_{\text{th}}$. The fuel is Westinghouse Vantage+ OFA with 193 fuel

¹⁰⁸ EPRI TR-1021106, Section 4.3.2.1

assemblies. The mass of coolant in the active core region is 12,925 kg.¹⁰⁹ The hydrogen gas overpressure in the Volume Control Tank (VCT) effectively eliminates N₂ and NH₃ in the RCS, therefore ¹⁴C production from the ¹⁴N(n,p)¹⁴C reaction is insignificant.

The core average neutron flux, the Effective Full Power Years (EFPY), and the fuel burnup are specific to the reactor operation for the period.

7) Inhalation Dose at the Nearest Residence Location from ¹⁴C

The child age group is the critical age group for an airborne release of ¹⁴C due to higher inhalation dose factors and higher ingestion dose factors.¹¹⁰ The inhalation dose for the child age group, *D*, is calculated according to the expression¹¹¹:

$$D_j = 3.17E4 \cdot R_a \cdot DFA_j \cdot Q_i \cdot X/Q$$

Where:

D is the dose in mrem, to a member of the public from ¹⁴C, from the inhalation pathway, received by organ *j*;

3.17 E4 is the number of pCi/Ci divided by the number of sec/yr;

R_a is the breathing rate for the child age group (3700 m³/yr);¹¹²

DFA_j is the ¹⁴C inhalation pathway dose factor for organ *j*, appropriate to the child age group (mrem/pCi). For ¹⁴C, the limiting organ is the bone. The *DFA_{bone}* for the child age group is 9.70E-6 mrem/pCi, and the *DFA_{total body}* for the child age group is 1.82E-6;¹¹³

Q_i is the quantity of ¹⁴C produced during the year (Ci/yr); and

X/Q is the highest calculated annual average concentration at the nearest receptor location (sec/m³).

The inhalation dose to the bone for the child age group at the Nearest Residence location is:

$$D_{bone} = 1138 \cdot Q_i \cdot X/Q$$

The inhalation dose to the total body for the child age group at the Nearest Residence location is:

$$D_{total\ body} = 213 \cdot Q_i \cdot X/Q$$

¹⁰⁹ Westinghouse Calculation Note CN-TA-02-135, "Callaway (SCP) RSG IGOR/RETRAN Base Deck", May 16, 2003

¹¹⁰ Regulatory Guide 1.109, Table E-9, and Table E-13

¹¹¹ Regulatory Guide 1.109, equations C-3 and C-4.

¹¹² Regulatory Guide 1.109, Table E-5

¹¹³ Regulatory Guide 1.109, Table E-9.

8) Dose from ^{14}C in Fresh Leafy Vegetation

The concentration of ^{14}C in leafy vegetation is calculated by assuming that the ^{14}C ratio to the natural carbon in the vegetation is the same as the ratio of ^{14}C to natural carbon in the atmosphere surrounding the vegetation.¹¹⁴

Only ^{14}C released in the oxide form (CO or CO_2) is incorporated into the plant material.¹¹⁵ All ^{14}C released from the waste gas decay tanks is assumed to be CO_2 . CH_4 is not incorporated into plant material, therefore, only CO_2 contributes to the ingestion dose pathway. $^{14}\text{CO}_2$ released outside the growing season or at night is not incorporated into plant material and does not contribute to the dose from the ingestion pathway. $^{14}\text{CO}_2$ released during the growing season in the daytime is assumed to be incorporated into the plant material and contributes to the ingestion dose pathway. The growing season in mid-Missouri is approximately April 1- November 1.¹¹⁶

The concentration of ^{14}C in leafy vegetation is given by:¹¹⁷

$$\text{Conc}_v = \frac{3.17\text{E}7 \cdot Q_i \cdot X/Q \cdot 0.11}{0.16}$$

Where:

Conc_v is the concentration of ^{14}C in leafy vegetation grown at the nearest receptor location (pCi/kg);

3.17E7 is equal to $(1\text{E}12\text{pCi/C})(1\text{E}3\text{g/kg})/(3.15\text{E}7 \text{ sec/yr})$;

Q_i is the quantity of ^{14}C released as CO_2 during periods of photosynthesis (Ci/yr);

X/Q is the highest calculated annual average concentration at the nearest receptor location (sec/m^3);

0.11 is the fraction of total plant mass that is natural carbon, dimensionless; and

0.16 is the concentration of natural carbon in the atmosphere (g/m^3).

Substitution of constants yields:

$$\text{Conc}_v = 2.2\text{E}7 \cdot Q_i \cdot X/Q$$

The leafy vegetation ingestion dose for the Child age group at the nearest receptor location is given by:¹¹⁸

$$D = \text{DFI} \cdot f_i \cdot U_a \cdot \text{Conc}_v$$

Where:

¹¹⁴ Regulatory Guide 1.109, Appendix C

¹¹⁵ Regulatory Guide 1.109, Appendix C

¹¹⁶ Hammer, G. R.

¹¹⁷ Regulatory Guide 1.109, equation C-8

¹¹⁸ Regulatory Guide 1.109, equation C-13

D is the annual dose to the bone or total body for the child age group from ingestion of fresh leafy vegetation, (mrem/yr);

DFI is the ingestion dose conversion factor for the maximum exposed organ. For the child age group, the bone is the maximum exposed organ. The **DFI_{bone}** is 1.21E-5 mrem/pCi ingested and the **DFI_{total body}** is 2.42E-6 mrem/pCi ingested;¹¹⁹

f_i is the fraction of leafy vegetation grown in the garden at the nearest receptor location. $f_i = 1.0$;¹²⁰ and

U_a is the ingestion rate of leafy vegetation. For the child age group, $U_a = 26$ kg/yr.¹²¹

9) Dose from ¹⁴C in Milk

The concentration of ¹⁴C in milk is determined as¹²²:

$$Conc_{milk} = F_m \cdot Conc_v \cdot Q_F \cdot e^{-\lambda t_f}$$

Where:

Conc_{milk} is the concentration of ¹⁴C in milk, in pCi/L;

F_m is the average fraction of the animal's daily intake of ¹⁴C which appears in each liter of milk, in days/L. For cow milk, F_m is 1.2E-2 days/L.¹²³ For goat milk, F_m is 0.10 days/L;¹²⁴

Conc_v is the concentration of ¹⁴C in leafy vegetation grown at the receptor location (pCi/kg), as described above;

Q_F is the amount of feed consumed by the animal per day, in kg/day. For cows, Q_F is equal to 50 kg/day and for goats Q_F is equal to 6 kg/day;¹²⁵

t_f is the average transport time of the ¹⁴C from the feed into the milk and to the receptor (a value of 2 days is assumed): and

λ is the radiological decay constant for ¹⁴C, 3.32E-7 days⁻¹.

The dose from ¹⁴C in milk is determined as:

$$D = DFI \cdot U_a \cdot Conc_{milk}$$

Where:

D is the annual dose to the bone or total body for the child age group from milk ingestion, (mrem/yr);

¹¹⁹ Regulatory Guide 1.109, Table E-13

¹²⁰ Regulatory Guide 1.109, Table E-15

¹²¹ Regulatory Guide 1.109, Table E-5

¹²² Regulatory Guide 1.109, equation C-10

¹²³ Regulatory Guide 1.109, Table E-1

¹²⁴ Regulatory Guide 1.109, Table E-2

¹²⁵ Regulatory Guide 1.109, Table E-3

DFI is the ingestion dose conversion factor for the maximum exposed organ. For the child age group, the bone is the maximum exposed organ. The **DFI_{bone}** is 1.21E-5 mrem/pCi ingested and the **DFI_{total body}** is 2.42E-6 mrem/pCi ingested;¹²⁶ and **U_a** is the ingestion rate for milk. For the child age group, U_a = 330 L/yr (for both cow and goat milk).¹²⁷

10) Dose from ¹⁴C in Meat

The concentration of ¹⁴C in meat is determined as¹²⁸:

$$Conc_{meat} = 3.1E-2 \cdot Conc_v \cdot 50 \cdot e^{-(20g3.32E-7)}$$

Where:

Conc_{meat} is the concentration of ¹⁴C in meat, in pCi/kg;

3.1E-02 is the stable element transfer factor, in days/kg, for beef¹²⁹

Conc_v is the concentration of ¹⁴C in leafy vegetation grown at the receptor location (pCi/kg), as described above;

50 kg/day is the amount of feed consumed by the beef animal per day;¹³⁰

20 days is the average time from slaughter to consumption¹³¹; and

3.32E-7 days⁻¹ is the radiological decay constant for ¹⁴C.

The dose from ¹⁴C in meat is determined as:

$$D = DFI \cdot U_a \cdot Conc_{meat}$$

Where:

D is the annual dose to the bone or total body for the child age group from milk ingestion, (mrem/yr);

DFI is the ingestion dose conversion factor for the maximum exposed organ. For the child age group, the bone is the maximum exposed organ. The **DFI_{bone}** is 1.21E-5 mrem/pCi ingested and the **DFI_{total body}** is 2.42E-6 mrem/pCi ingested;¹³² and

U_a is the ingestion rate for meat. For the child age group, U_a = 41 kg/yr.¹³³

11) Dose to the Member of the Public from Activities within the Site Boundary

¹²⁶ Regulatory Guide 1.109, Table E-13

¹²⁷ Regulatory Guide 1.109, Table E-5

¹²⁸ Regulatory Guide 1.109, equation C-12

¹²⁹ Regulatory Guide 1.109, Table E-1

¹³⁰ Regulatory Guide 1.109, Table E-3

¹³¹ Regulatory Guide 1.109, Table E-15

¹³² Regulatory Guide 1.109, Table E-13

¹³³ Regulatory Guide 1.109, Table E-5

The Member of the Public performing activities within the Site Boundary is described in Section 4. The ingestion dose pathways do not exist within the Site Boundary. ^{14}C is not a gamma- emitting nuclide; therefore the ground plane pathway is negligible.

The inhalation dose, D , is calculated according to the expression¹³⁴:

$$D_j = 3.17\text{E}4 \cdot R_a \cdot \text{DFA}_j \cdot Q_i \cdot X/Q \cdot 1.26\text{E}-1$$

Where:

D is the dose in mrem, to a member of the public from ^{14}C , from the inhalation pathway, received by organ j ;

$3.17\text{E}4$ is the number of pCi/Ci divided by the number of sec/yr;

R_a is the breathing rate for the adult age group ($8000\text{ m}^3/\text{yr}$);¹³⁵

DFA_j is the ^{14}C inhalation pathway dose factor for organ j , appropriate to the adult age group (mrem/pCi). For ^{14}C , the limiting organ is the bone. The DFA_{bone} for the adult age group is $2.27\text{E}-6$ mrem/pCi, and the $\text{DFA}_{\text{total body}}$ and $\text{DFA}_{\text{thyroid}}$ is $4.26\text{E}-7$ mrem/pCi.¹³⁶

Q_i is the quantity of ^{14}C produced during the year (Ci/yr)

X/Q is the highest calculated annual average concentration for activities within the Site Boundary, as shown in Table 10.

$1.26\text{E}-1$ is the fraction of the year the farmer performs activities within the Site Boundary ($1100\text{ hrs}/8760\text{ hrs}$), dimensionless.

¹³⁴ Regulatory Guide 1.109, equations C-3 and C-4

¹³⁵ Regulatory Guide 1.109, Table E-5

¹³⁶ Regulatory Guide 1.109, Table E-7

12) Alternate Methodologies

Regulatory Guide 1.21 states that the following methods are acceptable for estimating the production of ^{14}C .¹³⁷

- Sampling and analysis of effluent streams
- Use of normalized ^{14}C source term and scaling factors based on power generation, e.g., NCRP Report 81¹³⁸
- Use of the PWR GALE code¹³⁹

Callaway Plant effluents have not been sampled for ^{14}C . NCRP Report 81, Table 3.3 states that the total ^{14}C production rate for a PWR without reactor coolant nitrogen is 6 Ci/GW_e-yr. Assuming a conversion of 0.34 GW_e/GW_{th}, the expected ^{14}C production rate is 2 Ci/GW_{th}-yr or 7.2 Ci/EFPY for Callaway, which is significantly lower than the quantity of ^{14}C calculated using the EPRI methodology. The PWR GALE code does not calculate the quantity of ^{14}C produced, but instead assigns a value of 7.3 Ci/yr for every PWR without regard for power level, reactor coolant nitrogen concentration, or waste gas system design and operation. Again, this is significantly lower than the quantity of ^{14}C calculated using the EPRI methodology. For example, using the EPRI methodology and the neutron flux distribution for Cycle 18, the ^{14}C production for Callaway is 13.2 Ci/EFPY.¹⁴⁰ The ^{14}C production calculated using the EPRI methodology is therefore conservative with respect to the methodologies mentioned in Regulatory Guide 1.21, rev. 2.

The EPRI methodology also provides for a PWR proxy calculation. The average ^{14}C production rate for Westinghouse PWRs is 3.4 Ci/ GW_{th}- yr¹⁴¹. Callaway is rated at 3.565 GW_{th} (3565 MW_{th}), therefore, the ^{14}C production rate based on the proxy PWR is 12.1 Ci/ EFPY. The ^{14}C production calculated using the EPRI proxy methodology is therefore conservative with respect to the acceptable methodologies described in Regulatory Guide 1.21, rev. 2.

¹³⁷ Regulatory Guide 1.21, Section 1.9

¹³⁸ NCRP Report 81

¹³⁹ NUREG-0017

¹⁴⁰ HPCI 1102

¹⁴¹ EPRI TR-1021106, Section 4.8 and Appendix D

Appendix B: Record of Revisions¹⁴²**Rev. No. 0 Date: March 1983****Rev. No. 1 Date: November, 1983**

Revised to support the current RETS submittal and to incorporate NRC Staff comments.

Rev. No. 2 Date: March, 1984

Revised to incorporate NRC Staff comments

Rev. No. 3 Date: June, 1985

Revised to incorporate errata identified by ULNRC00803 and changes to the Environmental Monitoring Program. Incorporate results of 1984 Land Use Census.

Rev. No. 4 Date: February, 1987

Minor clarifications, incorporated 31-day projected dose methodology. Change in the utilization of areas within the Site Boundary.

Rev. No. 5 Date: January, 1988

Minor clarifications, revised descriptions of liquid and gaseous rad monitors, revised liquid setpoint methodology to incorporate monitor background, revised dose calculations for 40CFR190 requirements, Revised Table 6 and Figures 5.1A and 5.1B to refine descriptions of environmental TLD stations, incorporated description of environmental TLD testing required by Reg. Guide 4.13, revised Tables 1, 2, 4 and 5 to add additional nuclides, deleted redundant material from Chapter 6.

Rev. No. 6 Date: May, 1989

Revised methodology for calculating maximum permissible liquid effluent discharge rates and liquid effluent discharge rates and liquid effluent monitor setpoints, provided methodology for calculating liquid effluent monitors response correction factors, provided an enhanced description of controls on liquid monitor background limits, provided additional liquid and gaseous dose conversion factors and bioaccumulation factors (Tables 1, 2, 4 & 5), provided description of the use of the setpoint required by Technical Specification 4.9.4.2 during Core Alterations, added discussion of gaseous and liquid monitor setpoint selection in the event that the sample contains no detectable activity, added minimum holdup requirements for Waste Gas Decay tanks, revised dispersion parameters and accompanying description per FSAR Change Notice 88-42.

APA-ZZ-01003**Rev. No. 0 Date: August, 1989**

Radiological Effluent Technical Specifications were moved from the Callaway Plant Technical Specifications to Section 9.0, Radioactive Effluent Controls, of the ODCM per NRC Generic Letter 89-01. At the same time, in order to formalize control of the entire ODCM, it was converted to APA-ZZ-01003, Offsite Dose Calculation Manual.

¹⁴² Section numbers, table numbers, etc. refer to the numbering schema used in the particular revision.

Rev. No. 1 Date: October, 1990

Revise Action 41 of Table 9.2-A to allow continued purging for 24 hours per Amendment 20 to operating license, issued 4/10/87.

Rev. No. 2 Date: May, 1991

Section 2.4.2: Changed gross alpha analysis frequency from "each batch" to a monthly composite per Table 9.3-A, and the Callaway Plant NPDES permit (reissued March 15, 1991).

Rev. No. 3 Date: June, 1993

Deleted HF-RE-45 and LE-RE-59 as effluent monitors. Revised table numbering for consistency with those in Section 9.0, deleted redundant material, incorporated 1992 Land Use Census results, moved LLD description to Attachment 1, moved REC Bases to Attachment 2. Deleted reporting requirements for solid radwaste, which are described in APA-ZZ-01011, Process Control Program. Addressed compliance with 10 CFR 20.1301. Revised the dilution flow rate to allow values other than 5000 gpm, based on dilution flow monitor setpoint. Revised "MPC" terminology to "ECV". Added Action 46 to REC 9.2 to clarify actions for inoperable mid and high range WRGM Channels. Revised references to be consistent with the revised 10 CFR 20. Added Appendix A. Revised Action 41 of Rec 9.2 and the operability requirements of GT-RE-22/33. Incorporated the revised R_i values in Tables 3.2 and 3.3. Added Section 6.2 and Table 6.5.

Rev. No. 4 Date: September, 1994

Increased the minimum channels OPERABLE requirement of REC 9.2 for GT-RE-22 & 33 from 1 channel to 2 channels. Revised Action 41 and the Bases for REC 9.2 accordingly. Incorporated the operability requirements from Tech Spec 3.9.9 into the Action statement for clarity. (Refer to CARS 199401176).

Rev. No. 5 Date: February, 1995

Removed the REMP station locations. Removed particulate nuclides with a half-life of less than 8 days from Tables 3.2-3.4 and removed ^{14}C , ^{32}P , ^{63}Ni , and $^{125\text{m}}\text{Te}$ from Tables 2.1, 2.2, 3.2, 3.3, and 3.4. Changed the reporting frequency of the Effluent Release Report from semiannual to annual. Removed the meat, milk and vegetable pathway dispersion parameters from Tables 6.1, 6.2, and 6.3, and clarified the applicability of the dispersion parameters and dose locations in Table 6.4. Relocated REC 9.1 and 9.2 to the FSAR. Revised footnotes 3 and 7 of Table 16.11-4 to require additional sampling of the Unit Vent in the event of a reactor power transient, only if the Unit Vent noble gas activity increases by a factor of 3 or greater. Added Section 4.1.3.1.3 for determination of dose due to the on-site storage of low level radioactive waste.

Rev. No. 6 Date September, 1996

Section 2: Added dose factors (A_i) for $^{110\text{m}}\text{Ag}$, ^{237}Np , ^{238}Pu , $^{239/240}\text{Pu}$, ^{241}Pu , ^{241}Am , ^{242}Cm , and $^{234/244}\text{Cm}$ to Table 2.1, and Bioaccumulation Factors (B_f) for Ag, Pu, Am, and Cm to Table 2.2 due to a change in the liquid radwaste treatment process. Revised the description of the methodology for performing the 31 day dose projection in Section 2.5. Revised the maximum allowable background for HB-RE-18. Section 3: Eliminated $^{91\text{m}}\text{Y}$ and $^{99\text{m}}\text{Tc}$ from Table 3.4 (Meat Pathway) due to a half-life of < 8 days. Substituted the phrase "more restrictive" in lieu of "lesser" in Section 3.2. Revised the definition of F_a in equation 3.1. Added description of use of samples to verify dose rates in Section 3.3.1.2. Augmented the definition of q_i in Section 3.3.2.1. Edited

equations 3.13 and 3.14 and added equation 3.15 to clarify dose calculations. Revised the methodology for performing the 31 day dose projection in Section 3.4. Section 4: Strengthened the discussion of the reevaluation of assumptions in Section 4.1.3. Section 6: Added new Table 6.6 to describe the selection and use of dispersion parameters during the preparation of the Effluent Release Report. Updated Tables 6.1 and 6.2 to reference the 1995 Land Use Census. There were no changes in the receptor locations. Section 8: Replaced the reference to HDP-ZZ-04500 to a more generic reference to the plant operating procedures, due to change in organizational structure and responsibilities. Section 9: (1) Eliminated 9.0.1 and 9.0.2 due to redundancy with Technical Specifications 3.0.1 and 3.0.2; (2) Revised Table 9.3-A to incorporate sampling and analysis requirements for TRU nuclides in liquid effluents; (3) Eliminated sampling of Fuel Building Exhaust from Table 16.11-4 and the associated footnotes due to redundancy with Unit Vent sampling; revised the continuous sampling requirements for the gaseous batch release points consistent with plant design; revised the ^3H analysis frequency for Purges from weekly to "prior to each purge"; and, (4) Revised the air sampling station location criteria on Table 9.11-A and footnote # 1, and eliminated footnote #3 in order to be less generic and more descriptive of the parameters used in determining the station locations (See CARS 199502280). Revised the location requirements for milk and vegetables. Revised description of use of baseline samples to trigger gamma isotopic analysis in footnote #4, revised requirement for location of downstream sample station in footnote #6. Revised Surveillance Requirement 9.10.2.1 to eliminate liquid effluents from the surveillance. (5) Revised REC 9.5 and REC 9.9 to eliminate exceptions for partially tested effluents being released in excess of the respective limit. Section 11: Added reference 11.14.13. Attachment 2: Revised the Bases for REC 9.10 to support the elimination of liquid effluents from Surveillance 9.10.2.1. The remaining changes are editorial in nature and have no technical impact. (This revision implements CARS 199502055, CARS 199600167, CARS 199600961, CARS 199502280, and CARS 199600986).

Rev. No. 7 Date February, 1997

Section 9: (1) REC 9.5, "Liquid Radwaste Treatment System", Action statement: Eliminated reference to COMN 1161. (2) Table 9.11-A, items 4a (milk) and 4c (vegetation): revised to required control stations in the least prevalent wind direction. (See CARS 199700166). Appendix A: revised the discussion relative to the appropriate gross alpha Effluent Concentration Value.

Rev. No. 8 Date May, 1997

Section 1: The Purpose and Scope was revised to describe the split of the ODCM into two sections Per FSAR Change Notice 95-058. Section 2: Sections 2.2 and 2.3 were revised to clarify the use of nuclide- specific alpha activity vice gross alpha activity for setpoint determination. Section 2.5 was revised to delete the description of the Liquid Radwaste Treatment System. Section 6: Tables 6.1, 6.2, and 6.3 were revised to reflect the results of the 1996 Annual Land Use Census. Section 7: The reporting requirements for the Annual Radiological Environmental Operating Report and the Effluent Release Report were relocated to the FSAR Per FSAR Change Notice 95-058. Section 9: REC's and the supporting Attachments 1 and 2 were relocated to the FSAR Per FSAR Change Notice 95-058. Appendix A: Appendix A was deleted. Editorial changes were made throughout the ODCM reflecting the relocation of the REC's to the FSAR.

Rev. No. 9 Date March, 1998

Section 2.5: Revised projected liquid dose calculation to use previous 31 day cumulative doses. Section 3.1.1: Added GL-RE-202, Laundry Decon Facility Dryer Exhaust Monitor. Added action to be taken when the particulate and/or iodine grab sampler is not operable. Section 3.2: Added setpoint calculation for GL-RE-202. Section 3.2.1 and 3.3.2.2: Changes were made to correct typographical errors and have no technical impact. Section 3.4: Revised projected gas dose calculation to use previous 31 day cumulative doses. Section 3.5: Removed the word secular from "secular equilibrium" since the equilibrium mode could be secular or transient depending on the isotope. Table 6.2: Added Laundry Decon Facility Dryer Exhaust to title of table since these will be the dispersion factors used for this release point.

Rev. No. 10 Date December 20, 1999

Section 3.1: Added explanation that GL-RE-202 only monitors particulate. Section 3.2: Changed Laundry Decon Facility Exhaust Monitor setpoint to less than or equal to 2000 cpm above equilibrium background with a maximum allowed background of 2000 cpm as calculated in HPCI 9905. Tables 6.1, 6.2, 6.3: Updated values as calculated in HPCI 9902. Section 5.1: Defined how REMP sample locations were determined. Removed reference to Plant Operating manual since it no longer exists.

Rev. No. 11 Date December 22, 1999

Changes required to go from old Technical Specifications to Improved Technical Specifications (ITS). Technical Specification 4.9.4.2 changed to FSAR 16.11.2.4.1. Technical Specification 6.8.4.F changed to FSAR 16.11.4. Technical Specification 6.8.1.F changed to Improved Technical Specification 5.4.1. Technical Specification 6.14 changed to Improved Technical Specification 5.5.1. Technical Specification 6.8.4.E changed to Improved Technical Specification 5.5.4. Technical Specification 6.9.1.6 changed to Improved Technical Specification 5.6.2. Technical Specification 6.9.1.7 changed to Improved Technical Specification 5.6.3. Changed name of Annual Radiological Effluent Release Report to Effluent Release Report as stated in ITS. Added liquid releases are limited to 10 times the Appendix B, Table 2, Column 2 limits Per FSAR CN 98-041 supporting implementation of ITS.

Rev. No. 12 Date December 01, 2000

Section 2.1 and 2.2.1: Updated 10CFR20, Appendix B, Table II, Column 2 reference to the new 10CFR20 format. Corrected typo for "f", flow setpoint should be undiluted waste flow rate. Section 3.2.1: Corrected typo, default value for safety factor should be 0.1. Section 5.1: Updated crosscheck program used to EML since EPA program is no longer available. Section 6.2: Added vertical height of highest adjacent building used to perform concurrent year annual average atmospheric dispersion (X/Q) calculations and reference for this value. This information should be documented in the ODCM. Added responsibility for validation of meteorological data, since responsibility has changed from engineering to HPTS. Section 10.1.1: Revised to require a summary of Major Radwaste System changes to be included in the annual report. This was done to be consistent with FSAR 16.11.5.2. Several changes were made throughout the procedure to correct typographical errors and have no technical impact.

Rev. No. 13 Date September 19, 2002

Section 3.2: Revised to implement the approved OL 1218, Rev. 1; License Amendment no. 152 allowing equipment hatch and emergency air lock to remain open during refueling activities (FSAR CN-01-030 and CN-02-049). The amendment eliminated FSAR 16.11.2.4.1B and subsequently deleted the core alteration setpoint value $5.0 \text{ E-3 } \mu\text{Ci/cc}$ for Containment Purge

Monitors GT-RE-22 and GT-RE-33. The alarm setpoints for the Containment Purge Monitors will be based on the methodology described in Section 3 of the ODCM.

Rev. No. 14 Date June 17, 2003

Revised Table 2.1 (Ingestion Dose Commitment Factor for Adult Age Group) to include dose factors for Pr-144. (CARS 200303251). Revised Section 4.1.3.1 to adjust the Farmer's residence (critical receptor) from 3830 meters in the SE sector to 2897 meters in the NNW sector. The Farmer's residence (critical receptor) was changed in 2002 to a location directly across the street from the Nearest residence. For conservatism and ease in calculation, Table 6.1 and 6.2 were revised making the distances and dispersion parameters for the Farmer's residence (critical receptor) and the Nearest residence the same. Revised section 7.2 to reference Table 6.6. Revised section 10.2.2 to remove the requirement for QA department review of the ODCM for reach revision (CARS 200304509). Added a reference to 11.14.14, Calculation HPCI 0304 (Rev. 0), "Calculation of Liquid Effluent Dose Commitment factor for Pr-144 (A_{IT}) for the Adult Age Group", June, 2003.

Rev. No. 15 Date December 9, 2004

Reformatted references to FSAR-SP Chapter 16.11 in section 1, 2.1.1, 2.1.2, 2.2.1, 2.3, 2.4.2, 2.5, 2.6, 3.1, 3.2.1, 3.5, 5.1, 7.1, 7.2, and 9. References to ^{63}Ni were added to section 2.2.1 for the calculation of ECVSUM, section 2.3, and described in section 2.6 since it is an exception to non- gamma emitters not listed in FSAR-SP Table 16.11-1. ^{63}Ni was added to the ODCM based on previous 10 CFR 61 sample results and 2nd quarter liquid composite analyses. Consolidated references listed in section 2.4.2 and 2.6 for the site related ingestion dose commitment factors (A_{IT} of Table 2.1 into HPCI 0406, Revision 1. References to HPCI 9504 (Ref: 11.14.13) and HPCI 0304 (Ref: 11.14.14) were deleted and replaced with HPCI 0406, Revision 1 which is now listed as Ref: 11.14.13. Added ^{63}Ni and ^{122}Sb to Table 2.1- INGESTION DOSE COMMITMENT FACTOR (A_{IT}) FOR ADULT AGE GROUP. Revised the reference for Table 2.1 to 11.14.13. Corrected a typo in section 3.1.2 referring to the Radwaste Building Vent system designator as GT vs. GH (CAR 200406851). References 11.19 and 11.20 were deleted in section 4.1.3.1.1. Reference 11.18 was changed to MicroShield (Grove Engineering, Inc.) vs. ISOSHL. Reference 11.24 in section 4.1.3.1.3 was corrected to 11.18. Section 5.1 and 5.2 were revised to indicate that the Radiological Environmental Monitoring Program TLDs will be processed and provided by a vendor laboratory beginning in the first quarter of 2005. Section 5.2 was revised to delete reference 11.14.10 which refers to HPCI 8808, "Performance Testing of the Environment TLD System at Callaway Plant", August 1989. Reference 11.14.7 was corrected with HPCI 8710 vice HPCI 8810. Revised Table 6.1, Note (c) to reference FSAR Table 2.3-83 vs. Table 2.3-82. Revised Table 6.1 and 6.2 Note (b) to reference data is from the 2002 Land Use Census. Changed and/or corrected the Skin dose factor (L_i) units in Table 3.1 (Dose Factor for exposure to a Semi-Infinite Cloud of Noble Gases) to mrem/yr per $\mu\text{Ci}/\text{m}^3$. Revised section 3.3.1.2: Added units for the term BR in m^3/yr . Removed paragraph in section 3.3.2.2 that describes actions for implementing the use of appropriate $R_{i,j}$ values. This paragraph was taken directly from section 5.3.1 of NUREG 0133, U.S. Nuclear Regulatory Commission, "Preparation of Radiological Effluent Technical Specification for Nuclear Power Plants", USNRC NUREG-0133, Washington, D.C. 20555, October, 1978. This paragraph does not apply since the use of pathways is already considered as described in sections 4.1.2 and 4.1.3.1. Revised note (c) of Table 6.1 to reference FSAR-SA Table 2.3-83. Revised note (a) from Table 6.1 to reference FSAR-SA Table 2.3-82. In addition, revised Note (b) from Table 6.1 to reference data taken from the 2002 Land Use Census. Revised Notes (a) and (c) from Table 6.2 to reference FSAR-SA Table 2.3-84 and 2.3-

81 respectively. Added a 0.95 conservatism factor to section 2.2.3 *Calculation of Liquid Effluent Monitor Setpoint*. This will conservatively reduce the liquid monitor setpoint to further ensure the section 4.4.1 of NUREG 0133, U.S. Nuclear Regulatory Commission, "Preparation of Radiological Effluent Technical Specification for Nuclear Power Plants", USNRC NUREG-0133, Washington, D.C. 20555, October, 1978 which states the alarm and trip setpoints for each instrument channel listed in Table 3.3-11 should be provided and should correspond to a value(s) which represents a safe margin of assurance that the instantaneous liquid release limit of 10 CFR Part 20 is not exceeded. A determination was made IAW T/S 5.5.1 that the associated changes with Revision 15 maintain the levels of radioactive effluent control required by 10 CFR 20.1302, 40 CFR 190, 10 CFR 50.36a, and 10 CFR 50 Appendix I, and not adversely impact the accuracy or reliability of effluent, dose, or setpoint calculations.

Rev. No. 16 Date December 1, 2005

Section 5.1 was revised to remove an invalid requirement that a third-party laboratory performing analysis specifically state the Interlaboratory Comparison (crosscheck) requirements for the Radiological Environmental Monitoring Program (REMP) contract lab. Reference 11.14.14 to Reg. Guide 4.15, Quality Assurance for Radiological Monitoring Programs (Normal Operations)- Effluent Streams and the Environment, was added to provide supporting documentation for contract lab Interlaboratory Comparison requirements. Additional information on REMP contract lab participation in Interlaboratory Comparisons was also added in section 5.1. (CAR 200500891) Revised reference 11.14.7 by adding normalization and standardization factors for radionuclides listed in Table 2.1 of the ODCM that were not included in the original calculation. Added section 4.1.3.1.4 to describe direct dose to a Member of the Public from the Old Steam Generator Storage Facility (OSGSF). Reworded step 4.1.2 to describe the sources of direct radiation from "outside storage tanks" to "storage of radioactive material". Revised section 4.1.3.1.2 to include and describe direct dose calculations in support of Modification 03-1008, Equipment Hatch Platform and Missile Shield Modification. Reference 11.14.10 was added to reference direct dose calculation to the Member of the Public from Modification 03-1008. Revised section 4.1.3.1.3 to include and describe direct dose calculations from the Radwaste Yard RAM storage and Stores II. Reference 11.19 and 11.20 were added to reference direct dose calculations to the Member of the Public from RAM storage at Stores II and the Radwaste Yard. A determination was made IAW T/S 5.5.1 that the associated changes with Revision 16 maintain the levels of radioactive effluent control required by 10 CFR 20.1302, 40 CFR 190, 10 CFR 50.36a, and 10 CFR 50 Appendix I, and not adversely impact the accuracy or reliability of effluent, dose, or setpoint calculations.

Rev. No. 17 Date March 14, 2007

Section 2.4.1 was revised Per CAR 200701309 to state that no potable water intakes exist within 10 miles of the plant discharge point. This is due to the fact that the Annual Land Use Census ensures no newly developed potable water intakes within 10 miles of the plant discharge Per FSAR-SP Chapter 16.11.4.2c. Section 2.4.2 was revised to add reference 11.6.18 to CAR 200700053 which provides documentation of an evaluation of the site specific mixing factor for liquid effluents. Modification 06-0061 reconfigured the plant discharge terminus at the Missouri River. The modification was completed in January 2007.

Rev. No. 18 Date October 11, 2007

Revised Table 6.5 was revised to reflect upgrade/replacement of the primary meteorological tower instrumentation as per Modification Package 04-1020. Section 2.4.2 was

revised to remove the discussion of the nearest municipal potable water intake downstream from the liquid effluent discharge point as being located near the city of St. Louis, Missouri, approximately 78 miles downstream. Since the Land Use Census annually verifies no potable water intakes within 10 miles – this discussion was deemed inappropriate in describing methodology for calculating dose to the public from liquid effluents. In addition, the distance referenced as not having potable water intakes downstream of the plant discharge was changed for consistency with section 2.4.1 and the Land Use Census.

Rev. No. 19 Date August, 2012

Converted to Word 2010, including appropriate formatting changes and cross-referencing for the conversion. Deleted all references to the obsolete Commitment Tracking System (COMN) and all hidden text for the obsolete hidden text referencing system. Added level of use. (CAR 201104163, Action 1) Section 3.4- Added dose reduction controls for discharge of ^{14}C from the waste gas system and defined the growing season. Section 3.5- Deleted statement that non- gamma emitting nuclides not listed in the FSAR-SP Table 16.11.4 are not considered in dose calculations. Eliminated Sections 4.1.3.1.1, 4.1.3.1.2, 4.1.3.1.3, and 4.1.3.1.4- direct radiation dose is negligible; refer to HPCI 1206. Section 5.2- changed to allow use of dosimeters other than TLDs. Section 6.1- Deleted discussion of short- term X/Q processing and the slope factor and deleted the associated table of 'S' factors. Section 6.2- Deleted designation of responsibilities for met data review. (CAR 201104163, Action 1) Section 10.2- changed to align with T/S 5.5.1. CAR 201104163, Action 2) Corrected the department title to align with organizational structure. (CAR 201104163, Action 1). Table 10 and Table 11- The dispersion parameters for the Farmer's residence were removed. As a first approximation, the dispersion parameters for the Nearest Residence will be used for the Farmer's residence. Appendix A- Appendix A was added to describe the calculation of the production of ^{14}C and the calculation of dose from ^{14}C in gaseous effluents. (CAR 201104163) ^{63}Ni was added to the gaseous effluent inhalation pathway and ingestion pathways dose factor tables. Values for ^{63}Ni are from APA-ZZ-01003, rev. 4. (CAR 201104197). Adult ingestion dose factors removed. Ingestion dose pathway removed from Table 13 for activities inside the Site Boundary.

Rev. No. 20 Date April, 2015

Revised Table 10 to implement the recalculated dispersion parameters using 2009- 2013 meteorology. Deleted Table 11 as described in HPCI1503. Added HPCI1502, HPCI1503, HPCI1504, & HPCI1505 as references. Deleted reference to ZZ-67. Added ISFSI to Appendix A, Figure 1. Revised Section 6 to describe the recalculation of the long- term dispersion parameters. Deleted Section 8; following sections were renumbered accordingly.

Rev. No. 21 Date May, 2015

Revised Table 10 to correct the dispersion parameters for the Site Boundary and Nearest Resident locations and edited to two significant digits for consistency with the remainder of Table 10. (CAR 201502908)

Rev. No. 22 Date March, 2017

The following changes implement CR's 201604927, 201602733, 201603668, and 201602733: The methodology used to calculate the A_{it} values was added to section 2.4.2. Default setpoint values for GTRE21B and GHRE10B were added to section 3.2. Deleted the specific years of the meteorological data in section 6.1 and instead stated the dispersion parameters represent five years of on- site data to eliminate a potential error trap. The HPCI referenced in section 6.1

provides the necessary level of detail, including the years represented by the data. A footnote was added to section 6.1.2 to clarify that the farmer is a composite and not an actual person. Section 6.2 was revised to clarify the quality check of the meteorological data prior to processing. Section 10, "Bibliography" was revised to add new references and to update the revision level of CDP-ZZ-00200. ^{126}Sb was added to Table 1. Table 12 was revised to change the "Farmer's Residence" to the "Nearest Resident" because the farming plots are now leased to multiple farmers and it is not feasible to calculate dose to multiple farmers' residences. The footnote in Table 12 regarding ^3H dispersion parameters was moved into the table. ^{14}C was added to Table 12. Appendix A was reformatted for better readability. Appendix A, Section 2, "Assumptions" was revised to clarify the assumptions, principally dispersion parameter use and the dose pathways and locations. Appendix A, Section 3, "Applicable Dose Limits", was revised to add 10 CFR 72.104. Appendix A, Section 11, "Dose to the Member of the Public from Activities Within the Site Boundary", was revised to eliminate the value of the X/Q for activities within the Site Boundary and to instead refer to Table 10 as the source for the X/Q. The three condensed form equations were likewise eliminated. This eliminated an error trap in that the X/Q could be revised and it may not be recognized that the specific value was stated in the text of Appendix A, Section 11. Appendix A, Section 12 was edited for readability.

Rev. No. 23 Date June, 2018

Section 5.1 was revised to delete the phrase referring to HPCI 9901 because HPCI 9901 is obsolete. HPCI 1506, rev. 1, superseded portions of HPCI 9901, the remainder is superseded by HTP-ZZ-DTI-REMP-SMPL-SCHED, REMP Sample Locations and Analysis Schedule". (CR 201705399) Section 10, "Bibliography", was revised to update the revision level of CDP-ZZ-00200, Appendix B, ANSI N42.18-2004 (redesignation of ANSI N13.10-1974), and HPCI 1604. Table 1 was revised to add the Dose Commitment Factors for $^{117\text{m}}\text{Sn}$. (CR 201706108) Format changes are not marked with revision bars.

Rev. No. 24 Date September, 2019

- Added pathway dose factors (R_i) for adult inhalation and ingestion dose pathways for gaseous effluents (Tables 14- 18) from ZZ-78, rev.2. (CR 201903925)
- Added references for all the dose tables.
- Added "Grass- Cow" to titles of Tables 8 and 17.
- Appendix A, Section 8: Removed the terms "inorganic" and "organic" when referring to CO_2 and CH_4 .
- Format changes are not marked with revision bars.

Rev. No. 25 Date December, 2020

Section 2.1 was revised to include new requirements for dilution flow in the current NPDES permit (effective 7/1/2020). Special condition #3 of the 7/1/2020 NPDES permit requires a minimum of 3000 gpm dilution flow from outfalls #002, Cooling Tower Blowdown and #016, Cooling Tower Bypass (CR 202003290-001). Table 10, 'Farming Areas within the Site Boundary' was revised with HPCI 1502, rev 1 dispersion parameters. The only affected parameter was D/Q (CR 202005158-002). Section 2.1.1. was revised to remove BM-RE-52 as the continuous liquid discharge pathway no longer exists due to MP 19-0114 (BT 202002245-002).

Rev. No. 26 Date June, 2021

Section 4.1 was revised to remove reference to skin dose calculations (CR 202102269). Noble gas organ dose equations 26 and 27 were added to sections 4.1.2. and 4.1.3.1, respectively (CR 202102269). These equations were derived using equation 15. Typographical errors in Table 12 and the associated footnote were also identified and corrected in this revision. The footnote was not updated to reflect the current methodology for calculating historical dispersion values in revision 025. When incorporating the C-14 dose calculation information into table 12 from appendix A, there was a copy and paste error. Dose calculation of C-14 has always incorporated the historical dispersion value for both the child and adult controlling age groups.

16.11 OFFSITE DOSE CALCULATION MANUAL
(ODCM 9.0) RADIOACTIVE EFFLUENT CONTROLS

16.11.1 LIQUID EFFLUENT

16.11.1.1 LIQUID EFFLUENTS CONCENTRATION LIMITING CONDITION FOR
OPERATION

(ODCM 9.3.1)

The concentration of radioactive material released in liquid effluents to UNRESTRICTED AREAS (see [Figure 16.11-1](#)) shall be limited to 10 times the concentration values in Appendix B, Table 2, Column 2 to 10 CFR 20.1001-20.2402, for radionuclides other than dissolved or entrained noble gases. For dissolved or entrained noble gases, the concentration shall be limited to 2×10^{-4} microCurie/ml total activity.

APPLICABILITY: At all times.

ACTION:

With the concentration of radioactive material released in liquid effluents to UNRESTRICTED AREAS exceeding the above limits, immediately restore the concentration to within the above limits.

16.11.1.1.1 SURVEILLANCE REQUIREMENTS

(ODCM 9.3.2)

16.11.1.1.1.a

Radioactive liquid wastes shall be sampled and analyzed according to the sampling and analysis program of [Table 16.11-1](#).

16.11.1.1.1.b

The results of the radioactivity analysis shall be used in accordance with the methodology and parameters in the ODCM to assure that the concentrations at the point of release are maintained within the limits of [Section 16.11.1.1](#).

16.11.1.1.2 BASES

This section is provided to ensure that the concentration of radioactive materials released in liquid waste effluents to UNRESTRICTED AREAS will be less than 10 times the concentration in Appendix B, Table 2, Column 2 to 10 CFR 20.1001-20.2402. This limitation provides additional assurance that the levels of radioactive materials in bodies of water in UNRESTRICTED AREAS will result in exposures within: (1) the Section II.A design objectives of Appendix I, 10 CFR Part 50, to a MEMBER OF THE PUBLIC, and

(2) the limits of 10 CFR Part 20.1301 to the population. The concentration limit for dissolved or entrained noble gases is based upon the assumption that Xe-135 is the controlling radioisotope and its MPC in air (submersion) was converted to an equivalent concentration in water using the methods described in International Commission on Radiological Protection (ICRP) Publication 2.

The required detection capabilities for radioactive materials in liquid waste samples are tabulated in terms of the lower limits of detection (LLD's).

16.11.1.2 DOSE FROM LIQUID EFFLUENTS LIMITING CONDITION FOR OPERATION

(ODCM 9.4.1)

The dose or dose commitment to a MEMBER OF THE PUBLIC from radioactive materials in liquid effluents released, from each unit, to UNRESTRICTED AREAS (see **Figure 16.11-1**) shall be limited:

- a. During any calendar quarter to less than or equal to 1.5 mrem to the whole body and to less than or equal to 5 mrem to any organ, and
- b. During any calendar year to less than or equal to 3 mrem to the whole body and to less than or equal to 10 mrem to any organ.

APPLICABILITY: At all times.

ACTION:

With the calculated dose from the release of radioactive materials in liquid effluents exceeding any of the above limits, prepare and submit to the Commission within 30 days a Special Report that identifies the cause(s) for exceeding the limit(s) and defines the corrective actions that have been taken to reduce the releases and the proposed corrective actions to be taken to assure that subsequent releases will be in compliance with the above limits. This Special Report shall also include: (1) the results of radiological analyses of the drinking water source, and (2) the radiological impact on finished drinking water supplies with regard to the requirements of 40 CFR Part 141, Clean Drinking Water Act.*

16.11.1.2.1 SURVEILLANCE REQUIREMENTS

(ODCM 9.4.2)

Cumulative dose contributions from liquid effluents for the current calendar quarter and the current calendar year shall be determined in accordance with the methodology and parameters in the ODCM at least once per 31 days.

16.11.1.2.2 BASES

This section is provided to implement the requirements of Sections II.A and IV.A of Appendix I, 10 CFR Part 50. The Limiting Condition for Operation implements the guides set forth in Section II.A of Appendix I. The ACTION statements provide the required

* The requirements of ACTION a.(1) and (2) are applicable only if drinking water supply is taken from the receiving water body within 3 miles of the plant discharge. In the case of river-sited plants this is 3 miles downstream only.

operating flexibility and at the same time implement the guides set forth in Section IV.A of Appendix I to assure that the releases of radioactive material in liquid effluents to UNRESTRICTED AREAS will be kept "as low as is reasonably achievable".

Also, for fresh water sites with drinking water supplies that can be potentially affected by plant operations, there is reasonable assurance that the operation of the facility will not result in radionuclide concentrations in the finished drinking water that are in excess of the requirements of 40 CFR Part 141. The dose calculation methodology and parameters in the ODCM implement the requirements in Section III.A of Appendix I which specify that conformance with the guides of Appendix I be shown by calculational procedures based on models and data, such that the actual exposure of a MEMBER OF THE PUBLIC through appropriate pathways is unlikely to be substantially underestimated. The equations specified in the ODCM for calculating the doses due to the actual release rates of radioactive materials in liquid effluents are consistent with the methodology provided in Regulatory Guide 1.109, "Calculations of Annual Doses to Man from Routine Releases of Reactor Effluents with 10 CFR Part 50, Appendix I", Revision 1, October 1977 and Regulatory Guide 1.113, "Estimating Aquatic and Dispersion of Effluents from accidental and Routine Reactor Releases for the Purpose of Implementing Appendix I", April 1977.

The reporting requirements of Action(a) implement the requirements of 10CFR20.2203.

16.11.1.3 RADIOACTIVE LIQUID EFFLUENT MONITORING INSTRUMENTATION LIMITING CONDITION FOR OPERATION

(ODCM 9.1.1)

The radioactive liquid effluent monitoring instrumentation channels shown in **Table 16.11-2** shall be FUNCTIONAL with their Alarm/Trip Setpoints set to ensure that the limits of **Section 16.11.1.1** are not exceeded. The Alarm/Trip Setpoints of these channels shall be determined and adjusted in accordance with the methodology and parameters in the ODCM.

APPLICABILITY: At all times.

ACTION:

- a. With a radioactive liquid effluent monitoring instrumentation channel Alarm/Trip Setpoint less conservative than required by the above, immediately suspend the release of radioactive liquid effluents monitored by the affected channel, or declare the channel non-functional.
- b. With less than the minimum number of radioactive liquid effluent monitoring instrumentation channels FUNCTIONAL, take the ACTION shown in **Table 16.11-2**. Restore the non-functional instrumentation to FUNCTIONAL status within 30 days and, if unsuccessful, explain in the next Radioactive Effluent Release Report, pursuant to Technical Specification 5.6.3, why this non-functionality was not corrected within the time specified.

16.11.1.3.1 SURVEILLANCE REQUIREMENTS

(ODCM 9.1.2)

Each radioactive liquid effluent monitoring instrumentation channel shall be demonstrated FUNCTIONAL by performance of the CHANNEL CHECK, SOURCE CHECK, CHANNEL CALIBRATION and CHANNEL OPERATIONAL TEST at the frequencies shown in **Table 16.11-3**.

16.11.1.3.2 BASES

The radioactive liquid effluent monitoring instrumentation is provided to monitor and control, as applicable, the releases of radioactive materials in liquid effluents during actual or potential releases of liquid effluents. The Alarm/Trip Setpoints for these instruments shall be calculated and adjusted in accordance with the methodology and parameters in the ODCM to ensure that the alarm/trip will occur prior to exceeding the limits of 10 CFR Part 20. The FUNCTIONALITY and use of this instrumentation is consistent with the requirements of General Design Criteria 60, 63, and 64 of Appendix A to 10 CFR Part 50.

16.11.1.4 LIQUID RADWASTE TREATMENT SYSTEM LIMITING CONDITION FOR OPERATION

(ODCM 9.5.1)

The Liquid Radwaste Treatment System shall be FUNCTIONAL and appropriate portions of the system shall be used to reduce releases of radioactivity when the projected doses due to the liquid effluent, from each unit, to UNRESTRICTED AREAS (see [Figure 16.11-1](#)) would exceed 0.06 mrem to the whole body or 0.2 mrem to any organ in a 31 day period.

APPLICABILITY: At all times.

ACTION:

With radioactive liquid waste being discharged in excess of the above limits and the Liquid Radwaste Treatment Systems are not being fully utilized, prepare and submit to the Commission within 30 days a Special Report that includes the following information:

- 1) Explanation of why liquid radwaste was being discharged without treatment, identification of any inoperable equipment or subsystems, and the reason for the inoperability.
- 2) Action(s) taken to restore the inoperable equipment to OPERABLE status, and
- 3) Summary description of action(s) taken to prevent a recurrence.

16.11.1.4.1 SURVEILLANCE REQUIREMENTS

(ODCM 9.5.2)

16.11.1.4.1.a

Doses due to liquid releases from each unit to UNRESTRICTED AREAS shall be projected at least once per 31 days in accordance with the methodology and parameters in the ODCM.

16.11.1.4.1.b

The installed Liquid Radwaste Treatment System shall be considered FUNCTIONAL by meeting [Sections 16.11.1.1](#) and [16.11.1.2](#).

16.11.1.4.2 BASES

The FUNCTIONALITY of the Liquid Radwaste Treatment System ensures that this system will be available for use whenever liquid effluents require treatment prior to

release to the environment. The requirement that the appropriate portions of this system be used when specified provides assurance that the releases of radioactive materials in liquid effluents will be kept "as low as is reasonably achievable". This section implements the requirements of 10 CFR Part 50.36a, General Design Criterion 60 of Appendix A to 10 CFR Part 50 and the design objective given in Section II.D of Appendix I to 10 CFR Part 50. The specified limits governing the use of appropriate portions of the Liquid Radwaste Treatment System were specified as a suitable fraction of the dose design objectives set forth in Section II.A of Appendix I, 10 CFR Part 50, for liquid effluents.

16.11.1.5 LIQUID HOLDUP TANKS LIMITING CONDITION FOR OPERATION

The quantity of radioactive material contained in each of the following unprotected outdoor tanks shall be limited to less than or equal to 150 Curies, excluding tritium and dissolved or entrained noble gases:

- a. Reactor Makeup Water Storage Tank,
- b. Refueling Water Storage Tank,
- c. Condensate Storage Tank, and
- d. Outside temporary tanks, excluding demineralizer vessels and the liner being used to solidify radioactive waste.

APPLICABILITY: At all times.

ACTION:

With the quantity of radioactive material in any of the above listed tanks exceeding the above limit, immediately suspend all additions of radioactive material to the tank, within 48 hours reduce the tank contents to within the limit, and describe the events leading to this condition in the next Radioactive Effluent Release Report, pursuant to Technical Specification 5.6.3.

e.

16.11.1.5.1 SURVEILLANCE REQUIREMENTS

(4.11.1.4)

The quantity of radioactive material contained in each of the above listed tanks shall be determined to be within the above limit by analyzing a representative sample of the tank's contents at least once per 7 days when radioactive materials are being added and within 7 days following any addition of radioactive material to the tank. The provisions of **Sections 16.0.2.2 and 16.0.2.3** are applicable, however the allowed surveillance interval extension beyond 25% shall not be exceeded. These tanks are also covered by Administrative Controls Section 5.5.12 of the plant Technical Specifications.

16.11.1.5.2 BASES

The tanks listed above include all those outdoor radwaste tanks that are not surrounded by liners, dikes, or walls capable of holding the tank contents and that do not have tank overflows and surrounding area drains connected to the Liquid Radwaste Treatment System.

Restricting the quantity of radioactive material contained in the specified tanks provides assurance that in the event of an uncontrolled release of the tanks' contents, the resulting concentrations would be less than the limits of 10 CFR Part 20.1-20.602, Appendix B, Table II, Column 2, (redesignated at 56FR23391, May 21, 1991) at the nearest potable water supply and the nearest surface water supply in an UNRESTRICTED AREA.

16.11.2 GASEOUS EFFLUENTS

16.11.2.1 GASEOUS EFFLUENTS DOSE RATE LIMITING CONDITION OF OPERATION

(ODCM 9.6.1)

The dose rate due to radioactive materials released in gaseous effluents from the site to areas at and beyond the SITE BOUNDARY (see [Figure 16.11-2](#)) shall be limited to the following:

- a. For noble gases: Less than or equal to 500 mrem/yr to the whole body and less than or equal to 3000 mrem/yr to the skin, and
- b. For Iodine-131 and 133, for tritium, and for all radionuclides in particulate form with half-lives greater than 8 days: Less than or equal to 1500 mrem/yr to any organ.

APPLICABILITY: At all times.

ACTION:

With the dose rate(s) exceeding the above limits, immediately restore the release rate to within the above limit(s).

16.11.2.1.1 SURVEILLANCE REQUIREMENTS

(ODCM 9.6.2)

16.11.2.1.1.a

The dose rate due to noble gases in gaseous effluents shall be determined to be within the above limits in accordance with the methodology and parameters in the ODCM.

16.11.2.1.1.b

The dose rate due to Iodine-131 and 133, tritium and all radionuclides in particulate form with half-lives greater than 8 days in gaseous effluents shall be determined to be within the above limits in accordance with the methodology and parameters in the ODCM by obtaining representative samples and performing analyses in accordance with the sampling and analysis program specified in [Table 16.11-4](#).

16.11.2.1.2 BASES

This section is provided to ensure that the dose at any time at and beyond the SITE BOUNDARY from gaseous effluents from all units on the site will be within the annual dose limits of 10 CFR Part 20 to UNRESTRICTED AREAS. The dose rate limits are the

doses associated with the concentrations of 10 CFR Part 20.1-20.601, Appendix B, Table II, Column 1. These limits provide reasonable assurance that radioactive material discharged in gaseous effluents will not result in the exposure of a MEMBER OF THE PUBLIC in an UNRESTRICTED AREA, either within or outside the SITE BOUNDARY, to annual average concentrations exceeding the dose limits specified in 10 CFR Part 20 10 CFR 20.1301. For MEMBERS OF THE PUBLIC who may at times be within the SITE BOUNDARY, the occupancy of that MEMBER OF THE PUBLIC will usually be sufficiently low to compensate for any increase in the atmospheric diffusion factor above that for the SITE BOUNDARY. Examples of calculations for such MEMBERS OF THE PUBLIC, with the appropriate occupancy factors, shall be given in the ODCM. The specified release rate limits restrict, at all times, the corresponding gamma and beta dose rates above background to a MEMBER OF THE PUBLIC at or beyond the SITE BOUNDARY to less than or equal to 500 mrem/year to the whole body or to less than or equal to 3000 mrem/year to the skin. These release rate limits also restrict, at all times, the corresponding thyroid dose rate above background to a child via the inhalation pathway to less than or equal to 1500 mrem/year.

The required detection capabilities for radioactive materials in gaseous waste samples are tabulated in terms of the lower limits of detection (LLD's).

The requirement for additional sampling of the Unit Vent following a reactor power transient is provided to ensure that the licensee is aware of and properly accounts for any increases in the release of gaseous effluents due to spiking which may occur as a result of the power transient. Monitoring the Unit Vent for increased noble gas activity is appropriate because it is the release point for any increased activity which may result from the power transient.

Since the escape rate coefficients for the noble gas nuclides is equal to or greater than the escape rate coefficient for iodine and the particulate nuclides*,** , it is reasonable to assume that the RCS spiking behavior of the noble gas nuclides is similar to that of the particulate and iodine nuclides. Considering the effects of iodine and particulate partitioning, plateout on plant and ventilation system surfaces, and the 99% efficiency of the Unit Vent HEPA filters and charcoal absorbers, it is reasonable to assume that the relative concentrations of the noble gas nuclides will be much greater than those of the iodine and particulate nuclides. Therefore, an increase in the iodine and particulate RCS activity is not an appropriate indicator of an increase in the Unit Vent activity, and it is appropriate to monitor the Unit Vent effluent activity as opposed to the RCS activity as an indicator of the need to perform post-transient sampling. In addition, it is appropriate to monitor the noble gas activity due to its relatively greater concentration in the Unit Vent.

* Cohen, Paul, Water Coolant Technology of Power Reactors, Table 5.19, page 198. American Nuclear Society. 1980.

** NUREG-0772, "Technical Bases for Estimating Fission Product Behavior During LWR Accidents", Silberberg, M., editor, USNRC; Figure 4.3, page 4.22. June, 1981.

16.11.2.2 DOSE - NOBLE GASES LIMITING CONDITION OF OPERATION

(ODCM 9.7.1)

The air dose due to noble gases released in gaseous effluents, from each unit, to areas at and beyond the SITE BOUNDARY (see [Figure 16.11-2](#)) shall be limited to the following:

During any calendar quarter: Less than or equal to 5 mrad for gamma radiation and less than or equal to 10 mrad for beta radiation, and

During any calendar year: Less than or equal to 10 mrad for gamma radiation and less than or equal to 20 mrad for beta radiation.

APPLICABILITY: At all times.

ACTION:

With the calculated air dose from radioactive noble gases in gaseous effluents exceeding any of the above limits, prepare and submit to the Commission within 30 days a Special Report that identifies the cause(s) for exceeding the limit(s) and defines the corrective actions that have been taken to reduce the releases and the proposed corrective actions to be taken to assure that subsequent releases will be in compliance with the above limits.

16.11.2.2.1 SURVEILLANCE REQUIREMENTS

(ODCM 9.7.2)

Cumulative dose contributions for the current calendar quarter and current calendar year for noble gases shall be determined in accordance with the methodology and parameters in the ODCM at least once per 31 days.

16.11.2.2.2 BASES

This section is provided to implement the requirements of Sections II.B, III.A, and IV.A of Appendix I, 10 CFR Part 50. The Limiting Condition for Operation implements the guides set forth in Section II.B of Appendix I. The ACTION statement provides the required operating flexibility and at the same time implement the guides set forth in Section IV.A of Appendix I to assure that the releases of radioactive material in gaseous effluents to UNRESTRICTED AREAS will be kept "as low as is reasonably achievable".

The Surveillance Requirements implement the requirements in Section III.A of Appendix I that conformance with the guides of Appendix I be shown by calculational procedures based on models and data such that the actual exposure of a MEMBER OF THE PUBLIC through appropriate pathways is unlikely to be substantially underestimated. The dose calculation methodology and parameters established in the ODCM for

calculating the doses due to the actual release rates of radioactive noble gases in gaseous effluents are consistent with the methodology provided in Regulatory Guide 1.109, "Calculation of Annual Doses to Man from Routine Releases on Reactor Effluents for the Purpose of Evaluating Compliance with 10 CFR Part 50, Appendix I", Revision 1, October 1977 and Regulatory Guide 1.111, "Methods for Estimating Atmospheric Transport and Dispersion of Gaseous Effluents in Routine Releases from Light-Water Cooled Reactors", Revision 1, July 1977. The ODCM equations provided for determining the air doses at and beyond the SITE BOUNDARY are based upon the historical average atmospheric conditions.

The reporting requirements of Action(a) implement the requirements of 10CFR20.2203.

16.11.2.3 DOSE - IODINE-131 AND 133, TRITIUM, AND RADIOACTIVE MATERIAL IN PARTICULATE FORM LIMITING CONDITION OF OPERATION

(ODCM 9.8.1)

The dose to a MEMBER OF THE PUBLIC from Iodine-131 and 133, tritium, and all radionuclides in particulate form with half-lives greater than 8 days in gaseous effluents released, from each unit, to areas at and beyond the SITE BOUNDARY (see **Figure 16.11-2**) shall be limited to the following:

- a. During any calendar quarter: Less than or equal to 7.5 mrem to any organ, and
- b. During any calendar year: Less than or equal to 15 mrem to any organ.

APPLICABILITY: At all times.

ACTION:

With the calculated dose from the release of Iodine-131 and 133, tritium, and radionuclides in particulate form with half-lives greater than 8 days, in gaseous effluents exceeding any of the above limits, prepare and submit to the Commission within 30 days a Special Report that identifies the cause(s) for exceeding the limits and defines the corrective actions that have been taken to reduce the releases and the proposed corrective actions to be taken to assure that subsequent releases will be in compliance with the above limits.

16.11.2.3.1 SURVEILLANCE REQUIREMENTS

(ODCM 9.8.2)

Cumulative dose contributions for the current calendar quarter and current calendar year for Iodine-131 and 133, tritium, and radionuclides in particulate form with half-lives greater than 8 days shall be determined in accordance with the methodology and parameters in the ODCM at least once per 31 days.

16.11.2.3.2 BASES

This section is provided to implement the requirements of Sections II.C, III.A, and IV.A of Appendix I, 10 CFR Part 50. The Limiting Conditions for Operation are the guides set forth in Section II.C of Appendix I. The ACTION statements provide the required operating flexibility and at the same time implement the guides set forth in Section IV.A of Appendix I to assure that the release of radioactive material in gaseous effluents to UNRESTRICTED AREAS will be kept "as low as reasonably achievable". The ODCM calculational methods specified in the Surveillance Requirements implement the requirements in Section III.A of Appendix I that conformance with the guides of Appendix I be shown by calculational procedures based on models and data such that the actual exposure of a MEMBER OF THE PUBLIC through appropriate pathways is unlikely to be

substantially underestimated. The ODCM calculational methodology and parameters for calculating the doses due to the actual release rates of the subject materials are consistent with the methodology provided in Regulatory Guide 1.109, "Calculation of Annual Doses to Man from Routine Releases of Reactor Effluents for the Purpose of Evaluating Compliance with 10 CFR Part 50, Appendix I", Revision 1, October 1977 and Regulatory Guide 1.111, "Methods for Estimating Atmospheric Transport and Dispersion of Gaseous Effluents in Routine Releases from Light-Water Cooled Reactors", Revision 1, July 1977. These equations also provide for determining the actual doses based upon the historical average atmospheric conditions. The release rate controls for Iodine-131, and 133, tritium, and radionuclides in particulate form with half-lives greater than 8 days are dependent upon the existing radionuclide pathways to man, in the areas at and beyond the SITE BOUNDARY. The pathways that were examined in the development of these calculations were: (1) individual inhalation of airborne radionuclides, (2) deposition of radionuclides onto green leafy vegetation with subsequent consumption by man, (3) deposition of radionuclides onto grassy areas where milk animals and meat-producing animals graze with consumption of the milk and meat by man, and (4) deposition on the ground with subsequent exposure of man.

The reporting requirements of Action(a) implement the requirements of 10CFR20.2203.

16.11.2.4 RADIOACTIVE GASEOUS EFFLUENT MONITORING INSTRUMENTATION LIMITING CONDITION FOR OPERATION

(ODCM 9.2.1)

The radioactive gaseous effluent monitoring instrumentation channels shown in [Table 16.11-5](#) shall be FUNCTIONAL with their Alarm/Trip Setpoints set to ensure that the limits of [Section 16.11.2.1](#) are not exceeded. The Alarm/Trip Setpoints of these channels meeting [Section 16.11.2.1](#) shall be determined and adjusted in accordance with the methodology and parameters in the ODCM.

APPLICABILITY: As shown in [Table 16.11-5](#).

ACTION:

- a. With a radioactive gaseous effluent monitoring instrumentation channel Alarm/Trip Setpoint less conservative than required by the above, immediately declare the channel non-functional.
- b. With less than the minimum number of radioactive gaseous effluent monitoring instrumentation channels FUNCTIONAL, take the ACTION shown in [Table 16.11-5](#). Restore the non-functional instrumentation to FUNCTIONAL status within the time specified in the ACTION, or explain in the next Radioactive Effluent Release Report, pursuant to Technical Specification 5.6.3, why this non-functionality was not corrected within the time specified.

16.11.2.4.1 SURVEILLANCE REQUIREMENTS

(ODCM 9.2.2)

Each radioactive gaseous effluent monitoring instrumentation channel shall be demonstrated FUNCTIONAL by performance of the CHANNEL CHECK, SOURCE CHECK, CHANNEL CALIBRATION and CHANNEL OPERATIONAL TEST at the frequencies shown in [Table 16.11-6](#).

16.11.2.4.2 BASES

The radioactive gaseous effluent monitoring instrumentation is provided to monitor and control, as applicable, the releases of radioactive materials in gaseous effluents during actual or potential releases of gaseous effluents. The Alarm/Trip Setpoints for these instruments shall be calculated and adjusted in accordance with the methodology and parameters in the ODCM to ensure that the alarm/trip will occur prior to exceeding the limits of 10 CFR Part 20. The FUNCTIONALITY and use of this instrumentation is consistent with the requirements of General Design Criteria 60, 63, and 64 of Appendix A to 10 CFR Part 50. The sensitivity of any noble gas activity monitor used to show compliance with the gaseous effluent release requirements of [Section 16.11.2.1](#) shall be such that concentrations as low as 1×10^{-6} $\mu\text{Ci/cc}$ are measurable.

The monitors GT-RE-22 and GT-RE-33 are only required for automatic containment purge isolation in MODES 1 through 4. For plant conditions during CORE ALTERATIONS and during movement of irradiated fuel within containment, the function of the monitors is to alarm only and the trip signals for automatic actuation of CPIS may be bypassed. Based on the guidance provided in Regulatory Guide 1.97 concerning monitoring requirements for containment or purge effluent, the monitors GT-RE-22 and GT-RE-33 do not need to meet the single failure criterion for an Alarm function only during CORE ALTERATIONS or during movement of irradiated fuel in containment. One instrumentation channel at a minimum is required for the alarm only function during refueling activities.

In the event that the containment mini-purge supply and exhaust valves have been closed to satisfy Action 41 of **Table 16.11-5** due to non-functionality of GTRE0022 and/or GTRE0033, an allowance is provided in Action 41 to open the containment mini-purge supply and exhaust valves under administrative controls for the purpose of equalizing containment pressure. The administrative controls consist of designating a control room operator to rapidly close the valves when a need for system isolation is indicated.

16.11.2.5 GASEOUS RADWASTE TREATMENT SYSTEM LIMITING CONDITION OF OPERATION

(ODCM 9.9.1)

The VENTILATION EXHAUST TREATMENT SYSTEM and the WASTE GAS HOLDUP SYSTEM shall be FUNCTIONAL and appropriate portions of these systems shall be used to reduce releases of radioactivity when the projected doses in 31 days due to gaseous effluent releases, from each unit, to areas at and beyond the SITE BOUNDARY (see [Figure 16.11-2](#)) would exceed:

- a. 0.2 mrad to air from gamma radiation, or
- b. 0.4 mrad to air from beta radiation, or
- c. 0.3 mrem to any organ of a MEMBER OF THE PUBLIC.

APPLICABILITY: At all times

ACTION:

With radioactive gaseous waste being discharged without treatment and in excess of the above limits, prepare and submit to the Commission within 30 days a Special Report that includes the following information:

- 1) Identification of any non-functional equipment or subsystems, and the reason for the non-functionality,
- 2) Action(s) taken to restore the non-functional equipment to FUNCTIONAL status, and
- 3) Summary description of action(s) taken to prevent a recurrence.

16.11.2.5.1 SURVEILLANCE REQUIREMENTS

(ODCM 9.9.2)

16.11.2.5.1.a

Doses due to gaseous releases to areas at and beyond the SITE BOUNDARY shall be projected at least once per 31 days in accordance with the methodology and parameters in the ODCM.

16.11.2.5.1.b

The installed VENTILATION EXHAUST TREATMENT SYSTEM and the WASTE GAS HOLDUP SYSTEMS shall be considered FUNCTIONAL by meeting Sections 16.11.2.1 and 16.11.2.2 or 16.11.2.3.

16.11.2.5.2 BASES

The FUNCTIONALITY of the WASTE GAS HOLDUP SYSTEM and the VENTILATION EXHAUST TREATMENT SYSTEM ensures that the system will be available for use whenever gaseous effluents require treatment prior to release to the environment. The requirement that the appropriate portions of these systems be used, when specified, provides reasonable assurance that the releases of radioactive materials in gaseous effluents will be kept "as low as is reasonably achievable." This control implements the requirements of 10 CFR Part 50.36a, General Design Criterion 60 of Appendix A to 10 CFR Part 50, and the design objectives given in Section II.D of Appendix I to 10 CFR Part 50. The specified limits governing the use of appropriate portions of the systems were specified as a suitable fraction of the dose design objectives set forth in Sections II.B and II.C of Appendix I, 10 CFR Part 50, for gaseous effluents.

16.11.2.6 EXPLOSIVE GAS MIXTURE LIMITING CONDITION FOR OPERATION

The concentration of oxygen in the WASTE GAS HOLDUP SYSTEM shall be limited to less than or equal to 3% by volume whenever the hydrogen concentration exceeds 4% by volume.

APPLICABILITY: At all times.

ACTION:

- a. With the concentration of oxygen in the WASTE GAS HOLDUP SYSTEM greater than 3% by volume but less than or equal to 4% by volume, reduce the oxygen concentration to the above limit within 48 hours.
- b. With the concentration of oxygen in the WASTE GAS HOLDUP SYSTEM greater than 4% by volume and the hydrogen concentration greater than 4% by volume, immediately suspend all additions of waste gases to the system and reduce the concentration on oxygen to less than or equal to 4% by volume, then take ACTION a. above.

16.11.2.6.1 SURVEILLANCE REQUIREMENTS

The concentrations of hydrogen and oxygen in the WASTE GAS HOLDUP SYSTEM shall be determined to be within the above limits by continuously monitoring the waste gases in the WASTE GAS HOLDUP SYSTEM with the hydrogen and oxygen monitors required FUNCTIONAL by [Section 16.11.2.7](#). This system is covered by Technical Specification 5.5.12 which governs surveillance test frequencies and missed surveillances.

16.11.2.6.2 BASES

This Requirement is provided to ensure that the concentration of potentially explosive gas mixtures contained in the WASTE GAS HOLDUP SYSTEM is maintained below the flammability limits of hydrogen and oxygen. Automatic control features are included in the system to prevent the hydrogen and oxygen concentrations from reaching these flammability limits. These automatic control features include isolation of the source of hydrogen and/or oxygen. Maintaining the concentration of hydrogen and oxygen below their flammability limits provides assurance that the releases of radioactive materials will be controlled in conformance with the requirements of General Design Criterion 60 of Appendix A to 10 CFR Part 50.

16.11.2.7 WASTE GAS HOLDUP SYSTEM RECOMBINER EXPLOSIVE GAS MONITORING INSTRUMENTATION LIMITING CONDITION FOR OPERATION

At least one hydrogen and both the inlet and outlet oxygen explosive gas monitoring instrument channels for each WASTE GAS HOLDUP SYSTEM recombinaer shall be FUNCTIONAL with their Alarm/Trip Setpoints (with the exception of the "FEED H2 4%/FEED O2 3%" and "FEED H2 4%/FEED O2 4%" alarms) set to ensure that the limits of [Section 16.11.2.6](#) are not exceeded.

APPLICABILITY: During WASTE GAS HOLDUP SYSTEM operation.

ACTION:

- a. With an outlet oxygen monitor channel non-functional, operation of the system may continue provided grab samples are taken and analyzed at least once per 24 hours.
- b. With both oxygen or both hydrogen channels or both the inlet oxygen and inlet hydrogen monitor channels for one recombinaer non-functional, suspend oxygen supply to the recombinaer. Addition of waste gas to the system may continue provided grab samples are taken and analyzed at least: 1) once per 4 hours during mechanical or chemical degassing in preparation for plant shutdown, and 2) once per 24 hours during other operations.
- c. With the inlet oxygen analyzer non-functional, operation of the system may continue provided the inlet hydrogen is maintained less than 4%. If inlet hydrogen is greater than 4%, suspend oxygen to the recombinaer. Addition of waste gas to the system may continue provided grab samples are taken and analyzed at least: 1) once per 4 hours during mechanical or chemical degassing operations in preparation for plant shutdown, and 2) once per 24 hours during other operations.

16.11.2.7.1 SURVEILLANCE REQUIREMENTS

This system is covered by Technical Specification 5.5.12 which governs surveillance test frequencies and missed surveillances.

Each waste gas holdup system recombinaer explosive gas monitoring instrumentation channel shall be demonstrated FUNCTIONAL by performance of:

- a. A CHANNEL CHECK at least once per 24 hours,
- b. Not used

- c. A CHANNEL CALIBRATION at least once per 92 days with the use of standard gas samples containing a nominal:
- 1) One volume percent hydrogen, balance nitrogen and four volume percent hydrogen, balance nitrogen for the hydrogen monitor, and
 - 2) One volume percent oxygen, balance nitrogen, and four volume percent oxygen, balance nitrogen for the inlet oxygen monitor, and
 - 3) 10 ppm by volume oxygen, balance nitrogen and 80 ppm by volume oxygen, balance nitrogen for the outlet oxygen monitor.

16.11.2.7.2 BASES

Mechanical 'degassing operation' is defined as the transfer of gas from the Volume Control Tank (VCT) to the Waste Gas Holdup System when establishing a nitrogen blanket on the VCT in preparation for a plant shutdown. Chemical 'degassing operation' is the process of adding hydrogen peroxide to the RCS after the VCT hydrogen blanket has been replaced with nitrogen per the mechanical degassification process and the RCS has been reduced to less than 180°F. Both mechanical and chemical degassification may lead to an explosive gas mixture in the Waste Gas Holdup System, thus requiring the more restrictive 4-hour sampling. Other operations require 24-hour sampling.

The "FEED H₂ 4%/FEED O₂ 3%" AND "FEED H₂ 4%/FEED O₂ 4%" alarms are not required to be FUNCTIONAL. These alarms result from the combination of inlet hydrogen and inlet oxygen analyzer outputs while the FSAR only addresses FUNCTIONALITY of each separate analyzer. Only the individual alarms and control functions associated with each analyzer are to be used to determine its functionality. These alarms and control functions are sufficient to ensure that the limits of **Section 16.11.2.6** are not exceeded.

The CHANNEL CALIBRATION includes triggering the following alarms at the analyzer and verifying that the required control board annunciators and control functions actuate:

- 1) Feed Gas High H₂
- 2) HARC-1104 OAIC-1112 Hi Hi H₂/O₂ O₂ Shutdown
- 3) H₂ Reactor High Oxygen O₂ Limit
- 4) Product Gas High H₂
- 5) Product Gas High Oxygen

6) Product Gas Hi Hi O₂ Shutdown

This surveillance verifies the FUNCTIONALITY of the analyzers' output relays, all interposing relays, and the annunciators. Setpoint verification consists of verifying that the correct setpoint values are entered in the analyzers' database.

16.11.2.8 GAS STORAGE TANKS LIMITING CONDITION FOR OPERATION

The quantity of radioactivity contained in each gas storage tank shall be limited to less than or equal to 2.5×10^5 Curies of noble gases (considered as Xe-133 equivalent).

APPLICABILITY: At all times.

ACTION:

With the quantity of radioactive material in any gas storage tank exceeding the above limit, immediately suspend all additions of radioactive material to the tank and, within 48 hours, reduce the tank contents to within the limit, and describe the events leading to this condition in the next Radioactive Effluent Release Report, pursuant to Technical Specification 5.6.3.

16.11.2.8.1 SURVEILLANCE REQUIREMENTS

The provisions of **Sections 16.0.2.2** and **16.0.2.3** are applicable, however the allowed surveillance interval extension beyond 25% shall not be exceeded. This system is also covered by Administrative Controls Section 5.5.12 of the plant Technical Specifications.

The quantity of radioactive material contained in each gas storage tank shall be determined to be within the above limit at least once per 18 months.

16.11.2.8.2 BASES

The tanks included in this Requirement are those tanks for which the quantity of radioactivity contained is not limited directly or indirectly by another Requirement. Restricting the quantity of radioactivity contained in each gas storage tank provides assurance that in the event of an uncontrolled release of the tank's contents, the resulting whole body exposure to a MEMBER OF THE PUBLIC at the nearest SITE BOUNDARY will not exceed 0.5 rem. This is consistent with Standard Review Plan 11.3, Branch Technical Position ETSB 11-5, "Postulated Radioactive Releases Due to a Waste Gas System Leak or Failure," in NUREG-0800, July 1981. The determination of Xe-133 equivalent uses the effective dose conversion factors for air submersion listed in Table III.1 of EPA Federal Guidance Report No. 12, EPA-402-R-93-081, "External Exposure to Radionuclides in Air, Water, and Soil," 1993.

16.11.3 TOTAL DOSE

16.11.3.1 TOTAL DOSE LIMITING CONDITION FOR OPERATION

(ODCM 9.10.1)

The annual (calendar year) dose or dose commitment to any MEMBER OF THE PUBLIC due to releases of radioactivity and to radiation from uranium fuel cycle sources shall be limited to less than or equal to 25 mrem to the whole body or any organ, except the thyroid, which shall be limited to less than or equal to 75 mrem.

APPLICABILITY: At all times.

ACTION:

With the calculated doses from the release of radioactive materials in gaseous effluents exceeding twice the limits of [Section 16.11.2.2a](#), [16.11.2.2b](#), [16.11.2.3a](#), or [16.11.2.3b](#), calculations should be made including direct radiation contributions from the units and from outside storage tanks to determine whether the above limits of [Section 16.11.3.1](#) have been exceeded. If such is the case, prepare and submit to the Commission within 30 days a Special Report that defines the corrective action to be taken to reduce subsequent release to prevent recurrence of exceeding the above limits and includes the schedule for achieving conformance with the above limits. This Special Report, as defined in 10 CFR 20.2203, shall include an analysis that estimates the radiation exposure (dose) to a MEMBER OF THE PUBLIC from uranium fuel cycle sources, including all effluent pathways and direct radiation, for the calendar year that includes the release(s) covered by this report. It shall also describe levels of radiation and concentrations of radioactive material involved, and the cause of the exposure levels or concentrations. If the estimated dose(s) exceeds the above limits, and if the release condition resulting in violation of 40 CFR Part 190 has not already been corrected, the Special Report shall include a request for a variance in accordance with the provisions of 40 CFR Part 190. Submittal of the report is considered a timely request, and a variance is granted until staff action on the request is complete.

16.11.3.1.1 SURVEILLANCE REQUIREMENTS

(ODCM 9.10.2)

16.11.3.1.1.a

Cumulative dose contributions from gaseous effluents shall be determined in accordance with [Sections 16.11.2.2.1](#), and [16.11.2.3.1](#), and in accordance with the methodology and parameters in the ODCM.

16.11.3.1.1.b

Cumulative dose contributions from direct radiation from the units and from radwaste storage tanks shall be determined in accordance with the methodology and parameters in the ODCM. This requirements is applicable only under conditions set forth in ACTION a. of [Section 16.11.3.1](#).

16.11.3.1.2 BASES

This Requirement is provided to meet the dose limitations of 40 CFR Part 190 that have been incorporated into 10 CFR Part 20.1301. The control requires the preparation and submittal of a Special Report whenever the calculated doses due to releases of radioactivity and the radiation from uranium fuel cycle sources exceed 25 mrem to the whole body or any organ except the thyroid, which shall be limited to less than or equal to 75 mrem. For sites containing up to four reactors, it is highly unlikely that the resultant dose to a MEMBER OF THE PUBLIC will exceed the dose limits of 40 CFR Part 190 if the individual reactors remain within twice the dose design objectives of Appendix I, and if direct radiation doses from the reactor units and from outside storage tanks are kept small. The Special Report will describe a course of action that should result in the limitation of the annual dose to a MEMBER OF THE PUBLIC to within the 40 CFR Part 190 limits.

For the purposes of the Special Report, it may be assumed that the dose commitment to the MEMBER OF THE PUBLIC from other uranium fuel cycle sources is negligible, with the exception that dose contributions from other nuclear fuel cycle facilities at the same site or within a radius of 8 km must be considered. If the dose to any MEMBER OF THE PUBLIC is estimated to exceed the requirements of 40 CFR Part 190, the Special Report with a request for a variance (provided the release conditions resulting in violation of 40 CFR Part 190 have not already been corrected), in accordance with the provisions of 40 CFR Part 190.11 and 10 CFR 20.2203, is considered to be a timely request and fulfills the requirements of 40 CFR Part 190 until NRC staff action is completed. The variance only relates to 40 CFR Part 190, and does not apply in any way to the other requirements for dose limitation of 10 CFR Part 20, as addressed in [Sections 16.11.1.1](#) and [16.11.2.1](#). An individual is not considered a MEMBER OF THE PUBLIC during any period in which he/she is engaged in carrying out any operation that is part of the nuclear fuel cycle.

There are three defined effluent release categories: 1.) Releases directly to the hydrosphere; 2.) noble gas releases to the atmosphere; 3.) radioiodine and particulate releases to the atmosphere. For each effluent release category, it is assumed in the dose calculations that an individual with the highest dose potential is the receptor. In general, the adult is considered to be the critical age group for liquid effluents, and the child age group is the most limiting for radioiodine and particulates in gaseous effluents. Thus, it is highly unlikely or impossible for the same individual to simultaneously receive the highest dose via all three effluent categories. For most reactor sites, it is also unlikely that all different potential dose pathways would contribute to the dose to a single real individual. Since it is difficult or impossible to continually determine actual food use patterns and critical age group, for calculational purposes, assumptions are made which tend to maximize doses. Any refinement in the assumptions would have the effect of

reducing the estimated dose. For radionuclides released to the hydrosphere, the degree of overestimation in most situations is such that no individual will receive a significant dose. These conservative assumptions generally result in an overestimation of dose by one or two orders of magnitude. Since these assumptions are reflected in the Radiological Effluent Controls limiting radionuclide releases to design objective individual doses, no offsite individual is likely to actually receive a significant dose. Since the doses from liquid releases are very conservatively evaluated, there is reasonable assurance that no real individual will receive a significant dose from radioactive liquid release pathway. Therefore, only doses to individuals via airborne pathways and dose resulting from direct radiation need to be considered in determining potential compliance to 40 CFR 190*.

The reporting requirements of Action(a) implement the requirements of 10CFR20.2203.

* NUREG-0543, "Methods for Demonstrating LWR compliance with the EPA Uranium Fuel Cycle Standard (40 CFR 190)", Congel, F. J., Office of Nuclear Reactor Regulation, USNRC. January, 1980. pp. 5-8.

16.11.4 RADIOLOGICAL ENVIRONMENTAL MONITORING

16.11.4.1 MONITORING PROGRAM LIMITING CONDITION OF OPERATION

(ODCM 9.11.1)

The Radiological Environmental Monitoring Program shall be conducted as specified in [Table 16.11-7](#).

APPLICABILITY: At all times.

ACTION:

- a. With the Radiological Environmental Monitoring Program not being conducted as specified in [Table 16.11-7](#), prepare and submit to the Commission, in the Annual Radiological Environmental Operating Report required by Technical Specification 5.6.2, a description of the reasons for not conducting the program as required and the plans for preventing a recurrence.
- b. With the level of radioactivity as the result of plant effluents in an environmental sampling medium at a specified location exceeding the reporting levels of [Table 16.11-8](#) when averaged over any calendar quarter, prepare and submit to the Commission within 30 days a Special Report that identifies the cause(s) for exceeding the limit(s) and defines the corrective actions to be taken to reduce radioactive effluents so that the potential annual dose* to a MEMBER OF THE PUBLIC is less than the calendar year limits of [Sections 16.11.1.2](#), [16.11.2.2](#), or [16.11.2.3](#). When more than one of the radionuclides in [Table 16.11-8](#) are detected in the sampling medium, this report shall be submitted if:

$$\frac{\text{concentration (1)}}{\text{reporting level (1)}} + \frac{\text{concentration (2)}}{\text{reporting (2)}} + \dots \geq 1.0$$

When radionuclides other than those in [Table 16.11-8](#) are detected and are the result of plant effluents, this report shall be submitted if the potential annual dose* to A MEMBER OF THE PUBLIC from all radionuclides is equal to or greater than the calendar year limits of [Sections 16.11.1.2](#), [16.11.2.2](#) or [16.11.2.3](#). This report is not required if the measured level of radioactivity was not the result of plant effluents; however, in such an event, the condition shall be reported and described in the Annual Radiological Environmental Operating Report, required by Technical Specification 5.6.2.

- c. With milk or fresh leafy vegetable samples unavailable from one or more of the sample locations required by [Table 16.11-7](#), identify specific locations for

* The methodology and parameters used to estimate the potential annual dose to a MEMBER OF THE PUBLIC shall be indicated in this report.

obtaining replacement samples and add them within 30 days to the Radiological Environmental Monitoring Program*. The specific locations from which samples were unavailable may then be deleted from the monitoring program. In the next Annual Radiological Environmental Operating Report include the revised figure(s) and tables reflecting the new sample location(s) with supporting information identifying the cause of the unavailability of samples and justifying the selection of new location(s) for obtaining samples.

- d. When LLDs specified in **Table 16.11-9** are unachievable due to uncontrollable circumstances such as background fluctuations, unavailable small sample sizes, the presence of interfering nuclides, etc., the contributing factors shall be identified and described in the Annual Radiological Environmental Operating Report.

16.11.4.1.1 SURVEILLANCE REQUIREMENTS

(ODCM 9.11.2)

The radiological environmental monitoring samples shall be collected pursuant to **Table 16.11-7** and shall be analyzed pursuant to the requirements of **Table 16.11-7** and the detection capabilities required by **Table 16.11-9**.

16.11.4.1.2 BASES

The Radiological Environmental Monitoring Program provides representative measurements of radiation and of radioactive materials in those exposure pathways and for those radionuclides that lead to the highest potential radiation exposures of MEMBERS OF THE PUBLIC resulting from the station operation. This monitoring program implements Section IV.B.2 of Appendix I to 10 CFR Part 50 and thereby supplements the Radiological Effluent Monitoring Program by verifying that the measurable concentrations of radioactive materials and levels of radiation are not higher than expected on the basis of the effluent measurements and the modeling of the environmental exposure pathways. Guidance for the initial monitoring program was provided by the Radiological Assessment Branch Technical Position on Environmental Monitoring, Revision 1, November 1979.

The required detection capabilities for environmental sample analyses are tabulated in terms of the lower limits of detection (LLD's). The LLD's required by **Table 16.11-9** are considered optimum for routine environmental measurements in industrial laboratories.

* Excluding short term or temporary unavailability.

16.11.4.2 LAND USE CENSUS LIMITING CONDITION OF OPERATION

(ODCM 9.12.1)

A Land Use Census shall be conducted and shall identify within a distance of 8 km (5 miles) the location in each of the 16 meteorological sectors of the nearest milk animal, the nearest residence and the nearest garden* of greater than 50 m² (500 ft²) producing broad leaf vegetation. The Land Use Census shall identify water intakes constructed within 10 river miles downstream of the plant discharge point.

APPLICABILITY: At all times.

ACTION:

- a. With a Land Use Census identifying a location(s) that yields a calculated dose or dose commitment greater than the values currently being calculated by **Section 16.11.2.3.1**, identify the new location(s) in the next Radioactive Effluent Release Report, pursuant to Technical Specification 5.6.3.
- b. With a Land Use Census identifying a location(s) that yields a calculated dose or dose commitment (via the same exposure pathway) 20% greater than at a location from which samples are currently being obtained in accordance with **Section 16.11.4.1**, add the new location(s) within 30 days to the Radiological Environmental Monitoring Program except for vegetation samples which shall be added to the program before the next growing season. The sampling location(s), excluding the control station location, having the lowest calculated dose or dose commitment(s), via the same exposure pathway, may be deleted from this monitoring program after October 31 of the year in which this Land Use Census was conducted. In the next Annual Radiological Environmental Operating Report include the revised figure(s) and tables reflecting the new sample location(s) with information supporting the change in sample location.
- c. With a Land Use Census identifying a water intake within 10 river miles downstream of the plant discharge point, implement the appropriate waterborne or ingestion sampling required by **Table 16.11-7**.

* Broad leaf vegetation sampling of at least three different kinds of vegetation may be performed at the SITE BOUNDARY in each to two different direction sectors with the highest predicted D/Q's in lieu of the garden census. Requirements for broad leaf vegetation sampling in Table 16.11-7, Part 4.c shall be followed, including analysis of control samples.

16.11.4.2.1 SURVEILLANCE REQUIREMENTS

(ODCM 9.12.2)

The Land Use Census shall be conducted during the growing season at least once per 12 months using that information which will provide the best results, such as, but not limited to, door-to-door survey, aerial survey, or by consulting local agriculture authorities and/or residents. The results of the Land Use Census shall be included in the Annual Radiological Environmental Operating Report pursuant to Technical Specification 5.6.2.

16.11.4.2.2 BASES

This Requirement is provided to ensure that changes in the use of areas at and beyond the SITE BOUNDARY are identified and that modifications to the Radiological Environmental Monitoring Program given in the ODCM are made if required by the results of this census. Information that will provide the best results, such as door-to-door survey, aerial survey, or consulting with local agricultural authorities, shall be used. This census satisfies the requirements of Section IV.B.3 of Appendix I to 10 CFR Part 50.

Restricting the census to gardens of greater than 50 m² provides assurance that significant exposure pathways via leafy vegetables will be identified and monitored since a garden of this size is the minimum required to produce the quantity (26 kg/year) of leafy vegetables assumed in Regulatory Guide 1.109 for consumption by a child. To determine this minimum garden size, the following assumptions were made: (1) 20% of the garden was used for growing broad leaf vegetation (i.e., similar to lettuce and cabbage), and (2) a vegetation yield of 2 kg/m².

16.11.4.3 INTERLABORATORY COMPARISON PROGRAM LIMITING CONDITION OF OPERATION

(ODCM 9.13.1)

Analyses shall be performed on radioactive materials supplied as part of an Interlaboratory Comparison Program that has been approved by the USNRC.

APPLICABILITY: At all times.

ACTION:

With analyses not being performed as required above, report the corrective actions taken to prevent a recurrence to the Commission in the Annual Radiological Environmental Operating Report pursuant to Technical Specification 5.6.2.

16.11.4.3.1 SURVEILLANCE REQUIREMENTS

(ODCM 9.13.2)

The Interlaboratory Comparison Program shall be described in the plant procedures. A summary of the results obtained as part of the above required Interlaboratory Comparison Program shall be included in the Annual Radiological Environmental Operating Report pursuant to Technical Specification 5.6.2.

16.11.4.3.2 BASES

The requirement for participation in an approved Interlaboratory Comparison Program is provided to ensure that independent checks on the precision and accuracy of the measurements of radioactive material in environmental sample matrices are performed as part of the quality assurance program for environmental monitoring in order to demonstrate that the results are valid for the purpose of Section IV.B.2 of Appendix I to 10 CFR Part 50.

16.11.5 ADMINISTRATIVE CONTROLS

16.11.5.1 ANNUAL RADIOLOGICAL ENVIRONMENTAL OPERATING REPORT (ODCM 7.1)

Routine Annual Radiological Environmental Operating Report covering the operation of the unit during the previous calendar year shall be submitted prior to May 1 of each year.

The Annual Radiological Environmental Operating Report shall include summaries, interpretations, and an analysis of trends of the results of the radiological environmental surveillance activities for the report period, including a comparison with preoperational studies, with operational controls and with previous environmental surveillance reports, and an assessment of the observed impacts of the plant operation on the environment. The reports shall include the results of Land Use Census required by [Section 16.11.4.2](#). It shall also include a listing of new locations for environmental monitoring identified by the Land Use Census pursuant to [Section 16.11.4.2](#).

The Annual Radiological Environmental Operating Report shall include the results of analysis of all radiological environmental samples and of all environmental radiation measurements taken during the period pursuant to [Section 16.11.4.1](#), as well as summarized tabulated results of these analyses and measurements in the format of the table in the Radiological Assessment Branch Technical Position, Revision 1, November 1979. In the event that some individual results are not available for inclusion with the report, the report shall be submitted noting and explaining the reasons for the missing results. The missing data shall be submitted as soon as possible in a supplementary report. The reports shall also include the following: a summary description of the radiological environmental monitoring program; at least two legible maps* covering all sampling locations keyed to a table giving distances and directions from the midpoint between the two reactors; the results of licensee participation in the Interlaboratory Comparison Program and the corrective action being taken if the specified program is not being performed as required by [Section 16.11.4.3](#); reasons for not conducting the Radiological Environmental Monitoring Program as required by [Section 16.11.4.1](#) and discussion of all deviations from the sampling schedule of [Table 16.11-7](#), discussion of environmental sample measurements that exceed the reporting levels of [Table 16.11-8](#), but are not the result of the plant effluents, pursuant to [Section 16.11.4.1](#); and discussion of all analyses in which the LLD required by [Table 16.11-9](#) was not achievable.

16.11.5.1.1 BASES

The reporting requirement for the Annual Radiological Environmental Operating Report is provided to ensure compliance with Technical Specification 5.6.2. This requirement was relocated from the Offsite Dose Calculation Manual to FSAR Chapter 16.

* One map shall cover stations near the SITE BOUNDARY; a second shall include the more distant stations.

16.11.5.2 RADIOACTIVE EFFLUENT RELEASE REPORT

(ODCM 7.2)

Routine Radioactive Effluent Release Reports covering the operation of the unit during the previous calendar year shall be submitted prior to May 1 of each year.

The Radioactive Effluent Release Report shall include a summary of the quantities of radioactive liquid and gaseous effluents released from the unit as outlined in Regulatory Guide 1.21, "Measuring, Evaluating, and Reporting Radioactivity in Solid Wastes and Releases Gaseous Effluents from Light-Water-Cooled Nuclear Power Plants," Revision 1, June 1974, with data summarized on a quarterly basis in a format acceptable to the NRC.

The Radioactive Effluent Release Report shall include an annual summary of hourly meteorological data collected over the previous calendar year. This annual summary may be either in the form of an hour-by-hour listing on magnetic tape of wind speed, wind direction, atmospheric stability, and precipitation (if measured), or in the form of joint frequency distribution of wind speed, wind direction, and atmospheric stability* .

This report shall also include an assessment of the radiation doses due to the radioactive liquid and gaseous effluents released from the unit during the previous calendar year. This report shall also include an assessment of the radiation doses from radioactive liquid and gaseous effluents to MEMBERS OF THE PUBLIC due to their activities inside the SITE BOUNDARY (Figures 16.11-1 and 16.11-2) during the report period using historical average atmospheric conditions. All assumptions used in making these assessments, i.e., specific activity, exposure time and location, shall be included in these reports. The meteorological conditions concurrent with the time of release of radioactive materials in gaseous effluents, as determined by sampling frequency and measurement, shall be used for determining the gaseous pathway doses. Assessment of radiation doses shall be performed in accordance with the methodology and parameters in the OFFSITE DOSE CALCULATION MANUAL (ODCM).

The Radioactive Effluent Release Report shall include an assessment of radiation doses to the most likely exposed MEMBER OF THE PUBLIC from reactor releases and other nearby uranium fuel cycle sources, including doses from primary effluent pathways and direct radiation, for the previous calendar year to show conformance with 40 CFR Part 190, "Environmental Radiation Protection Standards for Nuclear Power Operation." Doses to the MEMBER OF THE PUBLIC shall be calculated using the methodology and parameters of the ODCM.

* In lieu of submission with the Annual Radioactive Effluent Release Report, Union Electric has the option of retaining this summary of required meteorological data on site in a file that shall be provided to the NRC upon request.

As required by 10 CFR 72.44(d)(3), an annual report shall be submitted to the Commission in accordance with 10 CFR 72.4, specifying the quantity of each of the principal radionuclides released to the environment in liquid and in gaseous effluents during the previous 12 months of operation. The report must be submitted within 60 days after the end of the 12-month monitoring period.

The Radioactive Effluent Release Report shall include a list and description of unplanned releases from the site to UNRESTRICTED AREAS of radioactive materials in gaseous and liquid effluents made during the reporting period.

The Radioactive Effluent Release Report shall include a summary description of any major changes made during the year to any Liquid or Gaseous Treatment Systems, pursuant to Offsite Dose Calculation Manual. It shall also include a listing of new locations for dose calculations identified by the Land Use Census pursuant to [Section 16.11.4.2](#).

Reporting requirements for changes to Solid Waste Treatment Systems are addressed in APA-ZZ-01011, PROCESS CONTROL PROGRAM (PCP).

The Radioactive Effluent Release Report shall also include the following information: An explanation as to why the liquid or gaseous effluent monitoring instrumentation was not restored to service within the time specified, and a description of the events leading the liquid holdup tanks or gas storage tanks exceeding the limits of [Section 16.11.1.5](#) or [16.11.2.8](#).

The Radioactive Effluent Release Report shall include as part of or submitted concurrent with, a complete and legible copy of all revisions of the ODCM that occurred during the year pursuant to Technical Specification 5.5.1.

Solid Waste reporting is addressed in APA-ZZ-01011, PROCESS CONTROL PROGRAM (PCP).

16.11.5.2.1 BASES

The reporting requirement for the Radioactive Effluent Release Report is provided to ensure compliance with Technical Specification 5.6.3. This requirement was relocated from the Offsite Dose Calculation Manual implementing procedure to FSAR Chapter 16.

In addition to the above reporting requirement, an annual report shall also be submitted in compliance with the HI-STORM UMAX Certificate of Compliance (CoC), Appendix A, Section 5.1

CALLAWAY - SP

TABLE 16.11-1 RADIOACTIVE LIQUID WASTE SAMPLING AND ANALYSIS PROGRAM

1. Discharge Monitor Tanks (Batch Release) (2)			
SAMPLING FREQUENCY(7)	MINIMUM ANALYSIS FREQUENCY	TYPE OF ACTIVITY ANALYSIS	LLD (1) (μCi/ml)
Prior to Each Batch	Prior to Each Batch	Principal Gamma Emitters (3)	5E-7
		I-131	1E-6
		Dissolved and Entrained Gases (Gamma Emitters)	1E-5
		H-3	1E-5
	Monthly Composite (4)	Gross Alpha	1E-7
	Quarterly Composite (4)	Sr-89, Sr-90	5E-8
		Fe-55	1E-6
		Ni-63	5E-8
		Np-237	5E-9
		Pu-238	5E-9
		Pu-239/240	5E-9
		Pu-241	5E-7
		Am-241	5E-9
		Cm-242	5E-9
		Cm-243/244	5E-9

TABLE NOTATIONS

- (1) The LLD is defined, for purposes of these Requirements, as the smallest concentration of radioactive material in a sample that will yield a net count, above system background, that will be detected with 95% probability with only 5% probability of falsely concluding that a blank observation represents a "real" signal.

For a particular measurement system, which may include radiochemical separation:

$$LLD = \frac{4.66 S_b}{E \times V \times 2.22E6 \times Y \times \exp(-\lambda \Delta t)}$$

Where:

- LLD = the "a priori" lower limit of detection (microCuries per unit mass or volume),
 S_b = the standard deviation of the background counting rate or of the counting rate of a blank sample as appropriate (counts per minute),
 E = the counting efficiency (counts per disintegration),
 V = the sample size (units of mass or volume),
 $2.22E6$ = the number of disintegrations per minute per microCurie,
 Y = the fractional radiochemical yield, when applicable,
 λ = the radioactive decay constant for the particular radionuclide (sec⁻¹), and
 Δt = the elapsed time between the midpoint of the sample collection period, and the time of counting (sec). For batch releases, $\Delta t=0$.

Typical values of E , V , Y , and Δt should be used in the calculation.

It should be recognized that the LLD is defined as a "a priori" (before the fact) limit representing the capability of a measurement system and not as an "a posteriori" (after the fact) limit for a particular measurement. Analyses shall be performed in such a manner that the stated LLD's will be achieved under routine conditions.

- (2) A batch release is the discharge of liquid wastes of a discrete volume. Prior to sampling for analyses, each batch shall be isolated, and then thoroughly mixed by a method described in the ODCM to assure representative sampling.
- (3) The principal gamma emitters for which the LLD control applies include the following radionuclides: Mn-54, Fe-59, Co-58, Co-60, Zn-65, Mo-99, Cs-134, Cs-137, Ce-141, and Ce-144. This list does not mean that only these nuclides are to be considered. Other gamma peaks that are identifiable, together with those of the above nuclides, shall also be analyzed and reported in the Radioactive Effluent Release Report pursuant to Technical Specification 5.6.3, in the format outlined in Regulatory Guide 1.21, Appendix B, Revision 1, June 1974.

CALLAWAY - SP

TABLE 16.11-1 (Sheet 2)

- (4) A composite sample is one in which the quantity of liquid sampled is proportional to the quantity of liquid waste discharged and in which the method of sampling employed results in a specimen that is representative of the liquids released. Prior to analysis, all samples taken for the composite shall be thoroughly mixed in order for the composite samples to be representative of the effluent release.
- (5) Deleted
- (6) Deleted
- (7) Samples shall be representative of the effluent release.

TABLE 16.11-2 RADIOACTIVE LIQUID EFFLUENT MONITORING
INSTRUMENTATION

	<u>INSTRUMENT</u>	<u>MINIMUM CHANNELS FUNCTIONAL</u>	<u>ACTION</u>
1.	Radioactivity Monitors Providing Alarm and Automatic Termination of Release		
a.	Liquid Radwaste Discharge Monitor (HB-RE-18)	1	31
b.	DELETED		
2.	Flow Rate Measurement Devices		
a.	Liquid Radwaste Blowdown Discharge Line (HB-FE-2017)	1	34
b.	Steam Generator Blowdown Discharge Line (BM-FE-0054)	1	34
c.	Cooling Tower Blowdown and Bypass Flow Totalizer (FYDB1017A)	1	34
3.	Discharge Monitoring Tanks (DMT's) Level		
a.	DMT A (HB-LI-2004)	1	33
b.	DMT B (HB-LI-2005)	1	33

ACTION STATEMENTS

ACTION 31 - With the number of channels FUNCTIONAL less than required by the Minimum Channels FUNCTIONAL requirement, effluent releases via this pathway may continue provided that prior to initiating a release:

- a. At least two independent samples are analyzed in accordance with **Section 16.11.1.1.1**, and
- b. At least two technically qualified members of the facility staff independently verify the release rate calculations and discharge line valving.

Otherwise, suspend release of radioactive effluents via this pathway.

TABLE 16.11-2 (Sheet 2)

ACTION STATEMENTS

ACTION 32 - DELETED

ACTION 33 - With the number of channels FUNCTIONAL less than required by the Minimum Channels FUNCTIONAL requirement, effluent releases via this pathway may continue provided the volume discharged is determined by alternate means.

ACTION 34 - With the number of channels FUNCTIONAL less than required by the Minimum Channels FUNCTIONAL requirement, effluent releases via this pathway may continue provided the flow rate is estimated at least once per 4 hours during actual releases. Pump performance curves generated in place may be used to estimate flow.

TABLE 16.11-3 RADIOACTIVE LIQUID EFFLUENT MONITORING
INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>INSTRUMENT</u>	<u>CHANNEL CHECK</u>	<u>SOURCE CHECK</u>	<u>CHANNEL CALIBRATION</u>	<u>CHANNEL OPERATIONAL TEST</u>
1. Radioactivity Monitors Providing Alarm and Automatic Termination of Release				
a. Liquid Radwaste Discharge Monitor (HB-RE-18)	D	P	R(2)	Q(1)
b. DELETED				
2. Flow Rate Measurement Devices				
a. Liquid Radwaste Blowdown Discharge Line (HB-FE-2017)	D(3)	N.A.	R	N.A.
b. DELETED				
c. Cooling Tower Blowdown and Bypass Flow Totalizer (FYDB1017A)	D(3)	N.A.	R	N.A.
3. Discharge Monitoring Tanks (DMT's) Level				
a. DMT A(HB-LI-2004)	Prior to release (4)	N.A.	R	N.A.
b. DMT B(HB-LI-2005)	Prior to release (4)	N.A.	R	N.A.

TABLE 16.11-3 (Sheet 2)

TABLE NOTATIONS

1. The CHANNEL OPERATIONAL TEST shall also demonstrate that automatic isolation of this pathway and control room alarm annunciation occur as appropriate if any of the following conditions exists:
 - a. Instrument indicates measured levels above the Alarm/Trip Setpoint (isolation and alarm), or
 - b. Circuit failure (alarm only), or
 - c. Instrument indicates a downscale failure (alarm only), or
 - d. Instrument controls not set in operate mode (alarm only).
2. The initial CHANNEL CALIBRATION shall be performed using one or more of the reference (gas or liquid and solid) standards obtained from the National Institute of Standards and Technology (NIST) or using standards that have been obtained from suppliers that participate in measurement assurance activities with NIST. These standards shall permit calibrating the system over its intended range of energy, measurement range, and establish monitor response to a solid calibration source. For subsequent CHANNEL CALIBRATION, NIST traceable standard (gas, liquid, or solid) may be used; or a gas, liquid, or solid source that has been calibrated by relating it to equipment that was previously (within 30 days) calibrated by the same geometry and type of source standard traceable to NIST.
3. CHANNEL CHECK shall consist of verifying indication of flow during periods of release. CHANNEL CHECK shall be made at least once per 24 hours on days on which continuous, periodic, or batch releases are made.
4. CHANNEL CHECK shall consist of verifying indication of tank level during periods of release. CHANNEL CHECK shall be made at least once per 24 hours on days on which continuous, periodic, or batch releases are made from the DMT.

CALLAWAY - SP

TABLE 16.11-4 RADIOACTIVE GASEOUS EFFLUENTS SAMPLING
AND ANALYSIS PROGRAM

1. Waste Gas Decay Tank			
SAMPLING FREQUENCY (9)	MINIMUM ANALYSIS FREQUENCY	TYPE OF ACTIVITY ANALYSIS	LLD (1) (μ Ci/ml)
Prior to each release- grab sample	Prior to each tank	Principal Gamma Emitters- particulate, iodine, noble gas (2)	1E-4
Continuous	See footnote 8		

2. Containment Purge or Vent			
SAMPLING FREQUENCY (9)	MINIMUM ANALYSIS FREQUENCY	TYPE OF ACTIVITY ANALYSIS	LLD (1) (μ Ci/ml)
Prior to each release- grab sample	Prior to each release	Principal Gamma Emitters- particulate, iodine, noble gas (2) H-3(oxide)	1E-4 1E-6
Continuous	See footnote 8		

3. Unit Vent (3)			
SAMPLING FREQUENCY (9)	MINIMUM ANALYSIS FREQUENCY	TYPE OF ACTIVITY ANALYSIS	LLD (1) (μ Ci/ml)
Monthly- grab sample (3)(4)	Monthly (3)(4)	Principal Gamma Emitters- noble gas (2) H-3(oxide)	1E-4 1E-6
Continuous (6)	Weekly (7)	I-131 I-133 Principal Gamma Emitters- particulate nuclides only (2)	1E-12 1E-10 1E-11
		Monthly Composite	1E-11
		Quarterly Composite	1E-11

4. Radwaste Building Vent			
SAMPLING FREQUENCY (9)	MINIMUM ANALYSIS FREQUENCY	TYPE OF ACTIVITY ANALYSIS	LLD (1) (μ Ci/ml)
Monthly- grab sample	Monthly	Principal Gamma Emitters- noble gas (2)	1E-4
Continuous (6)	Weekly (7)	I-131 I-133 Principal Gamma Emitters- particulate nuclides only (2)	1E-12 1E-10 1E-11
		Monthly Composite	1E-11
		Quarterly Composite	1E-11

5. Laundry Decontamination Facility Dryer Exhaust			
SAMPLING FREQUENCY (9)	MINIMUM ANALYSIS FREQUENCY	TYPE OF ACTIVITY ANALYSIS	LLD (1) (μ Ci/ml)
Continuous (6)	Weekly (7)	Principal Gamma Emitters- particulate nuclides only (2)	1E-11
	Monthly (10) Composite	Gross Alpha	1E-11
	Quarterly (10) Composite	Sr-89, Sr-90, Ni-63, Fe-55	1E-11

CALLAWAY - SP

TABLE 16.11-4 (Sheet 2)

6. Containment ILRT Depressurization (Post-test Vent)			
SAMPLING FREQUENCY (9)	MINIMUM ANALYSIS FREQUENCY	TYPE OF ACTIVITY ANALYSIS	LLD (1) ($\mu\text{Ci/ml}$)
Prior to each release- grab sample	Prior to each release	Principal Gamma Emitters- particulate, iodine, noble gas (2) H-3(oxide)	1E-4 1E-6

TABLE NOTATIONS

- (1) The LLD is defined, for purposes of these Requirements, as the smallest concentration of radioactive material in a sample that will yield a net count, above system background, that will be detected with 95% probability with only 5% probability of falsely concluding that a blank observation represents a "real" signal.

For a particular measurement system, which may include radiochemical separation:

$$\text{LLD} = \frac{4.66 S_b}{E \times V \times 2.22\text{E}6 \times Y \times \exp(-\lambda \Delta t)}$$

Where:

- LLD = the "a priori" lower limit of detection (microCuries per unit mass or volume),
- S_b = the standard deviation of the background counting rate or of the counting rate of a blank sample as appropriate (counts per minute),
- E = the counting efficiency (counts per disintegration),
- V = the sample size (units of mass or volume),
- 2.22E6 = the number of disintegrations per minute per microCurie,
- Y = the fractional radiochemical yield, when applicable,
- λ = the radioactive decay constant for the particular radionuclide (sec^{-1}), and
- Δt = the elapsed time between the midpoint of the sample collection period, and the time of counting (sec).

Typical values of E, V, Y, and Δt should be used in the calculation.

It should be recognized that the LLD is defined as a "a priori" (before the fact) limit representing the capability of a measurement system and not as an "a posteriori" (after the fact) limit for a particular measurement. Analyses shall be performed in such a manner that the stated LLD's will be achieved under routine conditions.

- (2) The principal gamma emitters for which the LLD Requirement applies include the following radionuclides: Kr-87, Kr-88, Xe-133, Xe-133m, Xe-135, and Xe-138 in noble gas releases and Mn-54, Fe-59, Co-58, Co-60, Zn-65, I-131, Cs-134, Cs-137, Ce-141, and Ce-144 in iodine and particulate releases. This list does not mean that only these nuclides are to be considered. Any nuclide which is identified in the sample and which is also listed in the ODCM gaseous effluents dose factor tables, shall be analyzed and reported in the Radioactive Effluent Release Report.
- (3) If the Unit Vent noble gas monitor (GT-RE-21B) shows that the effluent activity has increased (relative to the pre-transient activity) by more than a factor of 3 following a reactor shutdown, startup, or a thermal power change which exceeds 15% of the rated thermal power within a 1 hour period, samples shall be obtained and analyzed for noble gas, particulates and iodines. This sampling shall continue to be performed at least once per 24 hours for a period of 7 days or until the Unit Vent noble gas monitor no longer indicates a factor of 3 increase in Unit Vent noble gas activity, whichever comes first.
- (4) Tritium grab samples shall be taken and analyzed at least once per 24 hours when the refueling canal is flooded.
- (5) Deleted.
- (6) The ratio of the sample flow rate to the sampled stream flow rate shall be known for the time period covered by each dose or dose rate calculation made in accordance with [Sections 16.11.2.1](#), [16.11.2.2](#), and [16.11.2.3](#).
- (7) Samples shall be changed at least once per 7 days and analyses shall be completed within 48 hours after changing, or removal from the sampler. When sampling is performed in accordance with footnote 3 (above), then the LLD may be increased by a factor of 10.
- (8) Continuous sampling of this batch release pathway is included in the continuous sampling performed for the corresponding continuous release pathway.
- (9) Samples shall be representative of the effluent release.
- (10) Required only if Mn-54, Fe-59, Co-58, Co-60, Zn-65, Cs-134, Cs-137, Ce-141, or Ce-144 are detected in principle gamma emitter analyses.

TABLE 16.11-5 RADIOACTIVE GASEOUS EFFLUENT MONITORING
INSTRUMENTATION

<u>INSTRUMENT</u>	<u>MINIMUM CHANNELS FUNCTIONAL</u>	<u>APPLICABILITY</u>	<u>ACTION</u>	
1. Unit Vent System				
a. Noble Gas Activity Monitor - Providing Alarm (GT-RE-21)	1	At all times	40,46	
b. Iodine Sampler	1	At all times	43	
c. Particulate Sampler	1	At all times	43	
d. Unit Vent Flow Rate	1	At all times	45	
e. Particulate and Radioiodine Sampler Flow Rate Monitor	1	At all times	43	
2. Containment Purge System				
a. Noble Gas Activity Monitor				
- Providing Alarm and Automatic Termination of Release (GT-RE-22, GT-RE-33)	2	MODES 1,2,3, and 4.	41	
- Providing Alarm function only	1	During CORE ALTERATIONS or movement of irradiated fuel within the containment	42	
b. Iodine Sampler	1	MODES 1,2,3,4 and during CORE ALTERATIONS or movement of irradiated fuel within the containment	43	
c. Particulate Sampler	1	MODES 1,2,3,4 and during CORE ALTERATIONS or movement of irradiated fuel within the containment	43	
d. Containment Purge Ventilation Flow Rate	N/A	N/A	N/A	

TABLE 16.11-5 (Sheet 2)

e. Particulate and Radioiodine Sampler Flow Rate Monitor	1	MODES 1,2,3,4 and during CORE ALTERATIONS or movement of irradiated fuel within the containment	43
3. Radwaste Building Vent System			
a. Noble Gas Activity Monitor-Providing Alarm and Automatic Termination of Release (GH-RE-10)	1	At all times	38,40
b. Iodine Sampler	1	At all times	43
c. Particulate Sampler	1	At all times	43
d. Radwaste Building Vent Flow Rate	N/A	N/A	N/A
e. Particulate and Radioiodine Sampler Flow Rate Monitor	1	At all times	43
4. Laundry Decontamination Facility Dryer Exhaust			
a. Particulate Monitor	1	When the dryers are operating	47
b. Particulate Monitor Flow Rate Meter	1	When the dryers are operating	47
c. Dryer Exhaust Ventilation Flow Rate	NA	NA	NA

ACTION STATEMENTS

ACTION 38 - With the number of low range channels FUNCTIONAL less than required by the Minimum Channels FUNCTIONAL requirement, the contents of the tank(s) may be released to the environment for up to 14 days provided that prior to initiating the release:

- a. At least two independent samples of the tank's contents are analyzed, and
- b. At least two technically qualified members of the facility staff independently verify the release rate calculations and discharge valve lineup.

TABLE 16.11-5 (Sheet 3)

Otherwise, suspend release of radioactive effluents via this pathway.

ACTION 39 - Deleted.

ACTION 40 - With the number of low range channels FUNCTIONAL less than required by the Minimum Channels FUNCTIONAL requirement, effluent releases via this pathway may continue for up to 30 days provided grab samples are taken at least once per 12 hours and these samples are analyzed for radioactivity within 24 hours.

ACTION 41 - With the number of channels FUNCTIONAL one less than required by the Minimum Channels FUNCTIONAL requirement, restore the affected channel to FUNCTIONAL status within 4 hours. If the non-functional channel is not restored within 4 hours or with no channels FUNCTIONAL, immediately suspend the release of radioactive effluents via this pathway.

Containment mini-purge supply and exhaust valves that have been closed to satisfy this Action may be opened under administrative controls provided either:

- a. one channel is FUNCTIONAL, or
- b. the requirements for Table 16.11-5 Function 1.a are met and the requirements for minimum channels FUNCTIONAL for the Unit Vent Noble Gas Monitor (GT-RE-21) specified in **Table 16.3-7** Function 3 are met.

The administrative controls consist of designating a control room operator to rapidly close the valves when a need for system isolation is indicated.

ACTION 42 - With the number of channels FUNCTIONAL less than required by the Minimum Channels FUNCTIONAL requirement, and if the containment equipment hatch is open, then immediately suspend CORE ALTERATIONS and movement of irradiated fuel assemblies within containment. If the containment equipment hatch is not open, then suspend the release of radioactive effluents via this pathway or immediately suspend CORE ALTERATIONS and movement of irradiated fuel assemblies within containment.

ACTION 43 - With the number of channels FUNCTIONAL less than required by the Minimum Channels FUNCTIONAL requirement, effluent releases via the affected pathway may continue for up to 30 days provided samples are continuously collected with auxiliary sampling equipment as required in **Table 16.11-4**.

TABLE 16.11-5 (Sheet 4)

- ACTION 44 - Deleted.
- ACTION 45 - Flow rate for this system shall be based on fan status and operating curves or actual measurements.
- ACTION 46 - For midrange and high range channels only - with the number of FUNCTIONAL channels less than required by the Minimum Channels FUNCTIONAL requirement, take the action specified in **Section 16.3.3.4**, ACTION C.
- ACTION 47 - With the number of channels FUNCTIONAL less than required by the Minimum Channels FUNCTIONAL requirement, immediately suspend the release of radioactive effluents via this pathway.

CALLAWAY - SP

TABLE 16.11-6 RADIOACTIVE GASEOUS EFFLUENT MONITORING INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>INSTRUMENT</u>	<u>CHANNEL CHECK</u>	<u>SOURCE CHECK</u>	<u>CHANNEL CALIBRATION</u>	<u>CHANNEL OPERATIONAL TEST</u>	<u>MODES FOR WHICH SURVEILLANCE IS REQUIRED</u>
1. Unit Vent System					
a. Noble Gas Activity Monitor - Providing Alarm (GT-RE-21)	D	M	R(3)	Q(2)	At all times
b. Iodine Sampler	W	N.A.	N.A.	N.A.	At all times
c. Particulate Sampler	W	N.A.	N.A.	N.A.	At all times
d. Unit Vent Flow Rate	N.A.	N.A.	R(4)	Q	At all times
e. Particulate and Radioiodine Sampler Flow Rate Monitor	D	N.A.	R	Q	At all times
2. Containment Purge System					
a. Noble Gas Activity Monitor - Providing Alarm and Automatic Termination of Release (GT-RE-22, GT-RE-33)	N.A.	P	N.A.	N.A.	MODES 1,2,3,4 and during CORE ALTERATIONS or movement of irradiated fuel within the containment
b. Iodine Sampler	W	N.A.	N.A.	N.A.	MODES 1,2,3,4 and during CORE ALTERATIONS or movement of irradiated fuel within the containment
c. Particulate Sampler	W	N.A.	N.A.	N.A.	MODES 1,2,3,4 and during CORE ALTERATIONS or movement of irradiated fuel within the containment
d. Containment Purge Ventilation Flow Rate	N.A.	N.A.	R(4)	N.A.	MODES 1,2,3,4 and during CORE ALTERATIONS or movement of irradiated fuel within the containment

CALLAWAY - SP

TABLE 16.11-6 (Sheet 2)

<u>INSTRUMENT</u>	<u>CHANNEL CHECK</u>	<u>SOURCE CHECK</u>	<u>CHANNEL CALIBRATION</u>	<u>CHANNEL OPERATIONAL TEST</u>	<u>MODES FOR WHICH SURVEILLANCE IS REQUIRED</u>
e. Particulate and Radioiodine Sampler Flow Rate Monitor	D	N.A.	R	N.A.	MODES 1,2,3,4 and during CORE ALTERATIONS or movement of irradiated fuel within the containment
3. Radwaste Building Vent System					
a. Noble Gas Activity Monitor - Providing Alarm and Automatic Termination of Release (GH-RE-10)	D,P	M,P	R(3)	Q(1)	At all times
b. Iodine Sampler	W	N.A.	N.A.	N.A.	At all times
c. Particulate Sampler	W	N.A.	N.A.	N.A.	At all times
d. Radwaste Building Vent Flow Rate	N.A.	N.A.	R(4)	N.A.	At all times
e. Particulate and Radioiodine Sampler Flow Rate Monitor	D	N.A.	R	N.A.	At all times
4. Laundry Decontamination Facility Dryer Exhaust					
a. Particulate Monitor	NA	D	A	Q(5)	When the dryers are operating
b. Particulate Monitor Flow Rate Meter	D	NA	A	NA	When the dryers are operating
c. Dryer Exhaust Ventilation Flow Rate	NA	NA	R(4)	NA	When the dryers are operating

CALLAWAY - SP

TABLE 16.11-6 (Sheet 3)

1. The CHANNEL OPERATIONAL TEST shall also demonstrate that automatic isolation of this pathway and control room alarm annunciation occur as appropriate if any of the following conditions exists:
 - a. Instrument indicates measured levels above the Alarm/Trip Setpoint (isolation and alarm), or
 - b. Circuit failure (alarm only), or
 - c. Instrument indicates a downscale failure (alarm only), or
 - d. Instrument controls not set in operate mode (alarm only).
2. The CHANNEL OPERATIONAL TEST shall also demonstrate that control room alarm annunciation occurs if any of the following conditions exists:
 - a. Instrument indicates measured levels above the Alarm Setpoint, or
 - b. Circuit failure, or
 - c. Instrument indicates a downscale failure, or
 - d. Instrument controls not set in operate mode.
3. The initial CHANNEL CALIBRATION shall be performed using one or more of the reference (gas or liquid and solid) standards certified by the National Institute of Standards & Technology (NIST) or using standards that have been obtained from suppliers that participate in measurement assurance activities with NIST. These standards shall permit calibrating the system over its intended range of energy, measurement range, and establish monitor response to a solid calibration source. For subsequent CHANNEL CALIBRATION, NIST traceable standard (gas, liquid, or solid) may be used; or a gas, liquid, or solid source that has been calibrated by relating it to equipment that was previously (within 30 days) calibrated by the same geometry and type of source standard traceable to NIST.
4. If flow rate is determined by exhaust fan status and fan performance curves, the following surveillance operations shall be performed at least once per 18 months:
 - a. The specific vent flows by direct measurement, or
 - b. The differential pressure across the exhaust fan and vent flow established by the fan's "flow- ΔP " curve, or
 - c. The fan motor horsepower measured and vent flow established by the fan's "flow-horsepower" curve.
5. The CHANNEL OPERATIONAL TEST shall also demonstrate that automatic isolation of this pathway and the shutdown of the dryers occur as appropriate if any of the following conditions exists:
 - a. Instrument indicates measured levels above the Alarm/Trip Setpoint, or
 - b. Monitor failure.

CALLAWAY - SP

TABLE 16.11-7 RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM^a

EXPOSURE PATHWAY AND/OR SAMPLE	NUMBER OF REPRESENTATIVE SAMPLES AND SAMPLE LOCATIONS ⁽¹⁾	SAMPLING AND COLLECTION FREQUENCY	TYPE AND FREQUENCY OF ANALYSIS
1. Direct Radiation ⁽²⁾	<p>Forty routine monitoring stations either with two or more dosimeters or with one instrument for measuring and recording dose rate continuously, placed as follows:</p> <p>An inner ring of sixteen stations, one in each meteorological sector in the general area of the SITE BOUNDARY;</p> <p>Four of the stations shall be placed to monitor for gamma and neutron dose from the ISFSI;</p> <p>An outer ring of stations, one in each meteorological sector in the 6- to 8-km (3 to 5 mile) range from the site; and</p> <p>Eight stations to be placed in special interest areas such as population centers, nearby residences, schools, and in one or two areas to serve as control stations.</p>	Quarterly	Gamma dose for each sample. Neutron dose for the four samples monitoring ISFSI direct radiation.
2. Airborne Radioiodine and Particulates	<p>Samples from five locations;</p> <p>Three samples from close to the SITE BOUNDARY locations, in different sectors, with high calculated annual average ground level D/Qs.</p> <p>One sample from the vicinity of a community located near the plant with a high calculated annual average ground level D/Q.</p> <p>One sample from a location in the vicinity of Fulton, MO.</p>	Continuous sampler operation with sample collection weekly, or more frequently if required by dust loading.	<p>Radioiodine Canister: I-131 analysis for each sample.</p> <p>Gamma isotopic analysis(5) for each sample.</p>

CALLAWAY - SP

TABLE 16.11-7 (Sheet 2)

EXPOSURE PATHWAY AND/OR SAMPLE	NUMBER OF REPRESENTATIVE SAMPLES AND SAMPLE LOCATIONS ⁽¹⁾	SAMPLING AND COLLECTION FREQUENCY	TYPE AND FREQUENCY OF ANALYSIS
3. Waterborne			
a. Surface (6) (river)	One sample upstream One sample downstream	Composite sample over 1-month period (7).	Gamma Isotopic ⁽⁵⁾ and tritium analysis for each sample.
b. DELETED			
c. Groundwater (non-drinking water)	<p>Groundwater samples from non- drinking water shallow and deep⁽¹²⁾ monitoring wells located as follows:</p> <p>Samples from one deep well located upgradient of the plant power block and one deep well located downgradient of the sludge lagoons.</p> <p>Samples from six shallow wells or groundwater sumps in locations suitable to monitor for subsurface leakage from power block structures and components.</p> <p>Samples from five shallow wells located along the discharge pipeline corridor.</p> <p>Samples from three shallow wells near the property boundary located to monitor for migration of contaminated groundwater from the discharge pipeline to the nearest potable water well.</p>	Quarterly	<p>Gamma isotopic⁽⁵⁾ and tritium analyses for each sample. If contaminated with gamma emitting nuclides of plant origin, analyze for HTD nuclides⁽¹¹⁾.</p>

CALLAWAY - SP

TABLE 16.11-7 (Sheet 3)

EXPOSURE PATHWAY AND/OR SAMPLE	NUMBER OF REPRESENTATIVE SAMPLES AND SAMPLE LOCATIONS ⁽¹⁾	SAMPLING AND COLLECTION FREQUENCY	TYPE AND FREQUENCY OF ANALYSIS
d. Drinking (river water)	One sample of each of one to three of the nearest water supplies within 10 miles downstream that could be affected by its discharge. One sample from a control location.	Composite sample over 2-week period ⁽⁷⁾ when I-131 analysis is performed, monthly composite otherwise.	I-131 analysis on each composite when the dose calculated for the consumption of the water is greater than 1 mrem per year ⁽⁹⁾ . Composite for gross beta and gamma isotopic analyses ⁽⁵⁾ monthly. Composite for tritium analysis quarterly.
As there are no drinking water intakes within 10 miles downstream of the discharge point, the drinking water pathway is currently not included as part of the Callaway Plant Radiological Environmental Monitoring Program. Should the annual Land Use Census identify water intakes within 10 river miles downstream of the discharge point, the program will be revised to include this pathway.			
e. Drinking (potable well water)	Samples of potable well water appropriate for monitoring for radioactivity in drinking water supplies in areas most likely to be affected by a spill or leak. Two samples of potable well water from the community of Portland, MO. One sample of Callaway Plant potable water. One sample of potable well water from each resident bordering plant property along Mud Creek and Logan Creek.	Quarterly	Gamma isotopic ⁽⁵⁾ and tritium analyses for each sample. If contaminated with nuclides of plant origin, analyze for HTD nuclides ⁽¹¹⁾ .
f. Sediment from river shoreline	One sample from downstream area with existing or potential recreational value One sample from upstream control location.	Semiannually	Gamma isotopic analysis ⁽⁵⁾ for each sample

CALLAWAY - SP

TABLE 16.11-7 (Sheet 4)

EXPOSURE PATHWAY AND/OR SAMPLE	NUMBER OF REPRESENTATIVE SAMPLES AND SAMPLE LOCATIONS ⁽¹⁾	SAMPLING AND COLLECTION FREQUENCY	TYPE AND FREQUENCY OF ANALYSIS
g. Shoreline sediment from sludge ponds	Shoreline sediment from each on site sludge pond most likely to be affected. One sample from each in-service sludge pond. One sample from each wetlands pond.	Annually	Gamma isotopic ⁽⁵⁾ analysis for each sample.
4. Ingestion			
a. Milk	Samples from milking animals in three different meteorological sectors within 5 km (3 mile) distance having the highest dose potential. If there are none, then one sample from milking animals in each of three different meteorological sectors between 5 to 8 km (3 to 5 mile) distance where doses are calculated to be greater than 1 mrem per yr. ⁽⁹⁾ One sample from milking animals at a control location, 15 to 30 km (10 to 20 mile) distance and in the least prevalent wind direction.	Semimonthly when animals are on pasture, monthly at other times	Gamma isotopic ⁽⁵⁾ and I-131 analyses for each sample
Due to the lack of milking animals which satisfy these requirements, the milk pathway is currently not included as part of the Callaway Plant Radiological Environmental Monitoring Program. Should the Annual Land Use Census identify the existence of milking animals in locations which satisfy these requirements, then the program will be revised to include this pathway.			
b. Fish	One sample of each commercially and recreationally important species in vicinity of plant discharge area. One sample of same species in areas not influenced by plant discharge.	Sample in season, or semiannually if they are not seasonal	Gamma isotopic analysis ⁽⁵⁾ on edible portions for each sample

CALLAWAY - SP

TABLE 16.11-7 (Sheet 5)

EXPOSURE PATHWAY AND/OR SAMPLE	NUMBER OF REPRESENTATIVE SAMPLES AND SAMPLE LOCATIONS ⁽¹⁾	SAMPLING AND COLLECTION FREQUENCY	TYPE AND FREQUENCY OF ANALYSIS
c. Food Products	One sample of each principal class of food products from any area that is irrigated by water in which liquid plant wastes have been discharged.	At time of harvest ⁽¹⁰⁾	Gamma isotopic analysis ⁽⁵⁾ on edible portion for each sample
As there are no areas irrigated by water in which liquid plant wastes have been discharged within 50 miles downstream of the discharge point, this sample type is not currently included as part of the Callaway Plant Radiological Environmental Monitoring Program. Should the annual Land Use Census identify irrigation water intakes within 10 river miles downstream of the discharge point, the program will be revised to include this sample type.			
	Samples of three different kinds of broad leaf vegetation if available grown nearest each of two different offsite locations of highest predicted annual average ground level D/Q if milk sampling is not performed	Monthly when available	Gamma isotopic ⁽⁵⁾ and I-131 analyses
	One sample of each of the similar broad leaf vegetation grown 15 to 30 km (10 to 20 mile) distant in the least prevalent wind direction if milk sampling is not performed	Monthly when available	Gamma isotopic ⁽⁵⁾ and I-131 analyses
5. Soil	Surface soil samples suitable for monitoring for ground deposition if radioactivity in gaseous effluents as follows: Four ecology plots located in four quadrants surrounding the plant. One control location from an area not likely to be influenced by plant gaseous effluents.	Annually	Gamma isotopic ⁽⁵⁾ analysis for each sample.

I

CALLAWAY - SP

TABLE 16.11-7 (Sheet 6)

TABLE NOTATIONS

1. Specific parameters of distance and direction sector from the centerline of one unit, and additional description where pertinent, shall be provided for each and every sample location in **Table 16.11-7** in a table and figure(s) in the appropriate plant procedures. Deviations are permitted from the required sampling schedule if specimens are unobtainable due to hazardous conditions, seasonal unavailability, malfunction of automatic sampling equipment, and other legitimate reasons. If specimens are unobtainable due to sampling equipment malfunction, every effort shall be made to complete corrective action prior to the end of the next sampling period. All deviations from the sampling schedule shall be documented in the Annual Radiological Environmental Operating Report pursuant to Technical Specification 5.6.2.

It is recognized that, at times, it may not be possible or practicable to continue to obtain samples of the media of choice at the most desired location or time. In these instances suitable specific alternative media and locations may be chosen for the particular pathway in question and appropriate substitutions made within 30 days in the Radiological Environmental Monitoring Program. Submit in the next Annual Radiological Environmental Operating Report documentation for a change including the revised figure(s) and table reflecting the new location(s) with supporting information identifying the cause of the unavailability of samples for that pathway and justifying the selection of the new location(s) for obtaining samples.

The selection of sample locations should consider accessibility of sample site, availability of power, wind direction frequency, sector population, equipment security, and the presence of potentially adverse environmental conditions (such as unusually dusty conditions, etc.).

2. One or more instruments, such as a pressurized ion chamber, for measuring and recording dose rate continuously may be used in place of, or in addition to, integrating dosimeters. For the purposes of this table, a thermoluminescent dosimeter (TLD) and/or an optically stimulated luminescent dosimeter (OSLD), are considered to be one phosphor; two or more phosphors in a packet are considered as two or more dosimeters. Film badges shall not be used as dosimeters for measuring direct radiation. The number of direct radiation monitoring stations may be reduced according to geographical limitations; e.g., at an ocean site, some sectors will be over water so that the number of dosimeters may be reduced accordingly. The frequency of analysis or readout for TLD systems will depend upon the characteristics of the specific system used and should be selected to obtain optimum dose information with minimal fading.
3. Deleted.
4. Deleted.
5. Gamma isotopic analysis means the identification and quantification of gamma-emitting radionuclides that may be attributable to the effluents from the facility.
6. The "upstream sample" shall be taken at a distance beyond significant influence of the discharge. The "downstream" sample shall be taken in an area near the downstream edge of the mixing zone.
7. In this program, composite sample aliquots shall be collected at time intervals that are very short (e.g., hourly) relative to the compositing period (e.g., monthly) in order to assure obtaining a representative sample.
8. Groundwater samples shall be taken when this source is tapped for drinking or irrigation purposes in areas where the hydraulic gradient or recharge properties are suitable for contamination.
9. The dose shall be calculated for the maximum organ and age group, using the methodology and parameters in the ODCM.
10. If harvest occurs more than once a year, sampling shall be performed during each discrete harvest. If harvest occurs continuously, sampling shall be monthly. Attention shall be paid to including samples of tuberous and root food products.

CALLAWAY - SP

TABLE 16.11-7 (Sheet 7)

11. In this program, HTD nuclides are defined as ^{89}Sr , ^{90}Sr , ^{55}Fe , ^{63}Ni , ^{237}Np , ^{238}Pu , ^{241}Am , ^{242}Cm , and $^{243/244}\text{Cm}$.
12. In this program, a shallow well is defined as a well which extracts groundwater from the vadose zone. A deep well is defined as a well which extracts groundwater from the saturated zone.

I

CALLAWAY - SP

TABLE 16.11-8 REPORTING LEVELS FOR RADIOACTIVITY CONCENTRATIONS IN ENVIRONMENTAL SAMPLES

REPORTING LEVELS

ANALYSIS	WATER (pCi/ℓ) ^a	AIRBORNE PARTICULATE OR GASES (pCi/m ³)	FISH (pCi/kg, wet) ^b	MILK (pCi/ℓ) ^a	FOOD PRODUCTS pCi/kg, wet) ^b
H-3	20,000*				
Mn-54	1,000		30,000		
Fe-59	400		10,000		
Co-58	1,000		30,000		
Co-60	300		10,000		
Zn-65	300		20,000		
Zr-Nb-95**	400				
I-131	2	0.9		3	100
Cs-134	30	10	1,000	60	1,000
Cs-137	50	20	2,000	70	2,000
Ba-La-140**	200			300	

(a) Multiply the values in this table by 1E-9 to convert to units of μCi/ml.

(b) Multiply the values in this table by 1E-9 to convert to units of μCi/g.

* For drinking water samples. This is 40 CFR Part 141 value. For surface water samples, a value of 30,000 pCi/ℓ may be used.

** Total activity, parent plus daughter activity.

CALLAWAY - SP

TABLE 16.11-9 DETECTION CAPABILITIES FOR ENVIRONMENTAL SAMPLE ANALYSIS

LOWER LIMIT OF DETECTION (LLD) ⁽¹⁾, ⁽²⁾, ⁽³⁾

ANALYSIS	SURFACE WATER (pCi/ℓ) ^a	DRINKING WATER (pCi/ℓ) ^a	AIRBORNE PARTICULATE OR GASES (pCi/m ³)	FISH (pCi/kg, wet) ^b	MILK (pCi/ℓ) ^a	FOOD PRODUCTS (pCi/kg, wet) ^b	SEDIMENT (pCi/kg, dry) ^b
Gross Beta	4	4	0.01				
H-3	3000	2000					
Mn-54	15	15		130			
Fe-59	30	30		260			
Co-58,60	15	15		130			
Zn-65	30	30		260			
Zr-Nb-95 [*]	15	15					
I-131	**	1	0.07		1	60	
Cs-134	15	15	0.05	130	15	60	150
Cs-137	18	18	0.06	150	18	80	180
Ba-La-140 [*]	15	15			15		

(a) Multiply the values in this table by 1E-9 to convert to units of μCi/ml.

(b) Multiply the values in this table by 1E-9 to convert to units of μCi/g.

* Total activity, parent plus daughter activity.

** For surface water samples, the LLD of gamma isotopic analysis may be used.

CALLAWAY - SP

TABLE 16.11-9 (Sheet 2)

TABLE NOTATIONS

1. This list does not mean that only these nuclides are to be considered. Other peaks that are identifiable, together with those of the listed nuclides, shall also be analyzed and reported in the Annual Radiological Environmental Operating Report.
2. Required detection capabilities for thermoluminescent dosimeters used for environmental measurements shall be in accordance with the recommendations of Regulatory Guide 4.13, Revision 1, July 1977.
3. The LLD is defined, for purposes of these Requirements, as the smallest concentration of radioactive material in a sample that will yield a net count, above system background, that will be detected with 95% probability with only 5% probability of falsely concluding that a blank observation represents a "real" signal.

For a particular measurement system, which may include radiochemical separation:

$$LLD = \frac{4.66 S_b}{E \times V \times 2.22E6 \times Y \times \exp(-\lambda \Delta t)}$$

Where:

- LLD = the "a priori" lower limit of detection (microCuries per unit mass or volume),
- S_b = the standard deviation of the background counting rate or of the counting rate of a blank sample as appropriate (counts per minute),
- E = the counting efficiency (counts per disintegration),
- V = the sample size (units of mass or volume),
- 2.22E6 = the number of disintegrations per minute per microCurie,
- Y = the fractional radiochemical yield, when applicable,
- λ = the radioactive decay constant for the particular radionuclide (sec^{-1}), and
- Δt = the elapsed time between the end of the sample collection period, and the time of counting (sec).

Typical values of E, V, Y, and Δt should be used in the calculation.

It should be recognized that the LLD is defined as a "a priori" (before the fact) limit representing the capability of a measurement system and not as an "a posteriori" (after the fact) limit for a particular measurement. Analyses shall be performed in such a manner that the stated LLD's will be achieved under routine conditions.